

RECEIVED
APR 18 1995
OSTI

DOE/METC-96/1028-Vol. I

**METC/Shell Cooperative Agreement CRADA 93-011
High Temperature High Pressure Filtration and
Sorbent Test Program**

Final Report, Volume I


June 1995

U.S. Department of Energy
Office of Fossil Energy
Morgantown Energy Technology Center
3610 Collins Ferry Road
Morgantown, WV 26505

and
Shell Synthetic Fuels Incorporated
Two Shell Plaza
P.O. Box 2099
Houston, TX 77252

Contributors:

J.M. Rockey, J.R. Bird, E. Galloway, A.P. Lui,
D. Eckels, J. Rutten, M.S. Tucker, P.C. Yue,
R.L. Pineault, J.C. Pack, T. Thomson



**METC/Shell Cooperative Agreement CRADA 93-011
High Temperature High Pressure Filtration and
Sorbent Test Program**

Final Report, Volume I

June 1995

U.S. Department of Energy
Office of Fossil Energy
Morgantown Energy Technology Center
3610 Collins Ferry Road
Morgantown, WV 26505

and
Shell Synthetic Fuels Incorporated
Two Shell Plaza
P.O. Box 2099
Houston, TX 77252

Contributors:

J.M. Rockey, J.R. Bird, E. Galloway, A.P. Lui,
D. Eckels, J. Rutten, M.S. Tucker, P.C. Yue,
R.L. Pineault, J.C. Pack, T. Thomson

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.





Table of Contents

	<u>PAGE</u>
Volume I	
1. Executive Summary	4-5
2. Objective	6
3. Gasifier and Cleanup Facility Description	6-14
4. Gasifier and Cleanup Facility Operation	15
A. Test Run 93FBG/MGC04	15
a. Test Objectives	15
b. Run Highlights	15
c. Summary of Gasifier Operating Conditions . . .	16
d. Product Analysis	17
e. Summary of Cleanup Rig Conditions	18
B. Test Run 93FBG/MGC05	19
a. Test Objectives	19
b. Run Highlights	19
c. Summary of Gasifier Operating Conditions . . .	20
d. Product Analysis	21
e. Summary of Cleanup Rig Conditions	22
C. Test Run 93FBG/MGC06	23
a. Test Objectives	23
b. Run Highlights	23
c. Summary of Gasifier Operating Conditions . . .	24
d. Product Analysis	25
e. Summary of Cleanup Rig Conditions	26
D. Test Run 94FBG/MGC07	27
a. Test Objectives	27
b. Run Highlights	27
c. Summary of Gasifier Operating Conditions . . .	28
d. Product Analysis	29-31
e. Summary of Cleanup Rig Conditions	32
E. Test Run 94FBG/MGC08	33
a. Test Objectives	33
b. Run Highlights	33
c. Summary of Gasifier Operating Conditions . . .	34
d. Product Analysis	35-37
e. Summary of Cleanup Rig Conditions	38



F.	Test Run 94FBG/MGC09	39
a.	Test Objectives	39
b.	Run Highlights	39
c.	Summary of Gasifier Operating Conditions	40
d.	Product Analysis	41-42
e.	Summary of Cleanup Rig Conditions	43
G.	Test Run 94FBG/MGC10	44
a.	Test Objectives	44
b.	Run Highlights	44
c.	Summary of Gasifier Operating Conditions	45
d.	Product Analysis	46-47
e.	Summary of Cleanup Rig Conditions	48

Volume II

Appendix 1:	Summary of Particulate Monitoring Results	A1
Appendix 2:	Summary of Alkali Monitoring Results	A2
Appendix 3:	Detailed Chronology of Significant Run Events	A3
Appendix 4:	Daily Process Variable Plots	A4
Appendix 5:	Process and Instrumentation Drawings	A5



1. Executive Summary

In conjunction with shakedown, operation, and desulfurization testing at the Morgantown Energy Technology Center (METC) 10" Fluid Bed Gasification and Cleanup facility, a series of tests was completed in cooperation with Shell Synthetic Fuels, Incorporated to obtain data relevant to the design and operation of dry particulate solids filters, and Nahcolite as a chloride removal sorbent.

Shell Synthetic Fuels Incorporated provided 60mm O.D. x 40mm I.D. x 0.5m long silicon carbide, LayCer™ 70/3 candle filters for use in filtering coal gas from the METC gasifier. METC installed the filters in a vessel existing in the METC Cleanup Facility and provided process data in exchange for ceramic filter and ash/char characterization. Details of the cooperative research and development agreement (CRADA) are found in CRADA #93-011. This report contains METC's contribution to CRADA #93-011.

Seven gasifier runs were conducted over an eighteen month period to accumulate 868 hours of operation. During this time, 3 filters were used 2 at a time to give individual candle usage of 254 hours, 525 hours, and 868 hours, respectively. During one 89 hour test, one Laycer 70/3 candle was installed with a 3M ceramic composite filter. The face velocity through the candles was maintained nominally at 2.5 ft/min throughout the testing.

Average operating conditions are as follows:

The approximate gas composition in mole percent was 15% H₂, 10% CO, 49% N₂, 12% H₂O, 2.4% CH₄, 11% CO₂, 0.3% H₂S, and 0.3% Ar.

Based on analysis of the condensables in the gas stream (stream cooled to 34 °F) the ammonia concentration was on the order of 2000 ppmw.

The average gas flow to the filter vessel was 123 lb/hr.

The average of the filter inlet and outlet temperatures was 1063°F.

The average filter operating pressure was 294 psig.

The average candle purge pressure was 454 psig.

The average operating differential pressure was 5 psid.

The blow back cycle for the filters was approximately once per hour for 100 - 200 msec duration.

Based on char recovery from the filter vessel, the average loading of particulate in the coal gas was 0.28 lb/hr (0.23) gm/Nm³.

Online monitoring of particulate and alkali species in the coal gas fed to the candle filters was conducted per availability of the equipment.

Online particulate monitoring was conducted during runs 5 - 10. Detailed loading and particle size analysis is included in Appendix 1 of this report.

Alkali monitoring was conducted for 6 hours during run 5 and for 30 hours during run 6. A report titled "Summary of Alkali Monitoring Results for November 1993 at the Morgantown Energy Technology Center" is enclosed in Appendix 2.

2. Objective

The purpose of this effort was to collect process data relevant to the design and operation of dry particulate solids filters employing rigid ceramic filter elements in a gasifying environment at temperatures between 1,000 and 1,100 °F, a system pressure of 300 psia, filter differentials between 1 and 10 psid, filter superficial face velocities of about 2.5 feet per minute, and solids loadings from the METC 10-inch diameter fluid bed gasifier.

A second and related purpose was to collect process data relevant to the physical and chemical characteristics of nahcolite after passing filtered coal gas through a packed bed of nahcolite at a temperature of approximately 480 °F, and approximately 300 psia.

3. Gasifier and Cleanup Facility Description

A simplified process flow diagram of the METC Integrated Gasification and Cleanup Facility is shown in Figure 1 and a summary of operating conditions is shown in Table 1.

Coal ground to 14 X 60 mesh (1.41 mm to 0.250 mm) is pneumatically conveyed into the bottom of a 3 stage, refractory-lined gasifier along with steam, preheated air and a small amount of nitrogen. Solids from the gasification process are continuously withdrawn from the top and intermittently withdrawn from the bottom of a 10 foot high, 10-inch diameter fluid bed. Representative feed and residue solid particle sizes are shown in Table 2. The product gases are processed through two cyclone separators and heat traced to the inlet of a candle filter vessel in an adjacent structure.

The gasifier operates at 425 psig (30 atm). The pressure is let down to approximately 290 psig (20 atm) prior to the inlet of the candle filter vessel. Downstream of the candle filter vessel the pressure is controlled to 285 psig (20 atm) in the desulfurizer. The portion of the system upstream of the pressure letdown valve is considered the gasification system and that downstream is the cleanup system.

Located just upstream of pressure letdown, gas slip streams are used for monitoring particulate and alkali species. These systems were used as they were available throughout the experimental testing of this CRADA (May 1993 - October 1994). Table 3 shows the time and dates when the particulate and alkali systems were operational throughout the CRADA test campaign.

Instantaneous gas grab samples and accumulated liquid and solid samples upstream of the candle filter vessel and down stream of the desulfurizer were also obtained periodically throughout the test campaign. The sampling intervals varied from hourly to




Figure 1. METC Integrated Gasification & Cleanup Facility

M95002401*

Table 1.

SUMMARY OF OPERATING CONDITIONS

	FBG	Filter	Desulfurizer
Coal Feed Rate (lb/hr)	70	—	—
Particle Size Range (microns)	<1400	<7	150 - 500
Air Flow Rate (lb/hr)	150	—	—
Steam Flow Rate (lb/hr)	50	—	—
Gas Throughput (lb/hr)	290	123	123
Bed Velocity (ft/s)	0.3	2.5	0.5
Temperature (°F)	1550	1100	1100
Pressure (psig)	425	295	285

Table 2. Feed and Residue Solid Particle Size Distribution**Screen Analysis of Raw Coal Before Passing Through Feeder**

Description: Montana Rosebud #7
 Collection Time: 09/16/94 Sample No.: 94FBG09-RC1
 Report Received: 09/23/94 CH No.: 9410

Screen Passing	Size,mesh Retained	micron	Avg. di	Cumulative %wt	Direct xi, %wt	xi/(di*100)
	14	1410	1545.0	0.0	0.00	0.00E+00
14	16	1190	1300.0	3.92	3.92	3.02E-05
16	30	595	892.5	75.52	71.60	8.02E-04
30	50	297	446.0	97.42	21.90	4.91E-04
50	80	177	237.0	99.25	1.83	7.71E-05
80	100	149	163.0	99.40	0.16	9.63E-06
100	Pan	30	89.5	100.00	0.60	6.67E-05
Avg. Particle Size, micron						677.10

Screen Analysis of Raw Coal After Passing Through Feeder

Description: Montana #7 (Bituminous Coal) after feeder "A"
 Collection Time: 11/04/94 Sample No.: 94FBG09-CFA3
 Report Received: 11/18/94 CH No.: 9484

Screen Passing	Size,mesh Retained	micron	Avg. di	Cumulative %wt	Direct xi, %wt	xi/(di*100)
	25	707	774.0	15.89	15.89	2.05E-04
25	35	500	603.5	35.09	19.20	3.18E-04
35	45	354	427.0	45.55	10.46	2.45E-04
45	60	250	302.0	70.64	25.09	8.31E-04
60	80	177	213.5	79.36	8.72	4.09E-04
80	200	74	125.5	92.13	12.77	1.02E-03
200	Pan	30	52.0	100.00	7.87	1.51E-03
Avg. Particle Size, micron						220.30

(Cont'd) Table 2. Feed and Residue Solid Particle Size Distribution

Screen Analysis of Representative Char Sample of Overflow Solid (94FBG09)

Description: Overflow
Collection Time: 11/07/93 Sample No.: 94FBG09-OF29
Report Received: 12/06/93 CH No.: 9419

Screen Passing	Size,mesh Retained	micron	Avg. di	Cumulative %wt	Direct xi, %wt	xi/(di*100)
	35	500	547.5	16.61	16.61	3.03E-04
35	45	354	427.0	36.56	19.96	4.67E-04
45	60	250	302.0	58.55	21.99	7.28E-04
60	80	177	213.5	70.23	11.68	5.47E-04
80	170	88	132.5	85.42	15.19	1.15E-03
170	325	44	66.0	91.69	6.28	9.51E-04
325	Pan	30	37.0	100.00	8.31	2.25E-03

Avg. Particle Size, micron 156.54

Screen Analysis of Representative Char Sample of Underflow Solid (94FBG09)

Description: Underflow
Collection Time: 09/16/94 Sample No.: 94FBG09-UF29
Report Received: 11/21/94 CH No.: 9441

Screen Passing	Size,mesh Retained	micron	Avg. di	Cumulative %wt	Direct xi, %wt	xi/(di*100)
	14	1410	1545.0	5.1	5.12	3.31E-05
14	18	1000	1205.0	17.9	12.75	1.06E-04
18	25	707	853.5	33.2	15.29	1.79E-04
25	35	595	651.0	58.2	24.99	3.84E-04
35	45	354	474.5	83.3	25.19	5.31E-04
45	60	250	302.0	94.8	11.49	3.80E-04
60	Pan	30	140.0	100.0	5.17	3.69E-04

Avg. Particle Size, micron 504.40

(Cont'd) Table 2. Feed and Residue Solid Particle Size Distribution

Screen Analysis of Representative Char Sample of Cyclone Solid (94FBG09)

Description: Mixed Cyclone
Collection Time: 09/16/94 Sample No.: 94FBG09-PSC6
Report Received: 11/21/94 CH No.: 9464

Screen Passing	Size,mesh	Retained micron	Avg. di	Cumulative %wt	Direct xi, %wt	xi/(di*100)
	170	88	96.5	11.98	11.98	1.24E-03
170	200	74	81.0	28.81	16.83	2.08E-03
200	230	63	68.5	56.87	28.06	4.10E-03
230	270	53	58.0	75.27	18.40	3.17E-03
270	325	44	48.5	86.85	11.57	2.39E-03
325	400	37	40.5	97.61	10.77	2.66E-03
400	Pan	30	33.5	100.00	2.39	7.13E-04
Avg. Particle Size, micron						61.18

Table 3.

ONLINE PARTICULATE AND ALKALI MONITORING PERIODS

RUN	DATE	TIME PERIOD (hh:mm:ss)	SYSTEM
5	08/04/93 08/07/93 08/11/93	10:47:00 - 20:15:00 09:19:46 - 15:27:26 00:00:00 - 06:35:37	P
6	11/02/93 11/04/93 11/05/93 11/06 - 07/93	12:52:00 - 18:07:00 09:46:41 - 20:01:28 13:59:00 - 18:51:22 11:06:33 - 01:32:26	P
6	11/02/93 11/04/93 11/05/93 11/08/93	12:00:00 - 18:00:00 10:00:00 - 20:00:00 14:00:00 - 26:00:00 13:00:00 - 21:45:00	A
7	06/14/94	00:17:44 - 09:11:13	P
8	07/20/94 07/21/94 07/22/94	00:47:29 - 07:23:49 18:09:09 - 00:12:19 00:13:49 - 23:07:35	P
9	09/13/94 09/15/94 09/15-16/94	09:51:47 - 17:46:48 04:58:42 - 11:38:03 20:20:09 - 05:19:38	P
10	10/26/94	09:30:00 - 19:30:00	P

P - Particulate

A - Alkali

every four hours and results were normally averaged over 12 hour steady state periods.

Two parallel gas slip streams located between the candle filter vessel and the desulfurizer were used periodically throughout the test campaign. A slip stream used for testing of industrial grade sodium bicarbonate (nahcolite) as a chloride getter from the coal gas stream was maintained at 400 - 500 °F. A second slip stream for testing of the Direct Sulfur Recovery Process developed by Research Triangle Institute was maintained at 688 °F.

Table 4 gives the analyses of the feed coal used during the test campaign. Montana #5, #6, and #7 is subbituminous coal from the Rosebud seam. The numbers (5,6,7) denote shipments that have been received at different times. Montana #6 was used for 619 hours of the testing. Montana #6 was used in runs 5, 6, 7, 8, and during the nahcolite and COS hydrolysis catalyst testing conducted in runs 9 and 10. Montana #5 was used in run 4 (108 hours). Montana #7 was used for 106 hours in runs 9 and 10. Coke breeze and Illinois #6 were each used for 7 hours in run 9.

Table 4. Analysis of Feed Solids Used in FBG Tests

METC Lab #:	042885	043022	044128	043023	045335	044921	045336	044920
Solids:	Coke Breeze	Montana #5	Montana #6	Montana #6	Cl-/M#6	Montana #7	Montana #7	Illinois #6
Used in Test Run:	-09	-02 to -04	-05 to -08	-09	-10	-09	-10	-09
Ultimate Analysis, %wt:								
Moisture	0.46	4.17	6.38	3.48	5.55	7.35	6.06	3.38
Carbon	85.84	64.38	64.54	61.92	63.77	63.38	63.74	73.39
Hydrogen	1.22	4.36	4.4	4.61	4.85	4.52	4.47	3.6
Nitrogen	1.01	1.03	0.97	0.98	0.69	0.88	0.76	1.26
Sulfur	0.78	0.61	0.86	2.92	1.77	1.03	1.12	1.98
Oxygen (by diff.)	2.14	17.26	16.56	15.77	14.31	16.23	16.42	11.1
Ash*	8.55	8.20	6.29	10.32	9.07	6.62	7.43	5.29
Proximate Analysis %wt:								
Volatile Matter	3.28	41.43	41.94	40.54	40.68	40.54	39.73	26.34
Fixed Carbon (by diff.)	87.71	46.205	44.1	45.66	44.705	45.495	46.78	64.99
Mineral Carbon, %wt	0.06	0.19	0.14	0.14	0.09	0.11	0.14	0.04
Chloride, ppmw	NA	NA	8	<10	4500	<10	38	77
Ash Analysis, %wt of Ash								
Al2O3	NA	NA	24.35	NA	NA	15.63	NA	17.79
CaO	NA	NA	21.3	NA	NA	17.32	NA	3.14
Fe2O3	NA	NA	6.58	NA	NA	8.28	NA	11.74
K2O	NA	NA	0.36	NA	NA	0.13	NA	1.5
MgO	NA	NA	4.74	NA	NA	4.75	NA	0.92
MnO	NA	NA	0.08	NA	NA	0.14	NA	0
P2O5	NA	NA	1.31	NA	NA	0.41	NA	0.12
SiO2	NA	NA	32.28	NA	NA	27.24	NA	39.1
TiO2	NA	NA	1.31	NA	NA	0.59	NA	0.24
Others	NA	NA	7.69	NA	NA	25.51	NA	25.45
Density, kg/l								
Helium	1.86	1.56	1.55	1.58	1.5	1.43	1.44	1.55
Skeletal by Hg	1.87	1.45	1.5	1.47	1.543	1.49	1.4967	1.52
Bulk (packed in air)	0.443	0.65	NA	0.6411	NA	0.4973	NA	0.681
Pore Volume, l/kg								
by N2 Adsorption	0.0017	NA	0.0294	NA	0.01213	0.013	0.01145	0.006
by N2 Desorption	0.0021	NA	NA	NA	0.01318	0.0138	0.0124	0.00645
by Hg Intrusion (Cum.)	0.23	0.364	0.16	0.1639	0.2278	0.31	0.1558	0.48
BET Surface Area, m2/kg								
2000	NA	2855	NA	3167	2843	2558	1728	
Ash Fusion Temp., oF:								
ID/HT	2420/2520	2220/2280	2100/2200	2080/2140	2080/2120	2180/2240	2060/2100	2140/2220
ST/FT	2440/2580	2240/2380	2160/2220	2100/2200	2100/2140	2220/2260	2080/2120	2180/2380
Coke F.S.I.	0	0	0	0	NA	0	NA	1
Particle Size (Mean), um	NA	218.4	NA	NA	NA	220.3	NA	426

Note: All %wt are on As-Received basis except specified otherwise.

*corrected for SO3 formed in ash during analysis.

4. Gasifier and Cleanup Facility Operation

A. Test Run 93FBG/MGC04

Test Run 93FBG04 was conducted from May 16, 1993, through May 26, 1993 (5/16/93 (14:00) to 5/26/93 (23:00).

a. Test Objective

The overall objective of this run was to initiate multi-day shakedown of the integrated fluid bed gasifier and hot gas cleanup system. No desulfurization sorbent was used in this run. Baseline sulfur levels were determined upstream and downstream of the desulfurization vessel. Coal gas was provided to the filter vessel (F-100) equipped with two 0.5 meter lenght LayCer™ 70/3 clay bonded silicon carbide candle filters (C34 and C35).

b. Run Highlights

Below is a bulletized listing of the run highlights. Appendix 3 contains a detailed chronology of significant run events.

- Accumulated 108 hours of integrated FBG/MGCR operation. Demonstrated multiple day (45 hr) operation. Longest period - 45 hours; Shortest period - 3 hours.
- The line heaters maintained the process gas temperature throughout the FBG and to the MGCR filter vessel (F-100) above 1000°F as desired.
- Procedures to put the gasifier in a hot depressurized standby condition and then restart it on demand were tested and proven to work.
- Fluctuations in the coal gas flow to the filter vessel were larger than expected and typically varied from 1500 to 2000 SCFH.

c. Summary of Gasifier Operating Conditions

Test No. 83FFG04.

Period #	Test Period		Duration hrs	Press. psig (1)	Reactor Temp. °F (2)	Coal Feed lb/h (3)	Convey Air scfm (4)	Reaction Air scfm (5)	Steam lb/h (6)	N2 to Reactor lb/h (7)	Air/H2O ofF (8)	H2O/Coal (13) lb/lb
	Start	End										
1	5/18 (10:32)	5/19 (12:50)	26.30	425	1517	83.9	810.0	127	1395.8	647	74.7	647
2	5/21 (04:10)	5/23 (09:08)	52.60	425	1482	74.4	800.7	113	1252.4	665	63.7	665
3	5/23 (19:00)	5/24 (16:00)	23.00	425	1477	74.1	866.8	125	1153.0	646	70.0	646
4	5/26 (03:00)	5/26 (16:30)	13.50	425	1400	72.4	889.6	129	1123.6	633	69.8	633
	Total:		115.40	Avg:	1479	76.3	826.4	120	1250.4	653	70.5	653
											50.6	50.6
											31	31
											2.3	2.3
											0.92	0.92

Followings are time-averaged values:

(1) : PT-713 reading.

(2) : TE-703 reading.

(3) : (ST-503 reading in rpm) x CFC lb/h/rpm

where: CFC=2.72

(4) : Average of FT-107, -108, -109 readings.

(5) : Average of TE-107, -108, -109 readings.

(6) : Average of FT-113, -114, -115 readings.

(7) : TE-504 reading.

(8) : Average of FT-219, -220, -221 readings.

(9) : TE-504 reading.

(10) : Average of FT-310, -311, -312, -313 readings.

(11) : Average of TE-310, -311, -312, -313 readings.

(12) : (4)+(5)/0.0765/(8)

(13) : (8)/(3)

d. Product Gas Analysis

Test No. 82FBG04

Date/ Sample I.D. (Time Taken)	Test Period #	A. Volume Percent (V/V)						B. Mole Percent (Wt Basis)					
		H ₂ %	C ₂ %	N ₂ %	CH ₄ %	CO %	C ₂ H ₆ %	H ₂ S PPM	COS PPM	SO ₂ PPM	COS PPM	H ₂ O* %	
May 18, 1993	1	15.38	0.52	45.59	2.89	10.71	12.09	0.02	1000.88	70.71	1.22	12.70	
0.1 (1400)	1	16.05	0.52	43.49	2.97	12.56	11.59	0.01	923.65	100.22	1.05	12.70	
1.1 (1715)	1	16.34	0.58	46.34	3.22	13.86	11.58	0.00	788.84	53.36	1.20	8.00	
1.2 (2315)	1												
May 19, 1993	1	15.79	0.58	50.49	1.78	10.33	12.76	0.00	634.15	44.14	1.01	8.23	
2.1 (0515)	1												
2.2 (1125)	1	15.14	0.52	52.52	4.52	5.53	15.12	0.08	1160.74	53.23	1.22	6.44	
May 21, 1993	2	14.83	0.50	42.33	2.89	11.71	11.18	0.01	825.43	68.99	0.67	16.48	
3.1 (1020)	2	14.59	0.52	48.08	2.90	9.36	12.47	0.02	842.78	43.22	2.90	11.97	
3.2 (1600)	2	15.63	0.57	46.18	3.07	10.91	12.68	0.01	780.37	56.69	1.34	10.87	
4.1 (1600)	2												
May 22, 1993	2	15.53	0.51	46.42	2.88	10.90	12.24	0.00	985.66	65.12	0.82	11.40	
4.2 (0400)	2	15.29	0.49	46.73	2.71	10.33	11.64	0.00	905.88	59.62	1.13	12.71	
5.1 (1000)	2	14.64	0.52	47.94	2.54	9.99	11.62	0.01	811.66	55.55	1.31	12.65	
5.2 (1600)	2	14.99	0.51	45.98	2.72	10.46	11.52	0.00	985.38	62.72	1.12	13.73	
6.1 (2200)	2												
May 23, 1993	2	15.61	0.50	45.71	2.76	10.99	11.74	0.00	1046.66	65.83	1.14	12.57	
6.2 (0400)	2	12.71	0.53	55.11	0.81	8.10	11.88	0.00	1028.66	46.05	0.98	10.76	
7.1 (0910)	2	13.92	0.56	49.63	2.49	9.20	11.70	0.01	676.42	48.95	0.96	12.43	
8.1 (1930)	3	15.05	0.52	46.97	2.65	10.04	11.90	0.01	882.83	49.29	0.44	12.76	
May 24, 1993	3	14.80	0.53	47.88	2.75	8.65	12.60	0.02	929.29	39.82	0.98	12.67	
8.2 (0700)	3	16.13	0.56	52.68	3.37	8.92	13.83	0.02	976.50	36.15	1.15	4.12	
9.1 (1000)	3												
9.2 (1310)	3												
May 26, 1993	4	11.68	0.55	52.78	2.75	7.88	12.59	0.13	20.59	51.44	0.00	11.62	
10.1 (0310)	4	14.23	0.49	52.73	2.23	9.84	11.16	0.00	691.18	66.26	0.91	9.23	
10.2 (0900)	4												

*Instantaneous gas flow rate at sampling was used to calculate H₂O content in gas. However, it is more accurate to use the averaged gas flow across the collection period.

e. Summary of Clean Up Rig Conditions

Test No. 93MGC04

Period #*	Steady - State		Test Mode*	Coal Type	Gas Flow Rates	Filter Temperatures		Filter Operating Pressure	Single Filter Differential Pressure	Filter Assembly Differential Pressure	Filter Blowback Pressure	
	Date (Time)	Duration, hrs.				FIR-501 (SCFH)	TIR-248 (deg F)					
1A	05/18 (11:47)	05/18 (16:55)	F	M5	1895.3	972.3	1019.6	282.6	1.01	5.87	425.0	
1B	05/18 (18:00)	05/19 (01:02)	F	M5	1721.3	1084.3	1112.1	289.5	3.71	7.56	425.9	
1C	05/19 (02:36)	05/19 (05:15)	F	M5	1716.7	1031.2	1074.4	295.7	3.18	7.79	425.3	
1D	05/19 (05:25)	05/19 (12:00)	F	M5	1963.6	1061.9	1074.4	296.7	2.65	7.72	424.7	
2A	05/21 (06:00)	05/21 (11:35)	F, P	M5	1793.7	987.5	1134.4	294.2	2.41	6.78	434.0	
2B	05/21 (12:22)	05/23 (09:10)	F, P	M5	1648.8	1015.9	1155.7	294.9	1.96	6.69	431.7	
3	05/23 (18:10)	05/24 (17:20)	F	M5	1688.7	1001.7	1116.3	293.8	0.34	5.35	429.2	
4	05/26 (03:03)	05/26 (16:25)	F	M5	1866.0	1024.5	1131.7	293.5	0.27	5.26	426.1	
Average	Values	108.31				1728.8	1018.0	1127.0	293.7	1.57	6.34	429.3

* Total Steady-State Run Time

** Steady-state Periods are based on FBG Steady-state Periods

+Key to Test Mode Symbols

- Filtering (F)
- Sorbent Test Period (S)
- Naphthalite Bed (Na)
- COS Hydrolysis Bed (C)
- Particle Monitoring (P)
- Alkali Monitoring (A)
- Ammonia Monitor (N)

-Key to Coal Type Symbols

- Montana #5 (M5)
- Montana #6 (M6)
- Montana #7 (M7)
- Chloride Salt with Montana #6 (CL/M6)
- Illinois #6 (I6)

B. Test Run 93FBG/MGC05

Test run 93FBG/MGC05 was conducted from August 1, 1993 through August 13, 1993 (8/1/93 14:00 to 8/13/93 23:00).

a. Test Objective

The objective of this run was to attain 200 hours of steady state operation of the integrated gasifier and hot gas cleanup facility to accumulate additional hours on the C34 and C35 candle filters and to test fluidizable zinc ferrite desulfurization sorbent.

b. Run Highlights

Below is a bulletized listing of the run highlights. Appendix 3 contains a detailed chronology of significant run events.

- The second multi-day shakedown run attained 145.5 hours of integrated steady-state operation in 5 periods and the normal shutdown procedure was followed to complete the test.
- The longest continuous, steady-state gasification period was 91 hours, compared to 53 hours in the prior run. The test run was shut down 3 times due to loss of coal feed caused by clinker formation, boiler system valve leakage and coal feeder break-down, respectively. Although the 200-hr goal for this test run was not met, the operation efficiency was improved significantly.
- The sulfur breakthrough curves (hydrogen sulfide level at the outlet of the desulfurizer versus time) for zinc ferrite (35x100 mesh) was obtained during the run.
- Approximately 22 hours of online particulate monitoring of the coal gas entering F-100 was attained.

c. Summary of Gasifier Operating Conditions

Test No. 93-BGGS

Period #	Test Period		Reactor		Coal		Convey/Air		Steam		N2 to Reactor		Air/H2O		H2O/Coal		
	Date (Time)	End	Duration hrs	Press. psig (1)	Temp. of (2)	Feed lb/in (3)	scfh	of (4)	scfh	(5) °F	(6) °F	(7) °F	(8) lb/in	(9) of	(10) scfm	(11) of	(12) lb/lb
1	8/02 (22:45)	8/03 (05:20)	6.58	425	1468	82.7	800.0	61	2000.0	685	74.7	685	0.0	-	-	2.9	0.90
2	8/03 (07:00)	8/03 (12:00)	5.00	425	1482	85.0	800.7	67	2000.0	670	73.2	670	0.0	-	-	2.9	0.86
3	8/04 (08:45)	8/04 (20:45)	12.00	425	1468	81.6	785.0	70	1480.0	625	58.2	625	0.0	-	-	3.0	0.71
4	8/05 (21:30)	8/09 (16:15)	80.75	425	1473	71.7	850.0	57	1201.0	586	49.9	586	19.6	64	3.1	0.70	
5	8/10 (23:35)	8/13 (05:35)	54.00	425	1434	71.2	833.0	66	1075.0	597	48.4	597	258.4	74	3.0	0.68	
	Total:		168.33	Avg.:	1465	78.4	815.7	64	1551.2	633	60.9	633	81.6	69	3.0	0.77	

Followings are time-averaged values:

(1) : PI-713 reading.

(2) : TE-703 reading.

(3) : (ST-603 reading in ppm) x CFC lb/hr/ppm
where: CFC=2.12 for S.S. 1 & 2; = 2.58 for S.S. 3 & 4

(4) : Average of FT-107, -108, -109 readings.

(5) : Average of TE-310, -311 readings.

(6) : Average of FT-113, -114, -115 readings.

(7) : TE-504 reading.

(8) : Average of FT-218, -220, -221 readings.

(9) : TE-504 reading.

(10) : Average of F-311 reading.

(11) : TE-311 reading.

(12) : [(4)+(6)]/0.0765/(8)

(13) : (8)/(3)

d. Product Gas Analysis

Test No. 93FBG05

10⁴ Fluid Bed Gasifier

B. Mole Percent (wt basis)

Date/ Sample I.D. (Time Taken)	Test Period #	H ₂ %	O ₂ %	N ₂ %	CH ₄ %	CO %	CO ₂ %	C ₂ H ₆ %	H ₂ S PPM	COS PPM	SO ₂ PPM	H ₂ O* %
August 2, 1993	1	15.38	0.94	48.18	3.89	7.95	16.17	0.20	162.7	156.04	9.01	7.12
0.1 (2312)												
August 3, 1993	1	17.02	0.66	46.54	3.85	8.36	16.03	0.08	328.7	231.14	8.27	7.10
1.1a (0015)												
1.1b (0430)	1	17.43	0.66	45.59	3.48	10.95	14.55	0.02	209.7	165.75	3.53	7.09
1.2 (0860)	2	15.64	0.56	46.00	2.82	8.56	14.09	0.01	489.1	285.44	8.03	11.79
August 4, 1993												
2.1 (0930)	3	14.86	0.59	44.09	3.61	7.27	14.57	0.14	290.6	142.25	10.85	14.56
2.2 (1520)	3	16.23	0.56	41.24	4.65	8.47	14.65	0.03	245.1	123.21	2.84	13.90
August 5, 1993												
4.1a (2130)	4	10.55	0.57	55.88	3.59	4.92	13.59	0.37	246.9	117.01	6.10	10.27
August 6, 1993												
4.1b (0320)	4	14.46	0.54	49.92	3.81	7.27	13.47	0.03	299.0	98.54	3.59	10.19
4.2 (0925)	4	14.84	0.53	48.54	3.81	6.54	12.83	0.02	196.0	105.58	5.72	10.68
5.1 (1530)	4	12.88	0.45	40.09	3.29	6.73	11.43	0.02	265.7	113.95	2.41	24.83
5.2 (2125)	4	14.39	0.55	45.75	3.75	8.05	12.39	0.02	159.1	240.69	7.59	14.92
August 7, 1993												
6.1 (0225)	4	13.71	0.51	45.71	3.42	7.34	12.40	0.02	428.2	98.26	17.30	16.44
6.2 (0925)	4	14.37	0.50	47.66	3.82	8.22	12.22	0.03	192.2	127.49	8.18	12.98
7.1 (1530)	4	13.72	0.54	45.69	3.88	7.75	12.18	0.02	283.8	144.98	9.23	16.11
7.2 (2115)	4	15.06	0.55	48.27	3.95	8.54	13.45	0.02	367.9	180.63	5.95	9.78
August 8, 1993												
8.1 (0315)	4	15.19	0.54	49.13	3.86	8.87	13.05	0.02	267.1	136.31	4.00	9.07
8.2 (0915)	4	14.72	0.51	49.47	3.89	8.67	12.55	0.03	186.7	105.9	3.98	9.95
9.1 (1515)	4	13.13	0.51	44.97	3.76	7.03	11.85	0.02	198.5	92.88	11.32	18.53
9.2 (2115)	4	0.96	17.80	66.42	0.22	0.41	0.67	0.00	29.75	6.05	0.86	13.52
August 9, 1993												
10.1 (0315)	4	15.00	0.54	49.97	3.84	8.71	12.78	0.02	273.4	125.88	10.48	8.88
10.2 (0915)	4	14.49	0.51	47.32	3.99	8.28	12.67	0.03	264.6	120.85	9.37	12.42
11.1 (1515)	4	13.77	0.49	41.43	3.87	8.12	12.10	0.02	178.9	0.00	5.28	

(Cont'd) Product Gas Analysis

Test No. 93FBG05

10⁴ Fluid Bed Gasifier

B. Mole Percent (wt basis)

Date/ Sample I.D. (Time Taken)	Test Period #	H ₂ %	O ₂ %	N ₂ %	CH ₄ %	CO %	CO ₂ %	C ₂ H ₆ %	H ₂ S PPM	COS PPM	SO ₂ PPM	H ₂ O* %
August 10, 1993	5	12.64	0.55	49.93	3.47	6.25	12.99	0.17	2440.9	210.08	7.33	13.72
12.0 (2326)												
August 11, 1993	5	13.30	0.54	48.55	3.47	7.73	12.35	0.02	3575.1	193.93	15.80	13.67
12.1 (0515)												
12.2 (1115)	5	13.41	0.56	48.66	3.59	7.50	12.23	0.04	3248.7	79.61	4.58	13.66
13.1 (1715)	5	13.67	0.51	50.58	3.75	6.89	12.49	0.03	3338.3	218.05	17.74	11.72
13.2 (2315)	5	13.56	0.49	47.57	3.75	7.18	12.48	0.03	2716.1	169.39	1.02	14.66
August 12, 1993												
14.1 (0515)	5	12.69	0.44	50.78	3.38	6.08	11.90	0.03	2305.5	118.86	3.76	14.45
14.2 (1115)	5	11.58	0.51	51.48	3.03	6.67	10.81	0.03	1935.5	108.41	4.05	15.70
15.1 (1715)	5	12.92	0.53	51.34	3.34	7.16	11.79	0.04	2228.3	116.20	7.88	12.63
15.2 (2315)	5	10.86	0.47	56.97	2.82	5.46	10.22	0.05	1472.9	82.92	3.92	12.99
August 13, 1993												
16.1 (0515)	5	11.34	0.47	59.74	3.11	5.45	10.95	0.05	2038.6	97.53	5.57	8.68

* Instantaneous gas flow rate was used to calculate H₂O content in gas. However, it is more accurate to use the averaged gas flow across the collection period.

e. Summary of Clean Up Rig Conditions

Test No. 93MGC05

Period #*	Steady - State		Test Mode*	Coal Type	Filter Temperatures		Filter Operating Pressure	Single Filter Differential Pressure	Filter Assembly Differential Pressure	Filter Blowback Pressure
	Date (Time)	Duration, hrs.			FIR-501 (SCFH)	Inlet TIR-248 (deg F)				
1	08/02 (23:45)	08/03 (05:17)	5.50	F	M6	1928.6	1024.8	1133.6	297.32	0.79
2	08/03 (07:12)	08/03 (11:00)	3.77	F, P, S	M6	2085.6	1016.8	1137.5	296.6	0.87
3	08/04 (08:45)	08/04 (20:37)	11.87	F, P, S	M6	2019.0	1069.9	1129.2	296.92	8.33
4A	08/05 (21:30)	08/06 (09:25)	11.92	F, P, S	M6	1660.5	1047.2	1134.0	294.32	0.79
4B	08/06 (16:25)	08/06 (18:00)	1.42	F, S	M6	1741.2	974.43	1103.4	294.11	1.05
4C	08/07 (07:15)	08/09 (16:15)	57.00	F, P, S	M6	1694.2	1056.1	1102.4	287.40	1.21
5	08/10 (23:30)	08/13 (5:35)	54.08	F, P, S	M6	1622.3	1089.1	1147.8	299.26	1.49
Average	Values	145.56*				1710.7	1065.8	1126.1	293.83	1.83
										5.18
										432.47

* Total Steady-State Run Time

** Steady-state Periods are based on FBG Steady-state Periods

+Key to Test Mode Symbols

- Filtering (F)
- Sorbent Test Period (S)
- Nahcolite Bed (Na)
- COS Hydrolysis Bed (C)
- Particle Monitoring (P)
- Alkali Monitoring (A)
- Ammonia Monitor (N)

-Key to Coal Type Symbols

- Montana #5 (M5)
- Montana #6 (M6)
- Montana #7 (M7)
- Chloride Salt with Montana #6 (CL/M6)
- Illinois #6 (I6)

C. Test Run 93FBG/MGC06

Test run 93FBG/MGC06 was conducted from November 1, 1993 through November 9, 1993 (11/1/93 00:00 to 11/9/93 18:00).

a. Test Objective

The objective of this run was to attain 190 hours of steady state operation of the integrated gasifier and hot gas cleanup facility to accumulate additional hours on the C34 candle, initiate operation with candle C36 and to test fluidizable zinc titanate desulfurization sorbent. Candle C35 was removed from service for analysis after 254 hours of operation.

b. Run Highlights

Below is a bulletized listing of the run highlights. Appendix 3 contains a detailed chronology of significant run events.

- 130 hours of integrated steady-state operation was attained during 6 steady state periods.
- The longest continuous, steady-state gasification period was 60 hours.
- The sulfur breakthrough curves (hydrogen sulfide level at the outlet of the desulfurizer versus time) for two fluidizable zinc titanate materials (Zt-2 and Zt-5) manufactured by Research Triangle Institute (RTI) were obtained.
- Approximately 35 hours of online particulate and 30 hours of online alkali monitoring of the coal gas entering F-100 was attained.

10^a Fluid Bed Gasifier

c. Summary of Gasifier Operating Conditions

Test No. 93FBG06

Period #	Test Period		Duration hrs	Reactor Press. psig (1)	Coal Feed lb/h (3)	Convey/Air (4) scfh	Reactor Air (5) scfh	Steam (6) lb/h	N2 to Reactor (7) scfh	(8) oF	(9) oF	(10) oF	(11) oF	(12) lb/b	(13) lb/b	H2O/Coal
	Date (Time)	Start														
1*	11/01 (14:00)	11/02 (18:42)	28.70	425	1514.31	78.3	812.7	35	1079.5	639	78.1	639	289.2	35	1.9	1.00
2	11/04 (01:00)	11/04 (21:11)	20.13	425	1441.65	80.4	823.4	46	814.1	624	67.6	624	226.1	44	1.9	0.84
3	11/05 (01:00)	11/07 (13:00)	60.00	425	1429.96	77.4	816.8	46	742.3	651	73.5	651	240.6	44	1.6	0.95
4	11/07 (20:00)	11/07 (23:20)	3.34	425	1386.94	79.4	806.8	41	887.1	609	62.6	609	235.7	30	2.0	0.79
5	11/08 (06:00)	11/08 (07:30)	1.50	425	1388.65	80.5	825.4	31	807.6	583	82.9	583	314.0	26	1.5	1.03
6	11/08 (11:00)	11/09 (09:00)	22.00	425	1392.45	79.3	792.2	39	773.4	664	81.4	684	732.6	33	1.5	1.03
	Total:		135.72	Avg:	1441.9396	78.4	812.8	42	833.1	645	74.7	645	289.2	40	1.7	0.95

Followings are time-averaged values:

- (1) : FT-713 reading.
- (2) : TE-703 reading.
- (3) : (ST-603 reading in rpm) x CFC lb/h/ rpm
where: CFC=2.12
- (4) : Average of FT-107, -108, -109 readings.
- (5) : Average of TE-107, -108, -109 readings.
- (6) : Average of FT-113, -114, -115 readings.
- (7) : TE-504 reading.
- (8) : Average of FT-219, -220, -221 readings.
- (9) : TE-504 reading.
- (10) : Average of FT-311, -312 readings.
- (11) : TE-311 reading.
- (12) : (4)+(6)]/0.0765/(8)
- (13) : (8)/(3)

* A newly designed feed nozzle was tested in S.S. #1. Other S.S periods used the originally designed nozzle.

d. Product Gas Analysis

Test No. 92FBG06

10³ Fluid Bed Gattifier

Date/ Sample I.D. (Time Taken)	Test Period #	A%						B. Mole Percent (Wet Basis)						
		H ₂	N ₂	C ₂	CH ₄	CO	CO ₂	C ₂ H ₆	H ₂ S	COS	SO ₂	CS ₂	CAHs	H ₂ O ^a
November 1, 1993 2 (100)	1	0.37	14.81	0.17	46.34	2.72	10.80	11.70	0.00	2153.39	271.98	6.62	0.78	0.87
3 (100)	1	0.39	14.95	0.19	46.46	2.62	9.31	12.58	0.01	5437.48	365.20	6.10	0.44	0.00
November 2, 1993 5 (0200)	1	0.29	14.87	0.21	45.04	3.21	9.10	12.47	0.01	2397.80	144.07	11.56	0.80	0.00
6 (0300)	1	0.41	14.77	0.18	43.36	3.00	9.41	11.75	0.01	2083.70	114.80	4.82	8.81	0.00
7 (1000)	1	0.39	15.10	0.16	45.70	2.38	9.63	11.51	0.00	3722.47	210.39	8.87	2.13	0.00
8 (1400)	1	0.41	15.71	0.20	46.45	2.81	10.43	12.13	0.00	3070.11	147.57	1.07	0.88	0.00
8A (1500)	1	0.43	15.42	0.22	46.46	2.94	10.57	12.15	0.01	2316.42	147.94	14.86	0.88	0.00
9 (1800)	1	0.41	14.96	0.18	47.26	2.99	10.06	12.34	0.01	2673.53	182.97	11.22	1.41	0.00
November 4, 1993 10 (0300)	2	0.22	13.03	0.77	45.44	3.83	5.23	7.19	0.02	4016.07	3048.62	111.75	6.10	1.67
11 (0500)	2	0.27	14.32	0.30	44.16	3.88	5.25	13.06	0.03	2712.70	146.61	0.00	0.00	11.58
12 (0810)	2	0.36	14.25	0.72	45.59	4.42	7.00	13.97	0.02	2859.08	142.52	4.90	0.35	0.00
13 (0900)	2	0.25	14.08	0.17	49.92	4.04	6.50	12.62	0.04	1455.00	104.86	7.37	0.54	0.00
14 (1002)	2	0.00	12.92	1.75	51.59	3.83	6.50	13.80	0.04	3136.02	9.32	0.36	0.48	0.00
15 (1102)	2	0.30	15.36	0.56	46.84	4.48	7.89	13.80	0.04	2521.23	133.94	5.74	0.83	0.00
16 (1202)	2	0.39	15.63	0.29	46.03	4.79	8.44	13.79	0.03	2814.10	181.41	4.04	2.51	0.00
17 (1300)	2	0.01	16.13	0.51	45.57	4.76	8.33	14.05	0.04	4536.56	195.65	9.68	1.99	0.00
18 (1410)	2	0.38	15.29	0.22	44.43	4.40	7.43	13.77	0.03	2517.97	120.65	5.63	0.43	0.43
19 (1600)	2	0.00	15.53	0.49	44.40	4.57	8.01	13.23	0.03	3932.61	212.11	8.56	1.04	1.12
20 (1700)	2	0.41	15.23	0.14	44.89	4.51	7.12	13.68	0.03	2597.50	138.86	7.94	1.14	0.00
21 (2100)	2	0.35	14.75	0.22	45.51	4.60	8.33	13.79	0.03	1724.06	153.15	11.40	0.75	0.00
November 5, 1993 22 (0115)	3	0.01	1.68	7.28	70.68	0.66	0.97	2.65	0.01	0.00	24.54	12.94	0.69	0.00
23 (0200)	3	0.35	13.61	0.13	45.37	4.46	6.75	13.95	0.03	2017.04	168.17	6.56	0.60	0.00
24 (0300)	3	0.34	14.25	0.17	44.77	4.25	7.23	13.86	0.03	2858.13	132.79	1.53	1.36	0.00
25 (0400)	3	0.34	14.03	0.67	45.87	4.12	6.48	13.38	0.03	2447.33	123.47	0.80	0.00	14.78
26 (0500)	3	0.01	14.87	0.49	43.76	4.33	7.98	14.57	0.03	2812.00	92.91	1.88	0.43	0.00
27 (0600)	3	0.00	14.05	0.48	42.04	4.19	6.87	13.60	0.02	2597.50	138.86	7.94	1.14	0.00
28 (0700)	3	0.00	14.26	0.47	41.77	4.19	6.50	13.77	0.02	3296.19	149.06	4.98	0.57	0.00

10³ Fluid Bed Gattifier

Test No. 92FBG06

92FBG06

Date/ Sample I.D. (Time Taken)	Test Period #	A%						B. (Cont'd) Mole Percent (Wet Basis)						
		H ₂	N ₂	C ₂	CH ₄	CO	CO ₂	C ₂ H ₆	H ₂ S	COS	SO ₂	CS ₂	CAHs	H ₂ O ^a
November 5, 1993 29 (0100)	3	0.38	14.23	0.12	41.89	4.15	6.48	13.87	0.02	3272.83	161.63	8.70	0.57	0.00
30 (0200)	3	0.32	13.80	0.15	42.20	4.41	6.18	13.86	0.03	2823.87	135.01	6.25	1.04	18.77
31 (1200)	3	0.33	15.19	0.18	45.52	4.79	6.37	13.87	0.04	3013.00	113.30	1.55	0.97	12.03
32 (1200)	3	0.00	14.45	0.50	43.56	4.51	6.11	13.47	0.04	2839.10	135.56	6.71	0.50	17.04
33 (2100)	3	0.30	14.03	0.13	44.01	4.62	5.88	13.92	0.04	2839.19	156.54	9.90	0.33	0.50
34 (0100)	3	0.00	13.87	0.48	42.51	4.35	5.75	13.30	0.04	2710.54	209.20	11.12	0.48	2.01
35 (0200)	3	0.00	14.35	0.51	44.85	4.62	6.11	14.07	0.04	4145.26	237.45	8.80	0.43	1.19
36 (0300)	3	0.00	13.59	0.50	44.01	4.55	5.94	13.31	0.04	2820.17	191.6	7.73	0.66	14.80
37 (1300)	3	0.00	14.51	0.51	43.56	4.67	6.03	13.91	0.04	2978.67	215.87	6.10	0.24	16.54
38 (1200)	3	0.42	13.69	0.21	44.72	4.23	6.68	13.36	0.04	3329.91	260.95	8.70	0.25	0.00
39 (2100)	3	0.43	11.10	1.05	48.27	4.05	6.72	12.61	0.03	2337.24	113.62	29.88	0.00	16.59
November 7, 1993 40 (0100)	3	0.44	12.86	0.30	44.93	4.10	6.06	13.02	0.04	2471.60	105.38	19.54	0.00	17.88
41 (0200)	3	0.40	12.91	0.20	43.46	4.21	6.53	12.91	0.03	2805.80	164.85	26.72	0.00	19.03
42 (0200)	3	0.36	13.11	0.18	42.02	4.07	5.50	12.89	0.04	2844.30	120.18	14.49	0.32	21.25
November 8, 1993 43 (2130)	4	0.34	12.15	0.13	43.20	4.04	5.58	12.57	0.04	1769.42	122.14	6.23	3.58	21.64
44 (0500)	5	0.00	12.05	0.52	46.19	4.54	5.46	13.91	0.05	4240.18	172.13	9.04	0.26	0.77
45 (1300)	6	0.00	12.18	0.85	50.70	4.21	4.14	13.48	0.08	4098.68	140.89	12.82	0.00	2.93
46 (1900)	6	0.00	12.73	0.47	45.81	3.98	5.47	12.95	0.07	2833.80	137.52	8.76	0.57	18.14
47 (2300)	6	0.00	12.65	0.43	47.30	3.70	4.70	12.68	0.07	3130.32	157.65	10.80	0.23	0.98
November 9, 1993 48 (0200)	6	0.30	12.20	0.17	45.41	3.73	4.36	12.66	0.07	2224.99	107.15	15.81	0.00	1.58
49 (0700)	6	0.28	8.93	0.11	56.96	2.80	2.47	9.95	0.07	1284.57	49.32	8.58	0.23	18.60
50 (0800)	6	0.01	10.37	0.38	46.40	3.18	3.86	10.59	0.05	1873.73	67.43	14.87	0.90	24.89

* Averaged gas flow across the collection period is used to calculate H₂O content in gas.

e. Summary of Clean Up Rig Conditions

Test No. 93MGC06

Period #*	Steady - State		Test Mode*	Coal Type	Gas Flow Rates	Filter Temperatures		Filter Operating Pressure	Single Filter Differential Pressure	Filter Assembly Differential Pressure	Filter Blowback Pressure		
	Date (Time)	Start	End			Duration, hrs.	FIR-501 (SCFH)	Inlet TIR-248 (deg F)	Outlet TIR-224 (deg F)	PIR-247 (psig)	PDIR-459 (psig)	PDIR-155 (psig)	PIR-458 (psig)
1	11/01 (18:00)	11/02 (18:25)		F, P, A, S	M6	24.42	1748.7	1066.4	1114.7	299.9	488.1	8.04	488.06
2	11/04 (02:25)	11/04 (21:00)		F, P, A, S	M6	18.58	1845.7	1003.2	1069.2	298.2	479.1	7.28	479.11
3	11/05 (01:20)	11/05 (13:15)		F, P, A, S	M6	60.92	1801.6	1117.8	1115.8	298.7	486.6	7.41	486.62
4	11/07 (20:07)	11/07 (23:02)		F, P, S	M6	2.92	1546.4	1090.3	1122.6	293.5	493.8	6.61	493.77
5	11/08 (06:00)	11/08 (07:40)		F, P, S	M6	1.67	1760.4	1011.1	1040.6	289.9	494.7	6.23	494.67
6	11/08 (11:30)	11/09 (09:10)		F, P, A, S	M6	21.67	1957.5	1116.6	1104.0	297.8	494.2	7.67	494.21
Average	Values		130.18*				1817.7	1089.6	1106.2	298.5	487.3	7.52	487.34

* Total Steady-State Run Time

** Steady-state Periods are based on FBG Steady-state Periods

+ Key to Test Mode Symbols

- Filtering (F)
- Sorbent Test Period (S)
- Nahcolite Bed (Na)
- COS Hydrolysis Bed (C)
- Particle Monitoring (P)
- Alkali Monitoring (A)
- Ammonia Monitor (N)

- Key to Coal Type Symbols

- Montana #5 (M5)
- Montana #6 (M6)
- Montana #7 (M7)
- Chloride Salt with Montana #6 (CL/M6)
- Illinois #6 (I6)

D. Test Run 94FBG/MGC07

Test run 94FBG/MGC07 was conducted from June 6, 1994, through June 15, 1994, (6/6/94 (00:00) to 6/15/94 (24:00)).

a. Test Objective

The objective of this run was to attain 170 hours of steady state operation of the integrated gasifier and hot gas cleanup facility to accumulate additional hours on the C34 and C36 candles, initiate exposure testing of 3 materials supplied by 3M (SICONEX™, NEXTEL™ 312 and NEXTEL™550), and to test a fixed bed of desulfurization sorbent prepared by researchers at METC (METC#2).

b. Run Highlights

Below is a bulletized listing of the run highlights. Appendix 3 contains a detailed chronology of significant run events.

- 119 hours of integrated steady-state operation was attained during 3 steady state periods.
- The longest continuous, steady-state gasification period was 89 hours.
- The sulfur breakthrough curve (hydrogen sulfide level at the outlet of the desulfurizer versus time) for METC #2 was obtained.
- Approximately 9 hours of online particulate monitoring of the coal gas entering F-100 was attained.
- The fluctuations in flow to vessel F-100 were greatly reduced from previous runs when the pneumatics of the control valve upstream of that vessel were replaced.

10" Fluid Bed Gasifier

c. Summary of Gasifier Operating Conditions

Test No. 94FBG07

(06/06 - 06/15/94)

Period #	Test		Reactor	Coal Feed	Convey Air		Reactor Air		Steam +		Underflow N2		Air/H2O		H2O/Coal	
	Date	(Time)			Duration	Press. psig (1)	Temp. 0F (2)	(4) scfh	(5) 0F	(6) scfh	(7) 0F	(8) lb/h	(9) 0F	(10) scfh	(11) 0F	(12) lb/h
1*	06/06 (18:30)	06/07 (05:38)	11.13	425	1480	69.3	946.2	55	1333	570	39.1	570	314.3	68	4.5	0.56
2	06/08 (18:30)	06/12 (11:30)	89.00	425	1500	69.3	857.4	55	1192.4	670	37.3	670	430.8	70	4.2	0.54
3	06/13 (19:00)	06/15 (12:40)	41.67	425	1530	69.3	1652.4	67	812.0	670	39.1	670	402.0	80	4.8	0.56
		Total:	141.80	Avg:	1507.2	69.3	1098.0	58.5	1091.6	662.2	37.9	662.2	413.2	72.8	4.4	0.5

Followings are time-averaged values:

(1) : PT-713 reading.

(2) : TE-703 reading.

(3) : (ST-603 reading in rpm) x CFC lb/h/rpm

where: CFC = 2.12

(4) : Average of FT-107, .109 readings.

(5) : TE-108 reading.

(6) : Average of FT-113, .115 readings.

(7) : TE-504 reading.

(8) : Average of FT-219, .221 readings.

(9) : TE-504 reading.

(10) : Average of FT-311, .313 readings.

(11) : TE-312 reading.

(12) : [(4) + (6)] * 0.0765/[8]

(13) : (8)/[3]

+ Adjusted by reducing 32%wt from measured flow

* A newly designed feed nozzle (with steam cone jet) was test in Test Period #7-1. In other test periods the originally designed nozzle was used.

10" Fluid Bed Gasifier

d • Product Gas Analysis
Test No. 94FB007 (6/6-8/15/94)

Date Sample I.D. (Time Taken)	Test Period #	B. Mole Percent (Wet Basis)												Total %, %
		Ar %	H ₂ %	N ₂ %	CH ₄ %	CO %	C ₂ H ₆ PPM	H ₂ S PPM	COS PPM	SO ₂ PPM	CS ₂ PPM	CAH ₄ S PPM	H ₂ O ^a %	
June 6, 1994														
1 (1850)	1	0.47	14.54	0.84	48.82	4.01	7.48	13.98	0.14	1633.50	259.98	3.82	1.81	27.88
2 (2050)	1	0.42	0.51	0.38	84.48	0.36	0.32	3.87	0.04	744.22	133.34	1.07	0.00	5.84
3 (2150)	1	0.43	12.69	0.35	50.14	5.81	5.77	14.42	0.08	5695.88	265.40	4.19	3.18	4.37
4 (2250)	1	0.00	12.08	0.75	52.59	3.37	8.11	12.06	0.02	2648.83	188.43	8.20	8.84	2.10
June 7, 1994	1													
5 (0250)	1	0.45	13.82	0.18	51.89	2.77	8.61	12.26	0.00	4751.38	228.78	4.75	0.55	0.00
June 8, 1994														
6 (1850)	2	0.17	8.80	0.20	72.48	2.16	2.57	6.64	0.07	1501.91	71.55	5.70	0.18	5.39
7 (1950)	2	0.47	17.33	0.12	42.75	5.18	8.80	16.25	0.11	2592.67	140.47	5.21	0.28	6.70
8 (2250)	2	0.46	18.69	0.11	44.38	4.52	8.71	15.88	0.03	4961.65	224.03	2.40	0.37	9.40
June 9, 1994														
9 (0250)	2	0.48	15.88	0.16	45.16	4.65	8.08	15.47	0.02	3938.40	163.49	7.40	0.00	4.25
10 (0830)	2	0.38	15.29	0.08	48.72	4.76	8.68	14.82	0.03	5034.04	103.01	8.94	0.00	10.50
11 (1030)	2	0.41	15.78	0.21	48.02	4.62	7.25	14.73	0.02	2554.44	70.53	9.48	1.00	0.18
12 (1430)	2	0.42	15.87	0.08	47.39	4.46	7.80	14.43	0.04	3598.53	86.42	5.75	5.81	6.25
13 (1830)	2	0.39	15.55	0.09	48.66	4.36	7.55	13.85	0.02	2742.67	118.25	3.54	4.38	3.27
14 (2230)	2	0.42	15.59	0.09	46.50	4.39	7.45	14.17	0.02	2358.80	107.65	8.41	0.45	5.79
June 16, 1994														
15 (0230)	2	0.41	15.95	0.11	48.03	4.17	7.58	14.25	0.03	3223.85	158.93	6.67	0.72	7.68
16 (0830)	2	0.41	15.83	0.07	48.18	4.16	7.40	14.84	0.03	3322.75	185.48	5.55	2.06	4.20
17 (1030)	2	0.40	15.59	0.07	48.18	4.36	7.83	14.29	0.03	3157.72	169.56	11.80	0.83	8.85
18 (1430)	2	0.38	15.58	0.07	48.43	4.29	7.35	14.40	0.04	3133.28	151.02	6.28	0.72	8.75
19 (1830)	2	0.42	15.39	0.14	48.39	4.48	7.36	14.31	0.05	3273.21	215.73	4.42	0.83	7.47
20 (2230)	2	0.38	15.26	0.08	48.09	3.98	6.88	14.38	0.06	7335.84	124.85	5.61	0.84	5.43
June 11, 1994														
21 (0230)	2	0.40	15.29	0.18	48.75	4.28	7.36	14.18	0.06	3763.27	165.91	6.33	0.55	10.84
22 (0830)	2	0.40	15.45	0.10	49.01	3.95	7.30	14.03	0.04	5238.41	132.34	6.51	0.64	9.13
23 (1030)	2	0.43	15.88	0.11	48.23	4.04	7.53	14.11	0.05	4898.07	211.43	18.36	0.00	8.05
24 (1430)	2	0.44	14.90	0.06	50.55	3.70	8.89	13.83	0.04	4525.31	111.25	5.57	0.65	6.26
25 (1830)	2	0.42	15.60	0.04	48.68	3.85	7.68	14.02	0.03	3491.28	194.98	5.15	1.22	7.78
26 (2230)	2	0.00	6.58	10.04	63.69	1.88	3.10	5.67	0.02	850.68	78.21	28.32	0.18	1.38

J-1

10^o Fluid Bed Classifier

d. (Cont'd) Product Gas Analysis
Test No. 9488007 (6/8-8/15/94)

B. (Cont'd) Mole Percent (Wat Basis)

Date/ Sample ID. (Time Taken)	Test Period #	Ar %	H2 %	O2 %	H2 %	CH4 %	CO %	CO2 %	C2H6 %	H2S PPM	CO PPM	S02 PPM	CS2 PPM	CAH4S PPM	H2O* %	Total %
June 12, 1994																
27 (0230)	2	0.00	2.51	12.82	71.11	0.68	1.22	2.58	0.00	0.00	21.18	6.59	0.00	0.09	9.13	100.00
28 (0830)	2	0.00	3.10	13.78	88.84	0.78	1.69	2.89	0.00	0.00	28.43	5.28	0.00	0.18	9.13	100.00
29 (1030)	2	0.00	3.11	14.35	88.12	0.80	1.70	2.79	0.00	0.00	27.78	3.62	0.00	0.28	9.13	100.00
June 13, 1994																
30 (1000)	3	0.44	14.53	0.08	50.88	3.34	6.42	14.35	0.08	4356.93	211.94	10.74	0.37	12.22	8.49	100.00
31 (2000)	3	0.50	2.93	14.22	87.30	0.78	1.47	3.33	0.08	144.91	43.58	12.78	0.00	1.38	9.40	100.00
32 (2100)	3	0.45	14.74	0.17	48.81	3.78	6.98	14.45	0.07	3021.71	136.60	12.54	0.48	4.89	8.49	100.00
33 (2300)	3	0.45	14.73	0.08	50.24	3.80	6.25	14.61	0.05	4026.28	167.70	8.03	0.46	4.47	9.40	100.00
34 (2400)	3	0.44	14.54	0.05	50.08	4.11	6.76	14.28	0.04	2805.17	130.43	8.22	0.00	1.10	9.40	100.00
June 14, 1994																
35 (0100)	3	0.43	13.88	0.12	46.39	4.24	6.73	14.21	0.04	124.78	91.59	1.35	0.00	0.81	10.84	100.00
36 (0200)	3	0.43	13.42	0.45	50.15	3.95	6.38	14.08	0.04	2777.88	80.93	15.93	0.00	3.87	10.84	100.00
37 (0300)	3	0.40	14.28	0.09	49.24	3.97	6.81	14.08	0.03	2391.31	143.01	9.22	0.53	1.68	10.84	100.00
38 (0400)	3	0.40	14.57	0.07	48.46	4.13	6.84	14.32	0.04	2306.86	92.71	7.37	0.00	1.32	10.84	100.00
39 (0500)	3	0.38	14.40	0.09	49.17	4.12	6.76	13.97	0.04	1985.55	89.59	7.91	0.00	4.48	10.84	100.00
40 (0600)	3	0.41	14.30	0.08	48.44	3.94	6.58	14.12	0.03	2728.80	106.27	5.72	0.00	4.34	10.84	100.00
41 (0700)	3	0.41	14.19	0.08	49.44	4.15	6.89	13.89	0.04	1822.66	84.80	3.43	0.00	3.43	10.84	100.00
42 (0800)	3	0.40	14.15	0.10	49.26	4.07	7.01	13.98	0.04	1686.75	95.60	4.32	0.00	0.97	10.84	100.00
43																
44 (1100)	3	0.42	14.84	0.09	48.22	3.85	7.33	13.75	0.03	2043.33	84.60	10.69	0.00	5.43	10.84	89.89
45 (1500)	3	0.41	15.07	0.08	48.05	3.80	7.83	13.44	0.03	2397.46	103.08	8.26	0.00	0.97	10.84	100.00
46 (1710)	3	0.42	14.06	0.18	46.88	3.50	6.95	13.61	0.02	4011.27	128.66	7.46	0.00	8.26	12.00	100.00
47 (1800)	3	0.39	13.82	0.25	48.88	3.45	7.07	13.62	0.02	3929.95	95.81	12.11	0.00	9.78	12.00	100.00
48 (1900)	3	0.37	14.18	0.09	48.35	3.49	7.37	13.45	0.02	3375.75	167.92	8.73	0.00	4.45	12.30	100.00
49 (2000)	3	0.39	14.67	0.07	47.23	3.73	8.18	13.10	0.02	3146.63	127.51	10.37	0.00	5.59	12.30	100.00
50 (2100)	3	0.40	14.87	0.08	47.84	3.60	8.00	13.08	0.02	2174.85	122.30	7.17	0.00	0.89	12.30	100.00
51 (2200)	3	0.43	14.13	0.08	48.53	3.52	7.57	13.12	0.03	2793.00	148.10	10.41	0.00	7.35	12.30	100.00
52 (2300)	3	0.41	14.12	0.14	48.08	3.68	7.92	13.11	0.03	2055.37	112.33	8.67	0.00	6.88	12.30	100.00
53 (2400)	3	0.43	14.51	0.08	47.52	3.70	8.14	13.07	0.02	2084.86	88.40	7.35	0.00	1.24	12.30	100.00
June 15, 1994																
54 (0100)	3	0.38	14.42	0.07	48.41	3.68	7.76	13.27	0.02	1954.77	105.27	7.76	0.00	5.77	11.75	100.00
55 (0200)	3	0.42	14.77	0.09	48.15	3.68	7.69	13.13	0.02	2116.40	93.57	7.39	0.00	5.13	11.75	100.00

10" Fluid Bed Gasifier

d. (Cont'd) Product Gas Analysis
Test No. 84FB007 (6/6/81/5/84)

Date/ Sample I.D. (Time Taken)	Test #	Period	B. (Cont'd) Mole Percent (Wt Basis)										Total %				
			Ar	H ₂	O ₂	N ₂	CH ₄	CO	C ₂ H ₆	H ₂ S	CO ₂	S ₂	C ₃ H ₈				
%	%	%	%	%	%	%	%	%	%	PPM	PPM	PPM	PPM	%			
June 16, 1984	56 (03:00)	3	0.42	14.71	0.06	47.73	3.78	6.08	13.25	0.02	1971.14	93.87	6.85	0.00	6.80	11.75	100.00
	57 (04:00)	3	0.44	14.31	0.11	48.98	3.50	7.84	13.01	0.02	2876.20	121.38	11.42	0.00	7.41	11.75	100.00
	58 (05:00)	3	0.43	14.39	0.18	48.88	3.72	7.86	12.76	0.02	2042.01	101.27	18.90	0.00	5.72	11.75	100.00
	59 (06:00)	3	0.43	14.85	0.11	48.25	3.58	7.84	12.92	0.03	2216.93	112.20	4.15	0.00	1.89	11.75	100.00
	60 (07:00)	3	0.41	15.11	0.07	47.47	3.81	7.88	13.34	0.03	1432.84	84.08	9.81	0.00	5.08	11.75	100.00
	61 (08:00)	3	0.42	14.55	0.10	48.41	3.36	7.90	13.14	0.02	2820.25	123.08	10.15	0.00	6.20	11.75	100.00
	62 (09:00)	3	0.43	14.79	0.08	47.28	3.63	6.24	12.98	0.02	2310.47	112.39	9.55	0.00	3.47	11.75	100.00
	63 (10:00)	3	0.43	14.35	0.12	48.10	3.41	8.82	12.98	0.02	2184.87	140.81	8.23	0.00	5.11	11.75	100.00
	64 (11:00)	3	0.39	14.21	0.09	48.39	3.65	8.35	12.94	0.03	2872.41	128.89	10.28	0.17	5.30	11.75	100.00
	65 (12:00)	3	0.42	14.67	0.08	47.77	3.63	8.70	12.82	0.02	1376.47	98.97	7.92	0.00	0.09	11.75	100.00

* Averaged gas flow across the collection period is used to calculate H₂O content in g/s.

e. Summary of Clean Up Rig Conditions

Test No. 93MGC07

Period #*	Steady - State		Test Mode*	Coal Type	Gas Flow Rates	Filter Temperatures		Filter Operating Pressure	Single Filter Differential Pressure	Filter Assembly Differential Pressure	Filter Blowback Pressure
	Date (Time)	Duration, hrs.				FIR-501 (SCFH)	Inlet TIR-248 (deg F)				
2A	06/08 21:15	06/09 22:20	25.08	F	M6	1837.2	1105.3	1055.9	290.21	2.086	3.85
2B	06/10 00:40	06/11 03:50	27.17	F	M6	1723.1	1102.7	1042.1	289.2	2.094	3.775
2C	06/11 04:48	06/12 11:30	30.42	F	M6	1601.6	1080.2	1029.0	291.93	2.024	3.60
3A	06/13 19:22	06/13 19:51	0.48	F, P, S	M6	1809.8	796.17	926.59	274.92	1.74	2.64
3B	06/13 22:05	06/14 13:05	16.0	F, P, S	M6	1799.1	1075.7	1075.4	291.80	2.201	3.35
3C	06/14 17:05	06/15 12:47	19.7	F	M6	1717.8	1082.9	1048.9	290.28	1.974	2.778
Average		118.85'				1683.6	1089.0	1046.8	290.58	2.063	3.52
											465.55

* Total Steady-State Run Time

** Steady-state Periods are based on FBG Steady-state Periods

+Key to Test Mode Symbols

- Filtering (F)
- Sorbent Test Period (S)
- Nahcolite Bed (Na)
- COS Hydrolysis Bed (C)
- Particle Monitoring (P)
- Alkali Monitoring (A)
- Ammonia Monitor (N)

-Key to Coal Type Symbols

- Montana #5 (M5)
- Montana #6 (M6)
- Montana #7 (M7)
- Chloride Salt with Montana #6 (CL/M6)
- Illinois #6 (I6)

E. Test Run 94FBG/MGC08

Test run 94FBG/MGC08 was conducted from July 18, 1994, through July 27, 1994, (7/18/94 (00:00) to 7/27/94 (24:00)).

a. Test Objective

The objective of this run was to attain 200 hours of steady state operation of the integrated gasifier and hot gas cleanup facility to accumulate additional hours on the C34, C36 candles and 3M materials (SICONEX™, NEXTEL™ 312 and NEXTEL™550), test a fixed bed of desulfurization sorbent prepared by researchers at METC (METC#2), and to initiate a slip stream test to determine the ability of nahcolite to remove chloride from the coal gas stream.

b. Run Highlights

Below is a bulletized listing of the run highlights. Appendix 3 contains a detailed chronology of significant run events.

- 191 hours of integrated steady-state operation was attained during 3 steady state periods.
- The longest continuous, steady-state gasification period was 132.6 hours.
- The sulfur breakthrough curve (hydrogen sulfide level at the outlet of the desulfurizer versus time) for METC #2 was obtained.
- Approximately 40 hours of online particulate monitoring of the coal gas entering F-100 was attained.
- A slip stream test of a nahcolite sorbent bed for removal of chloride from the coal gas was completed. (CaCl was used added to the feed coal to give a level of 1000 ppm of Cl in the feed coal.)

c . Summary of Gasifier Operating Conditions

Test No. 84FBG08 (07/18 - 07/27/94)

10⁶ Fluid Bed Gasifier

Period #	Steady-State		Rector Press. psig (1)	Duration hrs	Coal fed lb/h (13)	Convey Air scfm (4)	React Air scfm (5)	Steam lb/h (6)	Underfire M2 (9)	Air/H2O (10)	H2O/Caa (11)	
	Start	End										
1	07/18 (11:30)	07/20 (12:45)	44.25	425	1484.5	70.0	1604.1	87	500.2	704	54.8	
2	07/20 (12:45)	07/21 (04:45)	16.00	425	1478	67.9	1688.0	68	588.3	818	53.9	
3	07/21 (04:45)	07/27 (0:35)	139.83	425	1432	70.0	1602.4	67	532.2	740	54.6	
			Total:	200.08	Avg:	1442.8	85.8	1610.4	67	526.8	738	54.6
									400.5	495	3.0	
										0.78	0.79	

Following are time-averaged values:

(11) : PT-713 reading.

(21) : TE-703 reading.

(31) : (ST-503 reading in rpm) x CFC lb/h rpm

(7) : TE-504 reading.

(8) : Average of FT-219, -221 readings.

(9) : TE-504 reading.

(10) : Average of FT-311, -313 readings.

(11) : TE-312 reading.

(12) : (4) + (6)*0.0765/(8)

(13) : (6)/(3)

10^a Fluid Bed Gasifier

d. Product Gas Analysis
 Test No. 84FBG08 (7/18/72/784)

Detail Sample I.D. (Time Taken)	Test Period #	B. Mole Percent (Wet Basis)												Total %			
		Ar	H ₂	O ₂	N ₂	CH ₄	CO	CO ₂	C ₂ H ₆	H ₂ S	CS	SO ₂	C ₂ S	C ₄ H ₈	H ₂ O ^b		
Date	%	%	%	%	%	%	%	%	PPM	PPM	PPM	PPM	PPM	PPM	PPM	%	
July 18, 1984																	
1 (1830)	1	0.44	12.34	0.45	48.57	2.91	5.49	12.67	0.10	2205.83	2122.23	5.03	0.00	4.31	16.80	100.00	
2 (1720)	1	0.38	11.86	0.39	48.50	2.77	5.65	11.27	0.08	1437.40	2165.82	4.55	0.00	2.82	16.80	100.00	
3 (1830)	1	0.38	11.85	0.38	51.39	2.80	5.61	11.06	0.02	75.04	47.70	0.97	0.00	0.58	16.50	100.00	
4 (1930)	1	0.45	14.08	0.44	47.92	3.19	8.81	13.24	0.05	2840.03	257.07	9.30	0.00	2.54	13.70	100.00	
5 (2155)	1	0.44	14.48	0.45	48.50	4.03	7.04	13.14	0.06	1818.70	124.41	4.40	0.00	1.01	13.70	100.00	
6 (2230)	1	0.44	13.78	0.50	47.89	3.62	6.54	13.20	0.04	2534.56	171.31	18.72	0.26	1.57	13.70	100.00	
7 (2330)	1	0.46	13.89	0.46	47.57	3.99	6.55	13.06	0.03	2028.80	158.84	15.31	0.00	0.81	13.70	100.00	
July 19, 1984																	
8 (0030)	1	0.43	13.26	0.50	48.84	3.85	5.95	13.20	0.04	3082.12	182.69	16.15	0.00	1.48	13.60	100.00	
9 (0130)	1	0.44	13.81	0.52	49.46	3.98	6.17	13.80	0.05	2046.53	171.57	19.54	0.00	1.33	11.64	100.00	
10 (0230)	1	0.42	13.27	0.46	47.25	3.94	6.20	12.83	0.03	2256.25	165.04	12.91	0.00	1.02	15.33	100.00	
11 (0330)	1	0.43	13.40	0.50	49.41	3.83	5.37	13.13	0.04	2758.87	169.95	18.01	0.17	1.39	13.10	100.00	
12 (0430)	1	0.44	13.58	0.48	48.43	3.98	6.25	13.22	0.04	2100.88	125.00	9.63	0.00	0.95	13.40	100.00	
13 (0530)	1	0.45	14.51	0.52	50.01	4.06	8.51	14.28	0.04	3558.11	158.81	5.89	0.00	0.38	1.63	9.27	100.00
14 (1130)	1	0.43	13.77	0.49	48.54	3.90	6.28	13.24	0.03	3559.86	178.53	22.44	0.00	1.48	12.93	100.00	
15 (1630)	1	0.44	14.11	0.51	48.06	4.19	8.56	13.57	0.04	2453.02	129.63	5.52	0.00	0.80	12.24	100.00	
18 (2030)	1	0.44	13.72	0.50	46.77	3.72	6.38	13.04	0.03	2497.50	170.80	7.15	0.17	1.03	14.84	100.00	
July 20, 1984																	
17 (0030)	1	0.44	13.75	0.50	47.29	3.93	6.76	13.02	0.05	2685.18	141.00	7.75	0.00	0.87	13.87	100.00	
18 (0430)	1	0.44	13.52	0.68	48.14	4.05	7.07	12.89	0.05	1260.38	100.33	15.54	0.00	0.70	12.93	100.00	
19 (0830)	1	0.44	13.98	0.48	47.25	4.12	6.33	13.72	0.04	1172.75	80.18	4.18	0.00	0.61	12.93	100.00	
20 (1030)	1	0.44	13.93	0.50	47.83	4.02	8.79	13.56	0.03	1580.81	80.41	4.70	0.00	0.78	12.93	100.00	
21 (1130)	1	0.39	12.37	0.44	45.08	3.73	6.00	12.12	0.05	1955.10	83.61	2.63	0.00	0.70	14.87	100.00	
22 (1230)	1	0.43	12.99	0.47	44.77	3.63	6.04	13.26	0.05	2456.26	114.86	4.28	0.00	1.15	17.70	100.00	
23 (1330)	2	0.41	12.44	0.47	48.57	3.65	5.81	13.36	0.03	2302.84	134.84	20.24	0.00	0.98	17.02	100.00	
24 (1430)	2	0.43	12.55	0.48	47.25	3.59	5.80	12.86	0.02	2187.44	122.36	5.70	0.00	1.19	13.63	100.00	
25 (1530)	2	0.43	12.84	0.50	49.83	3.71	5.86	13.35	0.02	2482.52	143.30	14.02	0.00	1.24	12.04	100.00	
26 (1630)	2	0.44	12.80	0.52	50.61	3.44	5.85	14.27	0.00	3933.33	183.86	8.00	0.12	0.43	12.87	100.00	
27 (1730)	2	0.45	13.04	0.50	49.01	3.68	6.10	13.83	0.00	2804.54	168.84	5.12	0.43	1.71	12.87	100.00	
28 (1830)	2	0.44	13.33	0.51	47.38	3.79	6.51	13.02	0.00	1945.85	108.84	9.44	0.00	0.95	14.80	100.00	
28 (1930)	2	0.42	13.60	0.73	51.08	3.83	6.48	13.23	0.00	1104.53	110.08	8.05	0.09	1.38	10.45	-100.00	
30 (2030)	2	0.43	13.68	0.52	52.59	3.85	6.41	13.83	0.00	1808.76	131.63	3.87	0.00	1.47	8.50	100.00	
31 (2130)	2	0.44	13.38	0.50	49.26	3.84	6.41	13.17	0.00	2052.26	120.21	15.73	0.18	0.88	12.78	100.00	
32 (2230)	2	0.44	13.46	0.51	49.18	3.78	6.40	13.19	0.03	2251.48	120.87	15.91	0.00	0.70	12.77	100.00	

10th Fluid Bed Gasifier

d. (Cont'd) Product Gas Analysis
Test No. 84FBG08
(7/18-7/27/94)

Date/ Sample I.D. (Time Taken)	Test #	B. (Cont'd) Mole Percent (Wet Basis)														
		A _t	H ₂	O ₂	N ₂	CH ₄	CO	CO ₂	C ₂ H ₆	H ₂ S	CS	SO ₂	CS ₂	C ₄ H ₈ S	H ₂ O*	Total
%	%	%	%	%	%	%	%	%	%	%	PPM	PPM	PPM	PPM	%	
July 21, 1994																
33 (0030)	2	0.42	12.93	0.51	46.65	3.74	6.41	12.45	0.02	1250.20	83.76	10.16	0.25	1.00	16.74	100.00
34 (0130)	2	0.44	12.37	0.60	47.10	3.68	8.05	12.66	0.03	1802.72	109.23	13.45	0.00	1.09	16.87	100.00
35 (0230)	2	0.41	12.48	0.50	46.77	3.61	8.22	12.65	0.02	1520.99	98.73	12.75	0.00	1.08	16.78	100.00
36 (0330)	2	0.45	12.41	0.50	47.10	3.29	5.84	12.99	0.01	3711.79	197.03	10.65	0.08	2.15	16.93	100.00
37 (0430)	2	0.42	13.67	0.47	46.89	3.69	6.82	12.14	0.00	1980.54	127.37	15.22	0.00	0.91	16.69	100.00
38 (0530)	3	0.44	12.56	0.50	47.45	3.03	5.89	12.71	0.00	4982.87	253.26	32.81	0.00	1.16	16.80	100.00
39 (0630)	3	0.42	13.71	0.48	46.73	3.69	7.15	13.17	0.04	2781.05	140.31	11.48	0.00	0.88	14.31	100.00
40 (0830)	3	0.42	14.04	0.48	47.04	3.57	7.56	12.43	0.02	1804.41	114.63	10.50	0.00	0.52	14.20	100.00
41 (1230)	3	0.43	13.91	0.44	47.25	3.62	7.18	12.65	0.03	1881.71	121.22	5.57	0.00	0.96	14.24	100.00
42 (11830)	3	0.48	14.19	0.53	49.85	3.57	6.84	13.65	0.03	4689.12	185.12	8.65	1.17	1.44	10.38	100.00
43 (2030)	3	0.39	13.52	0.47	45.81	3.92	6.86	12.33	0.03	1949.76	94.14	8.41	0.68	0.59	16.57	100.00
July 22, 1994																
44 (0030)	3	0.43	13.42	0.50	45.95	3.57	6.57	12.80	0.03	2225.55	149.25	24.49	0.34	1.02	16.50	100.00
45 (0430)	3	0.39	12.32	0.50	42.56	3.40	6.14	11.49	0.02	1862.88	93.98	10.80	0.00	1.00	23.10	100.00
46 (0830)	3	0.41	13.69	0.46	45.20	3.66	7.17	13.10	0.05	1874.30	109.50	17.95	0.17	0.76	15.82	100.00
47 (1230)	3	0.43	13.53	0.48	45.11	3.58	6.95	12.65	0.03	2095.50	111.63	7.88	0.00	1.43	17.02	100.00
48 (1630)	3	0.41	13.32	0.49	46.03	3.53	6.81	13.11	0.03	2575.54	136.70	8.51	0.34	0.93	15.89	100.00
49 (2030)	3	0.41	13.18	0.48	45.81	3.84	6.84	12.80	0.03	2395.55	140.01	9.88	0.42	1.34	16.78	100.00
July 23, 1994																
50 (0030)	3	0.38	13.63	0.48	45.50	3.53	6.32	12.38	0.03	2234.42	119.56	23.38	0.16	0.97	16.81	100.00
51 (0430)	3	0.40	12.48	0.48	43.84	3.63	6.41	12.18	0.02	1971.32	88.42	21.49	0.32	1.84	20.52	100.00
52 (0830)	3	0.42	13.11	0.48	45.58	3.81	6.75	12.89	0.03	1849.23	101.84	9.38	0.08	0.50	16.72	100.00
53 (1230)	3	0.42	13.08	0.48	45.08	3.70	6.53	12.77	0.03	2776.80	113.51	11.27	0.25	0.91	17.83	100.00
54 (1630)	3	0.42	13.59	0.48	45.57	3.90	7.01	13.04	0.03	2355.17	125.02	12.29	0.42	0.76	15.72	100.00
55 (2030)	3	0.45	13.08	0.50	47.02	3.43	6.52	13.01	0.03	3716.38	160.93	21.11	0.88	1.00	15.57	100.00
July 24, 1994																
56 (0030)	3	Bottle broken at sample station														
57 (0430)	3	Bottle broken at sample station														
58 (0830)	3	0.42	12.81	0.48	45.21	3.68	6.73	12.11	0.03	2398.37	118.61	7.63	0.33	1.57	16.28	100.00
59 (1230)	3	0.40	13.71	0.47	45.28	3.98	7.18	12.41	0.03	2152.74	124.66	7.01	0.08	0.93	16.31	100.00
60 (2030)	3	0.44	13.13	0.48	49.33	3.67	6.84	13.16	0.03	3085.75	186.19	8.45	0.39	5.96	11.90	100.00

d. (Cont'd) Product Gas Analysis
 Test No. 695500
 (7/16-7/27/84)

Date/ Sample I.D. (Time Taken)	Test Period <i>J</i>	A. (Cont'd) Mole Percent (Net Basis)										B. (Cont'd) Mole Percent (Net Basis)										
		Ar	H ₂	O ₂	N ₂	CH ₄	CO	CO ₂	C ₂ H ₆	H ₂ S	CS	SO ₂	CS ₂	C ₄ H ₈	H ₂ O*	Total	%					
July 25, 1984																						
61 (0030)	3	0.00	14.34	0.47	48.60	4.05	7.47	13.24	0.04	1531.50	0.00	0.00	0.00	0.00	0.00	11.65	100.00					
62 (0430)	3	0.38	12.57	0.46	45.18	3.52	6.16	12.15	0.04	1813.54	121.98	8.30	0.33	4.64	18.34	100.00						
63 (0830)	3	0.43	13.61	0.54	47.63	4.05	6.87	12.75	0.04	2598.30	101.84	8.57	0.35	0.87	13.50	100.00						
64 (1230)	3	0.40	15.52	0.46	45.85	3.95	7.04	12.28	0.03	1053.71	78.81	19.15	0.25	0.67	16.34	100.00						
65 (1630)	3	0.42	13.62	0.47	45.49	3.67	6.39	12.58	0.03	1601.43	92.17	8.68	0.33	1.87	16.38	100.00						
66 (2030)	3	0.43	13.18	0.52	45.75	3.62	6.73	12.64	0.03	2555.70	125.85	10.43	0.33	2.17	18.80	100.00						
July 26, 1984																						
67 (0030)	3	0.42	13.34	0.48	45.86	3.73	6.61	12.26	0.04	1351.11	116.89	5.90	0.00	0.91	17.07	100.00						
68 (0430)	3	0.44	14.18	0.53	49.87	4.12	7.14	13.11	0.05	1932.22	75.66	15.85	0.18	0.90	10.37	100.00						
69 (0830)	3	0.39	12.81	0.47	45.14	3.74	6.83	11.97	0.03	1156.19	81.57	8.08	0.00	0.82	18.60	100.00						
70 (1230)	3	0.43	13.64	0.47	46.00	3.94	7.08	12.31	0.03	1161.00	88.45	5.20	0.00	0.67	16.00	100.00						
71 (1630)	3	0.39	12.44	0.48	41.59	3.59	6.55	11.49	0.05	1075.87	69.58	8.51	0.08	0.62	23.31	100.00						
72 (2030)	3	0.56	2.92	10.72	61.80	1.16	2.14	4.02	0.01	237.81	25.42	22.14	0.00	0.00	16.82	100.00						
July 27, 1984																						
73 (0030)	3	0.46	13.11	1.32	46.71	3.60	7.32	11.82	0.03	1047.43	60.08	8.03	0.00	0.00	15.41	100.00						
74 (0430)	ShutOff	0.02	0.00	0.11	82.80	0.00	0.00	0.72	0.00	20.14	0.00	1.69	0.00	0.00	16.55	100.00						

* Averaged gas flow across the collection period is used to calculate H₂O content in gas.

e. Summary of Clean Up Rig Conditions

Test No. 94MGC08

Period #"	Steady - State		Test Mode*	Coal Type	Gas Flow Rates	Filter Temperatures		Filter Operating Pressure	Single Filter Differential Pressure	Filter Assembly Differential Pressure	Filter Blowback Pressure
	Date (Time)	Duration, hrs.				FIR-501 (SCFH)	Inlet TIR-248 (deg F)				
1A	7/18 (17:10)	7/18 (19:48)	2.63	F	M6	800	960	910	285	0.33	0.45
1B	7/18 (21:48)	7/19 (07:45)	9.95	F, S	M6	1254	1091	1039	285	0.90	1.33
1C, 2A	7/19 (09:15)	7/20 (12:50)	27.58	F, P	M6	2112	1110	1049	287	2.09	3.04
2B	7/20 (12:50)	7/21 (4:50)	16.00	F, P, Na	CL/M6	1986	1030	1040	292	2.27	3.31
3A	7/21 (04:50)	7/26 (17:25)	132.58	F, P	M6	1950	871	1050	291	2.53	3.48
3B	7/26 (22:30)	7/27 (00:40)	2.17	F	M6	1837	396	799	286	1.17	1.52
Average	Values		190.91'			1921	926	1043	290	2.31	3.22
											453

* Total Steady-State Run Time

** Steady-state Periods are based on FBG Steady-state Periods

+Key to Test Mode Symbols

- Filtering (F)
- Sorbent Test Period (S)
- Nahcolite Bed (Na)
- COS Hydrolysis Bed (C)
- Particle Monitoring (P)
- Alkali Monitoring (A)
- Ammonia Monitor (N)

-Key to Coal Type Symbols

- Montana #5 (M5)
- Montana #6 (M6)
- Montana #7 (M7)
- Chloride Salt with Montana #6 (CL/M6)
- Illinois #6 (I6)

F. Test Run 94FBG/MGC09

Test run 94FBG/MGC09 was conducted from September 12, 1994, through September 16, 1994, (9/12/94 (00:00) to 9/16/94 (24:00)).

a. Test Objective

The objective of this run was to attain 90 hours of steady state operation of the integrated gasifier and hot gas cleanup facility to accumulate additional hours on the C34, C36 candles and 3M materials (SICONEX™, NEXTEL™ 312 and NEXTEL™550), test a fluid bed of desulfurization sorbent prepared by Contract Materials Processing (CMP) for RTI (Zt-4L), to perform a slip stream test to determine the ability of nahcolite to remove chloride from the coal gas stream, to initiate testing of the Direct Sulfur Recovery Process (patented by RTI and METC) using a slip stream of filtered hot coal gas, and to begin parametric testing of the gasifier by making slight adjustments to gasifier inputs.

b. Run Highlights

Below is a bulletized listing of the run highlights. Appendix 3 contains a detailed chronology of significant run events.

- 85 hours of integrated steady-state operation was attained during 10 steady state periods.
- The sulfur breakthrough curve (hydrogen sulfide level at the outlet of the desulfurizer versus time) for ZT-4L was obtained.
- Approximately 23 hours of online particulate monitoring of the coal gas entering F-100 was attained.
- A slip stream test of a nahcolite sorbent bed for removal of chloride from the coal gas was completed. (CaCl was used added to the feed coal to give a level of 1000 ppm of Cl in the feed coal.)
- 2 integrated DSRP tests and 2 cycles of sorbent testing were completed.

c. Summary of Gasifier Operating Conditions

Test No. 84FB009 (08/12 - 08/16/94)

10" Fluid Bed Gasifier

Period #	Steady-State Date (Time)	Duration hrs	Reactor		Convey Air		Reactor Air		Steam + Underflow N2		H2O/Cool Air/H2O						
			Start	End	Press. psig(1)	Temp. of(2)	Feed lb/h (3)	scfh (4)	Temp. of(5)	scfh (6)	Temp. of(7)	scfh (8)	Temp. of(9)	scfh (10)	Temp. of(11)	scfh (12)	Temp. of(13)
1	08/12 09/13 (16:22)	13.88	425	1070.5	88.8	1627.3	52	607.0	635	53.8	635	405.0	493	3.0	0.78		
2	08/13 09/13 (08:10)	11.75	425	1050	68.1	1601.6	65	796.2	841	53.4	641	402.3	493	3.4	0.77		
3*	08/13 09/14 (18:00)	12.17	425	1048	68.1	1624.3	59	1012.3	848	51.8	649	400.7	321	3.9	0.78		
4*	08/14 09/14 (10:22)	4.20	425	995.5	68.1	1585.0	82	1018.0	658	51.1	658	484.0	447	3.9	0.75		
5	08/14 09/14 (10:22) (16:27)	8.08	425	1002	68.1	1613.9	78	1008.0	658	52.2	658	483.0	NA	3.8	0.78		
6	08/14 09/15 (18:27) (08:10)	10.72	425	1087.6	76.7	1615.0	85	1011.8	661	51.7	681	402.3	NA	3.8	0.67		
7	08/15 09/15 (08:10) (16:06)	9.83	425	1107.4	76.7	1602.6	71	1337.7	674	49.5	674	400.2	NA	4.5	0.64		
8	08/15 09/15 (16:06) (21:12)	5.10	425	1200	78.5	1598.0	NA	1008.0	NA	51.9	NA	400.0	NA	3.8	0.68		
9**	08/15 09/16 (21:12)																
10***	08/16 09/16 (07:00)	8.80	425	1147.7	70.2	1620.3	83	1032.7	639	50.3	639	471.3	437	4.0	0.72		
	(07:00) (14:00)	7.00	425	1200.2	72.1	1606.3	70	1145.8	584	50.8	584	403.8	NA	4.1	0.70		
	Total:	83.83	Avg:	1083.4	71.3	1612.8	80	856.7	810	51.8	810	418.0	242	3.8	0.73		

Following are time-averaged values:

(1) : PT-713 reading.

(2) : TE-703 reading.

(3) : (TE-503 reading in rpm) x CFC blower

where: CFC = 2.61 (Montana #7); 2.58 (C- doped M&B)

(4) : Average of FT-107 - 108 readings.

(5) : TE-108 reading.

(6) : Average of FT-113 - 115 readings.

(7) : TE-504 reading.

(8) : Average of FT-218 - 221 readings.

(9) : TE-504 reading.

(10) : Average of FT-311 - 313 readings.

(11) : TE-312 reading.

(12) : [(9)+(8)]/0.0735/[8]

(13) : [8]/[9]

* C- doped Montana #6 Coal

** Coke Beads

*** Illinois #6 Coal

+ Adjusted by reducing 9Kwt from measured flow

10" Fluid Bed Gasifier

d . Product Gas Analysis
Test No. 038600 (8/12/91/8/94)

Date	Station I.D. (Time Taken)	#	B. Mole Percent (Wet Basis)										Total s%	
			Ar	H ₂	N ₂	CH ₄	CO	CO ₂	C ₂ H ₆	H ₂ S	CO	S ₂	CS ₂	
		%	%	%	%	%	%	%	%	PPM	PPM	PPM	PPM	
September 12, 1994														
1 (1100)	1	0.45	13.48	0.03	47.10	3.13	6.23	13.47	0.13	1693.47	205.58	2.02	0.00	4.46
2 (1900)	1	0.44	14.36	0.03	45.58	3.48	6.49	13.72	0.12	1287.92	150.23	2.18	0.00	3.21
3 (2000)	1	0.43	14.28	0.04	45.47	3.53	6.14	13.88	0.10	1904.28	136.71	125.30	0.00	1.43
4 (2100)	1	0.44	13.98	0.04	45.93	3.68	6.41	13.63	0.08	1375.05	78.93	5.40	0.00	0.93
5 (2200)	1	0.40	14.08	0.06	45.70	3.74	6.36	13.27	0.04	1055.59	120.40	1.60	0.00	0.42
6 (2300)	1	0.43	14.29	0.06	45.38	3.54	7.40	13.05	0.04	2023.08	127.37	3.12	0.00	1.88
7 (2400)	1	0.43	14.43	0.05	45.12	3.69	7.77	12.78	0.03	1555.06	103.56	2.53	0.00	1.01
September 13														
8 (0100)	1	0.41	14.13	0.06	45.84	3.70	7.88	12.68	0.03	1228.62	62.88	2.03	0.00	1.01
9 (0200)	1	0.41	14.28	0.06	45.32	3.52	8.05	12.58	0.03	1747.35	118.81	6.08	0.00	1.01
10 (0300)	1	0.42	14.14	0.06	45.56	3.59	8.02	12.50	0.03	1238.13	73.38	4.05	0.00	2.28
11 (0400)	1	0.41	14.32	0.08	45.35	3.54	8.30	12.33	0.02	1294.72	88.66	2.11	0.00	0.83
12 (0500)	1	0.41	14.43	0.07	45.26	3.51	8.47	12.22	0.03	1201.18	68.88	2.45	0.00	0.76
13 (0600)	1	0.41	14.32	0.05	45.38	3.56	8.48	12.15	0.03	1356.34	85.13	2.11	0.00	0.51
14 (0700)	2	0.42	14.54	0.05	45.15	3.24	9.29	11.70	0.01	1407.79	94.20	3.04	0.00	0.51
15 (0800)	2	0.44	14.54	0.05	44.92	3.21	9.89	11.30	0.02	1108.62	72.24	4.65	0.00	0.42
16 (0900)	2	0.42	14.61	0.05	44.74	3.16	9.87	11.36	0.02	834.48	58.33	2.45	0.00	1.27
17 (1000)	2	0.42	14.52	0.05	45.01	3.28	9.73	11.44	0.02	1243.54	86.30	2.54	0.00	0.93
18 (1100)	2	0.42	14.71	0.05	44.37	3.42	9.84	11.83	0.02	1153.43	74.35	2.54	0.00	1.95
19 (1500)	2	0.40	14.39	0.08	45.00	3.38	9.17	11.94	0.03	1461.54	63.32	3.04	0.00	0.34
20 (1600)	2	0.41	14.50	0.05	44.80	3.49	8.89	12.07	0.02	1072.27	78.11	1.86	0.00	1.27
21 (2000)	3	0.43	13.43	0.08	46.89	2.66	8.87	12.08	0.00	2867.59	146.25	5.14	0.00	0.51
22 (2400)	3	0.43	13.33	0.08	47.47	2.44	8.23	11.17	0.00	2022.90	168.98	4.47	0.00	0.00
September, 14														
23 (0400)	3	0.44	13.18	0.17	46.89	2.39	9.85	10.84	0.00	1715.18	93.59	8.76	0.00	0.58
24 (0800)	3	0.43	13.25	0.11	47.03	2.35	9.50	10.81	0.00	1788.48	138.71	10.37	0.00	0.33
25 (1000)	4	0.36	8.35	0.08	58.81	1.84	4.21	9.37	0.02	3104.63	191.78	6.81	0.00	2.16
26 (1400)	5	0.34	8.44	0.08	60.54	2.27	5.11	9.81	0.03	1164.22	80.65	3.44	0.00	1.67
27 (1800)	5	0.47	14.91	0.02	47.85	2.94	9.86	12.11	0.00	3077.42	219.68	5.23	0.00	0.53

d. (Cont'd) Product Gas Analysis

Test No. 83FBG08

10^a Fluid Bed Gasifier

Date/ Sample I.D. (Time Taken)	Study/ Site #	B. (Cont'd) Mole Percent (Wat Basis)												Total H2O* %		
		Ar %	H ₂ %	O ₂ %	N ₂ %	CH ₄ %	CO %	C ₂ H ₆ %	H ₂ S PPM	COS PPM	S ₀₂ PPM	CS ₂ PPM	CH ₄ S PPM			
28 (2200)	6	0.46	15.07	0.04	47.50	3.10	9.80	12.25	0.00	3468.40	237.07	6.91	0.00	0.87	11.41	100.00
September 15	6	0.43	15.21	0.09	45.43	3.33	10.89	11.45	0.01	1628.35	144.95	7.57	0.00	0.76	12.99	100.00
29 (0200)	6	0.43	13.96	0.31	47.05	2.98	9.74	11.99	0.00	2710.98	162.22	10.35	0.00	2.95	13.23	100.00
30 (0600)	8	0.43	14.86	0.06	46.82	2.86	11.14	10.87	0.00	2691.07	225.13	8.16	0.00	0.88	13.14	100.00
31 (1000)	7	0.43	13.57	0.58	47.75	2.87	11.26	10.31	0.00	1393.20	115.56	2.78	0.00	1.65	13.24	100.00
32 (1400)	8	0.42	14.85	0.08	46.26	3.07	10.42	11.55	0.01	1746.52	123.00	4.26	0.00	0.96	13.14	100.00
33 (1800)	9	0.46	12.89	0.03	51.15	1.23	9.30	11.68	0.00	1013.00	38.77	2.59	0.00	0.00	13.53	100.00
34 (2200)	9	0.52	9.23	0.08	56.54	0.67	5.89	12.95	0.00	1788.30	138.64	4.38	0.00	0.00	14.15	100.00
September 16	9	0.43	3.17	0.06	71.21	0.18	1.47	9.98	0.00	1230.65	59.60	2.36	0.00	0.00	13.38	100.00
35 (2400)	9	0.43	3.17	0.06	71.21	0.18	1.47	9.98	0.00	1230.65	59.60	2.36	0.00	0.00	13.38	100.00
36 (0400)	10	0.49	12.84	0.08	51.27	1.88	7.80	11.44	0.00	2867.28	207.19	8.19	0.00	2.33	13.78	100.00
37 (0745)	10	0.47	13.38	0.04	51.53	1.74	8.03	10.53	0.00	2859.11	221.45	5.53	0.00	0.00	13.67	100.00
38 (0900)	10	0.47	13.89	0.05	50.41	1.81	6.39	11.03	0.00	2241.59	243.19	4.06	0.00	0.00	13.61	100.00
39 (1100)	10	0.47	14.27	0.05	49.89	2.07	8.20	11.11	0.00	3601.63	221.66	5.10	0.00	0.00	13.55	100.00
40 (1100)	10	0.47	13.30	0.07	50.92	1.60	8.37	11.23	0.00	2892.17	288.16	7.16	0.00	0.00	13.72	100.00
41 (1200)	10	0.47	11.05	0.08	53.87	1.11	7.28	11.83	0.00	2028.02	158.68	5.15	0.00	0.00	14.10	100.00
42 (1300)	10	0.48	10.78	0.08	54.77	1.18	6.89	11.50	0.00	2128.33	155.81	4.12	0.00	0.00	14.11	100.00
43 (1400)	10	0.48	10.78	0.08	54.77	1.18	6.89	11.50	0.00	2128.33	155.81	4.12	0.00	0.00	14.11	100.00

* Averaged gas flow across the collection period is used to calculate H₂O content in g/t.

e. Summary of Clean Up Rig Steady-State Conditions
Test No. 94MGC09

Period #*	Steady - State		Test Mode*	Coal Type*	Gas Flow Rates	Filter Temperatures		Filter Operating Pressure	Single Filter Differential Pressure	Filter Assembly Differential Pressure	Filter Blowback Pressure
	Date (Time)	Duration, hrs.				FIR-501 (SCFH)	Inlet TIR-248 (deg F)				
1, 2	9/12 (20:00)	9/13 (18:45)	22.75	F, P, S	M7	1947	1085	1050	289	5.47	4.33
3, 4A	9/13 (19:02)	9/14 (10:33)	15.52	F, Na	M7, CLM6	1877	1151	1090	294	5.56	4.36
4B, 5, 6A	9/14 (10:33)	9/15 (01:50)	15.28	F, P, S	M7	1898	1144	1081	288	5.58	4.52
6B, 7A	9/15 (04:50)	9/15 (11:25)	6.58	F, S	M7	2015	1115	1063	293	5.16	4.16
7B, 8	9/15 (12:55)	9/15 (21:12)	8.28	F, P	M7	1828	1124	1076	295	5.59	4.45
9	9/15 (21:12)	9/16 (07:00)	9.80	F, P	Coke breeze	2263	1164	1091	293	4.29	3.10
10	9/16 (07:00)	9/16 (14:00)	7.00	F, P	I6	2226	1149	1090	294	4.60	3.32
Average	Values		85.22*			1979	1128	1074	292	5.29	4.14
											457

* Total Steady-State Run Time

** Steady-state Periods are based on FBG Steady-state Periods

+Key to Test Mode Symbols

-Key to Coal Type Symbols

- Filtering (F)
- Sorbent Test Period (S)
- Nahcolite Bed (Na)
- COS Hydrolysis Bed (C)
- Particle Monitoring (P)
- Alkali Monitoring (A)
- Ammonia Monitor (N)
- Montana #5 (M5)
- Montana #6 (M6)
- Montana #7 (M7)
- Chloride Salt with Montana #6 (CL/M6)
- Illinois #6 (I6)

G. Test Run 94FBG/MGC010

Test run 94FBG/MGC010 was conducted from October 24, 1994, through October 28, 1994, (10/24/94 (00:00) to 10/28/94 (24:00)).

a. Test Objective

The objective of this run was to attain 200 hours of steady state operation of the integrated gasifier and hot gas cleanup facility to accumulate additional hours on the C34 candle, 3M materials (SICONEX™, NEXTEL™ 312 and NEXTEL™550), to initiate filter testing of a ceramic composite candle, test a fluid bed of desulfurization sorbent prepared by Contract Materials Processing (CMP) for RTI (Zt-4L), to perform a slip stream test to expose a COS hydrolysis catalyst to a coal gas stream, to perform a test of the Direct Sulfur Recovery Process (patented by RTI and METC) using a slip stream of filtered hot coal gas, and to continue parametric testing of the gasifier by making slight adjustments to gasifier inputs.

b. Run Highlights

Below is a bulletized listing of the run highlights. Appendix 3 contains a detailed chronology of significant run events.

- 89 hours of integrated steady-state operation was attained during 11 steady state periods.
- The sulfur breakthrough curve (hydrogen sulfide level at the outlet of the desulfurizer versus time) for ZT-4L was obtained.
- Approximately 10 hours of online particulate monitoring of the coal gas entering F-100 was attained.
- A slip stream test of a COS hydrolysis bed was completed. (CaCl was used added to the feed coal to give a level of 1000 ppm of Cl in the feed coal.)
- 2 integrated DSRP tests and 18 hours of simulated SO₂ DSRP testing were completed.
- The run was shortened by 5 days when an overheated pipe buckled and could not be repaired in time to continue the run on the planned schedule.

Summary of Gasifier Operating Conditions

10" Fluid Bed Gasifier Test No. 94FBG10 (10/24 - 10/28/94)

Period #	Steady-State		Ractor Press. (1) of F(2)	Convey Air Temp. (3)	Ractor Temp. (4)	Steam +		Cone N2		Air/H2O / H2O/Coil								
	Start	End				scfh of	lb/h of	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
1	10/24 (11:50)	10/24 (23:00)	8.00	425	1243	71.8	1800.6	57	665.0	726	48.1	726	322.1	500	56.7	57	3.8	0.84
2	10/24 (23:00)	10/25 (05:00)	6.00	425	888	71.1	1807.8	48	982.0	744	42.2	744	301.2	495	123.2	48	4.7	0.59
3	10/25 (05:00)	10/25 (17:00)	12.00	426	928	71.6	1807.8	48	986.0	726	42.0	725	302.7	496	138.0	49	4.7	0.59
4	10/26 (17:00)	10/26 (05:00)	12.00	425	939	71.6	1807.8	43	984.0	729	38.0	728	302.3	497	47.3	43	5.2	0.53
5	10/26 (05:00)	10/26 (11:00)	6.00	425	940	71.8	1808.1	42	989.0	744	38.7	744	301.7	497	99.3	42	5.1	0.54
6*	10/26 (11:00)	10/26 (23:00)	12.00	425	944	70.1	1807.8	47	1044.0	744	42.1	744	302.9	500	100.0	47	4.8	0.60
7*	10/26 (23:00)	10/27 (03:00)	4.00	425	945	70.1	1807.6	43	923.0	747	40.8	747	302.5	495	98.8	43	4.7	0.58
8	10/27 (03:00)	10/27 (15:00)	12.00	425	904	74.8	1807.7	42	923.0	750	40.9	750	302.5	495	100.0	42	4.4	0.59
9	10/27 (15:00)	10/27 (21:00)	6.00	425	904	74.2	1807.4	52	983.0	751	42.8	751	301.9	500	100.8	52	4.6	0.58
10	10/27 (21:00)	10/28 (06:00)	12.00	440-425	980	75.8	1808.0	34	983.0	739	50.5	739	302.8	496	210.3	34	3.8	0.87
11	10/28 (08:00)	10/28 (13:30)	4.50	415	928	75.3	1807.0	44	880.0	714	48.1	714	284.1	N/A	87.0	44	3.9	0.84
		Total:	84.50	Avg:	981.7	72.8	1807.2	40	948.6	842	43.3	842	303.7	431	109.4	44.9	4.6	0.80

Flowings are time-averaged values:

(11) : FT-713 reading.

(2) : TE-703 reading.

(3) : ST-603 reading in rpm) x CFC (lb/h)pm

where: CFC= 2.61 (Montana #7); 2.55 (Cl-doped M#6)

(4) : Average of FT-107, -109 readings.

(5) : TE-108 reading.

(6) : Average of FT-113, -115 readings.

(7) : TE-504 reading.

(8) : Average of FT-218, -221 readings.

*

Adjusted by reducing 20% wrt from measured flow

(9)

(10)

(11)

(12)

(13)

(14)

(15)

d. Product Gas Analysis

Test No. 938610 (10/24-10/28/94)

10" Fluid Bed Gasifier

Date Sample I.D. (Time Taken)	Test- Period #	B. Mole Percent (Wet Basis)												Total %			
		Ar %	H2 %	N2 %	CH4 %	CO %	C2H6 %	HeS PPM	CO2 PPM	S02 PPM	CS2 PPM	CAH4S PPM	H2O* PPM				
October 24, 1994	1 (1600)	1	0.47	16.05	0.00	44.43	3.40	7.30	15.15	0.10	2594.74	269.50	5.83	12.82	100.00		
	2 (1700)	1	0.42	14.74	0.00	48.71	3.25	5.66	13.78	0.10	2278.74	257.72	4.88	0.00	1.42	12.89	100.00
	3 (1800)	1	0.42	13.26	0.00	50.83	3.41	4.62	13.98	0.07	4038.33	267.11	7.90	0.80	4.26	13.09	100.00
	4 (1900)	1	0.42	14.42	0.02	47.98	3.35	6.78	13.66	0.04	3038.14	330.77	6.48	0.35	3.46	12.92	100.00
	5 (2000)	1	0.43	14.88	0.00	47.45	3.25	7.96	13.01	0.04	3298.06	188.54	4.79	0.44	0.71	12.43	100.00
	6 (2100)	1	0.44	14.18	0.00	49.01	2.70	8.18	12.24	0.02	3888.72	287.84	6.32	0.44	0.00	12.07	100.00
	7 (2200)	1	0.43	14.41	0.01	48.07	2.67	8.88	12.26	0.01	2832.08	262.84	7.65	0.27	0.09	12.84	100.00
	8 (2300)	1	0.42	14.32	0.00	48.34	2.61	8.77	11.51	0.00	2085.38	210.70	6.15	0.18	0.09	12.90	100.00
	9 (2400)	2	0.44	14.90	0.02	46.04	2.50	9.83	11.43	0.00	3208.10	240.42	7.12	1.05	0.00	12.10	100.00
October 25, 1994	10 (0100)	2	0.45	14.45	0.01	48.94	2.28	9.43	11.85	0.00	3971.25	177.48	11.39	0.61	3.33	12.17	100.00
	11 (0200)	2	0.42	14.66	0.02	48.51	2.50	8.88	11.47	0.00	2462.80	223.58	6.98	0.35	0.70	12.07	100.00
	12 (0500)	2	0.44	14.18	0.00	48.24	2.35	10.52	10.80	0.00	3279.33	123.47	9.85	0.35	0.61	12.11	100.00
	13 (0800)	3	0.45	14.83	0.00	50.03	2.52	10.97	10.81	0.00	1860.05	131.35	3.85	0.83	5.38	10.09	100.00
	14 (1300)	3	0.46	14.87	0.00	49.80	2.84	10.62	11.20	0.01	1111.82	123.33	4.88	1.16	1.80	10.10	100.00
	15 (1700)	3	0.46	15.22	0.00	48.89	3.02	10.40	11.57	0.01	2053.10	112.50	6.77	0.83	0.00	10.08	100.00
	16 (2100)	4	0.46	15.47	0.00	48.78	2.68	11.52	11.28	0.00	2887.74	134.84	5.72	0.84	0.00	9.59	100.00
October 26, 1994	17 (0100)	4	0.46	15.55	0.01	48.83	2.32	12.55	10.51	0.00	1847.10	167.33	10.80	0.73	0.00	9.55	100.00
	18 (0500)	4	0.48	14.43	0.03	50.10	2.19	11.45	11.08	0.00	2140.03	79.30	13.88	0.63	0.00	9.68	100.00
	19 (0800)	5	0.46	15.43	0.00	48.76	2.31	12.48	10.54	0.00	2043.82	87.38	4.79	0.36	0.00	9.80	100.00
	20 (1100)	5	0.46	15.03	0.00	50.24	2.15	10.87	10.88	0.00	3582.17	271.82	6.05	1.28	2.38	9.37	100.00

d. (Cont'd) Product Gas Analysis

Test No. 32FBG10 (1024-012804)

10⁶ Fluid Bed Gasifier

Date/ Sample I.D. (Time Taken)	Test Period #	B. (Cont'd) Mole Percent (Wet Basis)										Total %				
		Ar	H ₂	D ₂	H ₂	CH ₄	CO	CO ₂	C ₂ H ₆	H ₂ S	CO ₃	SO ₂	C ₃ H ₈	C ₄ H ₁₀	H ₂ O*	
%	%	%	%	%	%	%	%	%	%	PPM	PPM	PPM	PPM	PPM	%	
October 28, 1994																
21 (1500)	6	0.46	15.01	0.00	48.77	2.42	10.60	11.28	0.00	191.38	78.42	6.99	0.44	1.15	11.27	100.00
22 (1800)	6	0.46	14.73	0.00	48.93	2.52	10.48	11.37	0.00	1804.11	171.86	9.43	0.82	1.87	11.31	100.00
23 (2300)	6	0.46	14.23	0.00	50.18	2.10	9.72	11.59	0.00	2708.00	202.90	7.72	0.80	5.41	11.40	100.00
October 27, 1994																
24 (0300)	7	0.46	14.46	0.02	49.39	2.35	10.56	11.12	0.00	2425.39	224.81	17.16	0.80	3.47	11.33	100.00
25 (0700)	8	0.51	14.76	0.00	49.01	2.10	10.35	11.27	0.00	3764.99	189.63	13.67	1.07	1.51	11.01	100.00
28 (0800)	8	0.46	15.26	0.00	48.23	2.50	11.36	11.04	0.00	2071.88	182.89	4.97	0.88	3.11	10.91	100.00
27 (1300)	8	0.50	15.85	0.00	47.15	2.84	10.98	11.80	0.00	1868.53	159.48	5.58	0.89	4.52	10.87	100.00
28 (1500)	8	0.47	15.13	0.00	48.73	2.61	9.61	12.98	0.00	3599.00	180.20	7.88	0.80	5.41	11.00	100.00
29 (1800)	9	0.50	15.05	0.00	47.68	2.28	10.45	11.58	0.00	3398.07	237.77	8.88	1.15	6.94	12.12	100.00
30 (2100)	9	0.46	14.85	0.00	48.24	2.22	10.75	11.08	0.00	2897.24	224.75	7.01	1.31	5.34	12.10	100.00
October 28, 1994																
31 (0100)	10	0.47	14.44	0.00	50.89	2.07	10.80	11.01	0.00	2184.38	110.50	7.95	0.90	3.61	9.89	100.00
32 (0500)	10	0.45	14.19	0.06	51.49	1.85	10.93	10.99	0.00	2104.44	109.15	10.51	0.38	0.00	9.91	100.00
33 (0800)	10	0.51	12.93	0.00	52.18	1.38	13.41	8.44	0.00	2274.18	148.72	4.66	1.17	0.00	9.91	100.00
34 (1300)	11	0.45	15.55	0.00	49.92	3.01	9.68	11.70	0.01	4038.04	223.84	5.80	0.97	0.00	12.25	100.00

* Averaged gas flow across the collection period is used to calculate H₂O content in gas.

e. Summary of Clean Up Rig Conditions

Test No. 93MGC10

Period #*	Steady - State		Test Mode*	Coal Type*	Gas Flow Rates	Filter Temperatures		Filter Operating Pressure	Single Filter Differential Pressure	Filter Assembly Differential Pressure	Filter Blowback Pressure
	Date (Time)	Duration, hrs.				Inlet TIR-248 (deg F)	Outlet TIR-224 (deg F)				
Start	End										
1, 2, 3, 4, 5	10/24 (16:30)	10/26 (10:10)	41.67	F, P, S, N	M7	2043	1057	PIR-247 (psig)	PIR-459 (psig)	PIR-155 (psig)	PIR-458 (psig)
6, 7, 8A	10/26 (11:10)	10/27 (05:04)	17.90	F, S, C	M7, CL/M6	2029	932	938	264	6.98	5.56
8B	10/27 (05:04)	10/27 (09:37)	4.55	F, P	M7	1873	1141	1088	300	7.77	6.79
8C, 9, 10, 11	10/27 (09:37)	10/28 (10:35)	24.97	F, S	M7	1400	1129	1051	293	4.90	4.46
Average	Values	89.08				1871	1053	1024	290	6.34	5.62
											450

* Total Steady-State Run Time

** Steady-state Periods are based on FBG Steady-state Periods

+Key to Test Mode Symbols

- Filtering (F)
- Sorbent Test Period (S)
- Nahcolite Bed (Na)
- CO₂ Hydrolysis Bed (C)
- Particle Monitoring (P)
- Alkali Monitoring (A)
- Ammonia Monitor (N)

-Key to Coal Type Symbols

- Montana #5 (M5)
- Montana #6 (M6)
- Montana #7 (M7)
- Chloride Salt with Montana #6 (CL/M6)
- Illinois #6 (I6)



