

RECEIVED

DOE/METC-96/1029-Vol. 2

APR 18 1995

OSTI

**METC/3M Cooperative Agreement CRADA 94-024
High Temperature High Pressure Filter Materials
Exposure Test Program**

Final Report, Volume II

June 1995

U.S. Department of Energy
Office of Fossil Energy
Morgantown Energy Technology Center
3610 Collins Ferry Road
Morgantown, WV 26505

and

Minnesota Mining and Manufacturing Company
3M Ceramic Materials Department
3M Center Building 207-1S-23
St. Paul, MN 55144-1000

Contributors:

J.M. Rockey, J.R. Bird, E. Galloway, A.P. Lui,
D. Eckels, J. Rutten, M.S. Tucker, P.C. Yue,
R.L. Pineault, J.C. Pack, T. Thomson

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED *al*

MASTER



**METC/3M Cooperative Agreement CRADA 94-024
High Temperature High Pressure Filter Materials
Exposure Test Program**

Final Report, Volume II

June 1995

U.S. Department of Energy
Office of Fossil Energy
Morgantown Energy Technology Center
3610 Collins Ferry Road
Morgantown, WV 26505

and

Minnesota Mining and Manufacturing Company
3M Ceramic Materials Department
3M Center Building 207-1S-23
St. Paul, MN 55144-1000

Contributors:

J.M. Rockey, J.R. Bird, E. Galloway, A.P. Lui,
D. Eckels, J. Rutten, M.S. Tucker, P.C. Yue,
R.L. Pineault, J.C. Pack, T. Thomson

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.






Table of Contents

	<u>PAGE</u>
Volume I	
1. Executive Summary	03
2. Objective	04
3. Gasifier and Cleanup Facility Description	04
4. Gasifier and Cleanup Facility Operation	13
A. Test Run 93FBG/MGC07	13
a. Test Objectives	13
b. Run Highlights	13
c. Summary of Gasifier Operating Conditions	14
d. Product Analysis	15-17
e. Summary of Cleanup Rig Conditions	18
B. Test Run 93FBG/MGC08	19
a. Test Objectives	19
b. Run Highlights	19
c. Summary of Gasifier Operating Conditions	20
d. Product Analysis	21-23
e. Summary of Cleanup Rig Conditions	24
C. Test Run 93FBG/MGC09	25
a. Test Objectives	25
b. Run Highlights	25
c. Summary of Gasifier Operating Conditions	26
d. Product Analysis	27-28
e. Summary of Cleanup Rig Conditions	29
D. Test Run 94FBG/MGC010	30
a. Test Objectives	30
b. Run Highlights	30
c. Summary of Gasifier Operating Conditions	31
d. Product Analysis	32-33
e. Summary of Cleanup Rig Conditions	34
Volume II	
Appendix 1: Summary of Particulate Monitoring Results	A1
Appendix 2: Detailed Chronology of Significant Run Events	A2
Appendix 3: Daily Process Variable Plots	A3
Appendix 4: Process and Instrumentation Drawings	A4



APPENDIX 1

SUMMARY OF PARTICULATE MONITORING RESULTS



Appendix 1: Summary of Particulate Monitoring Results

This report is a summary of the results of activities of the particulate monitoring group in support of the METC/3M CRADA 94-024. Online particulate monitoring began in June, 1994 and ended in October, 1994. The particulate monitoring group participated in four MGCR runs (#7 through #10). The instrument used in measuring the particle loadings (particle counts and size distribution) is the Particle Measuring Systems Classical Scattering Aerosol Spectrometer Probe High Temperature and High Pressure (PMS Model CSASP-100-HTHP). This PMS unit is rated to operate at temperatures up to 540°C and gage pressures up to 2.07 MPa.

Gas stream conditions, temperature at 540°C, gage pressure at 2.93 MPa, and gas flowrate at 0.0157 SCM per second, precluded the direct measurement of particulate loadings in the gas stream with the PMS unit. A side stream was extracted from the gas stream after it came over to the MGCR, Modular Gas Cleanup Rig, from the FBG, pressurized Fluidized-Bed Gasifier, but before it entered the filter testing vessel. A sampling probe of 0.635 cm O.D. thin wall stainless steel tubing was used for extracting the sample gas isokinetically based on the expected flowrate. The sample gas stream was further split into two streams; one was directed to the PMS unit and the other to the alkali monitor unit. The alkali monitor unit was not used during runs #7 through #10.

The gas flowrate to the PMS unit was controlled by a critical orifice to minimize particle loss. The actual sample gas flowrate was recorded continuously by the DDAS, Distributed Data Acquisition System.

The PMS unit was set to a measuring cycle of 90 seconds which resulted in about 40 measuring cycles per hour. At the end of each cycle it reported the total particle count and particle count in each size group. These were recorded by a PC. To obtain the particle loadings from measurements (i.e. particle number density and particle mass loading) it was necessary to perform post measurement calculations with flow data recorded by the DDAS which also recorded other operation parameters of the FBG and the MGCR.

Unfortunately, technical difficulties prohibited the DDAS recording of the flow data to the PMS unit for runs #7 and #10. All data were processed with flowrate values either actually recorded or a fixed value that was observed during the runs. In cases where actual flow information was available an average of 15 flow values was used to process each data set of 90 seconds (DDAS recorded flow data at a 6 second interval). Only data sets containing 6 or more hours of continuous records were processed in order to obtain a time history of the data trend.

In each data set presented, each data point represents a 15-minute ensemble average (an average of 10 measurements). Three plots of the ensemble averages were generated from each data set; mean particle diameter, mean number concentration, and mean mass loading. For mass loading calculations, a particle mass density value of 1.0 gram per cubic centimeter (1 gm/cc) was used, following the general practice used by some optical particle monitor vendors. The actual mass loading can be easily obtained by multiplying the mass loading with the appropriate particle mass density. For these FBG/MGCR runs the particle mass density varied from 2.2 to 2.5 gm/cc depending on the specific runs. A nominal value of 2.3 gm/cc has been suggested for use.

In the following, for each run presented is an example of an unprocessed particle size distribution of one 90 second measuring cycle and an example of a 15-minute averaged size distribution. Then for each data set, 3 plots are presented, one for the ensemble mean values of diameters, number concentration, and mass loading over each measuring period. In an ideal situation, when constant particle loadings and particle size distribution are present, a straight line curve for these last three plots is expected. But there are many factors that may contribute to the measured variations of particle loading and size; gasifier operations conditions, gas stream flow and pressure fluctuations, particle deposition on and re-entrainment from pipes and valves, etc.

PMS at MGCR Run #7

MGCR Run #7 took place in June, 1994. Nine hours of particulate data were collected. These data were processed with a constant flowrate of 1.18×10^{-3} SCM/sec (150 scfh) because no flow data for the particulate measuring period were recorded by the DDAS. This flow value was the expected flowrate using the combined critical flow orifice and backpressure controlled valve. Figure 5a is the particle size distribution of unprocessed data from a measuring cycle and Figure 5b shows a 15-minute average size distribution. Here we see that the average distribution is very much the same as the distribution of a single measurement. The ensemble mean diameter of the particles for this run is shown in Figure 5c. Since a constant flowrate was used to calculate the particle number concentration (Figure 5d) and mass loading (Figure 5e) they may not represent the true particle loadings.

PMS at MGCR Run #8

MGCR Run #8 took place in July, 1994. Particulate measurements included 8 hours on 7/19/94, 10 hours and 30 minutes on 7/21/94, and 23 hours on 7/22/94. Again, comparing the particle size distributions between an unprocessed single measurement (Figure 6a) and that of a 15 minute average (Figure 6b), shows no significant difference. Figures 6c, 6d, and 6e are plots of the 15 minute ensemble mean particle diameters, number concentrations, and mass loadings for the 8 hour period taken on

7/19/94. The particle data collected on 7/21 and 7/22 showed large fluctuations in ensemble mean diameters (Figure 7a and 7b) and number concentrations (Figures 7b and 8b). Consequently, the mass loadings also show large fluctuations (Figures 7c and 8c).

PMS at MGCR Run #9

Two sets of particulate measurements were taken in this run. On 9/13/94, 7 hours of particulate data were collected. Again, the size distribution is consistent between a single measuring cycle (Figure 9a) and the 15-minute averaged sized distribution (Figure 9b). The ensemble mean particle diameters are relatively large, about 0.8 microns, as shown in Figure 9c. The number concentration plot (Figure 9d) and the mass loading plot (Figure 9e) showed relatively constant values except for a sharp drop at around 1300 hours. The data collected between 9/15 and 9/16 show that the ensemble mean diameters (Figure 10a) varied more than those taken on 9/13. The mean particle concentrations also show large variations (Figure 10b). The mass loadings (Figure 10c) seem to amplify the variations in number concentration.

PMS at MGCR Run #10

In the final run, MGCR Run #10, the DDAS recording bug struck again. The record showed zero values for the particulate sample flow during the measuring period. We again used a constant flowrate of 1.18×10^{-3} SCM/sec (150 scfh) to process the data. The plots in Figures 10a through 10e for this set of data are the same as those for the previous sets of data. While the mean particle diameters remained between 0.85 to 0.7 micrometers (see Figure 10a) there was a big drop in particle number concentration occurring at 1245 hours, as shown in Figure 10b. This big drop in number concentration may be due to partial plugging of the sampling probe or flow valves. If DDAS flow data were available this loss of flow would be accounted for in the averaging.

Conclusion

Obviously the operating conditions of the FBG affected the particulate loading and size distributions in the gas stream. The ability to maintain size calibration of the PMS also affected the measured results. We tried to collect solid samples downstream of the PMS unit to compare loadings from optical measurements. However we found the mass loadings on the high temperature ceramic thimble filters were not consistent. We suspected that leakage at the seal of the thimble filter was the cause. For instance, solid catches under high temperature showed loadings varied from 0.09 to 0.13 gram per hour. It is suspected that thermal expansion may have contributed to the leakage problem.

Supplemental to the online particulate monitoring, the following table provides the hours of filtration and the pounds of solid filtered with respect to the filtration vessel.

Run Number	Hours of Filtration per Run	Pounds of Solid Collected
7	119	2.12
8	189	5.62
9	86	3.38
10	89	2.56

Particle Size Distribution
MGCR Run #7 94/06/14 01:01:26




Figure 5a. Unprocessed particle size distribution from a single measurement.

Averaged Particle Size Distribution
 MGCR Run #7 94/06/14 01:00




Figure 5b. A 15-minute averaged particle size distribution.

PMS at MGCR Run #7
6/14/94




Figure 5c. Ensemble mean particle diameters.

PMS at MGCR Run #7
6/14/94




Figure 5d. Ensemble mean particle concentrations.

PMS at MGCR Run #7
6/14/94




Figure 5e. Ensemble mean mass loadings.

Particle Size Distribution
MGCR Run #8 94/07/19 12:00:13




Figure 6a. Unprocessed particle size distribution from a single measurement.

Averaged Particle Size Distribution
 MGCR Run #8 94/07/19 12:00




Figure 6b. A 15-minute averaged particle size distribution.

PMS at MGCR Run #8
7/19/94




Figure 6c. Ensemble mean particle diameters.

PMS at MGCR Run #8
7/19/94




Figure 6d. Ensemble mean particle concentrations.

PMS at MGCR Run #8
7/19/94




Figure 6e. Ensemble mean mass loadings.

PMS at MGCR Run #8
7/21/94




Figure 7a. Ensemble mean particle diameters.

PMS at MGCR Run #8
7/21/94




Figure 7b. Ensemble mean particle concentrations.

PMS at MGCR Run #8
7/21/94




Figure 7c. Ensemble mean mass loadings.

PMS at MGCR Run #8
7/22/94




Figure 8a. Ensemble mean particle diameters.

PMS at MGCR Run #8
7/22/94





Figure 8b. Ensemble mean particle concentrations.

PMS at MGCR Run #8
7/22/94



A1-20

Figure 8c. Ensemble mean mass loadings.

Particle Size Distribution
MGCR Run #9 94/09/13 10:30:58




Figure 9a. Unprocessed particle size distribution from a single measurement.

Averaged Particle Size Distribution
 MGCR Run #9 49/09/13 10:30




Figure 9b. A 15-minute averaged particle size distribution.

PMS at MGCR Run #9
9/13/94





Figure 9c. Ensemble mean particle diameters.


PMS at MGCR Run #9
9/13/94



A1-24

Figure 9d. Ensemble mean particle concentrations.

PMS at MGCR Run #9
9/13/94



Time of Day

Figure 9e. Ensemble mean mass loadings.

PMS at MGCR Run #9
9/15-16/94




Figure 10a. Ensemble mean particle diameters.

PMS at MGCR Run #9
9/15-16/94




Figure 10b. Ensemble mean particle concentrations.

PMS at MGCR Run #9
9/15-16/94




Figure 10c. Ensemble mean mass loadings.

Particle Size Distribution
MGCR Run #10 94/10/26 10:01:10




Figure 11a. Unprocessed particle size distribution from a single measurement.

Averaged Particle Size Distribution
 MGCR Run #10 94/10/26 10:00




Figure 11b. A 15-minute averaged particle size distribution.

PMS at MGCR Run #10
10/26/94




Figure 11c. Ensemble mean particle diameters.

PMS at MGCR Run #10
10/26/94




Figure 11d. Ensemble mean particle concentrations.

PMS at MGCR Run #10
10/26/94





Figure 11e. Ensemble mean mass loadings.



APPENDIX 2

DETAILED CHRONOLOGY OF SIGNIFICANT RUN EVENTS



Table 1 . SUMMARY OF MAJOR EVENTS DURING TEST RUN
(Test No. 94FBG07)

June 6-15, 1994

<u>Date (Time)</u>	<u>Duration</u>	<u>Description of Events</u>
6/6 (00:00)		<ul style="list-style-type: none"> • Started <u>System Start-up</u> procedure. • Reactor insert with steam side-jets was used.
6/6 (02:57) - (14:01)	11 hr 4 min.	<ul style="list-style-type: none"> • Air Preheater ignited. Heated up reactor to 800°F (TIR-700, -701, -707 & -733, whichever one reached first). • FCV-113& 115 could not provide 7000 scfh. Opened HV-503 to obtain the required air flow. • Repaired leaks around FV-221. • DDAS on-line, changed logging rate from 2 to 4 sec. But crashed 4-5 times.
6/6 (14:01) - (16:10)	2 hr 9 min.	<ul style="list-style-type: none"> • Started <u>Combustion mode</u>.
6/6 (16:10) - (16:46)	36 min.	<ul style="list-style-type: none"> • Purged reactor to reduce O₂ conc. to < 3% by replacing reactor air with N₂.
6/6 (16:46) - (18:30)	1 hr 44 min.	<ul style="list-style-type: none"> • Started <u>Gasification mode</u>. <ul style="list-style-type: none"> a. Convey air at 850 scfh, Reactor air at 1200 scfh, side steam at 33 lb/h out of total 55 lb/h, underflow N₂ reduced from 400 to 350 scfh, and coal feed at 70.4 lb/h. b. Performed routine coal transfer from batch to feed hopper and from silo to batch hopper. c. Performed routine dumping of solids from all lockhoppers every hour; and purging all vent valves and transmitters every 4 hours.
6/6 (18:30) - 6/7 (05:38)	11 hr 8 min.	<ul style="list-style-type: none"> • <u>Steady-State #1</u> (with Montana #6). <ul style="list-style-type: none"> a. Change conditions many times to reduce the H₂O in underflow dump: Increased convey air to 1,080 and reactor air to 1,500 scfh; reduced underflow N₂ to 200 scfh; increased set points in air preheater and superheater) b. TIR-701 reached 1,770°F at 01:40 on 6/7.

<u>Date (Time)</u>	<u>Duration</u>	<u>Description of Events</u>
6/7 (05:38) - (15:45)	10 hr 7 min.	c. Reset the conditions to : Convey Air = 900 scfh, Reactor air = 1,300 scfh; underflow.N ₂ = 320 scfh; side steam of 33 lb/h with 50 lb/h total; and coal feed = 70 lbm/h. d. DDAS crashed 2 times.
6/7 (15:45) - 6/8 (00:30)	8 hr 45 min.	e. High temperature excursion to 1,900°F on TIR-701. f. Loss of coal feed at 05:32.
6/8 (00:30) - 6/8 (05:02)	4 hr 32 min.	Controlled <u>Shutdown</u> due to loss of coal feed. Cooled reactor from 1,500 to 800°F. DDAS off-line at 10:25.
6/8 (05:02) - (10:40)	5 hr 38 min.	Used air chisel to remove clinker from the wall that held the reactor insert in place. The reactor insert dropped out of the reactor at 23:50. Removed TE-707 and plugged the hole of the housing.
6/8 (10:40) - (11:45)	1 hr 5 min.	Started <u>System Start-up</u> procedure. Installed reactor insert with <u>no side-jets</u> .
6/8 (11:45) - (14:00)	2 hr 15 min.	Ignited air Preheater and incinerator. Heated up reactor to 800°F (TIR-700, -701, -707 & -733, whichever reached first). DDAS back on-line at 08:00 but crashed once at approx. 09:40.
6/8 (14:00) - (16:20)	1 hr 40 min.	Started <u>Combustion mode</u> .
6/8 (16:20) - (16:32)	12 min.	Dropped reactor pressure to fix coal plug in feed line. Restarted <u>Combustion mode</u> . Purged reactor to reduce O ₂ conc. to < 3% by replacing reactor air with N ₂ . TIR-700 at 1126°F.

<u>Date (Time)</u>	<u>Duration</u>	<u>Description of Events</u>
6/8 (16:32) - (21:38)	5 hr 6 min.	<ul style="list-style-type: none"> • Started <u>Gasification mode</u>. a. Convey air at 850 scfh, reactor air gradually raised from 500 to 1200 scfh, steam at 55 lb/h, underflow N₂ reduced from 400 to 0 scfh (to prevent steam condensation in the bed), and coal feed at 70.2 lb/h. b. Performed routine coal transfer from batch to feed hopper and from silo to batch hopper. c. Performed routine dumping of solids from all lockhoppers every hour; and purging all vent valves and transmitters every 4 hours.
6/8 (21:38) - 6/12 (11:30)	89 hr	<ul style="list-style-type: none"> • <u>Steady-State #2</u> (with Montana #6 coal). a. No underflow dumping due to bad leaks in transition MoGas valve (FV-908). But it caused very low underflow N₂ even with FCV-311/313 wide open. Clinker might have been formed. We fixed the problem with 1200-psig N₂ purge through FV-908. Then, we were able to get underflow N₂ back to 450 scfh. b. Reactor temperature crept up to 1,670°F (TIR-700). Had an excursion to 1,800 (TIR-733) at 02:50 of 6/9. To stop it, we increased steam from 50 to 55 lb/h, reduced reactor air from 1,200 to 1,100 scfh, switched convey air to N₂. At 03:50, all temperatures resumed uniform between 1,282 and 1,477°F. c. From 08:59 to 13:35 of 6/9, increased reactor air gradually to increase bed temperature. At 16:07, TE-700, -701, -702, and -703 read 1,076, 1,514, 1,499, and 1,458. d. At 21:39 of 6/10, another temperature creeping occurred at TE-701 (apprx. 1,816°F). We tuned down the reactor air and increased underflow N₂ flow to bring down TIR-701, but we overshoot it to 862°F. e. From 16:13 of 6/11 on, TIR-700 and -701 were very low (apprx. 300°F). We were very sure a clinker was formed in the bottom of the bed.

<u>Date (Time)</u>	<u>Duration</u>	<u>Description of Events</u>
6/12 (11:30) - 6/13 (04:21)	16 hr 51 min.	<ul style="list-style-type: none"> • <u>Controlled Shutdown</u> for MGCR to load sorbent. a. Found and fixed the leak in the gas grab sampling system by putting in a check valve in the exit line after the gas grab bottle. b. Cooled off the reactor bottom and bed so that the workers could work on it). Cleaned out the clinker from the insert and bed (8'1" tall from the face of the bottom flange). Feed nozzle was brushed clean. c. Installed TE-707 back for combustion zone temperature. d. Purge all hand valves and push-button purge lines. We got a lot of dust out of the purge line.
6/13 (04:21) - (13:30)	9 hr 9 min.	<ul style="list-style-type: none"> • e. Replaced the MoGas valve (FV-908) that had a groves on the bottom seat with a new one. • Started <u>System Start-up</u> procedure. a. At 07:40, MGCR decided to scratch their Dry Chloride Removal (DCR) test plan. At 10:15, all chloride doped coal was removed from silo and replaced with regular coal.
6/13 (13:30) - (15:00)	1 hr 30 min.	<ul style="list-style-type: none"> • Start <u>Combustion mode</u>. a. Added underflow N₂ during this mode.
6/13 (15:00) - (15:10)	10 min.	<ul style="list-style-type: none"> • Purged reactor to reduce O₂ conc. to < 3% by replacing reactor air with N₂.

<u>Date (Time)</u>	<u>Duration</u>	<u>Description of Events</u>
6/13 (15:10) - (17:26)	2 hr 16 min.	<ul style="list-style-type: none"> • Started Gasification mode. a. At the start of this mode, the following condition was set: Convey air at 850 scfh, reactor air at 1105 scfh, steam at 63 lb/h, underflow N₂ at 478 scfh, and coal feed at 70.2 lb/h.
6/13 (17:26) - 6/15 (12:40)	43 hr 14 min.	<ul style="list-style-type: none"> • <u>Steady-State #3 (with Montana #6 coal).</u> a. At 17:20, a different flow configuration was tried: Convey air at 1600 scfh, reactor air at 450 scfh, steam at 54 lb/h, underflow N₂ at 400 scfh and coal feed 70 lb/h. b. Performed routine coal transfer from batch to feed hopper and from silo to batch hopper. c. Performed routine dumping of solids from all lockhoppers every hour; and purging all vent valves and transmitters every 4 hours.
6/15 (12:40) - (24:00)	11 hr 20 min.	<ul style="list-style-type: none"> • <u>Normal System Shutdown.</u>

Total Gasification Time = 151 hr 74 min. Total Steady-State Time = 143 hr 22 min.
Total No. of Steady-State Periods = 3 (11.13; 89; and 43.23 hours).

Table 1 . SUMMARY OF MAJOR EVENTS DURING TEST RUN
 (Test No. 94FBG08) July 18-27, 1994

<u>Date (Time)</u>	<u>Duration</u>	<u>Description of Events</u>
7/18 (00:00)		<ul style="list-style-type: none"> Started <u>System Start-up</u> procedure. Reactor insert without side-jets was used (from the last S.S. period of Test Run 94FBG07). Montana Rosebud #6 coal in silo.
7/18 (00:40) -	10 hr 41 min.	<ul style="list-style-type: none"> Air Preheater ignited. Heated reactor to 800°F. (Based on TIR-700, -701, -707 & -733, whichever one reached first). Opened HV-503 and FCV-115 to obtain the high air flow (apprx. 7000 scfh). Repaired broken flexible coupling at VSL-906. Set all line heater temperatures to 500°F except Zone 6 & 7 to 1100°F (exits of both cyclones).
7/18 (11:21) - (13:10)	1 hr 49 min.	Started <u>Combustion mode</u> .
7/18 (13:10) - (13:55)	45 min.	Purged reactor to reduce O ₂ conc. to < 3% by replacing reactor air with N ₂ .
7/18 (13:55) - (16:30)	2 hr 35 min.	<ul style="list-style-type: none"> Started <u>Gasification mode</u>. a. Convey air at 1600 scfh, Reactor air at 460 scfh, under-flow N₂ at 402 scfh, steam at 55 lb/h and coal feed at 69.6 lb/h. b. Performed routine coal transfer from batch to feed hopper and from silo to batch hopper. c. Performed routine dumping of solids from all lockhoppers every hour; and purging all vent valves and transmitters every 4 hours.
7/18 (16:30) -	44 hr 15 min.	Steady State #1 (with regular coal for METC-2 Sorbent Test and Filter Test).
7/20 (12:45)		<ul style="list-style-type: none"> a. Low sample loop flow (FIR-806) - 3.2 scfh - due to crystal -like material built up. Cleaned and flow resumed. b. Sampling frequency: gas grab, detector tube, and condensate every hr., solids for every 4 hours.

<u>Date (Time)</u>	<u>Duration</u>	<u>Description of Events</u>
7/18 (2355)		c. Mass spec. went off-line numerous times during the run.
7/19 (0745)		d. MGR requested to postpone High Cl ⁻ -coal run for 24 hours. e. MGR sorbent test had a breakthrough between 7/18 2330 and 7/19 0030. Thus, sampling freq. changed from every hour to every 4 hrs for gas grab, condensate, and filter fines. No more detector tube. Solids for every 12 hours. f. Primary cyclone plugged. Unplugged with purging (bypassed interlock).
7/20 (1245)	16 hr	<u>Steady-State #2</u> (with high chloride coal for Dry Chloride Removal (DCR) Test).
7/21 (0445)		a. Continuous monitoring pH and Cl ⁻ content in condensate from 7/20 1130 to 7/21 0630: pH dropped from 9.3 to 8.6; and Cl ⁻ increased irregularly from < 10 ppm to 250 ppm.
7/21 (0445) - 7/27 (0035)	139 hr 50 min.	<u>Steady-State #3</u> (with regular coal to continue Filter Test). a. Operating Conditions: Convey air 1600 scfh @66°F, Reactor air 530 scfh @940°F, steam 52 lb/h @950°F, underflow N ₂ 400 scfh @495°F, coal @30 rpm (70 lb/h). b. In the underflow dump, occasionally found small pieces of clinkers. c. Neotronics personal monitors lost SO ₂ detecting capability. Need to use the Drager monitors along with the Neotronics. d. ES&H discovered gas leaked into B12 through the space around a pipe penetrating into the building. Did not know where was the source. Gas had 281 ppm CO and 9.5 ppm H ₂ S. The space was temporarily patch with insulation material. The source could be the baghouse, leaking from its top. e. Found a hole in the vent line above HV-950 and temporarily plug it with a screw. f. MGR lost all flow from FBG through FT-501. Switched to FCV-755. For 15 min. from 2108, there was a large pressure fluctuation on the reactor and manifold. PCV-756 slammed open and shut real bad. Had instrumentation tech. change the programming of the valve.
7/21 (1155)		
7/23 (0630)		
7/25 (0655)		
7/26 (2102)		

Table 1 . SUMMARY OF MAJOR EVENTS DURING TEST RUN
 (Test No. 94FBG09) September 12-16, 1994

<u>Date (Time)</u>	<u>Duration</u>	<u>Description of Events</u>
9/12 (00:00)		<ul style="list-style-type: none"> Started <u>System Start-up procedure</u>. Reactor insert without side-jets was used (from 94FBG08). Montana Rosebud #7 coal (1,950 lbm) loaded in silo.
9/12 (00:10) - (14:56)	14 hr 46 min.	<ul style="list-style-type: none"> Air Preheater ignited. Heated reactor to 800°F. (Based on TIR-700, -701, -707 & -733, whichever one reached first). Opened HV-503 and FCV-115 to obtain the high air flow (apprx. 4500 scfh max. vs 7,000 scfh max. in 94FBG08). Set all line heater temperatures to 500°F except Zone 6 & 7 to 1100°F (exits of both cyclones).
9/12 (14:56) - (16:08)	1 hr 12 min.	<ul style="list-style-type: none"> Started <u>Combustion mode</u>. a. Raised the reactor temperature in 3 stages: 1,045 - 1,300 - 1,400 - 1,600°F).
9/12 (16:08) - (16:22)	14 min.	<ul style="list-style-type: none"> Purged reactor to reduce O₂ conc. to < 3% by replacing reactor air with N₂.
9/12 (16:22) - (16:52)	30 min. (assumed)	<ul style="list-style-type: none"> Started <u>Gasification mode</u>. a. Convey air at 1600 scfh, Reactor air at 525 scfh, underflow N₂ at 402 scfh, steam at 58 lb/h and Montana #7 coal fed at 70 lb/h (air/coal=2.32; steam/coal=0.83). b. Performed routine coal transfer from batch to feed hopper and from silo to batch hopper. c. Performed routine dumping of solids every hour except underflow every 30 min. and 2nd cyclone every 6 hours; and purging all vent valves and transmitters every 4 hours.
9/12 (16:52) - 9/13 (06:15)	13 hr 23 min.	<ul style="list-style-type: none"> <u>Steady State #1</u> (with Montana #7 coal for METC-2 Sorbent Test and Filter Test with an air/coal of 2.32). a. Gas alarm went off twice (18:39 and 19:06) due to gas leak from the transition valve when dumping secondary cyclone. b. Sampling frequency: gas grab, detector tube and condensate every hr. until MGCR sorbent breakthrough, then every 4 hours; solids every 2 hours except cyclone every 12 hours.

<u>Date (Time)</u>	<u>Duration</u>	<u>Description of Events</u>
9/13 (06:15) - (18:00)	11 hr 45 min.	<ul style="list-style-type: none"> c. At 18:29, switched mass spec. (707) from FBG to MGCR. d. Moisture contents in product gas = 12.3, 10.3 and 10.7%wt.
		<ul style="list-style-type: none"> • <u>Steady State #2</u> (with Montana #7 coal for METC-2 Sorbent Test, Filter Test and Gain Matrix Test with an increase of air/coal from 2.32 to 2.65). <ul style="list-style-type: none"> a. At 06:15, started to increase reactor air from 525 to 825 scfh in 3 increments of 100 scfh. b. Gas alarm in alley read 2ppm SO₂ and PEL light on at 12:25. c. Mass spec. switched from MGCR to FBG at 12:42. d. At 11:45, loaded 1,120 lbm of Cl⁻ doped Montana #6 coal into silo. e. From 11:45-11:47, took DDAS off line for mass spec. (707).
9/13 (18:00) - 9/14 (10:22)	16 hr 22 min.	<ul style="list-style-type: none"> • <u>Steady State #3</u> (with 3% chloride doped Montana Rosebud #6 coal for DCR Test, Filter Test and Gain Matrix Test with an air/coal of 2.87). <ul style="list-style-type: none"> a. At 18:03, raised reactor air from 825 to 1,025 in 4 increments of 50, 50, 25 and 25 scfh. At 23:13, reactor air reached to 1,025. b. Moisture Content in product gas during this period: 13.8, 12.7 and 10.4%wt. c. At 02:00, loaded 520 lbm of Montana #7 coal into silo. d. At 06:10, increased underflow N₂ from 400 to 500 scfh. e. At 10:20, loaded 740 lbm of Montana #7 coal into silo. f. Gas sample changed to every 4 hours; no detector tube. g. Moisture contents in product gas = 13.8, 12.7, 10.4 and 8.7%wt.
9/14 (10:22) - (19:27)	9 hr 5 min.	<ul style="list-style-type: none"> • <u>Steady State #4</u> (with Montana #7 coal for Gain Matrix Test). <ul style="list-style-type: none"> a. At 11:21 and 12:21, loaded a total of 1,440 lbm of Montana #7 coal into silo. b. From 13:25-13:27, took DDAS off line to change strategy so that mass spec. signal goes to totalizer and an alarm. c. At 16:10, lowered underflow N₂ from 500 to 400 scfh. d. At 17:16, gas alarm activated by radio. e. At 18:44, load 325 lbm of Montana #7 coal into silo.

<u>Date (Time)</u>	<u>Duration</u>	<u>Description of Events</u>
9/14 (19:27) - 9/15 (06:10)	10 hr 43 min.	<p>f. Moisture Contents of product gas = 8.7 and 8.3 %wt.</p> <p>• <u>Steady State #5</u> (with Montana Rosebud #7 coal for Gain Matrix Test with an increase of coal feed rate from 70 to 80 lb/hr, resulting in a decrease of air/coal of 2.5).</p> <p>a. At 00:29 and 05:40, loss of coal feed during coal transfer into feed hopper and recovered with emergency N₂ (FV-409).</p> <p>b. Moisture Contents of product gas = 9, 10, 9.8 %wt.</p>
9/15 (06:10) - 9/15 (21:12)	15 hr 2 min.	<p>• <u>Steady State #6</u> (with Montana Rosebud #7 coal for Gain Matrix Test with an increase of air/coal of 2.87).</p> <p>a. At 06:10, started to increase reactor air from 1,025 to 1,400 scfh in 7 increments of 50 scfh and last increment of 25 scfh.. At 09:55, reactor air reached to 1,400 scfh.</p> <p>b. From 09:43-09:45, took DDAS off line to update the mass spec. alarm.</p> <p>c. At 16:06, decreased reactor air to 1,025 scfh and coal feed to 70 lb/h.</p> <p>d. At 17:25, loaded silo with 810 lbm of coke breeze.</p> <p>e. Moisture Contents of product gas = 9.1, 10.3 and 8.8 %wt.</p>
9/15 (21:12) - 9/16 (07:00)	9 hr 48 min.	<p>• <u>Steady State #7</u> (with Coke Breeze at 70 lbm/hr and an air/coke of 2.87)</p> <p>a. At 22:47, discovered old calibration curve for coke breeze, i.e., 30 rpm=72 lbm/hr of coke breeze.</p> <p>b. At 00:53, loaded 600 lbm of Illinois #6 coal into silo.</p> <p>c. At 01:05, reduced underflow N₂ from 500 to 475 scfh; at 01:10, reduce it further to 450 scfh.</p> <p>d. At 01:25, turned off air preheater to prepare for cooler reactor air for running caking (bituminous) coal.</p> <p>e. At 02:10, decreased reactor air from 1,025 to 1,000 scfh and increased underflow N₂ from 450 to 500 scfh.</p> <p>f. At 04:59, increased reactor air from 1,000 to 1,025 scfh.</p> <p>g. At 05:45, batch hopper is empty; then loaded Illinois #6 coal from silo to batch hopper.</p> <p>h. From 05:50 to 06:16, increased reactor air from 1,025 to 1,200 scfh in an increments of 25 scfh and 3 increments of 50 scfh.</p>

<u>Date (Time)</u>	<u>Duration</u>	<u>Description of Events</u>
9/16 (07:00) - (14:00)	7 hr	<ul style="list-style-type: none"> i. At 06:01, reduce underflow N₂ from 500 to 475 scfh; at 06:11, reduce it to 460 scfh; and at 06:47, further reduced to 440 scfh. j. Moisture Contents of product gas = 10.4 and 9.2 %wt.
		<ul style="list-style-type: none"> • <u>Steady State #8</u> (with Illinois #6 coal) <ul style="list-style-type: none"> a. From 07:02 to 07:25, reduced reactor air from 1,200 to 1,150 scfh, and underflow N₂ further down to 400 scfh.
9/16 (14:00) - (24:00)	10 hr	<ul style="list-style-type: none"> b. Moisture Contents of product gas = 13, 9.5 and 8.9 %wt. • <u>Normal System Shutdown</u> as scheduled. <ul style="list-style-type: none"> a. Changed convey and reactor air to N₂. b. Turned of coal feeder and N₂ preheater. c. Bypassed steam from reactor. d. Weighed and secured all barrels of solids. e. Shut off portable boiler. f. Transferred all solids from silo through batch into feed hopper. g. Blew out all vent lines with HV-950 for 10 sec. h. Shut all N₂ and sir header valves. i. Removed the center (3/4") feed nozzle from reactor bottom. j. Calibrated coal feeder ("A") with Illinois #6 coal.
9/19 Morning		<ul style="list-style-type: none"> • Dropped the reactor bottom and found no clinkers adhered on the reactor wall and the insert.

Total Gasification Time = 93 hr 38 min.
Total No. of Test Periods = 8 (13.38, 11.75, 16.37, 9.08, 10.72, 15.03, 9.8, and 7 hours).

Total Test Time = 93 hr 8 min.

Table 1. SUMMARY OF MAJOR EVENTS DURING TEST RUN
(Test No. 94FBG10)

October 24-28, 1994

<u>Date (Time)</u>	<u>Duration</u>	<u>Description of Events</u>
10/24 (00:00)	11 hr	<ul style="list-style-type: none"> • <u>Test Period #1</u> (Heat-Up of the system) <ul style="list-style-type: none"> a. Started <u>System Start-up</u> procedure. b. Reactor insert with side-jets was used (Brand new design). c. Montana #7 coal (3,500 lbm) loaded in silo on 10/18. d. Air Preheater ignited. Heated reactor to 800°F. (Based on TIR-700, -701, -707 & -733, whichever one reached first). e. Set cone N₂ to 50 scfh (FIR-311) and underflow N₂ (FIR-313) to 350 scfh with underflow N₂ preheater set at 350°F. f. Heated up reactor faster at lower pressure (100 psig). g. Set all line heater temperatures to 500°F except Zone 6 & 7 to 1100°F (exits of both cyclones). h. At 07:45, reactor pressure was raised to 425 psig when the bottom temperatures reached to 750°F. i. At 08:30, fixed steam leak at PCV-221 and reinsulated the line. Another small leak was found around TE-220 and was not fixed.
10/24 (11:00) - (13:00)	2 hr	<ul style="list-style-type: none"> • Started <u>Combustion mode</u>. Raised the reactor temperature in 3 stages: 1,045 - 1,300 - 1,400 - 1,600°F).
10/24 (13:00) - (13:46)	46 min.	<ul style="list-style-type: none"> • Purged reactor to reduce O₂ conc. to < 3% by replacing reactor air with N₂.
10/24 (13:46) - (15:00)	1 hr 14 min.	<ul style="list-style-type: none"> • Started <u>Gasification mode</u>. <ul style="list-style-type: none"> a. Convey air at 1600 scfh, Reactor air at 854 scfh, cone N₂ at 50 scfh and underflow N₂ at 350 scfh, steam at 60 lb/h and Montana #7 coal fed at 70 lb/h (Air/Coal (daf) = 3.3; Steam/Coal (daf) = 0.83). b. Performed routine coal transfer from batch to feed hopper and from silo to batch hopper. c. Performed routine dumping of solids every hour except underflow every 30 min. and 2nd cyclone every 6 hours; and purging all vent valves and transmitters every 4 hours.

<u>Date (Time)</u>	<u>Duration</u>	<u>Description of Events</u>
10/24 (15:00) - (23:00)	8 hr	<ul style="list-style-type: none"> • <u>Test Period #2</u> (Filled bed with an Air/Coal (daf) of 3.3 and Steam/Coal (daf) at 0.83). <ul style="list-style-type: none"> a. At 15:20, mass spec. (707) was turned on for MGCR. b. At 16:30, MGCR came on-line. c. Rupture disk 753A was blown and replaced with ES&H personnel present (CO on 3rd floor of the cell = 9ppm). d. Small fire around the overflow pipe on the 2nd level of cell was found and extinguished. e. Sampling frequency: gas grab, detector tube and condensate every hr. until MGCR sorbent breakthrough, then every 4 hours; solids every 2 hours except cyclone at the end of each test period (6 or 12 hours). f. Averaged Moisture Content in product gas = 9.4 %wt. g. DDAS was down twice.
10/24 (23:00) - 10/25 (05:00)	6 hr	<ul style="list-style-type: none"> • <u>Test Period #3</u> (Bed stabilization with Montana #7 coal for ZT-04 Sorbent Test, Filter Test and test matrix with an increase of reactor air to 1,000 scfh and cone N₂ to 100 scfh, and a decrease of steam to 55 lb/h and underflow N₂ to 300 scfh. <ul style="list-style-type: none"> a. Needed to purge the overflow line frequently to unplug it. b. Mass spec. (707) went off-line several times. c. Between 00:00 and 01:00, there was a breakthrough on ZT-04. d. Averaged Moisture Content in product gas = 8.9 %wt.
10/25 (05:00) - (17:00)	12 hr	<ul style="list-style-type: none"> • <u>Test Period #4</u> (with Montana #7 coal for test matrix with an increase of cone N₂ to 150 scfh). <ul style="list-style-type: none"> a. Needed to purge the overflow line frequently to unplug it. b. Mass spec. (707) went off-line several times. c. At 14:40, MGCR called to shut off mass spec. (707). d. At 16:46, reactor temperatures were: 927 (TIR-700), 1242 (-701), 1,568 (-701), 903 (-703), and 1,010°F (-733). e. Averaged Moisture Content in product gas = 7.4 %wt.

<u>Date (Time)</u>	<u>Duration</u>	<u>Description of Events</u>
10/25 (17:00) - 10/26 (05:00)	12 hr	<ul style="list-style-type: none"> • <u>Test Period #5</u> (with Montana #7 coal for test matrix with cone N₂ reset at 50 scfh). <ul style="list-style-type: none"> a. At 18:20, ES&H personnel accompanied one technician and shift engineer to check the CO level at the 2nd level, which hit 35 ppm. Needed to insulate the overflow pipe. b. Needed to purge the overflow line frequently to unplug it. c. Averaged Moisture Contents of product gas = 7.0 %wt.
10/26 (05:00) - (11:00)	6 hr	<ul style="list-style-type: none"> • <u>Test Period #6</u> (with Montana #7 coal for test matrix with an increase of cone N₂ to 100 scfh). <ul style="list-style-type: none"> a. At 05:45, loaded 1,190 lbm of Cl⁻ doped Montana #6 coal into silo. b. Averaged Moisture Content of product gas = 7.2 %wt.
10/26 (11:00) - 10/26 (23:00)	12 hr	<ul style="list-style-type: none"> • <u>Test Period #7</u> (with 3% chloride doped Montana #6 coal for DCR Test, Filter Test and test matrix with an Air/Coal (daf) of 3.82 and Steam/Coal (daf) of 0.83). <ul style="list-style-type: none"> a. At 16:14, reactor temperatures were: 1,027 (TIR-700), 1,277 (-701), 1,630 (-702), 940 (-903) and 1,027°F (-733). b. At 00:45, loaded 3,640 lb of Montana #7 coal into silo. c. Averaged Moisture Content of product gas = 8.3 %wt.
10/26 (23:00) - 10/27 (03:00)	4 hr	<ul style="list-style-type: none"> • <u>Test Period #8</u> (with 3% chloride doped Montana #6 coal for DCR Test, Filter Test and test matrix with an Air/Coal (daf) of 3.65 and Steam/Coal (daf) of 0.81). <ul style="list-style-type: none"> a. Reduced the reactor air flow to 940 scfh according to the test matrix planned.
10/27 (03:00) - (15:00)	12 hr	<ul style="list-style-type: none"> • <u>Test Period #9</u> (with Montana #7 coal for test matrix with a decrease of reactor air to 940 scfh. Air/Coal (daf) was 3.12 and steam/coal (daf) was 0.74) <ul style="list-style-type: none"> a. CO gas alarm in cell at 40 ppm. b. MGR was off-line from 13:16 to 13:29. c. Averaged Moisture Content of product gas = 8 %wt.
10/27 (15:00) - (21:00)	6 hr	<ul style="list-style-type: none"> • <u>Test Period #10</u> (with Montana #7 coal for test matrix with an increase of reactor air to 1,000 scfh, Air/Coal (daf) = 3.17 and Steam/Coal (daf) of 0.85)

<u>Date (Time)</u>	<u>Duration</u>	<u>Description of Events</u>
10/27 (21:00) - 10/28 (09:00)	12 hr	<ul style="list-style-type: none"> a. At 19:16, the Neotronics monitor carried by a technician detected 15 ppm CO and ES&H personnel was called in but detected no leak around the baghouse. b. Averaged Moisture Content in product gas = 9 %wt. • <u>Test Period #11</u> (with Montana #7 coal for test matrix with an increase of reactor pressure (PIR-713) to 440 psig) <ul style="list-style-type: none"> a. At 23:12, had problems with the steam flow and gas leak in cell (getting worse). Thus, reduced reactor pressure back to 425 psig. b. At 00:10, increased cone N₂ from 100 to 200 scfh (an additional study in the Test Matrix). c. At 07:20, discovered steam flow creeping up from 55 to 70 lb/h. Reduced to 55 lb/h, but it crept back up 60 lb/h within 10 min. Again reduced it to 58 lb/h but discovered TIR-702 creeping up to 1,698°F. Stopped reducing steam and watch TIR-702 closely. d. Averaged Moisture Content of product gas = 7.2 %wt.
10/28 (09:00) - (13:30)	4 hr 30 min.	<ul style="list-style-type: none"> • <u>Test Period #12</u> (with Montana #7 coal for test matrix with a decrease of reactor pressure to 400 psig) <ul style="list-style-type: none"> a. At 09:00, CO alarm on 3rd level in cell went off at 35 ppm. b. At 09:03, reduced reactor pressure down to 400 psig and cone N₂ flow from 200 to 100 scfh, keeping underflow N₂ at 300 scfh, causing the reactor pressure to swing for about 10 min. before it stabilized at 400 psig. c. At 09:05, the bed slumped (PDIR-706) which stopped the underflow N₂ about 15 min. The product gas flow also varied between 2,000 to 9,000 scfh during this 15 min. d. At 09:30, steam flow declined from 62 to 30 lb/h in 35 min. and raised back to 58 lb/h afterward. e. At 10:35, MGCR got off-line to remove sorbent and switch filter vessels and clean the plugged incinerator lines. f. At 10:50, TIR-700 went up to 1,962°F. Reduced reactor air to 950 scfh and increase steam to 70 lb/h. Brought reactor pressure down to 425 psig to alleviate the overheating problem but failed. g. Averaged Moisture Content of product gas = 9 %wt.

Date (Time) Duration Description of Events

10/28 (13:30) -
10/29 (08:00)


18 hr 30 min.

- Quick Controlled Shutdown (due to clinker formation and completely plugging in overflow line)
 - a. Changed convey and reactor air to N₂.
 - b. Turned off coal feeder and N₂ preheater.
 - c. Bypassed steam from reactor.
 - d. Weighed and secured all barrels of solids.
 - e. Shut off portable boiler and incinerator.

- f. Transferred all solids from silo through batch into feed hopper.
- g. Blew out all vent lines with HV-950 for 10 sec.
- h. Shut all N₂ and air header valves.
- i. Removed the center (3/4") feed nozzle from reactor bottom.
- j. Calibrated coal feeder ("A") with Montana #7 coal.
- k. Dropped the reactor bottom and found a few clinkers adhered on the reactor wall and filled up the insert.


Total Gasification Time = 95 hr 44 min.
Entire Test Period = 128 hrs.

Test Matrix Time = 94 hr 30 min.
No. of Test Periods = 11



APPENDIX 3

DAILY PROCESS VARIABLE PLOTS




The following trend charts were created for runs 94MGC07 through 94MGC10. Although the charts contain several process variables, only FIR-501, TIR-248, TIR-224, PIR-247, PIR-458 and, PDIR- (also shown as PDT- or PIR-)155 and 459 are relevant. The table below provides a description of each of these process variables.


<u>Process Variable</u>	<u>Description</u>
FIR-501	Cumulative syngas volumetric flow rate to the filtration vessel and the particle measurement system
TIR-248	Inlet gas temperature of the filtration vessel
TIR-224	Outlet gas temperature of the filtration vessel
PIR-247	Inlet gas pressure of the filtration vessel
PIR-458	Filter blowback pressure
PDIR-155	Differential pressure of the filtration vessel
PDIR-459	Differential pressure of the filter

All other process variables may be referenced through the process and instrumentation diagrams provided.

Since the needs of the project have changed somewhat from run to run, the trend charts have also changed somewhat. However, these changes are not major ones and the charts have been separated by run number and arranged in the order listed above for convenience.




94MGC07
(06/06/94 - 06/15/94)




MGCR INLET AND EXIT FLOWS

94MGC07 - 06/06/94




MGR INLET AND EXIT FLOWS


94MGC07 - 06/07/94




MGCR INLET AND EXIT FLOWS
 94MGCC07 - 06/08/94



MGCR INLET AND EXIT FLOWS
94MGCC07 - 06/09/94




MGCR INLET AND EXIT FLOWS 94MGC07 - 06/10/94




MGCR INLET AND EXIT FLOWS

94MGC07 - 06/11/94




MCCR INLET AND EXIT FLOWS

94MGC07 - 06/12/94




MCCR INLET AND EXIT FLOWS

94MGC07 - 06/13/94




MGCR INLET AND EXIT FLOWS

94MGCC07 - 06/14/94




MGCR INLET AND EXIT FLOWS

94MGC07 - 06/15/94




MGCR PROCESS GAS LINE TEMPERATURES
 94MGCC07 - 06/06/94




MGCRC PROCESS GAS LINE TEMPERATURES

94MGC07 - 06/07/94




MGCR PROCESS GAS LINE TEMPERATURES 94MGC07 - 06/08/94




MGCR PROCESS GAS LINE TEMPERATURES

94MGCC07 - 06/09/94




MGCR PROCESS GAS LINE TEMPERATURES


94MGC07 - 06/10/94



MGCR PROCESS GAS LINE TEMPERATURES 94MGC07 - 06/11/94




MGCR PROCESS GAS LINE TEMPERATURES 94MGC07 - 06/12/94




MGCR PROCESS GAS LINE TEMPERATURES

94MGCC07 - 06/13/94




MGCR PROCESS GAS LINE TEMPERATURES
94MGC07 - 06/14/94




MGCR PROCESS GAS LINE TEMPERATURES

94MGC07 - 06/15/94




FBG & MCCR PROCESS PRESSURES

94FBG07 - 94MGC07 - 06/06/94



FBG & MGCR PROCESS PRESSURES

94FBG07 - 94MGC07 - 06/07/94



FBG & MGCR PROCESS PRESSURES

94FBG07 - 94MGC07 - 06/08/94






Chart1 (4)

FBG & MCCR PROCESS PRESSURE
RUN 07, 06/09/94



A3-26
PSIG


FBG & MGCR PROCESS PRESSURE
RUN 07, 06/10/94



A3-27
PSIG


Chart1 (6)

FBG & MGR PROCESS PRESSURE
RUN 07, 06/11/94



A3-28


FBG & MGCR PROCESS PRESSURE
RUN 07, 06/12/94




A3-29

FBG & MGCR PROCESS PRESSURES


94FBG07 - 94MGC07 - 06/13/94




FBG & MGCR PROCESS PRESSURES
 94FBG07 - 94MGC07 - 06/14/94




FBG & MGCRCR PROCESS PRESSURES
94FBG07 - 94MGC07 - 06/15/94




MGCR F-100 DIFFERENTIAL PRESSURE
94MGCC07 - 06/06/94




MGCR F-100 DIFFERENTIAL PRESSURE
94MGCC07 - 06/07/94




MGCR F-100 DIFFERENTIAL PRESSURE
94MGCC07 - 06/08/94




MGCR F-100 DIFFERENTIAL PRESSURE
94MGC07 - 06/09/94



MGCR F-100 DIFFERENTIAL PRESSURE
94MGCC07 - 06/10/94




MGCR F-100 DIFFERENTIAL PRESSURE
94MGC07 - 06/11/94




◆ PDIR-155
□ PDIR-459


MGCR F-100 DIFFERENTIAL PRESSURE
94MGCC07 - 06/12/94




MGCR F-100 DIFFERENTIAL PRESSURE
94MGC07 - 06/13/94



MGCR F-100 DIFFERENTIAL PRESSURE
94MGC07 - 06/14/94




MGCR F-100 DIFFERENTIAL PRESSURE
94MGCC07 - 06/15/94




A3-42

◆ PDIR-155
■ PDIR-459


94MGC08
(07/18/94 - 07/27/94)



MGCR Inlet and Exit Flows
Run 94MGC08, 07/18/94




MGCR Inlet and Exit Flows
Run 94MGC08, 07/19/94




◆ FIR501-R
■ FIR-260
▲ FIR-211

MGCR Inlet and Exit Flows
Run 94MGCC08, 07/20/94




MGCR Inlet and Exit Flows
Run 94MGCC08, 07/21/94




◆ FIR501-R
■ FIR-260
▲ FIR-211

MGCR Inlet and Exit Flows
Run 94MGCC08, 07/22/94




◆ FIR501-R
□ FIR-260
▲ FIR-211

MGCR Inlet and Exit Flows
Run 94MGCC08, 07/23/94




◇ FIR501-R
□ FIR-260
△ FIR-211

MGCR Inlet and Exit Flows
Run 94MGCC08, 07/24/94



A3-50
Flow (SCFH)


MGCR Inlet and Exit Flows
Run 94MGCC08, 07/25/94




◆ FIR-301-R
■ FIR-260
▲ FIR-211

15-3-A


MGCR Inlet and Exit Flows
Run 94MGCC08, 07/26/94




MGCR Inlet and Exit Flows
Run 94MGC08, 07/27/94




MGCR Process Gas Line Temperatures
Run 94MGCC08, 07/18/94




MGCR Process Gas Line Temperatures
Run 94MGC08, 07/19/94




MGCR Process Gas Line Temperatures
Run 94MGC08, 07/20/94




MGCR Process Gas Line Temperatures
Run 94MGCC08, 07/21/94



MGCR Process Gas Line Temperatures
Run 94MGCC08, 07/22/94




MGCR Process Gas Line Temperatures
Run 94MGC08, 07/23/94




◆ TIR-224B
■ TIR-248B
▲ TIR-320B
× TIR-318B


MGCR Process Gas Line Temperatures
Run 94MGCC08, 07/24/94




MGCR Process Gas Line Temperatures
Run 94MGC08, 07/25/94




MGCR Process Gas Line Temperatures
Run 94MGC08, 07/26/94




MGCR Process Gas Line Temperatures
Run 94MGC08, 07/27/94



MGCR and FBG Process Pressures
 Run 94MGCC08, 07/18/94




MGCR and FBG Process Pressures
Run 94MGC08, 07/19/94



PIR-713
PIR-254
PIR-247
PIR-458


MGCR and FBG Process Pressures Run 94MGC08, 07/20/94




99-66

□ PIR-713
○ PIR-254
△ PIR-247
◇ PIR-458

MGCR and FBG Process Pressures
Run 94MGCC08, 07/21/94




MGCR and FBG Process Pressures
Run 94MGCC08, 07/22/94




—□— PIR-713
—○— PIR-254
—△— PIR-247
—◇— PIR-458


MGCR and FBG Process Pressures Run 94MGC08, 07/23/94



MGCR and FBG Process Pressures
Run 94MGCC08, 07/24/94



MGCR and FBG Process Pressures
Run 94MGC08, 07/25/94




□ PIR-713
○ PIR-254
△ PIR-247
◇ PIR-458

A3-71
Pressure (psig)


Time

MGCR and FBG Process Pressures
Run 94MGCC08, 07/26/94




□ PIR-713
○ PIR-254
△ PIR-247
◇ PIR-458


MGCR and FBG Process Pressures Run 94MGC08, 07/27/94




F-100 Differential Pressure
Run 94MGC08, 07/18/94




F-100 Differential Pressure
Run 94MGC08, 07/19/94




F-100 Differential Pressure
Run 94MGC08, 07/20/94




F-100 Differential Pressure
Run 94MGCC08, 07/21/94




F-100 Differential Pressure
Run 94MGC08, 07/22/94




F-100 Differential Pressure
Run 94MGC08, 07/23/94




F-100 Differential Pressure
Run 94MGC08, 07/24/94




F-100 Differential Pressure
Run 94MGC08, 07/25/94




F-100 Differential Pressure
Run 94MGC08, 07/26/94




F-100 Differential Pressure
Run 94MGC08, 07/27/94




94MGC09
(09/12/94 - 09/16/94)




MGCR Inlet and Exit Flows
Run 94MGCC09, 09/12/94




MGCR Inlet and Exit Flows
Run 94MGCC09, 09/13/94




MGCR Inlet and Exit Flows
Run 94MGCC09, 09/14/94




MGCR Inlet and Exit Flows
 Run 94MGCC09, 09/15/94




MGCR Inlet and Exit Flows
Run 94MGCC09, 09/16/94




MGCR Process Gas Line Temperatures
Run 94MGC09, 09/12/94




MGCR Process Gas Line Temperatures
Run 94MGC09, 09/13/94




MGCR Process Gas Line Temperatures
Run 94MGCC09, 09/14/94




MGCR Process Gas Line Temperatures
Run 94MGCC09, 09/15/94




MGCR Process Gas Line Temperatures
Run 94MGCC09, 09/16/94




FBG and MGCRCR Process Pressures
Run 94FBG09, 09/12/94




FBG and MGCR Process Pressures
Run 94FBG09, 09/13/94



FBG and MGCR Process Pressures
Run 94FBG09, 09/14/94




**FBG and MGCRCR Process Pressures
Run 94FBG09, 09/15/94**




A3-98

FBG and MGCR Process Pressures
Run 94FBG09, 09/16/94




F-100 Differential Pressure
Run 94MGC09, 09/12/94




◆ PDIR-155
■ PDIR-459


F-100 Differential Pressure
Run 94MGC09, 09/13/94




F-100 Differential Pressure
Run 94MGC09, 09/14/94




F-100 Differential Pressure
Run 94MGC09, 09/15/94




F-100 Differential Pressure
Run 94MGC09, 09/16/94




94MGC10
(10/24/94 - 10/28/94)




FBG EXIT FLOWS
RUN 94FBG10, 10/24/94



FBG EXIT FLOWS
RUN 94FBG10, 10/25/94




FBG EXIT FLOWS
RUN 94FBG10, 10/26/94




FIR501-R
FIR755-R

FBG EXIT FLOWS
RUN 94FBG10, 10/27/94




FIR501-R
FIR755-R


FBG EXIT FLOWS
RUN 94FBG10, 10/28/94




MGCR Process Gas Line Temperatures
Run 94MGC10, 10/24/94




MGCR Process Gas Line Temperatures
Run 94MGC10, 10/25/94




MGCR Process Gas Line Temperatures
Run 94MGC10, 10/26/94




MGCR Process Gas Line Temperatures
Run 94MGC10, 10/27/94




MGCR Process Gas Line Temperatures
Run 94MGC10, 10/28/94




FBG & MGCR Process Pressures
Run 94MGC10, 10/24/94



FBG & MGCR Process Pressures
Run 94MGC10, 10/25/94




FBG & MGCR Process Pressures
Run 94MGC10, 10/26/94




PIR-247
PIR-458

FBG & MGCR Process Pressures
Run 94MGC10, 10/27/94




PIR-247
PIR-458


FBG & MGCR Process Pressures
Run 94MGC10, 10/28/94




F-100 Differential Pressure
Run 94MGC10, 10/24/94




F-100 Differential Pressure
Run 94MGC10, 10/25/94




F-100 Differential Pressure
Run 94MGC10, 10/26/94



F-100 Differential Pressure
Run 94MGC10, 10/27/94




F-100 Differential Pressure
Run 94MGC10, 10/28/94




Appendix 4


Process and Instrumentation Drawings

1





ZONE	REV	
GEN.	6	MODIFIED
DRAFTER Gary Kulchock		DA 5/
EG&G ESMH W. E. Lowry		DA 5/
ZONE	REV	
GEN.	7	MODIFIED
DRAFTER TERRY MCKISIC		DA 8
EG&G ESMH		DA
ZONE	REV	
GEN.	8	MODIFIED
DRAFTER <i>W. E. Lowry</i>		DA 11/
EG&G ESMH <i>W. E. Lowry</i>		DA



TO OUTLET
FILTRATION

REVISION


NO	REV	DESCRIPTION						DATE
EN.	6	MODIFIED AS PER MARKED PRINT; ISSUED FOR CONSTRUCTION						5/12/94
OWNER		DATE	CHECKER	DATE	EG&G RESPONSIBLE ENGR.	DATE	REVIEWER	DATE
		5/18/94	S. Conko	5/18/94	Dave Lunfeld	5/24/94		
OWNER		DATE	PROJECT ENGR.	DATE	BRANCH MANAGER	DATE	DOE (EESD)	DATE
		5/24/94	S. Renninger	5/18/94	John Rockey	5/18/94	WJA John Rotunda	5/18/94
NO	REV	DESCRIPTION						DATE
EN.	7	MODIFIED AS PER MARKED PRINT; ISSUED FOR CONSTRUCTION						8/17/94
OWNER		DATE	CHECKER	DATE	EG&G RESPONSIBLE ENGR.	DATE	REVIEWER	DATE
		8/17/94	GARY KULCHOCK	8/17/94	Dave Lunfeld	8/17/94		
OWNER		DATE	PROJECT ENGR.	DATE	BRANCH MANAGER	DATE	DOE (EESD)	DATE
			JOHN M. ROCKEY	8/18/94	JOHN M. ROCKEY	8/18/94	WJA John Rotunda	8/18/94
NO	REV	DESCRIPTION						DATE
EN.	8	MODIFIED AS PER MARKED PRINT; ISSUED FOR CONSTRUCTION						9/30/94
OWNER		DATE	CHECKER	DATE	EG&G RESPONSIBLE ENGR.	DATE	REVIEWER	DATE
		10-3-94	<i>Gary Kulchok</i>	10/3/94	<i>D. Lunfeld</i>	10/5/94		
OWNER		DATE	PROJECT ENGR.	DATE	BRANCH MANAGER	DATE	DOE (EESD)	DATE
			<i>John M. Rockey</i>	10/2/94			<i>WJA</i>	10/5/94


H



G

F


E









600 PSIG





CV 27 F.C.





E




[

FROM
F-100







THERMOCOUPLE WELL
PRESSURIZATION




JACKET PURGE

V-100
BATCH REACTOR








NOTES:

1. ALL IMPULSE LINES ARE 3/8"
2. PREV. BLOCK RANGE (0-425)
3. CURRENT BLOCK RANGE (451
4. LAST POINT NUMBER USED 30
5. LAST TAG NUMBER USED 493

THIS DRAWING IS PART OF THE EG&G DOCUMENT CONTROL SYSTEM


REFERENCE DRAWINGS	DRAFTER	Jimmy Thorton	DATE	10/28/93	
	PROJECT ENGINEER	John Rockey	DATE	11/2/93	
	REQUESTOR	John Rockey	DATE	11/2/93	
	BRANCH MANAGER	Larry Strickland	DATE	11/2/93	
	ES&H		DATE		
	DDE	WJA John Rotunda	DATE	10/28/93	
			DATE		
		DATE		TITLE	B-12 AI MODU PRE DR
		DATE		SIZE	E
		DATE		FSCM NO	

C


CONNECT WITH RESEARCH
 TRIANGLE INSTITUTE (RTI)
 DWG. No. ZTFBD_01

DWG NO
 STD920080.08
 SH
 1


IMPULSE LINES ARE 3/8 UNLESS OTHERWISE NOTED.
 EV. BLOCK RANGE (0-425).
 RRENT BLOCK RANGE (451-499) P&ID's 1,2,3,6.
 ST POINT NUMBER USED 36.
 ST TAG NUMBER USED 493.

DRAFTER Jimmy Thorton	DATE 10/28/93	 United States Department of Energy MORGANTOWN ENERGY TECHNOLOGY CENTER Morgantown, WV			
PROJECT ENGINEER John Rockey	DATE 11/2/93				
REQUESTOR John Rockey	DATE 11/2/93				
BRANCH MANAGER Larry Strickland	DATE 11/2/93	TITLE B-12 ADVANCED GASIFICATION FACILITY MODULAR GAS CLEANUP RIG (MGCR) PROCESS AND INSTRUMENTATION DRAWING (P&ID1) BATCH MODE			
DOE WJA John Rotunda	DATE 10/28/93				
	DATE	SIZE E	FSCM NO	DWG NO STD920080.08	REV 8

A



VENT



H=24.5 IN. H₂O

F-25
FIL. BLOWBACK

SET 400 PSIG

FOR CONTINUOUS MODE OPERATIONS


23/80(5)23 3/8" SS TUBE P288 SCH STD

24/80(5)24 3/8" SS TUBE P286 SCH STD

25/80(5)25 3/8" SS TUBE P285 SCH STD

26/80(5)26 3/8" SS TUBE P284 SCH STD

0-4000 SCFH AT 425 PSIG AND 60 DEGF



FROM
PSL-152

80(3)22/80(2)22

FROM
ESD

80(6)18/80(2)18

F-1C
FILTE
PURC

3/8" SS TUBE
P30 SCH STD

80(2)2/80(3)2

3/8" SS TUBE
P31 SCH STD

80(2)3/80(3)3

3/8" SS TUBE
P32 SCH STD

80(2)4/80(3)4


3/8" SS TUBE
P33 SCH STD

80(2)5/80(3)5

HV
482


AIR 100PSIG

ZONE	REV	
GEN.	6	MODIFIED AS PER MARKED PRINT
DRAFTER	DATE	CHECKER
GARY J. KULCHOCK	5/18/94	S. CONKO
EG&G ESH	DATE	PROJECT ENGR.
W.E. LOWRY	5/24/94	S. RENNINGE
ZONE	REV	
GEN.	7	MODIFIED AS PER MARKED PRINT
DRAFTER	DATE	CHECKER
<i>Gary J. Kulchock</i>	10-3-94	<i>Gary J. Kulchock</i>
EG&G ESH	DATE	PROJECT ENGR.
<i>William E. Lowry</i>	10/11/94	<i>Scott Kane</i>



REVISION

LINE	REV	DESCRIPTION	DATE			
6		MODIFIED AS PER MARKED PRINT; ISSUED FOR CONSTRUCTION	5/13/94			
DATE	CHECKER	DATE	EG&G RESPONSIBLE ENGR.	DATE	REVIEWER	DATE
5/18/94	S. CONKO	5/18/94	DAVID LUNIFELD	5/24/94		
DATE	PROJECT ENGR.	DATE	BRANCH MANAGER	DATE	DOE CEESD	DATE
5/24/94	S. RENNINGER	5/18/94	JOHN M. ROCKEY	5/18/94	JOHN R. ROTUNDA	5/18/94
DATE	DATE	DATE	DATE	DATE	DATE	DATE
7		MODIFIED AS PER MARKED PRINT; ISSUED FOR CONSTRUCTION	9/30/94			
DATE	CHECKER	DATE	EG&G RESPONSIBLE ENGR.	DATE	REVIEWER	DATE
10-3-94	<i>David Lunifeld</i>	10/3/94	<i>David Lunifeld</i>	10/5/94		
DATE	PROJECT ENGR.	DATE	BRANCH MANAGER	DATE	DOE CEESD	DATE
10/11/94	<i>S. Renninger</i>	10/14/94			<i>[Signature]</i>	10/15/94



H


G


F


F

F

D







0 DEGF

0-600 PSIG

TE 77A TE 77B TIR 77

PT 76 PIR 76

CCv=1.84 ACv=2.0 FV FC 68

50 SCFH 25 PSIG 60 DEGF

0-600 PSIG

TE 74

PT 73 PIR 73

FV FC 72 CCv=0.037 ACv=0.053

80(2)29/08(0)29

HV 23

VESSEL PURGE AND THERMOCOUPLE PRESSURIZATION


1/2" SS TUBE P179 SCH STD


80(2)7/80(1)7

TO LOCKHOPPERS




80(2)31/930031


FSV 454






FROM
ESD





N2 6



C







B

FOR USE WITH CONTINUOUS MODE











THIS DRAWING IS PA
 OF THE EG&G DOCUME
 CONTROL SYSTEM

TE
187



NOTES:

1. ALL IMPULSE LINES 3/8"SS UNLESS OTHERW
- 2.
- 3.

REFERENCE DRAWINGS	DRAFTER Jimmy Thorton	DATE 10/28/93	 United S MORGANTOW	
	PROJECT ENGINEER John Rockey	DATE 11/2/93		
	REQUESTOR John Rockey	DATE 11/2/93		
	BRANCH MANAGER Larry Strickland	DATE 11/2/93		
	ES&H	DATE		
	DDE WJA John Rotunda	DATE 10/28/93		
	DATE	DATE	TITLE B-12 ADVANCED MODULAR GAS PROCESS ANI DRAWING (P&ID2)	
	DATE	SIZE E	FSCM NO	DVG NO S

DRAWING IS PART
THE EG&G DOCUMENT
CONTROL SYSTEM

TE
187

80(2)6/80(3)6

N2 PREHEAT AND FLUIDIZING


208VAC

NOTES:


1. ALL IMPULSE LINES 3/8" SS UNLESS OTHERWISE NOTED
- 2.
- 3.

C


DWG NO
STD920080.07
SH
2


DRAFTER Jimmy Thorton		DATE 10/28/93	 <p style="text-align: center;">United States Department of Energy MORGANTOWN ENERGY TECHNOLOGY CENTER Morgantown, WV</p>
PROJECT ENGINEER John Rockey		DATE 11/2/93	
REQUESTOR John Rockey		DATE 11/2/93	
BRANCH MANAGER Larry Strickland		DATE 11/2/93	
DOE WJA John Rotunda		DATE 10/28/93	<p style="text-align: center;">TITLE: B-12 ADVANCED GASIFICATION FACILITY MODULAR GAS CLEANUP RIG (MGCR) PROCESS AND INSTRUMENTATION DRAWING (P&ID2) FACILITY SERVICES</p>
SIZE E	FSCM NO	DWG NO STD920080.07	

A



TO BE ADDED FOR CONTINUOUS MODE






ZONE	REV	
GEN.	6	1
DRAFTER GARY J. KULCHI EGLG ESH		
W.E. LOWRY		
ZONE	REV	
GEN.	7	
DRAFTER <i>W.E. Lowry</i>		
EGLG ESH <i>W.E. Lowry</i>		

FROM GAS SAMPLING SYSTEM



HV 209



3/4" CS PIPE
P48 SCH 40

3/4" CS PIPE
P47 SCH 40

1/2" SS TUBE
P12 SCH STD

TI 193

TE 193A

TE 193B

FROM PIC



REVISION

NO.	REV	DESCRIPTION						DATE
EN.	6	MODIFIED AS PER MARKED PRINT; ISSUED FOR CONSTRUCTION						5/16/94
BY		DATE	CHECKER	DATE	EG&G RESPONSIBLE ENGR.	DATE	REVIEWER	DATE
		5/18/94	S. CONKO	5/18/94	DAVID LUNIFELD	5/24/94	GARY J. KULCHOCK	5/18/94
BY		DATE	PROJECT ENGR.	DATE	BRANCH MANAGER	DATE	DOE CEISSD	DATE
		5/24/94	S. RENNINGER	5/18/94	JOHN M. ROCKEY	5/18/94	WJA JOHN R. ROTUNDA	5/18/94
NO.	REV	DESCRIPTION						DATE
EN.	7	MODIFIED AS PER MARKED PRINT; ISSUED FOR CONSTRUCTION						9/30/94
BY		DATE	CHECKER	DATE	EG&G RESPONSIBLE ENGR.	DATE	REVIEWER	DATE
		10-3-94	<i>Gary J. Kulchock</i>	10/3/94	<i>David Lunifeld</i>	10/5/94		
BY		DATE	PROJECT ENGR.	DATE	BRANCH MANAGER	DATE	DOE CEISSD	DATE
		10/10/94	<i>Scott Renninger</i>	10/19/94			WJA <i>John R. Rotunda</i>	10/5/94

H

PROC.H20 RETURN


G

FROM PIC-254


FROM ESD


80(121/80(6)21

ASHH
323





F







HV
202










TO
F-100
OUTLET


80(6)27/80(3)27



FROM
CONT
MODE

80(5)28/80(6)28

1/2" SS TUBE
P9 SCH STD



ZS
352B

ZI
352B

HCV
352B
FD

FROM
BATCH
MODE

80(1)16/80(6)16

1/2" SS TUBE
P9A SCH STD



ZS
351B



ZI
351B


HCV
351B
FD


C

B

A









DRUM 1
COND. COLLECTION
3' x 2'

80(27/80(1)7

THIS OF

FROM SHT. 3




NOTES:

1. ALL IMPULSE LINES ARE 3/8" SS TUBING UNLESS OTHERWISE NOTED.
- 2.
- 3.

FORM
CS

THIS DRAWING IS PART OF THE EG&G DOCUMENT CONTROL SYSTEM

REFERENCE DRAWINGS	DRAFTER Jimmy Thorton	DATE 10/28/93	 MORE
	PROJECT ENGINEER John Rockey	DATE 11/2/93	
	REQUESTOR John Rockey	DATE 11/2/93	
	BRANCH MANAGER Larry Strickland	DATE 11/2/93	
	ES&H	DATE	
	DOE WJA John Rotunda	DATE 10/28/93	
	DATE	TITLE B-12 ADVAN MODULAR PROCESS ANI (P&IDE	
	DATE	SIZE E	FSC# NO

FROM SHT. 3

FSV
457

1' CS PIPE
P19 SCH 40

INCINERATOR

FSV
486


INCINERATOR

1" S.S.

C

STD920080.07 6


ALL LINES ARE 3/8" SS TUBING UNLESS OTHERWISE NOTED.


DRAFTER Jimmy Thorton	DATE 10/28/93	 United States Department of Energy MORGANTOWN ENERGY TECHNOLOGY CENTER Morgantown, WV			
PROJECT ENGINEER John Rockey	DATE 11/2/93				
REQUESTOR John Rockey	DATE 11/2/93				
BRANCH MANAGER Larry Strickland	DATE 11/2/93	TITLE: B-12 ADVANCED GASIFICATION FACILITY MODULAR GAS CLEANUP RIG (MGCR) PROCESS AND INSTRUMENTATION DRAWING (P&ID6) OUTLET FILTRATION			
DOE WJA John Rotunda	DATE 10/28/93				
	DATE				
	DATE	SIZE E	FSCH NO	DWG NO STD920080.07	REV 7


A

H


G







ZONE	REV	
GEN	0	ISSUED FOR CONSTRUCT
ZONE	REV	
GEN.	1	MODIFIED AS PER MARKED
DRAFTER	DATE	CHECKER
GARY J. KULCHOCK	6/30/94	S. CONK
ES&H	DATE	DOE (GDSD)
J.L. BUCKLEW	6/30/94	EDWIN
ZONE	REV	
GEN.	2	MODIFIED AS PER MARKED
DRAFTER	DATE	CHECKER
<i>Gary J. Kulchok</i>	8/15/95	<i>S. Con</i>
ES&H	DATE	DOE (GDSD)
<i>J.L. Bucklew</i>	9/8/95	<i>gjk</i>



Δ†


REVISION

ZONE	REV	DESCRIPTION	DATE				
GEN	0	ISSUED FOR CONSTRUCTION	5/25/94				
ZONE	REV	DESCRIPTION	DATE				
GEN.	1	MODIFIED AS PER MARKED PRINT. ISSUED FOR CONSTRUCTION	6/24/94				
AFTER	DATE	CHECKER	DATE	DESIGNER	DATE	RESPONSIBLE PERSON	DATE
GARY J. KULCHOCK	6/30/94	S. CONKO	6/30/94	C. ELAINE EVERITT	6/30/94		
BY	DATE	DOE (CDS/D)	DATE		DATE		DATE
J.L. BUCKLEW	6/30/94	EDWIN GALLOWAY	6/30/94	ROBERT ROMANOSKY	7/1/94	JOHN ROTUNDA	6/30/94
ZONE	REV	DESCRIPTION	DATE				
GEN.	2	MODIFIED AS PER MARKED PRINT. ISSUED FOR CONSTRUCTION	8/15/95				
AFTER	DATE	CHECKER	DATE	DESIGNER	DATE	RESPONSIBLE PERSON	DATE
<i>[Signature]</i>	8/15/95	<i>S. Conko</i>	8-15-95	<i>[Signature]</i>	8/30/95	<i>Rich Pineault</i>	9/1/95
BY	DATE	DOE (CDS/D)	DATE		DATE		DATE
<i>V.E. Loney</i>	9/8/95	<i>[Signature]</i>	9/8/95				

H



G

F




208 VAC

PREHEAT NITROGEN
425 PSIG



M

D




50 PSIG

CV 258B
FD

TE 439B
TE 439A

TI 439

PIR 430
F 431



JZ 440

7

SET @ 1150° F

SET @ 1125° F

TE 440A
TE 440B

TIC 440

TAH 440

TE 147A
TE 447B

TAHH 448 1150° F
TAH 448 1125° F

120 VAC

FD 723

FSV 708

SET @ 1150° F

80(2)-30/40(0)-30

d=0.042"

Q = 127 SCFH
P = 20 PSIG
T = 70° F

FI 441


TE 448B
TE 448A


TSHH 448

I-30

JZ 431

LINE HEATERS
HTR-448





SCFH
PSIG
F

CELL
#2

TE 605B TE 605A

TIR 605

$\Delta H=0-10'$
 H_2O
FT 606 FI 606

TYPE K

TE 429A TE 429B

TIR 429

1150° F

TAHH 607

1125° F

TAH 607

TI 607

TIR 607

TE 607B TE 607A

PROBE #2

1/4" TUBE-SS

PSV 449

SET @
50 PSIG
400° F

OUT OF SERVICE

MOTT
FILTER
XE-614

CALC Cv=0.48
INSTALLED Cv=1.0


I/P


FY 606


FV 606


FD

IR









NOTES:

(1) "NOTE REMOVED"

(2) "NOTE REMOVED"

3 SUPPLIED BY AMES

(4) PREV. TAG # BLOCK RANGE ALLOCATED FOR THIS P&ID:
425-450, 600-650, 701-725
CURRENT BLOCK RANGE 800-850


(5) LAST TAG No. USED: HV-826


6 COMMERCIALY PURCHASED UNIT: MODEL No. PMS CSASP F

7 COMMERCIALY PURCHASED UNIT: MODEL LINDBERG; TYPE

(8) TIR-609 AND FIR-611 ARE USED FOR MASS FLOW CALCUL



PMS-432 PARTICLE MONITOR





REDRAWN FROM


ECN NO	DESCRIPTION	REFERENCE DRAWINGS	DRAFTER
1			Gary Kulchc
2			S. Conko
			DESIGNER Dave Lunife
			RESPONSIBLE PERSON -NA-
			ES&H





C


DWG NO
E940040
SH
1

OWN FROM DRAWINGS STD930075 AND STD930008
WITH CHANGES

DRAFTER Gary Kulchock	DATE 5/26/94	 <p>United States Department of Energy MORGANTOWN ENERGY TECHNOLOGY CENTER Morgantown, WV</p>
CHECKER S. Conko	DATE 5/26/94	
DESIGNER Dave Lunifeld	DATE 5/26/94	
RESPONSIBLE PERSON -NA-	DATE -NA-	
		TITLE: BUILDING 12 MGECP PARTICLE MEASURING







ZONE
GEN.
DRAFTER GARY
EG&G ESI W.E. I
ZONE
GEN.
DRAFTER <i>C.D.</i>
EG&G ESI <i>N.O.</i>

GASIFIER

SIDESTREAM

TO 1-3



SET 340
PSIG



80(3)22/80(2)22

SET 250
PSIG




REVISION

ZONE	REV	DESCRIPTION						DATE
GEN.	6	MODIFIED AS PER MARKED PRINT; ISSUED FOR CONSTRUCTION						5/16/94
DRAFTER		DATE	CHECKER	DATE	EG&G RESPONSIBLE ENGR.	DATE	REVIEWER	DATE
GARY J. KULCHOCK		5/18/94	S. CONKO	5/18/94	DAVID LUNIFELD	5/24/94		
EG&G ES&H		DATE	PROJECT ENGR.	DATE	BRANCH MANAGER	DATE	DOE CEESID	DATE
W.E. LOWRY		5/24/94	S. RENNINGER	5/18/94	JOHN M. ROCKEY	5/18/94	WJA JOHN R. ROTUNDA	5/18/94
ZONE	REV	DESCRIPTION						DATE
GEN.	7	MODIFIED AS PER MARKED PRINT; ISSUED FOR CONSTRUCTION						9/30/94
DRAFTER		DATE	CHECKER	DATE	EG&G RESPONSIBLE ENGR.	DATE	REVIEWER	DATE
<i>W. Klein</i>		10-3-94	<i>David Lunifeld</i>	10/3/94	<i>David Lunifeld</i>	10/5/94		
EG&G ES&H		DATE	PROJECT ENGR.	DATE	BRANCH MANAGER	DATE	DOE CEESID	DATE
<i>W.E. Lowry</i>		10/11/94	<i>Scott Jennings</i>	10/11/94			<i>WJA</i> <i>C.L. L.C. L.C.</i>	10/15/94


H



G


TO BE ADDED FOR CONTINUOUS MODE OPERATIONS






F




















TO ALKALI
SAMPLE SYSTEM
AND PMS SYSTEM



0-600 PS:




FROM N2
PREHEATERS



C


B

A

FROM PIC-254
V-100 OUTLET








REFERENCE DR


THIS DRAWING IS PART
OF THE EG&G DOCUMENT
CONTROL SYSTEM




NOTES:


1. ALL IMPULSE LINES ARE 3/8" SS UNLESS OTHERWISE NOTED.
- 2.
- 3.


C
DWG NO
STD920080.07
3


DRAFTER	Jimmy Thorton	DATE	10/28/93	 <p>United States Department of Energy MORGANTOWN ENERGY TECHNOLOGY CENTER Morgantown, WV</p>
PROJECT ENGINEER	John Rockey	DATE	11/2/93	
REQUESTOR	John Rockey	DATE	11/2/93	
BRANCH MANAGER	Larry Strickland	DATE	11/2/93	
ESTD		DATE		
DOE	WJA John Rotunda	DATE	10/28/93	
TITLE:				<p>B-12 ADVANCED GASIFICATION FACILITY MODULAR GAS CLEANUP RIG (MGCR) PROCESS AND INSTRUMENTATION DRAWING (P&ID3) GAS TRANSPORT SYSTEM</p>
SIZE	FSCM NO	DWG NO	REV	
E		STD920080.07	7	

A










TO HV 159
DWG. E900011

80 CS



FCV
113

ZONE	REV	
GEN	1	UPDATED AS PER MARKE
GEN		REVISIED PER MARKED F
E-8		REMOVED HV-201 & PI-
B-6,7		RELOCATED LINE BETWEEN
C-8		RELOCATED CAPPED LIN
E-6		ADDED STEAM SITE LIN
B-7,8		ADDED HV-402, 402A, 40
DRAFTER		S.P.C.
		DATE
		12/10/90
		CHEC
		DATE
ZONE	REV	
GEN	2	UPDATED AS PER MARKI
GEN		ADDED NEW DWG. FORM
GEN		UPDATED AS PER MARK
GEN		UPDATED AS PER MARK
B-2		ADDED NOTE 8 AND NC
C-7		MODIFIED FILTER #208
GEN		ISSUED FOR CUSTOMER
DRAFTER		JIMMY SMITH
		DATE
		7/17/92
		CHEC
		GA
EG&G RESPON SECT SUPV		BURTON V. HARRELL
		DATE
		7/20/92
		EG&G
ZONE	REV	
A-1	3	CHANGED DWG. TITLE
GEN		UPDATED AS PER MARK
GEN		ISSUED FOR CONSTRUCT
E-7		ADDED ENTRAINED BOI
G-7		'PI-104' WAS 'PI-105,
F-7		'650 PSIG' ON PAHL-2
D-6	ADDED 'HS-217' TO	
A-8	ADDED NOTE TO 'HV-	
GEN		REVISED DESIGNATION
		BEHIND PANEL
DRAFTER		GARY J. KULCHOCK
		DATE
		11/18/92
		CHEC
EG&G ESHH		J. L. BUCKLEV
		DATE
		11/19/92
		PROJ
ZONE	REV	
GEN	4	REVISED SHTR-201 T
		REMOVED ALL NUMBE
		MODIFIED VARIOUS S
		ADDED FT-406, PT-4
DRAFTER		GARY J. KULCHOCK
		DATE
		4/5/93
		CHEC
EG&G ESHH		J. L. BUCKLEV
		DATE
		4/7/93
		PROJ
ZONE	REV	
GEN	5	ADDED NOTE 10; REV
		REVISED LINETYPE C
		ADDED '#2' TO No. 2
		PAHL-214, 700 PSIG
		ADDED FSV-412, FV-
		ISSUED FOR CONSTR
DRAFTER		Gary Kulchock
		DATE
		9/10/93
		CHEC
EG&G ESHH		Larry Bucklew
		DATE
		9/17/93
		PROJ
ZONE	REV	
GEN	6	EXTENSIVE CHANGES
		ISSUED FOR CONSTRUCT
DRAFTER		<i>Gary J. Kulchock</i>
		DATE
		10/17/94
		CHEC
EG&G ESHH		<i>J. L. Bucklew</i>
		DATE
		10-11-94
		PROJ


REVISION


LINE	REV	DESCRIPTION	DATE
EN		UPDATED AS PER MARKED PRINT	4/25/90
EN	1	REVISED PER MARKED PRINT REMOVED HV-201 & PI-201 REROUTED LINE BETWEEN HV-480 & PCV-308 RELOCATED CAPPED LINE ADDED STEAM SITE LINE, HV & CV ADDED HV-402, 402A, 403A & 404	10/11/90
ENTER	S.P.C.	DATE 12/10/90	CHECKER G.J.K.
		DATE 12/10/90	PROJECT ENGINEER J.P.K.
		DATE 2/13/91	DATE
LINE <th>REV</th> <th>DESCRIPTION</th> <th>DATE</th>	REV	DESCRIPTION	DATE
EN		UPDATED AS PER MARKED PRINT WITH W.D. #68547	10/3/91
EN	2	ADDED NEW DWG. FORMAT UPDATED AS PER MARKED PRINT WITH W.D. #70756	1/10/92
EN		UPDATED AS PER MARKED PRINT WITH WORK PLAN	3/6/92
EN		ADDED NOTE 8 AND NOTE DESIGNATIONS MODIFIED FILTER #208 SYMBOL ISSUED FOR CUSTOMER REVIEW AND COMMENT	7/17/92
ENTER	JIMMY SMITH	DATE 7/17/92	CHECKER GARY J. KULCHOCK
		DATE 7/17/92	EG&G RESPON ENGINEER JAY RUTTEN
		DATE 7/17/92	EG&G REVIEWER D. LUNIFIELD
ENTER	RESPON SECT SUPV	DATE 7/20/92	EG&G ESMH J. L. BUCKLEW
	RTON W. HARRELL	DATE 7/20/92	DATE
LINE <th>REV</th> <th>DESCRIPTION</th> <th>DATE</th>	REV	DESCRIPTION	DATE
EN	3	CHANGED DWG. TITLE UPDATED AS PER MARKED PRINT WITH WORK PLAN ISSUED FOR CONSTRUCTION	9/16/92
EN		ADDED ENTRAINED BOILER, VALVE HV-0601A, AND TIC-201 "PI-104" WAS "PI-105, AND "PI-105" WAS "PI-104" "650 PSIG" ON PAHL-214 WAS "500 PSIG" ADDED "HS-217" TO "JC-217" ADDED NOTE TO "HV-401A" REVISED DESIGNATIONS ON ALL FLOW COMPUTERS FROM "MOUNTED ON PANEL" TO "MOUNTED BEHIND PANEL"	11/16/92
ENTER	GARY J. KULCHOCK	DATE 11/18/92	CHECKER S. CONKO
		DATE 11/18/92	EG&G RESPONSIBLE ENGR. JAY RUTTEN
		DATE 11/19/92	REVIEWER D. LUNIFIELD
ENTER	ESMH L. BUCKLEW	DATE 11/19/92	PROJECT ENGR. JOHN ROCKEY
		DATE 11/19/92	BRANCH MANAGER LARRY STRICKLAND
		DATE 11/24/92	DOE (EISSD) JOHN ROTUNDA
LINE <th>REV</th> <th>DESCRIPTION</th> <th>DATE</th>	REV	DESCRIPTION	DATE
EN	4	REVISED SHTR-201 TO INCLUDE THE MAX. PRESS. AND TEMP. REMOVED ALL NUMBERS FROM ADACS SYMBOLS MODIFIED VARIOUS SCFH RATINGS ADDED FT-406, PT-406, HV-406A, HV-406B, HV-406C, TE-406A, TE-406B, AND ASSOCIATED ADACS SYMBOLS	4/1/93
ENTER	GARY J. KULCHOCK	DATE 4/5/93	CHECKER S. CONKO
		DATE 4/5/93	EG&G RESPONSIBLE ENGR. JAY RUTTEN
		DATE 4/7/93	REVIEWER D. LUNIFIELD
ENTER	ESMH L. BUCKLEW	DATE 4/7/93	PROJECT ENGR. JOHN ROCKEY
		DATE 5/27/93	BRANCH MANAGER LARRY STRICKLAND
		DATE 5/27/93	DOE (EISSD) JOHN ROTUNDA
LINE <th>REV</th> <th>DESCRIPTION</th> <th>DATE</th>	REV	DESCRIPTION	DATE
EN	5	ADDED NOTE 10; REVISED BOLD LINETYPE ON YY-209, PI-207, & PI-208 REVISED LINETYPE ON FV-103; REVISED LINE ROUTING IN ZONE G-6 ADDED "#2" TO N ₂ 2 PLACES PAHL-214, 700 PSIG RATING WAS 650 PSIG ADDED FSV-412, FV-412, AND ASSOCIATED PIPING ISSUED FOR CONSTRUCTION	8/24/93
ENTER	GARY J. KULCHOCK	DATE 9/10/93	CHECKER S. Conko
		DATE 9/14/93	EG&G RESPONSIBLE ENGR. Jay Rutten
		DATE 9/15/93	REVIEWER Dave Lunifeld
ENTER	ESMH Larry Bucklew	DATE 9/17/93	PROJECT ENGR. John Rockey
		DATE 9/21/93	BRANCH MANAGER Larry Shadle
		DATE 9/21/93	DOE (EISSD) John Rotunda/WJA
LINE <th>REV</th> <th>DESCRIPTION</th> <th>DATE</th>	REV	DESCRIPTION	DATE
EN	6	EXTENSIVE CHANGES AS PER MARKED PRINT REDLINED BY JAY RUTTEN ON 15 FEB 94. ISSUED FOR CONSTRUCTION	9/29/94
ENTER	Gary J. Kulchock	DATE 10/17/94	CHECKER S. Conko
		DATE 10-7-94	EG&G RESPONSIBLE ENGR. Jay Rutten
		DATE 10-11-94	REVIEWER Dave Lunifeld
ENTER	ESMH Larry Bucklew	DATE 10-11-94	PROJECT ENGR. John Rockey
		DATE 10/13/94	BRANCH MANAGER Larry Shadle
		DATE 10-18-94	DOE (EISSD) John Rotunda/WJA

H

G

F





VENT
160 LB/HR
578° F 1165 PSIG

MAX. OP. PRESS. 1100 PSIG
MAX. OP. COIL TEMP. 1200°F
10-160 LB/HR
1' SCH 80 316 SS
480V, 12 KW
SHTR-201
STEAM SUPER HEATER
DWG. E810220

OUTSIDE CELL | INSIDE CELL

CONDENSATE TO DRAIN

TEST CONNECTION

ELEMENT

COIL

0-2000 °F

0-2000 °F

1500 °F

1200 °F

600 °F

1/2" 650° F

-1100 PSIG

PUMP 201

MILLIPORE WATER

SUPPLY

500 SIG

PI 4A

PT 14

SITE STEAM

3/8" SS TUBING

1/2"

-1100 PSIG

1"

1/2"

650° F

0-2000 °F

0-2000 °F

1500 °F

1200 °F

600 °F

1/2" 650° F

-1100 PSIG

PUMP 201

MILLIPORE WATER

SUPPLY

500 SIG

PI 4A

PT 14

SITE STEAM

3/8" SS TUBING

1/2"

-1100 PSIG

1"

1/2"

650° F

0-2000 °F

0-2000 °F

1500 °F

1200 °F

600 °F

1/2" 650° F

-1100 PSIG

PUMP 201

MILLIPORE WATER

SUPPLY

500 SIG

PI 4A

PT 14

SITE STEAM

3/8" SS TUBING

1/2"

-1100 PSIG

1"

1/2"

650° F

0-2000 °F

0-2000 °F

1500 °F

1200 °F

600 °F

1/2" 650° F

-1100 PSIG

PUMP 201

MILLIPORE WATER

SUPPLY

500 SIG

PI 4A

PT 14

SITE STEAM

3/8" SS TUBING

1/2"

-1100 PSIG

1"

1/2"

650° F

0-2000 °F

0-2000 °F

1500 °F

1200 °F

600 °F

1/2" 650° F

-1100 PSIG

PUMP 201

MILLIPORE WATER

SUPPLY

500 SIG

PI 4A

PT 14

SITE STEAM

3/8" SS TUBING

1/2"

-1100 PSIG

1"

1/2"

650° F

0-2000 °F

0-2000 °F

1500 °F

1200 °F

600 °F

1/2" 650° F

-1100 PSIG

PUMP 201

MILLIPORE WATER

SUPPLY

500 SIG

PI 4A

PT 14

SITE STEAM

3/8" SS TUBING

1/2"

-1100 PSIG

1"

1/2"

650° F

0-2000 °F

0-2000 °F

1500 °F

1200 °F

600 °F

1/2" 650° F

-1100 PSIG

PUMP 201

MILLIPORE WATER

SUPPLY

500 SIG

PI 4A

PT 14

SITE STEAM

3/8" SS TUBING

1/2"

-1100 PSIG

1"

1/2"

650° F

0-2000 °F

0-2000 °F

1500 °F

1200 °F

600 °F

1/2" 650° F

-1100 PSIG

PUMP 201

MILLIPORE WATER

SUPPLY

500 SIG

PI 4A

PT 14

SITE STEAM

3/8" SS TUBING

1/2"

-1100 PSIG

1"

1/2"

650° F

0-2000 °F

0-2000 °F

1500 °F

1200 °F

600 °F

1/2" 650° F

-1100 PSIG

PUMP 201

MILLIPORE WATER

SUPPLY

500 SIG

PI 4A

PT 14

SITE STEAM

3/8" SS TUBING

1/2"

-1100 PSIG

1"

1/2"

650° F

0-2000 °F

0-2000 °F

1500 °F

1200 °F

600 °F

1/2" 650° F

-1100 PSIG

PUMP 201

MILLIPORE WATER

SUPPLY

500 SIG

PI 4A

PT 14

SITE STEAM

3/8" SS TUBING

1/2"

-1100 PSIG

1"

1/2"

650° F

0-2000 °F

0-2000 °F

1500 °F

1200 °F

600 °F

1/2" 650° F

-1100 PSIG

PUMP 201

MILLIPORE WATER

SUPPLY

500 SIG

PI 4A

PT 14

SITE STEAM

3/8" SS TUBING

1/2"

-1100 PSIG

1"

1/2"

650° F

0-2000 °F

0-2000 °F

1500 °F

1200 °F

600 °F

1/2" 650° F

-1100 PSIG

PUMP 201

MILLIPORE WATER

SUPPLY

500 SIG

PI 4A

PT 14

SITE STEAM

3/8" SS TUBING

1/2"

-1100 PSIG

1"

1/2"

650° F

0-2000 °F

0-2000 °F

1500 °F

1200 °F

600 °F

1/2" 650° F

-1100 PSIG

PUMP 201

MILLIPORE WATER

SUPPLY

500 SIG

PI 4A

PT 14

SITE STEAM

3/8" SS TUBING

1/2"

-1100 PSIG

1"

1/2"

650° F

0-2000 °F

0-2000 °F

1500 °F

1200 °F

600 °F

1/2" 650° F

-1100 PSIG

PUMP 201

MILLIPORE WATER

SUPPLY

500 SIG

PI 4A

PT 14

SITE STEAM

3/8" SS TUBING

1/2"

-1100 PSIG

1"

1/2"



650° F



0-2000 °F

0-2000 °F

1500 °F

1200 °F





TO SHTR-202 STEAM
SUPER HEATER
DWG. E900011

E

D

NOTES:

THIS FLAGGED NOTE DESIGNATES THE FOLLOWING EQUIPMENT
AS BEING OBSOLETE ON THIS DVC FOR CLARITY.

HV 206

HV 207

TO BUILDING SUPPLY

0-2000 PSIG

PI 305

CONTRACTOR SUPPLIED

OXYGEN SUPPLY 1500 PSIG

PI 301

EFV 304

1300 PSIG

PCV 301

HV 303

0-1500 PSIG

PI 403

HV 403

NITROGEN COMPRESSOR SUPPLY 600 PSIG

FSV 402

HV 402

HV 403A

0-1500 PSIG

PI 402

NITROGEN COMPRESSOR SUPPLY 1200 PSIG

0-1500 PSIG

HV 401

PI 401

HV 402A

HV 402C

1/2" SS TUBING

HV 401A

2000-8000 SCFH

HV 401C

FILTER 402

(VALVE OPEN WITH HANDLE REMOVED)

HV 401B

HV 402B

PCV 403

TO ATMOSPHERE


TO PURGE SYSTEM PCV-441
E900013, SHT 2 (A-8)
TO FLOW VALVE, FV-409, E900011 (H-7)


C

B


A

**PURIFICATION SYSTEM
PUR-208**





FH
CS




- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11

REFERENCE DRAWINGS	DRAFTER	S.
	CHECKER	A. R.
	PROJECT EN.	J. P.
E900011		
E900012		
E900013		

THIS DRAWING IS PART OF THE EG&G DOCUMENT CONTROL SYSTEM

- 1 WHICH IS NOT SHOWN ON THIS DWG. FOR CLARITY) PANEL-MOUNTED ON/OFF STATION (HAND SWITCH WITH POSITION INDICATION LAMPS), 24 VDC RELAY, 117 VAC 60 HZ SOLENOID VALVE.
- 2 FV-106 & FV-406 ARE ELECTRICALLY SELECTED BY A PANEL-MOUNTED 2-POSITION TOGGLE SWITCH. ONLY ONE VALVE CAN BE OPEN AT A TIME. REF. PRINT DWG D820030 SHTS 3 & 17.
- 3 HS-106, HS-107, AND HS-109 ARE ELECTRICALLY INTERLOCKED. FV-106 OPENS WHEN EITHER FV-107 OR FV-109 IS OPENED. FV-107 AND FV-109 CAN BOTH BE OPEN AT THE SAME TIME.
- 4 HS-112, HS-113 AND HS-115 ARE ELECTRICALLY INTERLOCKED. FV-112 OPENS WHEN EITHER FV-113 OR FV-115 IS OPENED. FV-113 AND FV-115 CAN BOTH BE OPEN AT THE SAME TIME.
- 5 WATER LEVEL SWITCH CONTROLS RELAY TO 117 VAC 60 HZ 3-WAY SOLENOID VALVE
- 6 LB/HR = (lb mass / hour)
- 7 THIS DWG. & DWGS. E900011, E900012 & E900013 SUPERCEDES DWG. R800524 (SEE DWG. E900013 FOR NOTES, TUBING & PIPING SUMMARY).
- 8 DESIGNATES THE CONTROL PANEL SWITCH IS PHYSICALLY LOCKED TO PREVENT ACCIDENTAL ACTUATION.
- 9 BOILER WATER LEVEL IS CONTROLLED BY 3 CAPACITANCE PROBES. SHORTEST PROBE SHUTS BOILER FEED WATER PUMP OFF. MIDDLE PROBE TURNS BOILER FEED WATER PUMP ON. LONGEST PROBE SHUTS THE BOILER DOWN.
- 10 FV-112 & FV-412 ARE ELECTRICALLY SELECTED BY A PANEL-MOUNTED 2-POSITION TOGGLE SWITCH. ONLY ONE VALVE CAN BE OPEN AT A TIME.
- 11 "NOTE REMOVED"


C
E900010


DRAFTER	S. CONKO	DATE	3/6/90	 United States Department of Energy MORGANTOWN ENERGY TECHNOLOGY CENTER Morgantown, WV
CHECKER	A. R. KUBALA	DATE	3/6/90	
PROJECT ENGINEER	J. P. KANDSKY	DATE	3/6/90	
	—	DATE	—	TITLE: B-12 P&ID FLUIDIZED BED GASIFIER A.G.C., CONCEPTUAL
	—	DATE	—	
	—	DATE	—	
	—	DATE	—	
	—	DATE	—	SIZE FSCM NO E
		DWG NO	E900010	REV 6


H


G

F










REVISION

LINE	REV	DESCRIPTION	DATE				
-1 EN EN	3	CHANGED DWG. TITLE UPDATED AS PER MARKED PRINT WITH WORK PLAN ISSUED FOR CONSTRUCTION	9/16/92				
		RELOCATED SAMPLE SYSTEM TO E900013_SHT_2 REVISED AS PER MARKED PRINT	11/16/92				
TER GARY KULCHOCK	DATE 11/18/92	CHECKER S CONKO	DATE 11/18/92	EG&G RESPON ENGINEER JAY RUTTEN	DATE 11/19/92	EG&G REVIEWER D. LUNIFIELD	DATE 11/19/92
RESPON SECT SUPV NA	DATE	EG&G ES&H J. L. BUCKLEW	DATE 11/19/92	DATE	DATE	JOHN ROTUNDA	DATE 11/24/92
LINE	REV	DESCRIPTION	DATE				
EN	4	ADDED DESIGN PRESS. AND TEMP. TO FDR-601, VSL-602, & VSL-601 ADDED MAX. OPP. PRESS. AND COIL TEMP. TO SHTR-202 AND HTR-101 ADDED PSE-120, REMOVED NUMBERS FROM ALL ADACS SYMBOLS	4/1/93				
TER GARY KULCHOCK	DATE 4/5/93	CHECKER S CONKO	DATE 4/5/93	EG&G RESPONSIBLE ENGR. JAY RUTTEN	DATE 4/7/93	REVIEWER D. LUNIFIELD	DATE 4/7/93
ES&H L. BUCKLEW	DATE 4/7/93	PROJECT ENGR. JOHN ROCKEY	DATE 5/27/93	BRANCH MANAGER LARRY STRICKLAND	DATE 5/27/93	DOE CEESID BILL AYERS	DATE 5/27/93
LINE	REV	DESCRIPTION	DATE				
EN	5	ADDED LT-602A, LT-603A, FSV-601, HV-321 & HV-320; MODIFIED LAHL 602 TO LAH-602 & LAL-602 MODIFIED LAHL 603 TO LAH-603 & LAL-603; ADDED #1 TO N ₂ ADDED NOTE 10 ADDED INCINERATOR NOTES TO (2) INCINERATOR DESIGNATIONS; ADDED NOTE TO VENT SYSTEM (G-4) REMOVED PSE-120, HCV-118, TCV-126 AND RELATED PIPING; RELOCATED FSV-315 ISSUED FOR CONSTRUCTION	9/01/93				
TER Gary Kulchock	DATE 9/10/93	CHECKER S. Conko	DATE 9/14/93	EG&G RESPONSIBLE ENGR. Jay Rutten	DATE 9/15/93	REVIEWER Dave Lunifeld	DATE 9/20/93
ES&H Larry Bucklew	DATE 9/17/93	PROJECT ENGR. John Rockey	DATE 9/21/93	BRANCH MANAGER Larry Shadle	DATE 9/21/93	DOE CEESID John Rotunda/WJA	DATE 9/20/93
LINE	REV	DESCRIPTION	DATE				
EN	6	EXTENSIVE CHANGES AS PER MARKED PRINT REDLINED BY JAY RUTTEN ON 15 FEB 94. ISSUED FOR CONSTRUCTION	8/18/94				
TER <i>Gary Kulchock</i>	DATE 10/7/94	CHECKER <i>S. Conko</i>	DATE 10-7-94	EG&G RESPONSIBLE ENGR. <i>Jay Rutten</i>	DATE 10-11-94	REVIEWER <i>D. Lunifeld</i>	DATE 10/11/94
ES&H <i>Larry Bucklew</i>	DATE 10-11-94	PROJECT ENGR. <i>John M. Rockey</i>	DATE 10/13/94	BRANCH MANAGER <i>Larry Shadle</i>	DATE 10-18-94	DOE CEESID <i>WJA</i>	DATE 10/14/94


H

G




F

F




E


MAX. OP. PRESS. 1100 PSIG
MAX. OP. COIL TEMP. 1200° F
480V, 12 KW
SHTR-202
STEAM SUPER HEATER
DWG. E810220




D


OPEI





0-20





0%

1/2" TUBING

HS 603

A

304 SS
25-150 LB/HR COAL

TO HV 707
DWG. E900012

TO FLUID BED
GASIFIER
DWG. E900012

TO FLUID BED
GASIFIER
DWG. E900012

HV 505


TO FLUID BED

F


E

D


C





B



A







NOTES:

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12

I
F
V
E
F
F
F
I
F
F
C
S
F
F
S
F
L
F
L
T
S
F
I
C

INDICATES THE CONNECTING SEGMENT OF THE TRANSMITTER SYSTEM, WHERE XXX IS THE SEGMENT IDENTIFICATION (SEE DWG. E900013, SHT. 2 OF 2 FOR DETAILS). THIS SYMBOL INDICATES THAT THE FOLLOWING EQUIPMENT IS ON THE PURGE LINE FROM THE NITROGEN HEADER TO THE TRANSMITTER:
TE-319A, FSV-441, HV-441, HV-XXXXP, FV-XXXXP, & FV-XXXXP

INDICATES THE CONNECTING SEGMENT OF THE TRANSMITTER SYSTEM, WHERE XXX IS THE SEGMENT IDENTIFICATION (SEE DWG. E900013, SHT. 2 OF 2 FOR DETAILS). THIS SYMBOL INDICATES THAT THE FOLLOWING EQUIPMENT IS ON THE PURGE LINE FROM THE NITROGEN HEADER TO THE TRANSMITTER:
TE-319A, FSV-441, HV-441, HV-XXXXP, & FSV-XXXXP.

DESIGNATES EQUIPMENT WHICH IS NOT SHOWN ON THIS DWG. FOR CLARITY, PANEL MOUNTED ON/OFF STATION (HAND SWITCH WITH POSITION INDICATION LAMPS), 24VDC RELAY, 117 VAC 60 Hz SOLENOID VALVES.

FV-610 & FV-610A WILL NOT OPEN UNTIL PDT-610 MEASURES A PRESSURE DIFFERENTIAL LESS THAN OR EQUAL TO 10 PSID. REF. DWGS: D820047 SHT 14 & D820030 SHT 9. THE PRESSURE IN VSL-602 MUST BE HIGHER THAN THE PRESSURE IN VSL-603.

RELAY INTERLOCKS DO NOT ALLOW THE TWO PAIRS OF PARALLEL FLOW VALVES (609 & 609A, 610 & 610A) TO BE OPEN AT THE SAME TIME. REFERENCE DRAWING: D920031

THIS DWG. & DWGS. E900010, E900012, & E900013 SUPERCEDES DWG. R800524 (SEE DWG. E900013 FOR NOTES, TUBING AND PIPING SUMMARY).

RELAY INTERLOCKS DO NOT ALLOW FV-602 AND FLOW VALVES 420 OR 427 TO BE OPEN AT THE SAME TIME.

RELAY INTERLOCKS DO NOT ALLOW FV-602 AND THE PAIR OF PARALLEL FLOW VALVES 610 & 610A TO BE OPEN AT THE SAME TIME.

"NOTE DELETED"

DESIGNATES THAT THE CONTROL PANEL SWITCH IS PHYSICALLY LOCKED TO PREVENT ACCIDENTAL ACTUATION.


FV-602 WILL NOT OPEN UNTIL PT-602 MEASURES A PRESSURE LESS THAN 20 PSIG.

THROUGH FV-912 TO VENT SYSTEM VSL-906, DWG. E900013, SHEET 1, (B-3)


INTERLOCKS PREVENT HTR-340 FROM OPERATING UNTIL NITROGEN FLOWS EXCEED 80 SCFH

INTERLOCKS PREVENT HTR-340 FROM OPERATING WHEN THE COIL TEMPERATURE EXCEEDS 500° F


THIS DRAWING IS PART
OF THE EG&G DOCUMENT
CONTROL SYSTEM



TO FLUID BED
GASIFIER
DWG. E900012

REFERENCE DRAWINGS E900010 E900012 E900013	DRAFTER S. CONKO	DATE 3/6/90	 United States Dept MORGANTOWN ENERGY Morgant
	CHECKER A. R. KUBALA	DATE 3/6/90	
	PROJECT ENGINEER J. P. KANSKY	DATE 3/6/90	
	_____	DATE _____	
	_____	DATE _____	
	_____	DATE _____	
		TITLE B-12 P& FLUIDIZED BED A.G.C.	
		SIZE E	FSC# NO DWG NO E90


IS PART
DOCUMENT
SYSTEM



TO FLUID BED
GASIFIER
DWG. E900012

C

DWG NO
E9000011
SH
1


DRAFTER S. CONKO	DATE 3/6/90	 <p>United States Department of Energy MORGANTOWN ENERGY TECHNOLOGY CENTER Morgantown, WV</p>			
CHECKER A. R. KUBALA	DATE 3/6/90				
PROJECT ENGINEER J. P. KANDSKY	DATE 3/6/90				
_____	DATE _____				
_____	DATE _____	<p>TITLE: B-12 P&ID FLUIDIZED BED GASIFIER A.G.C.</p>			
_____	DATE _____				
_____	DATE _____				
_____	DATE _____				
_____	DATE _____	SIZE E	FSC# NO	DWG NO E900011	REV 6


A

H


G

F





TO INCINERATOR
DWG E900013, SHT 1
(D-4)




TO
PCV 713
& PCV 713A
DWG. E900013
(G-4)

TO HV 728
DWG. E900013

TO HV 726
DWG. E900013

TO SECONDARY
CYCLONE
DWG. E900013



ZONE	REV	
GEN	1	UPDATED AS PER MARKED
E-6		REVISED PRESSURE RATIN
GEN		REVISED PER MARKED PRI
B-3		REMOVED LS AND LAH-90
C-3		REMOVED LS AND LAH-90
E-3		REMOVED LS AND LAH-90
G-7		REWORKED NOTE FOR ADD:
F-6		NOTE 1150 °F WAS 1100 °F

DRAFTER	G.J.K.	DATE	1/3/91	CHECKER	
		DATE			

ZONE	REV	
GEN	2	UPDATED AS PER MARKED
GEN		ADDED NEW DWG. FORMAT
GEN		UPDATED AS PER MARKED
GEN		UPDATED AS PER MARKED
		ISSUED FOR CUSTOMER RE

DRAFTER	JIMMY SMITH	DATE	7/17/92	CHECKER	GARY
EG&G RESPON SECT SUPV	BURTON W. HARRELL	DATE	7/20/92	EG&G ES	J. L

ZONE	REV	
A-1	3	CHANGED DWG. TITLE
GEN		UPDATED AS PER MARKED
GEN		ISSUED FOR CONSTRUCTI
B-2		ADDED NOTES 13 AND 14,
GEN		UPDATED AS PER MARKE

DRAFTER	GARY J. KULCHOCK	DATE	11/18/92	CHECKER	S
EG&G ESMH	J. L. BUCKLEW	DATE	11/19/92	PROJECT	

ZONE	REV	
GEN	4	ADDED DESIGN PRESSURE VSL-904, VSL-604, RPV-REMOVED NUMBERS FROM ISSUED FOR CONSTRUCTI

DRAFTER	GARY J. KULCHOCK	DATE	4/5/93	CHECKER	S
EG&G ESMH	J. L. BUCKLEW	DATE	4/7/93	PROJECT	JOHI

ZONE	REV	
GEN	5	ADDED NOTE ON ALL IN "PDAH-934B", "PDAH-9 "FO" WAS "FC" ON FV-TI-90L AND TE-90LB; REVISIED PIPING AROUND ISSUED FOR CONSTRUCT

DRAFTER	Gary Kulchock	DATE	9/10/93	CHECKER	
EG&G ESMH	Larry Bucklew	DATE	9/17/93	PROJECT	Jo

ZONE	REV	
GEN	6	EXTENSIVE CHANGES AS I ISSUED FOR CONSTRUCTIO

DRAFTER	<i>Gary Kulchock</i>	DATE	10/7/99	CHECKER	<i>J.C.</i>
EG&G ESMH	<i>Larry Bucklew</i>	DATE	10-11-99	PROJECT	<i>J.L.</i>

REVISION

ZONE	REV	DESCRIPTION	DATE
GEN	1	UPDATED AS PER MARKED PRINT	4/25/90
C-6		REVISED PRESSURE RATINGS	6/26/90
GEN		REVISED PER MARKED PRINT	10/11/90
B-3		REMOVED LS AND LAH-904	
C-3	REMOVED LS AND LAH-903		
C-3	REMOVED LS AND LAH-902		
F-7		RECORDED NOTE FOR ADDITIVE FEED HOPPER	
F-6		NOTE 1150 °F WAS 1100 °F	

H

DATE	G.J.K.	DATE	1/3/91	CHECKER	D.F.	DATE	1/3/91	PROJECT ENGINEER	J.P.K.	DATE	2/13/91	DATE	
DATE		DATE		DATE		DATE		DATE		DATE		DATE	

ZONE	REV	DESCRIPTION	DATE
GEN	2	UPDATED AS PER MARKED PRINT WITH W.D. #68547	10/3/91
GEN		ADDED NEW DWG. FORMAT	1/10/92
GEN		UPDATED AS PER MARKED PRINT WITH W.D. #70756	
GEN		UPDATED AS PER MARKED PRINT WITH WORK PLAN	7/17/92
GEN		ISSUED FOR CUSTOMER REVIEW AND COMMENT	

DATE	JIMMY SMITH	DATE	7/17/92	CHECKER	GARY J. KULCHOCK	DATE	7/17/92	EG&G RESPON ENGINEER	JAY RUTTEN	DATE	7/17/92	EG&G REVIEWER	D. LUNIFELD	DATE	7/17/92
DATE	EG&G RESPON SECT SUPV	DATE	7/20/92	EG&G ES&H	J. L. BUCKLEW	DATE	7/20/92	DATE		DATE		DATE		DATE	

ZONE	REV	DESCRIPTION	DATE
A-1	3	CHANGED DWG. TITLE	9/10/92
GEN		UPDATED AS PER MARKED PRINT WITH WORK PLAN	
GEN		ISSUED FOR CONSTRUCTION	
B-2		ADDED NOTES 13 AND 14, AND CORRESPONDING INTERLOCKS	9/16/92
GEN		UPDATED AS PER MARKED PRINT WITH WORK PLAN	11/16/92

G

DATE	J. KULCHOCK	DATE	11/18/92	CHECKER	S CONKO	DATE	11/18/92	EG&G RESPONSIBLE ENGR.	JAY RUTTEN	DATE	11/19/92	REVIEWER	D. LUNIFELD	DATE	11/19/92
DATE	EG&G ES&H	DATE	11/19/92	PROJECT ENGR.	J. L. BUCKLEW	DATE	11/19/92	BRANCH MANAGER		DATE		DOE (EDSD)	JOHN ROTUNDA	DATE	11/24/92

ZONE	REV	DESCRIPTION	DATE
GEN	4	ADDED DESIGN PRESSURE AND DESIGN TEMPERATURE TO VSL-901, VSL-902, VSL-903, VSL-904, VSL-604, RPV-701 AND CYC-701 REMOVED NUMBERS FROM ADACS SYMBOLS ISSUED FOR CONSTRUCTION	03/26/93

DATE	J. KULCHOCK	DATE	4/5/93	CHECKER	S CONKO	DATE	4/5/93	EG&G RESPONSIBLE ENGR.	JAY RUTTEN	DATE	4/7/93	REVIEWER	D. LUNIFELD	DATE	4/7/93
DATE	EG&G ES&H	DATE	4/7/93	PROJECT ENGR.	JOHN ROCKEY	DATE	5/27/93	BRANCH MANAGER	LARRY STRICKLAND	DATE	5/27/93	DOE (EDSD)	BILL AYERS	DATE	5/27/93

ZONE	REV	DESCRIPTION	DATE
GEN	5	ADDED NOTE ON ALL INCINERATOR DESIGNATIONS; "PLAL-934A" WAS "PLAL-934B"; "PDAH-934A" WAS "PDAH-934B"; "PDAH-934B" WAS "PDAH-934A"; MODIFIED PSID RANGE ON PDI-934, WAS "0-50" "FO" WAS "FC" ON FV-725; ADDED "#1" TO ALL N DESIGNATIONS; RELOCATED HV-436A, TE-901A, T1-901, AND TE-901B; ADDED HV-437 AND HV-438; ADDED NOTE TO VENT SYSTEM, ZONE A-6 REVISED PIPING AROUND VSL-901; ADDED LINE AHEAD OF FSV-435, ZONE C-8 & C-7 ISSUED FOR CONSTRUCTION	09/01/93

DATE	Gary Kulchock	DATE	9/10/93	CHECKER	S. Conko	DATE	9/14/93	EG&G RESPONSIBLE ENGR.	Jay Rutten	DATE	9/15/93	REVIEWER	Dave Lunifeld	DATE	9/20/93
DATE	EG&G ES&H	DATE	9/17/93	PROJECT ENGR.	John Rockey	DATE	9/21/93	BRANCH MANAGER	Larry Shadle	DATE	9/21/93	DOE (EDSD)	John Rotunda/WJA	DATE	9/20/93

ZONE	REV	DESCRIPTION	DATE
GEN	6	EXTENSIVE CHANGES AS PER MARKED PRINT REDLINED BY JAY RUTTEN ON 15 FEB 94. ISSUED FOR CONSTRUCTION	9/30/94

DATE	Gary Kulchock	DATE	10/7/94	CHECKER	S. Conko	DATE	10-7-94	EG&G RESPONSIBLE ENGR.	Jay Rutten	DATE	10-11-94	REVIEWER	D. Lunifeld	DATE	10/11/94
DATE	EG&G ES&H	DATE	10-11-94	PROJECT ENGR.	John Rockey	DATE	10/13/94	BRANCH MANAGER	Larry Shadle	DATE	10-18-94	DOE (EDSD)	John Rotunda/WJA	DATE	10/11/94

F

F

0-100' H₂O



0-100'
H₂O



0-100' H₂O



0-100' H₂O



0-100' H₂O



FROM PDT 424
DWG. E900011



0-100' H₂O



FROM HV 482
DWG. E900011



TO INCINERATOR
DWG E900013, SHT 1
(D-4)

200-550 PSIG
1150° F
500-13500 SCFH
1' SCH 160 316 SS
1' PIPE

550 PSIG
700° F
15000 SCFH

PSE
701

PI
701A 0-1500
PSIG

FLUIDIZED
BED
GASIFIER
RPV-701

DESIGN PRESS.
1100 PSIG

DESIGN STEEL TEMP.
650° F

OPERATING PRESS.
200-425 PSIG

OPERATING INTERNAL
TEMPERATURE
1400°-1800° F

SEE VESSEL
DWG. E910191

0-2000° F

TJR
10-8

TE
705B

TT
705

TI
705

TE
705A

A

0-2000° F

TJR
10-7

TE
704B

TT
704

TI
704

TE
704A

A

0-2000° F

TE
703A

A

TE
703B

TT
703

TI
703

TJR
10-6

TAH
703

1800° F

TE
760

1"

TE
702A

A

TE
702B

TT
702


TI
702


0-2000° F

35
PSID

PDAH
935

P
9





FROM FV
DWG. E900

1/2" PIPE 304 SS

FC

FV
450

1

HS
450

ZL
450

ZS
450

FV
450

1/2" PIPE
304 SS

FC

FV
452

ZS
452

ZL
452

HS
452

1

8

FSV
451

TE
16

J
16

TIC
16

0-1200° F

HS
913

I

9

ZS
913

ZL
913

0-1500
PSIG

PI
902A

PSE
902

750 PSIG
72° F
76000 SCFH

TO
INCINERATOR
DWG E900013
SHT 1, (D-4)

1/2"

I

PI
915

0-1000
PSIG

13

I

0-1000
PSIG

PI
902

A

PT
902

PRIMARY
CYCLONE
SEPARATOR
/SL-902
VESSEL
NO. D800560

IGN PRESS.
100 PSIG

IGN TEMP.
850° F

E

TE
1

J
1

TIC
1

0-1200° F

HV
902

5 PSIG

PAL
902

I

10

FROM
DWG.

FV
941

HS
941

ZS
941

ZL
941


1


GEN	6	EXTENSIVE CHANGES AS PER MARKED PRINT RECEIVED BY [unclear] ISSUED FOR CONSTRUCTION			
DRAFTER	DATE	CHECKER	DATE	EGLG RESPONSIBLE ENGR.	DATE
<i>Harold Kuhl</i>	10/7/99	<i>J. Carter</i>	10-7-99	<i>Gay Johnston</i>	10-11-99
EGLG ESH	DATE	PROJECT ENGR.	DATE	BRANCH MANAGER	DATE
<i>H. Kuhl</i>	10-11-99	<i>J. M. Kelsey</i>	10/13/99	<i>Larry Shells</i>	10-18-99


FROM FV 454
DWG. E900013

LEGEND:

 = PIPED TO PACKAGED INCINERATOR SYSTEM


 = INPUT TO THE DDAS SYSTEM


 IDENTIFIES THE CONNECTING SEGMENT OF THE T PURGE SYSTEM, WHERE XXX IS THE SEGMENT ID NUMBER. (SEE DWG. E900013, SHT. 2 OF 2 FOR THIS SYMBOL INDICATES THAT THE FOLLOWING IS IN THE PURGE LINE FROM THE NITROGEN HEA TRANSMITTER:
FV-440, FSV-441, HV-441, HV-XXXP, FV-XXXI
FSV-XXXP

 IDENTIFIES THE CONNECTING SEGMENT OF THE PURGE SYSTEM, WHERE XXX IS THE SEGMENT ID NUMBER. (SEE DWG. E900013, SHT. 2 OF 2 FOR THIS SYMBOL INDICATES THAT THE FOLLOWING IS IN THE PURGE LINE FROM THE NITROGEN HE TRANSMITTER:
FV-440, FSV-441, HV-441, HV-XXXP, & FSV-

FROM FV 458
DWG. E900013

NOTES:

 THIS FLAGGED NOTE DESIGNATES THE FOLLOWIN WHICH IS NOT SHOWN ON THIS DWG. FOR CLARI PANEL-MOUNTED ON/OFF STATION (HAND SWITCH POSITION INDICATION LAMPS), 24 VDC RELAY, 11 60 HZ SOLENOID VALVE.


 FV-940 WILL NOT OPEN UNTIL PT-901 MEASURE


DATE	CHECKER	DATE	EG&G RESPONSIBLE ENGR.	DATE	REVIEWER	DATE
10/7/94	S. Carter	10-7-94	Ray Ganten	10-11-94	A. Kimmfeld	10/11/94
DATE	PROJECT ENGR.	DATE	BRANCH MANAGER	DATE	DOE (EDSD)	DATE
10-11-94	Jim Kober	10/13/94	Larry Shelle	10-18-94	[Signature]	10/14/94


F


GEND:


 = PIPED TO PACKAGED INCINERATOR SYSTEM

 = INPUT TO THE DDAS SYSTEM

 IDENTIFIES THE CONNECTING SEGMENT OF THE TRANSMITTER PURGE SYSTEM, WHERE XXX IS THE SEGMENT IDENTIFICATION NUMBER. (SEE DWG. E900013, SHT. 2 OF 2 FOR DETAILS.) THIS SYMBOL INDICATES THAT THE FOLLOWING EQUIPMENT IS IN THE PURGE LINE FROM THE NITROGEN HEADER TO THE TRANSMITTER:
 FV-440, FSV-441, HV-441, HV-XXXX, FV-XXXX, & FSV-XXXX


 ~~IDENTIFIES THE CONNECTING SEGMENT OF THE TRANSMITTER PURGE SYSTEM, WHERE XXX IS THE SEGMENT IDENTIFICATION NUMBER. (SEE DWG. E900013, SHT. 2 OF 2 FOR DETAILS.) THIS SYMBOL INDICATES THAT THE FOLLOWING EQUIPMENT IS IN THE PURGE LINE FROM THE NITROGEN HEADER TO THE TRANSMITTER:
 FV-440, FSV-441, HV-441, HV-XXXX, & FSV-XXXX.~~

 THIS FLAGGED NOTE DESIGNATES THE FOLLOWING EQUIPMENT WHICH IS NOT SHOWN ON THIS DWG. FOR CLARITY; PANEL-MOUNTED ON/OFF STATION (HAND SWITCH WITH POSITION INDICATION LAMPS), 24 VDC RELAY, 117 VAC 60 HZ SOLENOID VALVE.

 FV-940 WILL NOT OPEN UNTIL PT-901 MEASURES A PRESSURE LESS THAN OR EQUAL TO 2 PSIG.

E

D



700B

TE 701B TT 701 TI 701 0-20

0-2

3" SCH 160 316 SS TE 707

2" SCH 160 SS

G 908 PDT 908 PDAH 908 PDAL 908 I LD -5.0 PSID HI 10.0 PSID HS 908

ZL 908 ZS 908 FV 908 FC TE 908 HJS 8 TI 908

1000 SIG

A PT 901

0-600 PSIC

PSE 901 750 PSIG 72° F 76000 SCFH TO INCINERATOR DWG. E900013 SHT 1, (D-4)

1" SCH 80 304 SS 450° F, 2000 SCFH TE 901A A TE 901B TI 901 ZL 909 ZS 909

13 I

2" SCH 160 SS


14 I FV 940 SCH 80 CS

HS 940 FC TE 940 HJS 14 TI 940 ZL 940 ZS 940




FV 912 ZS 912

TO VENT SYSTEM VSL-906, DWG. E90001 SHT 1, (D-5)

ANALYSIS AND DISPOSAL




3" SCH 160
 316 SS
 2" SCH 160 SS




TO VENT SYSTEM
 VSL-906, DWG. E900013
 SHT 1, (B-3)

SAL



ANALYSIS AND DISPOSAL

SHT 1, (D-4)



- 4 FV-
A PR
5.0 F
MUST
- 5 FV-
LESS
- 6 LOCK
VAL'
N₂ C
OPEN
- 7 RELA
VEN'
- 8 DESI
LOCK
- 9 FV-
PRES
5.0 F
LOW
- 10 FV-
PRES
- 11 RELA
909,
- 12 THIS
SUPE
TUBI
- 13 RELA
VAL
- 14 RELA
FRON

**THIS DRAWING IS PART
OF THE EG&G DOCUMENT
CONTROL SYSTEM**

REFERENCE DRAWINGS	DRAFTER
E900010	S. COI
E900011	CHECKER
E900013	A. R. KL
	PROJECT ENGINEER
	J.P. KAN

RFV-701.

FV-919 & FV-919A WILL NOT OPEN UNTIL PDT-919 MEASURES A PRESSURE DIFFERENTIAL LESS THAN OR EQUAL TO 5.0 PSID. REF. DWG. NO. D910379. THE PRESSURE IN VSL-903 MUST BE HIGHER THAN THE PRESSURE IN VSL-904.

FV-923 WILL NOT OPEN UNTIL PT-923 MEASURES A PRESSURE LESS THAN OR EQUAL TO 2 PSIG. REF. DWG. NO. D910379

LOCKHOPPER FILL VALVE CANNOT BE OPENED IF THE N2 CHARGING VALVE IS OPENED. DUMP VALVE CANNOT BE OPENED IF THE N2 CHARGING VALVE IS OPENED. N2 CHARGING VALVE CANNOT BE OPENED IF THE FILL OR DUMP VALVES ARE OPEN.

RELAY INTERLOCKS PREVENT THE LOCKHOPPER'S FILL VALVE AND VENT VALVE FROM BEING OPEN AT THE SAME TIME.

DESIGNATES THAT THE CONTROL PANEL SWITCH IS PHYSICALLY LOCKED TO PREVENT ACCIDENTAL ACTUATION.

FV-913 WILL NOT OPEN UNTIL PDT-934 MEASURES A PRESSURE DIFFERENTIAL LESS THAN OR EQUAL TO 5.0 PSID. THE PRESSURE IN VSL-902 MUST BE LOWER THAN THE PRESSURE IN CYC-701.

FV-941 WILL NOT OPEN UNTIL PT-902 MEASURES A PRESSURE LESS THAN OR EQUAL TO 2 PSIG.

RELAY INTERLOCKS PREVENT THE LOCKHOPPER VENT VALVES 909, 920 & 914 FROM OPENING UNLESS FV-912 IS OPEN.


THIS DWG. & DWGS. E900010, E900011 & E900013 SUPERCEDES DWG. R800524 (SEE DWG. E900013 FOR NOTES, TUBING & PIPING SUMMARY).

RELAY INTERLOCKS PREVENT THE LOCKHOPPER'S FILL AND DUMP VALVES FROM BEING OPEN AT THE SAME TIME.

RELAY INTERLOCKS PREVENT THE LOCKHOPPER'S DUMP VALVE FROM OPENING UNLESS THE VENT VALVE IS OPEN.


C

DWG NO
E9000012
SH
1


DRAFTER S. CONKO	DATE 3/6/90	 <p>United States Department of Energy MORGANTOWN ENERGY TECHNOLOGY CENTER Morgantown, WV</p>
CHECKER A. R. KUBALA	DATE 3/6/90	
PROJECT ENGINEER J.P. KANDSKY	DATE 3/6/90	
	DATE	TITLE B-12 P&ID FLUIDIZED BED GASIFIER A.G.C.
	DATE	
	DATE	
	DATE	SIZE FSCH NO DWG NO E
	DATE	E900012
	DATE	REV 6

A


H




G




F




1" SCH 80 316 SS



FROM PY 713
DWG. E900012
(H-2)



SYSTEM
906
13, SHT 1
)



REVISION

NO	REV	DESCRIPTION	DATE
4		ADDED DESIGN PRESSURE AND DESIGN TEMPERATURE TO VSL-905, VSL-906, VSL-907, CYC-906, CYC-908, AND CYC-702; MODIFIED FI-501 AND VARIOUS SCFH's REMOVED ALL NUMBERS FROM ADACS SYMBOLS ADDED FD-451, HCV-317B & FSV-452 ISSUED FOR CONSTRUCTION	04/01/93
DRAWN BY: GARY J. KULCHOCK DATE: 4/5/93 CHECKER: S CONKO DATE: 4/5/93 E&G RESPONSIBLE ENGR.: JAY RUTTEN DATE: 4/7/93 REVIEWER: D. LUNIFELD DATE: 4/7/93			
ESTD BY: L. BUCKLEW DATE: 4/7/93 PROJECT ENGR.: JOHN ROCKEY DATE: 5/27/93 BRANCH MANAGER: LARRY STRICKLAND DATE: 5/27/93 DOE CEESD: BILL AYERS DATE: 5/27/93			
5		ADDED NOTE ON (2) INCINERATOR DESIGNATIONS; ADDED PIPE SIZE (ZONE C-6) ADDED "#1" TO ALL N ₂ DESIGNATIONS; REMOVED HV-932; REVISED AND RENAMED FV-931 "WAS HV-931" MODIFIED INCINERATOR DESCRIPTION IN "LEGEND"; ADDED TUBING SIZE TO SAMPLE SYSTEM B (ZONE D-3) ADDED NOTE TO VENT SYSTEM, ZONE F-5; ADDED HV-800B, HV-800A & TE-900 CONNECTED PIPING FROM VENT SYSTEM, ZONE A-7 & VSL-906 TO EXISTING SYSTEM ISSUED FOR CONSTRUCTION	09/01/93
DRAWN BY: Gary Kulchock DATE: 9/10/93 CHECKER: S. Conko DATE: 9/14/93 E&G RESPONSIBLE ENGR.: Jay Rutten DATE: 9/15/93 REVIEWER: Dave Lunifeld DATE: 9/20/93			
ESTD BY: Larry Bucklew DATE: 9/17/93 PROJECT ENGR.: John Rockey DATE: 9/21/93 BRANCH MANAGER: Larry Shadle DATE: 9/21/93 DOE CEESD: John Rotunda/WJA DATE: 9/20/93			
6		EXTENSIVE CHANGES AS PER MARKED PRINT REDLINED BY JAY RUTTEN ON 15 FEB 94. ISSUED FOR CONSTRUCTION	9/29/94
DRAWN BY: Gary J. Kulchock DATE: 10/7/94 CHECKER: S. Conko DATE: 10-7-94 E&G RESPONSIBLE ENGR.: Jay Rutten DATE: 10-11-94 REVIEWER: D. Lunifeld DATE: 10/11/94			
ESTD BY: Larry Bucklew DATE: 10-11-94 PROJECT ENGR.: John M. Rockey DATE: 10/18/94 BRANCH MANAGER: Larry Shadle DATE: 10-18-94 DOE CEESD: John Rotunda/WJA DATE: 10/19/94			

H

G

TUBING SUMMARY


SIZE	WALL THICKNESS	TYPE
1/4"	0.035	304 SS
1/2"	0.035	CU TYPE K
1/2"	0.065	304 SS
1"	0.049	CU TYPE K

PIPING SUMMARY


SIZE	WALL THICKNESS	TYPE
1/2"	SCH 40	CS
1/2"	SCH 80	CS
1/2"	SCH 80	304 SS
1/2"	SCH 80	316 SS




F



TO FV 452
DWG. E900012



750 PSIG
72° F
76000 SCFH







1/2"	SCH 80	304 SS
1/2"	SCH 80	316 SS
1"	SCH 40	CS
1"	SCH 80	CS
1"	SCH 80	304 SS
1"	SCH 80	316 SS
1"	SCH 160	316 SS
2"	SCH 40	CS
2"	SCH 80	304 SS
2"	SCH 80	316 SS
3"	SCH 160	316 SS
4"	SCH 40	CS
4"	SCH 40	304 SS

NOTES:

- 1 THIS FLAGGED NOTE DESIGNATES THE FOLLOWING WHICH IS NOT SHOWN ON THIS DWG. FOR CLARITY PANEL-MOUNTED ON/OFF STATION (HAND SWITCH POSITION INDICATION LAMPS), 24 VDC RELAY, 117 60 HZ SOLENOID VALVE.
- 2 FV-926 WILL NOT OPEN UNTIL PDT-926 MEASURED DIFFERENTIAL LESS THAN OR EQUAL TO 5.0 PSID REF. DWG. NO. D910378. THE PRESSURE IN VSL-905 MUST BE LOWER THAN THE PRESSURE IN
- 3 FV-929 WILL NOT OPEN UNTIL PT-929 MEASURED LESS THAN OR EQUAL TO 2 PSIG. REF. DWG. NO.
- 4 THE (B-12) FBG'S HS-500 AND THE (B-4) SIDEST HS-500 MUST BOTH BE ON FOR FV-500 TO OPEN.
- 5 HS-59 IS LOCATED ON THE MGCR CONTROL PANEL
- 6 LOCKHOPPER FILL VALVE CANNOT BE OPENED IF DUMP VALVE IS OPENED. DUMP VALVE CANNOT BE OPENED IF CHARGING VALVE IS OPENED. N₂ CHARGING VALVE CANNOT BE OPENED IF THE FILL OR DUMP VALVES ARE OPEN
- 7 RELAY INTERLOCKS PREVENT THE LOCKHOPPERS FROM OPENING IF THE VENT VALVE IS OPEN AT THE SAME TIME
- 8 DESIGNATES THAT THE CONTROL PANEL SWITCH IS LOCKED TO PREVENT ACCIDENTAL ACTUATION.
- 9 RELAY INTERLOCKS PREVENT THE LOCKHOPPER VALVE FV-927 FROM OPENING UNLESS FV-912 IS OPEN.
- 10 LINES TO GAUGES, TRANSMITTERS, & MANUAL PRESSURE TO FLAIR ARE 1/2".
- 11 VALVE TYPES & END CONNECTIONS ARE NOT INDICATED

500
FH

I
53

DW
UTER

F

F

-1

1/2"	SCH 80	304 SS
1"	SCH 40	- CS
1"	SCH 80	CS
1"	SCH 80	304 SS
1"	SCH 80	316 SS
1"	SCH 160	316 SS
2"	SCH 40	CS
2"	SCH 80	304 SS
2"	SCH 80	316 SS
3"	SCH 160	316 SS
4"	SCH 40	CS
4"	SCH 40	304 SS

NOTES:

1 THIS FLAGGED NOTE DESIGNATES THE FOLLOWING EQUIPMENT WHICH IS NOT SHOWN ON THIS DWG. FOR CLARITY; PANEL-MOUNTED ON/OFF STATION (HAND SWITCH WITH POSITION INDICATION LAMPS), 24 VDC RELAY, 117 VAC 60 HZ SOLENOID VALVE.

2 FV-926 WILL NOT OPEN UNTIL PDT-926 MEASURES A PRESSURE DIFFERENTIAL LESS THAN OR EQUAL TO 5.0 PSID. REF. DWG. NO. D910378. THE PRESSURE IN VSL-905 MUST BE LOWER THAN THE PRESSURE IN CYC-702

3 FV-929 WILL NOT OPEN UNTIL PT-929 MEASURES A PRESSURE LESS THAN OR EQUAL TO 2 PSIG. REF. DWG. NO. D910378

4 THE (B-12) FBG'S HS-500 AND THE (B-4) SIDESTREAM'S HS-500 MUST BOTH BE ON FOR FV-500 TO OPEN.

5 HS-59 IS LOCATED ON THE MGCR CONTROL PANEL

6 2 LOCKHOPPER FILL VALVE CANNOT BE OPENED IF THE N₂ CHARGING VALVE IS OPENED. DUMP VALVE CANNOT BE OPENED IF THE N₂ CHARGING VALVE IS OPENED. N₂ CHARGING VALVE CANNOT BE OPENED IF THE FILL OR DUMP VALVES ARE OPEN.

7 RELAY INTERLOCKS PREVENT THE LOCKHOPPERS FILL VALVE AND VENT VALVE FROM BEING OPEN AT THE SAME TIME.

8 DESIGNATES THAT THE CONTROL PANEL SWITCH IS PHYSICALLY LOCKED TO PREVENT ACCIDENTAL ACTUATION.

9 RELAY INTERLOCKS PREVENT THE LOCKHOPPER VENT VALVE FV-927 FROM OPENING UNLESS FV-912 IS OPEN.

LINES TO GAUGES, TRANSMITTERS, & MANUAL PRESSURE RELIEF TO FLAIR ARE 1/2".

VALVE TYPES & END CONNECTIONS ARE NOT INDICATED

E

D

C

FROM VSL-601
DWG. E900011 (G-4)
FROM FV-609 & 609A
DWG. E900011, REGION H-2

1 1/2" SCH 40 CS

COAL DUST CYCLONE
CYC-907
SEE VESSEL
DWG. D800561
DESIGN PRESS.
150 PSIG
DESIGN TEMP.
150° F

COAL DUST STORAGE
VSL-907
SEE VESSEL
DWG. D800557
DESIGN PRESS.
150 PSIG
DESIGN TEMP.
150° F

TO ATMO
147 PSIG,
5000 S

PSE
907

HV
907

4" SCH 40 304 SS

FV
931


HS
931

ANALYSIS AND DISPOSAL

B

VEN


A





VENT SYSTEM

FROM B-12
ENTRAINED UNIT


DM SAMPLING
SYSTEM
E900013, SHT 2
H-6, F-6, E-3)



NATURAL GAS
35 PSIG



D DISABLED



- 12 SCF IS AT
- 13 THIS DWG. SUPERCEDE
- 14 RELAY IN VALVES
- 15 RELAY IN FROM OPE

LEGEND:

- RSS = RANGE SE
- I = MANIFOLI
- A = INPUT TC
- G
XXX IDENTIFI
PURGE S
NUMBER.
THIS SYM
IS IN TH
TRANSMIT
FV-44
FSV-X
- H
XXX IDENTIFI
PURGE S
NUMBER.
THIS SYM
IS IN TH
TRANSMIT
FV-44

REFERENCE DRAWINGS E900010 E900011 E900012 E920205	DRAFTER S. CONKO
	CHECKER A. R. KUBALA
	PROJECT ENGINEER J. P. KANSKY

THIS DRAWING IS PART
OF THE EG&G DOCUMENT
CONTROL SYSTEM

OSAL

12

SCF IS AT 14.7 PSIA AND 60° F

13

THIS DWG. & DWGS. E900010, E900011, AND E900012
SUPERCEDES DWG. R800524.

14

RELAY INTERLOCKS PREVENT THE LOCKHOPPERS FILL AND DUMP
VALVES FROM BEING OPEN AT THE SAME TIME.

15

RELAY INTERLOCKS PREVENT THE LOCKHOPPERS DUMP VALVE
FROM OPENING UNLESS THE VENT VALVE IS OPEN.

C

LEGEND:

RSS = RANGE SELECTOR SWITCH

I = MANIFOLD TO PACKAGED INCINERATOR SYSTEM

A = INPUT TO THE DDAS SYSTEM

**G
XXX** IDENTIFIES THE CONNECTING SEGMENT OF THE TRANSMITTER
PURGE SYSTEM, WHERE XXX IS THE SEGMENT IDENTIFICATION
NUMBER. (SEE DWG. E900013, SHT. 2 OF 2 FOR DETAILS.)
THIS SYMBOL INDICATES THAT THE FOLLOWING EQUIPMENT
IS IN THE PURGE LINE FROM THE NITROGEN HEADER TO THE
TRANSMITTER:
FV-440, FSV-441, HV-441, HV-XXXP, FV-XXXP, &
FSV-XXXP

**H
XXX** IDENTIFIES THE CONNECTING SEGMENT OF THE TRANSMITTER
PURGE SYSTEM, WHERE XXX IS THE SEGMENT IDENTIFICATION
NUMBER. (SEE DWG. E900013, SHT. 2 OF 2 FOR DETAILS.)
THIS SYMBOL INDICATES THAT THE FOLLOWING EQUIPMENT
IS IN THE PURGE LINE FROM THE NITROGEN HEADER TO THE
TRANSMITTER:
FV-440, FSV-441, HV-441, HV-XXXP, & FSV-XXXP.

DWG NO
E9000013
SHEET
1

DRAFTER	S. CONKO	DATE	3/6/90
CHECKER	A. R. KUBALA	DATE	3/6/90
PROJECT ENGINEER	J. P. KANDSKY	DATE	3/6/90
	—	DATE	—
	—	DATE	—
	—	DATE	—
	—	DATE	—



United States Department of Energy
MORGANTOWN ENERGY TECHNOLOGY CENTER
Morgantown, WV

TITLE
B-12 P&ID
FLUIDIZED BED GASIFIER
A.G.C.

SIZE	FSCM NO	DWG NO	REV
E		E9000013	6

A