

ME-IRQ-D9	1198760	Bldg. 5/Dagger-Repair broken shower & no water	07-JUL-07	PLUMB	COMP	4 SOO	US-SOP
ME-IRQ-D9	1198802	D9-Water tank superchlorination	07-JUL-07	PLUMB	COMP	4 SOO	US-SOP
ME-IRQ-D9	1198833	Tower 4 - Need new door handle	07-JUL-07	CARP	COMP	4 SOO	US-SOP
ME-IRQ-D9	1198858	Mylar/Bldg 8 - Clean and check AC	07-JUL-07	HVAC	COMP	4 SOO	SS-PM
ME-IRQ-D9	1198930	Mylar/Sniper Hut	07-JUL-07	HVAC	COMP	4 SOO	US-SOP
ME-IRQ-D9	1199374	Bldg 12 NAVy camp-Electrical panel needs grounding	07-JUL-07	ELEC	COMP	4 SOO	US-SOP
ME-IRQ-D9	1199425	Bldg 7 Ferguson-Label breaker & ground panel box	07-JUL-07	ELEC	COMP	4 SOO	US-SOP
ME-IRQ-D9	1199451	NRPC -Repalce busted booster tank	07-JUL-07	PLUMB	COMP	4 SOO	US-SOP
ME-IRQ-D9	1199484	Navy Camp- Ground panel box and label breakers	07-JUL-07	ELEC	COMP	4 SOO	US-SOP
ME-IRQ-D9	1199621	MWR-Install lights in horse shoe pit area	07-JUL-07	ELEC	CAN	4 SOO	US-SOP
ME-IRQ-D9	1199664	DFAC Rear/Falcon Palace-Replace flagpole light	07-JUL-07	ELEC	COMP	4 SOO	US-SOP
ME-IRQ-D9	1199693	Bldg. 1 Green -Repair flourescent light on wall	07-JUL-07	ELEC	COMP	4 SOO	US-SOP
ME-IRQ-D9	1199728	Bldg 8 Hornbeck - Repair outlet to AC	07-JUL-07	ELEC	COMP	4 SOO	US-SOP
ME-IRQ-D9	1199741	Green - Repair broken lights on volley ball court	07-JUL-07	ELEC	COMP	4 SOO	US-SOP
ME-IRQ-D9	1199765	NRPC near gen. - Labeling panel	07-JUL-07	ELEC	COMP	4 SOO	US-SOP
ME-IRQ-D9	1199790	Navy Camp - Label breaker and ground panel	07-JUL-07	ELEC	COMP	4 SOO	US-SOP
ME-IRQ-D9	1199806	SS-11 RSOI - Labeling/ regrounding panel	07-JUL-07	ELEC	COMP	4 SOO	US-SOP
ME-IRQ-D9	1199821	Tower 1 - Inop shower	07-JUL-07	PLUMB	COMP	4 SOO	US-SOP
ME-IRQ-D9	1199827	Bldg. 56 /NRPC-cracked water reservoir on pump	07-JUL-07	PLUMB	COMP	4 SOO	US-SOP
ME-IRQ-D9	1199837	Gym - Water cooler not working properly	07-JUL-07	HVAC	COMP	4 SOO	US-SOP
ME-IRQ-D9	1199843	THF - AC in IR#1 leaking	07-JUL-07	HVAC	COMP	4 SOO	US-SOP
ME-IRQ-D9	1207195	Hornbeck / Bldg 6- Ac not getting any power	08-JUL-07	ELEC	COMP	4 SOO	US-SOP
ME-IRQ-D9	1208111	LSF - Pipes have voltage,get shocked in shower	08-JUL-07	ELEC	COMP	4 SOO	US-SOP
ME-IRQ-D9	1208210	DFAC - Back door lock is broken	08-JUL-07	CARP	COMP	4 SOO	US-SOP
ME-IRQ-D9	1208918	Complex - Eye Wah station	08-JUL-07	PLUMB	COMP	4 SOO	US-SOR
ME-IRQ-D9	1208926	Complex-Area- Water testing	08-JUL-07	LABOR	COMP	4 SOO	SS-PM
ME-IRQ-D9	1208930	Complex - Punch List - Transport fuel	08-JUL-07	LABOR	COMP	4 SOO	SS-PM
ME-IRQ-D9	1208938	Complex-Area- Escort service	08-JUL-07	LABOR	COMP	4 SOO	SS-PM
ME-IRQ-D9	1208942	Complex-Area- Escort services	08-JUL-07	LABOR	COMP	4 SOO	SS-PM
ME-IRQ-D9	1208959	Complex-Area- Perform custodial services	08-JUL-07	LABOR	COMP	4 SOO	SS-PM
ME-IRQ-D9	1212525	Bldg 1/Dagger-Electricity felt at shower faucet	09-JUL-07	ELEC	COMP	4 SOO	US-SOP
ME-IRQ-D9	1208835	Complex-Area- Custodial service	08-JUL-07	LABOR	COMP	4 SOO	SS-PM
ME-IRQ-D9	1208843	MWR - Building - Custodial service	08-JUL-07	LABOR	COMP	4 SOO	SS-PM
ME-IRQ-D9	1208936	KBR / Site 2 Tank 100 replace broken pipe	08-JUL-07	PLUMB	COMP	1 SOO	US-SOE
ME-IRQ-D9	1208862	Complex - Area - Custodial service	08-JUL-07	OTHER	COMP	4 SOO	SS-PM
ME-IRQ-D9	1208874	Gym - Equipment and Building - Custodial service	08-JUL-07	LABOR	COMP	4 SOO	SS-PM
ME-IRQ-D9	1208880	MWR - Building - Custodial service	08-JUL-07	LABOR	COMP	4 SOO	SS-PM