



**TECHNICAL INSPECTION**

**TO:** Material Control Manager

**FROM:** Paul Hardin 299113 Paul Hardin  
**Print Name** **Badge No.** **Signature**

**DATE:** January 7, 2008

**INSPECTED BY:** David Nutt **Badge#** 373484

The below listed items have been inspected. They are found to be condition code: B 6

ID or GP#	DESCRIPTION	DEFICIENCY	EST. COST of REPAIRS
LSF Badge Office 1	Main Distribution Panel		
	Secondary Feeder Panel 63 AMP	Panel is missing cable glands for termination, panel are not grounded, No dead man front	
	Main Feeder Wire		
	Secondary Feeder Wire Circuits 2.5MM	Wire is not sized properly for the main breakers, incorrect thermal insulation coating on the wire does not meet BS or NEC 4X2.5MM no separate ground supplied to ground panel	
	220 V Outlets	4 outlets with broken covers and exposed wire jumped from outlet to outlet	
	220 V Fluorescent light Fixtures	4 fixtures no diffusers or ballast covers, incorrect wiring light fixture being used as a junction box. Two light circuit tapped off outlet circuit at the outlet	
	220 V A/C Disconnect	No disconnect for a/c unit plugged into outlet on the wall	
	External Light Fixtures	3 Light fixtures not working non weatherproof, exposed wiring	
	220 V Water Heater Disconnect	No disconnect present direct wire to the wall outlet, tank not grounded	

CODE	DESCRIPTION
A1	Serviceable - unused, good
A2	Serviceable - unused, fair
A3	Serviceable - unused, poor
A4	Serviceable - used, good
A5	Serviceable - used, fair
A6	Serviceable - used, poor
B1	Serviceable - unused, good (w/qualifications)

KELLOGG BROWN & ROOT, Inc

*KELLOGG BROWN & ROOT PROPRIETARY DATA - SOURCE SELECTION INFORMATION - SEE FAR 3.104*

NOTE: In addition to protection under Federal Acquisition Regulation 3.104 this document contains information which may be withheld from the public because disclosure would cause a foreseeable harm to an interest protected by one or more Exemptions of the Freedom of Information Act, 5 USC Section 552. Furthermore, it is requested that any Government entity receiving this information act in accordance with DoD 5400.7-R, and consider this information as being for official use only (FOUO), and mark, handle and store this information so as to prevent unauthorized access



B2	Serviceable - unused, fair (w/qualifications)
B3	Serviceable - unused, poor (w/qualifications)
B4	Serviceable - used, good (w/qualifications)
B5	Serviceable - used , fair (w/qualifications)
B6	Serviceable - used, poor (w/qualifications)
F7	Unserviceable - good, repairs required (reparable) 15% of acquisition cost
F8	Unserviceable - fair, repairs required (reparable) 16% to 40% of acquisition cost
F9	Unserviceable - poor, repairs required (reparable) 41% to 65% of acquisition cost
HX	Unserviceable salvage (condemned)
SS	Property has no value except for its basic material content (Scrap)

**KELLOGG BROWN & ROOT, Inc**

*KELLOGG BROWN & ROOT PROPRIETARY DATA - SOURCE SELECTION INFORMATION - SEE FAR 3.104*

NOTE: In addition to protection under Federal Acquisition Regulation 3.104 this document contains information which may be withheld from the public because disclosure would cause a foreseeable harm to an interest protected by one or more Exemptions of the Freedom of Information Act, 5 USC Section 552. Furthermore, it is requested tha any Government entity receiving this information act in accordance with DoD 5400.7-R, and consider this information as being for official use only (FOUO), and mark, handle and store this information so as to prevent unauthorized access

3170



**TECHNICAL INSPECTION**  
*(Unserviceable)*

**TO:** David Hintz  
**FROM:** Paul Hardin 299113 *Paul Hardin*  
**DATE:** Jan 09, 2008  
**INSPECTED BY:** Josef Fiala **Badge#** 288369

The below listed items have been inspected. They are found to be condition code: \_\_\_\_\_

ID or GP#	DESCRIPTION	DEFICIENCY	EST. COST of REPAIRS
LSF Office	280 LT Water Heater ×3	HX	
	Do not meet Safety Standard		
	Water Feed line	B6	

<b>CODE</b>	<b>DESCRIPTION</b>
A1	Serviceable - unused, good
A2	Serviceable - unused, fair
A3	Serviceable - unused, poor
A4	Serviceable - used, good
A5	Serviceable - used , fair
A6	Serviceable - used, poor
B1	Serviceable - unused, good (w/qualifications)
B2	Serviceable - unused, fair (w/qualifications)
B3	Serviceable - unused, poor (w/qualifications)
B4	Serviceable - used, good (w/qualifications)
B5	Serviceable - used , fair (w/qualifications)
B6	Serviceable - used, poor (w/qualifications)
F7	Unserviceable - good, repairs required (reparable) 15% of acquisition cost
F8	Unserviceable - fair, repairs required (reparable) 16% to 40% of acquisition cost
F9	Unserviceable - poor, repairs required (reparable) 41% to 65% of acquisition cost
HX	Unserviceable salvage (condemned)
SS	Property has no value except for its basic material content (Scrap)

NOTE: In addition to protection under Federal Acquisition Regulation 3.104 this document contains information which may be withheld from the public because disclosure would cause a foreseeable harm to an interest protected by one or more Exemptions of the Freedom of Information Act, 5 USC Section 552. Furthermore, it is requested tha any Government entity receiving this information act in accordance with DoD 5400.7-R, and consider this information as being for official use only (FOUO), and mark, handle and store this information so as to prevent unauthorized access