

Assumptions to the Annual Energy Outlook 2007

Table 38. Generating Capacity Types Represented in the Electricity Market Module

Capacity Type
Existing coal steam plants ¹
High Sulfur Pulverized Coal with Wet Flue Gas Desulfurization
Advanced Coal - Integrated Coal Gasification Combined Cycle
Advanced Coal with carbon sequestration
Oil/Gas Steam - Oil/Gas Steam Turbine
Combined Cycle - Conventional Gas/Oil Combined Cycle Combustion Turbine
Advanced Combined Cycle - Advanced Gas/Oil Combined Cycle Combustion Turbine
Advanced Combined Cycle with carbon sequestration
Combustion Turbine - Conventional Combustion Turbine
Advanced Combustion Turbine - Steam Injected Gas Turbine
Molten Carbonate Fuel Cell
Conventional Nuclear
Advanced Nuclear - Advanced Light Water Reactor
Generic Distributed Generation - Baseload
Generic Distributed Generation - Peak
Conventional Hydropower - Hydraulic Turbine
Pumped Storage - Hydraulic Turbine Reversible
Geothermal
Municipal Solid Waste
Biomass - Integrated Gasification Combined-Cycle
Solar Thermal - Central Receiver
Solar Photovoltaic - Single Axis Flat Plate
Wind

¹The EMM represents 32 different types of existing coal steam plants, based on the different possible configuration of No_x, particulate and SO₂ emission control devices, as well as future options for controlling mercury.

Source: Energy Information Administration, Office of Integrated Analysis and Forecasting.

Table 39. Cost and Performance Characteristics of New Central Station Electricity Generating Technologies

Technology	Online Year ¹	Size (mW)	Leadtimes (Years)	Base Overnight Costs in 2006 (\$2005/kW)	Contingency Factors		Total Overnight Cost in 2006 ³ (2005 \$/kW)	Variable O&M ⁴ (\$2005 mills/kWh)	Fixed O&M ⁴ (\$2005/kW)	Heatrate in 2006 (Btu/kWhr)	Heatrate nth-of-a-kind (Btu/kWhr)
					Project Contingency Factor	Technological Optimism Factor ²					
Scrubbed Coal New ⁷	2010	600	4	1,206	1.07	1.00	1,290	4.32	25.91	8,844	8,600
Integrated Coal-Gasification Combined Cycle (IGCC) ⁷	2010	550	4	1,394	1.07	1.00	1,491	2.75	36.38	8,309	7,200
IGCC with Carbon Sequestration	2010	380	4	1,936	1.07	1.03	2,134	4.18	42.82	9,713	7,920
Conv Gas/Oil Comb Cycle	2009	250	3	574	1.05	1.00	603	1.94	11.75	7,163	6,800
Adv Gas/Oil Comb Cycle (CC)	2009	400	3	550	1.08	1.00	594	1.88	11.01	6,717	6,333
ADV CC with Carbon Sequestration	2010	400	3	1,055	1.08	1.04	1,185	2.77	18.72	8,547	7,493
Conv Combustion Turbine ⁵	2008	160	2	400	1.05	1.00	420	3.36	11.40	10,807	10,450
Adv Combustion Turbine	2008	230	2	379	1.05	1.00	398	2.98	9.91	9,166	8,550
Fuel Cells	2009	10	3	3,913	1.05	1.10	4,520	45.09	5.32	7,873	6,960
Advanced Nuclear	2014	1350	6	1,802	1.10	1.05	2,081	0.47	63.88	10,400	10,400
Distributed Generation -Base	2009	2	3	818	1.05	1.00	859	6.70	15.08	9,500	8,900
Distributed Generation -Peak	2008	1	2	983	1.05	1.00	1,032	6.70	15.08	10,634	9,880
Biomass	2010	80	4	1,714	1.07	1.02	1,869	2.96	50.18	8,911	8,911
MSW - Landfill Gas	2009	30	3	1,491	1.07	1.00	1,595	0.01	107.50	13,648	13,648
Geothermal ^{6,7}	2010	50	4	1,790	1.05	1.00	1,880	0.00	154.92	36,025	30,641
Conventional Hydropower ⁹	2010	500	4	1,364	1.10	1.00	1,500	3.30	13.14	10,107	10,107
Wind	2009	50	3	1,127	1.07	1.00	1,206	0.00	28.51	10,280	10,280
Solar Thermal ⁷	2009	100	3	2,675	1.07	1.10	3,149	0.00	53.43	10,280	10,280
Photovoltaic ⁷	2008	5	2	4,114	1.05	1.10	4,751	0.00	10.99	10,280	10,280

¹Online year represents the first year that a new unit could be completed, given an order date of 2006.

²The technological optimism factor is applied to the first four units of a new, unproven design, or regulatory structure. It reflects the demonstrated tendency to underestimate actual costs for a first-of-a-kind unit.

³Overnight capital cost including contingency factors, excluding regional multipliers and learning effects. Interest charges are also excluded. These represent costs of new projects initiated in 2006.

⁴O&M = Operations and maintenance.

⁵Combustion turbine units can be built by the model prior to 2008 if necessary to meet a given region's reserve margin.

⁶Because geothermal and hydro cost and performance characteristics are specific for each site, the table entries represent the cost of the least expensive plant that could be built in the Northwest Power Pool region, where most of the proposed sites are located.

⁷Capital costs are shown before investment tax credits are applied.

Sources: The values shown in this table are developed by the Energy Information Administration, Office of Integrated Analysis and Forecasting, from analysis of reports and discussions with various sources from industry, government, and the Department of Energy Fuel Offices and National Laboratories. They are not based on any specific technology model, but rather, are meant to represent the cost and performance of typical plants under normal operating conditions for each plant type. Key sources reviewed are listed in the 'Notes and Sources' section at the end of the chapter.

Table 40. Learning Parameters for New Generating Technology Components

Technology Component	Period 1 Learning Rate	Period 2 Learning Rate	Period 3 Learning Rate	Period 1 Doublings	Period 2 Doublings	Minimum Total Learning by 2025
Pulverized Coal	-	-	1%	-	-	5%
Combustion Turbine - conventional	-	-	1%	-	-	5%
Combustion Turbine - advanced	-	10%	1%	-	5	10%
HRSG ¹	-	-	1%	-	-	5%
Gasifier	-	10%	1%	-	5	10%
Carbon Capture/Sequestration	20%	10%	1%	3	5	20%
Balance of Plant - IGCC	-	-	1%	-	-	5%
Balance of Plant - Turbine	-	-	1%	-	-	5%
Balance of Plant - Combined Cycle	-	-	1%	-	-	5%
Fuel Cell	10%	5%	1%	3	5	10%
Advanced Nuclear	5%	3%	1%	3	5	10%
Fuel prep - Biomass IGCC	20%	10%	1%	3	5	20%
Distributed Generation - Base	-	5%	1%	-	5	10%
Distributed Generation - Peak	-	5%	1%	-	5	10%
Geothermal	-	8%	1%	-	5	10%
Municipal Solid Waste	-	-	1%	-	-	5%
Hydropower	-	-	1%	-	-	5%
Wind	-	-	1%	-	-	1%
Solar Thermal	20%	10%	1%	3	5	20%
Solar PV	15%	8%	1%	3	5	20%

¹HRSG = Heat Recovery Steam Generator

Note: Please see the text for a description of the methodology for learning in the Electricity Market Module.

Source: Energy Information Administration, Office of Integrated Analysis and Forecasting.

Table 41. Component Cost Weights for New Technologies

Technology	Combustion Turbine-conventional	Combustion Turbine-advanced	HRSG	Gasifier	Carbon Capture/Sequestration	Balance of Plant-IGCC	Balance of Plant-Turbine	Balance of Plant-Combined Cycle	Fuelprep Biomass IGCC
Integrated Coal Gasification Comb Cycle (IGCC)	0%	15%	20%	41%	0%	24%	0%	0%	0%
IGCC with carbon sequestration	0%	10%	15%	30%	30%	15%	0%	0%	0%
Conv Gas/Oil Comb Cycle	30%	0%	40%	0%	0%	0%	0%	30%	0%
Adv Gas/Oil Comb Cycle (CC)	0%	30%	40%	0%	0%	0%	0%	30%	0%
Adv CC with carbon sequestration	0%	20%	25%	0%	40%	0%	0%	15%	0%
Conv Comb Turbine	50%	0%	0%	0%	0%	0%	50%	0%	0%
Adv Comb Turbine	0%	50%	0%	0%	0%	0%	50%	0%	0%
Biomass	0%	12%	16%	33%	0%	20%	0%	0%	19%

Note: All unlisted technologies have a 100% weight with the corresponding component. Components are not broken out for all technologies unless there is overlap with other technologies.

HRSG = Heat Recovery Steam Generator.

Source: Market Based Advanced Coal Power Systems, May 1999, DOE/FE-0400

Table 42. Component Capacity Weights for New Technologies

Technology	Combustion Turbine-conventional	Combustion Turbine-advanced	HRSG	Gasifier	Carbon Capture/Sequestration	Balance of Plant-IGCC	Balance of Plant-Turbine	Balance of Plant-Combined Cycle	Fuelprep Biomass IGCC
Integrated Coal_Gasification Comb Cycle (IGCC)	0%	67%	33%	100%	0%	100%	0%	0%	0%
IGCC with carbon sequestration	0%	67%	33%	100%	100%	100%	0%	0%	0%
Conv Gas/Oil Comb Cycle	67%	0%	33%	0%	0%	0%	0%	100%	0%
Adv Gas/Oil Comb Cycle (CC)	0%	67%	33%	0%	0%	0%	0%	100%	0%
Adv CC with carbon sequestration	0%	67%	33%	0%	100%	0%	0%	100%	0%
Conv Comb Turbine	100%	0%	0%	0%	0%	0%	100%	0%	0%
Adv Comb Turbine	0%	100%	0%	0%	0%	0%	100%	0%	0%
Biomass	0%	67%	33%	100%	0%	100%	0%	0%	100%

HRSG = Heat Recovery Steam Generator.

Source: Energy Information Administration, Office of Integrated Analysis and Forecasting.

Table 43. Nuclear Uprates by EMM Region (gigawatts)

Region	
East Central Area Reliability Coordination Agreement	0.1
Electric Reliability Council of Texas	0.4
Mid-Atlantic Area Council	0.1
Mid-America Interconnected Network	0.1
Mid-Continent Area Power Pool	0.0
New York	0.1
New England	0.1
Florida Reliability Coordinating Council	0.1
Southeastern Electric Reliability Council	1.8
Southwest Power Pool	0.0
Northwest Power Pool	0.0
Rocky Mountain Power Area, Arizona, New Mexico, and Southern Nevada	0.2
California	0.0
Total	2.7

Source: Energy Information Administration, Office of Integrated Analysis and Forecasting, based on Nuclear Regulatory Commission survey, <http://www.nrc.gov/reactors/operating/licensing/power-uprates.html>

Table 44. Summer Season NO_x Emissions Budgets for 2004 and Beyond
(Thousand tons per season)

State	Emissions Cap
Alabama	29.02
Connecticut	2.65
Delaware	5.25
District of Columbia	0.21
Illinois	32.37
Indiana	47.73
Kentucky	36.50
Maryland	14.66
Massachusetts	15.15
Michigan	32.23
New Jersey	10.25
New York	31.04
North Carolina	31.82
Ohio	48.99
Pennsylvania	47.47
Rhode Island	1.00
South Carolina	16.77
Tennessee	25.81
Virginia	17.19
West Virginia	26.86

Source: U.S. Environmental Protection Agency, Federal Register, Vol. 65, number 42 (March 2, 2002) pages 11222-11231.

Table 45. Coal Plant Retrofit Costs
(2005 Dollars)

Coal Plant Size (MW)	FGD Capital Costs (\$/KW)	SCR Capital Costs (\$/KW)
300	291	120
500	223	105
700	184	95

Note: The model was run for each individual plant assuming a 1.3 retrofit factor for FGDs and 1.6 factor for SCRs.

Source: CUECOST3.xls model (as updated 2/9/2000) developed for the Environmental Protection Agency by Raytheon Engineers and Constructors, Inc. EPA Contract number 68-D7-0001.

Table 46. Mercury Emission Modification Factors

Configuration			EIA EMFs			EPA EMFs		
SO ₂ Control	Particulate Control	NO _x Control	Bit Coal	Sub Coal	Lignite Coal	Bit Coal	Sub Coal	Lignite Coal
None	BH	—	0.11	0.27	0.27	0.11	0.26	1.00
Wet	BH	None	0.05	0.27	0.27	0.03	0.27	1.00
Wet	BH	SCR	0.10	0.27	0.27	0.10	0.15	0.56
Dry	BH	—	0.05	0.75	0.75	0.05	0.75	1.00
None	CSE	—	0.64	0.97	0.97	0.64	0.97	1.00
Wet	CSE	None	0.34	0.73	0.73	0.34	0.84	0.56
Wet	CSE	SCR	0.10	0.73	0.73	0.10	0.34	0.56
Dry	CSE	—	0.64	0.65	0.65	0.64	0.65	1.00
None	HSE/Oth	—	0.90	0.94	0.94	0.90	0.94	1.00
Wet	HSE/Oth	None	0.58	0.80	0.80	0.58	0.80	1.00
Wet	HSE/Oth	SCR	0.42	0.76	0.76	0.10	0.75	1.00
Dry	HSE/Oth	—	0.60	0.85	0.85	0.60	0.85	1.00

Notes: SO₂ Controls - Wet = Wet Scrubber and Dry = Dry Scrubber, Particulate Controls, BH - fabric filter/baghouse. CSE = cold side electrostatic precipitator, HSE = hot side electrostatic precipitator, NO_x Controls, SCR = selective catalytic reduction, — = not applicable, Bit = bituminous coal, Sub = subbituminous coal. The NO_x control system is not assumed to enhance mercury removal unless a wet scrubber is present, so it is left blank in such configurations.

Sources: EPA, EMFs. <http://www.epa.gov/clearskies/technical.html> EIA EMFs not from EPA: Lignite EMFs, Mercury Control Technologies for Coal-Fired Power Plants, presented by the Office of Fossil Energy on July 8, 2003. Bituminous coal mercury removal for a Wet/HSE/Oth/SCR configured plant, Table EMF1, Analysis of Mercury Control Cost and Performance, Office of Fossil Energy & National Energy Technology Laboratory, U.S. Department of Energy, January 2003, Washington, DC.

Table 47. Planned SO₂ Scrubber Additions Represented by Region

Region	Capacity (Gigawatts)
East Central Area Reliability Coordination Agreement	4.2
Electric Reliability Council of Texas	0.0
Mid-Atlantic Area Council	1.2
Mid-America Interconnected Network	0.0
Mid-Continent Area Power Pool	0.5
New York	0.0
New England	0.6
Florida Reliability Coordinating Council	0.0
Southeastern Electric Reliability Council	13.5
Southwest Power Pool	0.0
Northwest Power Pool	0.0
Rocky Mountain Power Area, Arizona, New Mexico, and Southern Nevada	0.0
California	0.0
Total	20.1

Source: Energy Information Administration, Office of Integrated Analysis and Forecasting, based on public announcements and reports to Form EIA-767, "Annual Steam-Electric Plant Operation and Design Data".

Table 48. Cost and Performance Characteristics for Fossil-Fueled Generating Technologies: Three Cases

	Total Overnight Cost in 2006 Reference (2005 \$/kW)	Total Overnight Cost ¹			Heatrate in 2006 (Reference) Btu/kWhr	Heat Rate		
		Reference (2005 \$/kW)	High Fossil (2005 \$/kW)	Low Fossil (2005 \$/kW)		Reference BTU/kWhr	High Fossil Btu/kWhr	Low Fossil Btu/kWhr
Pulverized Coal	1290				8844			
2015		1260	1260	1260		8661	8661	8661
2020		1235	1243	1232		8600	8600	8600
2025		1219	1226	1213		8600	8600	8600
2030		1209	1209	1205		8600	8600	8600
Advanced Coal	1491				8309			
2015		1436	1355	1491		7477	6937	8309
2020		1400	1280	1491		7200	6480	8309
2025		1335	1205	1491		7200	6480	8309
2030		1254	1129	1491		7200	6480	8309
Conventional Combined Cycle	603				7163			
2015		569	589	589		6866	6866	6866
2020		581	581	581		6800	6800	6800
2025		573	573	573		6800	6800	6800
2030		565	565	565		6800	6800	6800
Advanced Gas Technology	594				6717			
2015		576	564	594		6403	5875	6717
2020		561	522	594		6333	5700	6717
2025		542	497	594		6333	5700	6717
2030		525	472	594		6333	5700	6717
Conventional Combustion Turbine	420				10807			
2015		410	410	410		10486	10486	10486
2020		405	405	405		10450	10450	10450
2025		399	399	399		10450	10450	10450
2030		394	394	394		10450	10450	10450
Advanced Combustion Turbine	398				9166			
2015		384	362	398		8612	7828	9166
2020		371	343	398		8550	7695	9166
2025		353	323	398		8550	7695	9166
2030		337	304	398		8550	7695	9166

¹Total overnight cost (including project contingency, technological optimism and learning factors, but excluding regional multipliers), for projects initiated in the given year.

Source: AEO2007 National Energy Modeling System runs: AEO2007.D112106A, HFOSS07.D112706A, LFOSS07.D112706A.

Table 49. Cost Characteristics for Advanced Nuclear Technology: Two Cases

Advanced Nuclear Technology	Overnight Cost in 2006 (Reference) (2005\$/kW)	Total Overnight Cost ¹		
		Reference Case (2005\$/kW)	Low Nuclear Cost (2005\$/kW)	High Nuclear Cost (2005\$/kW)
	2081			
2015		1983	1886	2080
2020		1797	1777	2080
2025		1795	1667	2080
2030		1732	1559	2080

¹Total overnight cost (including project contingency, technological optimism and learning factors, but excluding regional multipliers), for projects initiated in the given year.

Source: AEO2007 National Energy Modeling System runs: AEO2007.D112106A, ADVNUC07.D112906A, LONUC07.D112706A.