

CHAIN LINK FENCE



CHAIN LINK FENCE									
POST SIZE AND WEIGHT TABLE									
		ROUND PIPE							
DESCRIPTION	FENCE HEIGHT	Yield strength 172 Mpa (min.)							
		dia. mm kg/m (min.)							
Brace rail	1500 mm or less	33.40 1.10							
& top rail	1800 mm	33.40 1.10							
Line post	1500 mm or less	<i>42.16 1.65</i>							
Line posi	1800 mm	48.26 1.89							
End, corner	1500 mm or less	<i>35.56 1.89</i>							
& pull post	1800 mm	60.32 2.38							


NOTE:

- 1. Dimensions not labeled are in millimeters.
- 2. Metal post and rails shall conform to ASTM F 761.
- 3. Set all posts in concrete. Set corner, end, pull posts to the dimensions shown. The minimum depth of concrete for line posts is 600 mm. Increase depth 75 mm for each additional 300 mm of fence height over 1200 mm.
- 4. Adjust the post top elevations to provide a smooth visual fence profile. Install corner posts at horizontal breaks in the fence of 15° or more.
- 5. Provide fence fabric with a 50 mm mesh, Use 3.05 mm wire in fabric heights of 1200 mm or less and 3.76 mm wire in fabric heights greater than 1200 mm. Provide a Class D coating when zinccoated steel fence fabric is provided. Knuckle both selvages on fabric.
- 6. See Detail WM619-21 for hardware and gate requirements.



WIRE SELVAGE DETAIL

TRUSS ROD TIGHTENER DETAIL



CHAIN LINK FENCE TIE DETAIL

U.S. DEPARTMENT OF TRANSPORTATION FEDERAL HIGHWAY ADMINISTRATION WESTERN FEDERAL LANDS HIGHWAY DIVISION

METRIC DETAIL


RESIDENTIAL CHAIN LINK FENCE

DETAIL APPROVED FOR USE 3/1996 DETAIL WM619-20

NO SCALE

REVISED:


STATE	PROJECT	SHEET NUMBER



DOUBLE LEAF GATE

300 mm

100 mm




WIDE SINGLE LEAF GATE

CHAIN LINK GATE									
POST AND FRAME SIZE AND MASS TABLE									
	Minimum yield strength 172 Mpa.								
		R	OUND	TUBING	9	S	QUARE	TUBING	Ĝ
GATE LEAF WIDTHS	Steel		Aluminum		Steel		Aluminum		
		dia.	kg/m	dia.	kg/m	dia.	kg/m		kg/m
		mm	(min.)	mm	(min.)	mm	(min.)	mm	(min.)
1200 mm or less	Gate	4.83	1.87	4.83	1.29	50x50	3.50	50x50	1.40
Over 1200 to 2100 mm	post	6.03	3.18	6.03	1.88	64x64	4. 06	64x64	1.88
Over 2100 mm	size	6.03	4.64	6.03	2.98	64x64	5.78	64x64	4.32
Outside frame member	frame	3.34	1.29	3.34	0.65	32x32	1.56	32x32	0.86
Interior bracing member	size	3.34	1.29	<i>3.34</i>	0.65	32x32	I . 56	32x32	0.86

NOTE:

- I. Dimensions not labeled are in millimeters.
- 2. Reinforce the gate frame corners with a malleable iron or pressed steel fitting designed for the purpose or shop weld the corners. Grind smooth all welds and paint with an approved zinc rich paint. Furnish each gate with the necessary hinges, latch, and drop rod locking device designed for the type of gate posts and gate used on the project, Provide positive type latching devices with provisions for pad locking at all gates. Provide keepers to retain the gate in the open position.
- 3. Approved alternate gate frames constructed of steel sections, other than pipe, may be
- 4. The design of the chain link hardware may vary from the details shown, however, all hardware and materials used in a single installations shall be uniform and compatible.
- 5. Furnish hardware in the metric sizes shown. Equivalent imperial sizes may be used when metric sizes are not available.



NARROW SINGLE LEAF GATE

U.S. DEPARTMENT OF TRANSPORTATION FEDERAL HIGHWAY ADMINISTRATION WESTERN FEDERAL LANDS HIGHWAY DIVISION

METRIC DETAIL

RESIDENTIAL CHAIN LINK HARDWARE AND GATE

NO SCALE

REVISED:


DETAIL APPROVED FOR USE 3/1996 DETAIL WM619-21

HARDWARE ITEM DESCRIPTION	STANDARD REQUIREMENTS
Brace rail and top rail	See table on Detail WM619-20
Line post	See table on Detail WM619-20
Corner, end and pull posts	See table on Detail WM619-20
Post cap	Cast non-ferrous alloy or galvanized pressed steel cap must fit snugly on post and gate top
Line post cap	Galvanized pressed steel minimum 2.38 mm thickness or galvanized malleable ferrous alloy
Tension band	Minimum 2.38 x 75 mm galvanized steel
Brace band	Minimum 2.38 x 75 mm galvanized steel
Band bolt	Minimum M8 x 32 mm galvanized carriage bolt, (Lock washer & flat washer for each band)
Rail end	Galvanized pressed steel or galvanized malleable ferrous alloy minimum 9.53 mm thickness on back bolting appendage
Brace rail end	Galvanized pressed steel or galvanized malleable ferrous alloy minimum 9.53 mm thickness on back bolting appendage
Truss rod tightener	Minimum 6.4 mm formed galvanized steel
Truss rod	9.5 mm galvanized, NC threaded rod, lock washer, & flat washer with two 90° bends opposite of threaded end
Top rail sleeve	Galvanized steel 1.30 mm minimum thickness by 150 mm minimum length
Tension bar	Minimum 4.76 x 75 mm galvanized steel
Fence fabric	50 mm diamond mesh fabric, See note no. 5 on Detail WM619-20
Tie wires	Minimum 3.76 mm aluminum with one hooked end
Gate latch	Minimum 3.18 mm galvanized pressed steel or malleable ferrous alloy. I latch per each single gate with bent minimum MIO attachment bolt, washer & nut.
Fence side Frame hinge Gate side	Minimum 3.18 mm galvanized pressed steel with 2 - MIO U-bolts, lockwasher & nuts per hinge. Use 2 hinges per gate leaf up to 2400 mm in width and 3 hinges per gate leaf widths greater than 2400 mm.
Drop rod latch & guide	Minimum 3.18 mm galvanized pressed steel. Drop rod guide includes MIO x 75 mm carriage bolt with lock washer & nut. Weld drop rod fork to rod & paint with an approved zinc rich paint.





NOTE:

- I. Dimensions not labeled are in millimeters.
- 2. Metal post and rails shall conform to ASTM F 669.
- 3. Use Type I requirements from the chain link fence table unless otherwise specified in the special contract requirements.
- 4. Set all posts in concrete. Set corner, end, pull posts to the dimensions shown. The minimum depth of concrete for line posts is 600 mm. Increase depth 75 mm for each additional 300 mm of fence height over 1200 mm.
- 5. Install braces on all terminals on fences without a top rail. No braces are required on fabric 1800 mm in height or less where a top rail is specified. Install braces where fabric is over 1800 mm in height. Where a top rail is used, attach the brace at the halfway point of the terminal post above grade and, where the rail is omitted, at the twothirds point above grade. Do not install top rail unless so specified in the special contract requirements.
- 6. Adjust the post top elevations to provide a smooth visual fence profile. Install corner posts at horizontal breaks in the fence of 15° or more.
- 7. If alternate steel posts are used, provide fastening bands, caps, brace rail, rail ends, and truss rod attaching hardware compatible with the post sizes and styles selected.
- 8. Provide fence fabric with a 50 mm mesh, Use 3.05 mm wire in fabric heights of 1200 mm or less and 3.76 mm wire in fabric heights greater than 1200 mm. Provide a Class D coating when zinc-coated steel fence fabric is provided. Knuckle both selvages on fabric less than 1800 mm high. For fabic 1800 mm high or higher, knuckle one selvage and twist the other.
- 9. See Detail WM619-23 for hardware and gate reauirements.



CHAIN LINK FENCE





CHAIN LINK FENCE

dia.

mm

1.17 4.22 2.08

--- | 4.22 | 2.08

6.03 3.44

Steel

345

mass

kg/m

Aluminum

172

TOP &

BRACE RAIL

mass

HOT ROLLED H-SHAPE

Minimum yield strength Mpa.

Size and mass

Steel

310

mass

kg/m

4.85

ALTERNATE STEEL POST

& BRACE SECTIONS

NO SCALE

dia.

mm

ROLLED FORMED

Steel

310

mass

kg/m

2.08

2.08

4.02

3.36

7.60

dia.

mm

32x40

32x40

57x40

28x40

90x90

U.S. DEPARTMENT OF TRANSPORTATION FEDERAL HIGHWAY ADMINISTRATION WESTERN FEDERAL LANDS HIGHWAY DIVISION METRIC DETAIL CHAIN LINK FENCE


DETAIL APPROVED FOR USE 3/1996 DFTAII REVISED: WM619-22

DOUBLE LEAF GATE

300 mm

Drop latch base

100 mm



WIDE SINGLE LEAF GATE

CH	<i>AIN</i>	LIN	K GA	<i>TE</i>				
POST AND FF	RAME	SIZE	ANL) WE	IGHT	TABL	_	
				ROUNL	PIPE			
		St	eel	Alum	inum	Ste	eel	
			Minimu	ım yie	ld stre	ngth M	ра.	
<i>GATE LEAF WIDTHS</i>		17	2	17	'2	34	!5	
			Size and ma				155	
		dia.	kg/m	dia.	kg/m	dia.	kg/m	
		mm	(min.)	mm	(min.)	mm	(min.)	
1800 mm or less	Gate	7.30	6.91	7.30	2.89	7.30	6.91	
Over 1800 to 3600 mm	post	10.16	12.87	10.16	4.4 5	10.16	9.76	
Over 3600 to 5400 mm	size	16.83	26.82					
Outside frame member	frame	4.83	3. 39	4.83	/ . 35	4.83	3.39	
Interior bracing member	size	4.22	2.72	4.83	/ . 35	4.22	2.74	


 All dimensions on this drawing are in millimeters.

STATE

PROJECT

NUMBE

- 2. Reinforce the gate frame corners with a malleable iron or pressed steel fitting designed for the purpose or shop weld the corners. Grind smooth all welds and paint with an approved zinc rich paint. Furnish each gate with the necessary hinges, latch, and drop rod locking device designed for the type of gate posts and gate used on the project, Provide positive type latching devices with provisions for pad locking at all gates. Provide keepers to retain the gate in the open position.
- 3. Approved alternate gate frames constructed of steel sections, other than pipe, may be used.
- 4. The design of the chain link hardware may vary from the details shown, however, all hardware and materials used in a single installations shall be uniform and compatible.
- 5. Furnish hardware in the metric sizes shown. Equivalent imperial sizes may be used when metric sizes are not available.



NARROW SINGLE LEAF GATE

U.S. DEPARTMENT OF TRANSPORTATION
FEDERAL HIGHWAY ADMINISTRATION
WESTERN FEDERAL LANDS HIGHWAY DIVISION

METRIC DETAIL


CHAIN LINK HARDWARE AND GATE


DETAIL APPROVED FOR USE 3/1996


REVISED:

DETAIL

WM619-23









NOTE:

- I. Dimensions not labeled are in millimeters.
- 2. Match Type I gates with the adjacent fence.
- 3. Hang gates on standard metal or wood brace posts corresponding with the type of posts used in adjacent line fence.
- 4. Construct end post for Type I gate with a section of metal fence post or a round wood post 65 mm to 75 mm diameter. Provide a 600 mm length of hardwood tool handle for the pry stick. Use 3.76 mm wire for loop wire and pry stick wire or a suitable chain and adjust for length so that the gate will be neat and taut when closed. Place two wood stays, equally spaced, on each gate. Provide 50 mm minimum diameter or 40 mm square stays. Staple or tie wires to the stays and end posts.
- 5. Form Type 2 gate frames with 33.40 mm OD cold rolled or drawn galvanized steel tubing with a wall thickness of 2.41 mm or with 25 mm galvanized standard steel pipe. Equip each gate with one standard adjustable diagonal truss rod from corner to corner. Provide galvanized mallable iron or steel hinges and two way self closing latch.
- 6. Form metal walk gate frames with 26.67 mm OD cold rolled or drawn galvanized steeltubing with a wall thickness of 2.41 mm or with 19.05 mm galvanized standard steel pipe. Construct metal walk gates similar to Type 2 gate but omit vertical brace and truss.
- 7. Approved alternate gates may be used.
- 8. Where a single opening requires two gates, provide an approved drop bar, latch, chain and snap between the gates.
- 9. 51 x 51 x 6.4 mm angle or 31.75 mm standard steel pipe brace.
- 10. 64 x 64 x 6.4 mm angle or 64 mm standard steel pipe post.



TYPE I GATE



METAL GATE BRACE

WOOD GATE BRACE

TYPE 2 GATE

U.S. DEPARTMENT OF TRANSPORTATION
FEDERAL HIGHWAY ADMINISTRATION
WESTERN FEDERAL LANDS HIGHWAY DIVISION
METRIC DETAIL

IDAHO GATES

DETAIL APPROVED FOR USE 3/1996

REVISED:


DETAIL

WM619-51






- I. Dimensions not labeled are in millimeters.
- 2. Furnish either painted or galvanized angles or galvanized steel round pipe posts for corner or line braces. Furnish round pipe posts with snug-fitting galvanized metal caps. Fabricate steel pipe fence posts and braces according to ASTM F 1083.
- 3. Furnish pressure treated Douglas fir, Western larch, Cedar, or Pine of any species for corner, pull, end or gate posts and braces. Provide posts with a minimum circumference of 444.5 mm and a minimum distance between opposite faces of 100 mm. Provide nominal 100 x 100 mm braces. Connect braces to post with three 16d nails or a 9.53 by 100 mm steel dowel. Treat the posts and braces with pentachlorophenal, ACZA, or CCA, Type I, A, B or C.
- 4. Where a fence ties into a bridge parapet or railing, the top of the fence shall not project above the top of the parapet or railing.
- 5. 51 x 51 x 6.4 mm angle or 31.75 mm standard steel pipe brace.
- 6. 64 x 64 x 6.4 mm angle or 64 mm standard steel pipe post.




(not necessary to form)

ALTERNATE CONCRETE BLOCK





DETAIL APPROVED FOR USE 3/1996 DETAIL
REVISED: WM619-52



METAL END AND GATE BRACE

See note 5-

450 mm

See note 6

(max.)

WOOD END AND GATE BRACE

WOOD LINE BRACE FOR TYPE 8 FENCE


3.6 m post spacing

3.6 m post spacing


brace wire

Brace intervals not


to exceed 120 m



WOOD CORNER BRACE



post set in concrete at sag point



Wood corner post or metal corner

addition to concrete brace

TYPICAL SAG SECTION FOR WOVEN WIRE. MESH OR COMBINATION FENCES

FENCE BRACE TABLE

Metal post — — 3.61 mm wire stays 450 mm (min.) Anchor-Two 3.76 mm plate Rock or concrete minimum mass wires spliced 45 kg to stay and

TYPICAL SAG SECTION - BARBED WIRE FENCES


bottom wire

(See fence brace last)	FENCE TYPE	RUN IN METERS	WOOD PANELS REQUIRED	METAL BRACES
		<20	NONE	NONE
, "	I, 5, II, & 6	20 - 200	SINGLE	SINGLE
		200 - 300	DOUBLE	NOT ALLOWED
<u>Exterior fence angle</u> (See note no. 6)		<10	NONE	NONE
(See Hore Ho. 6)	2, 3, & 33	10 - 100	SINGLE	SINGLE
		100 - 200	DOUBLE	NOT ALLOWED

DOUBLE BRACE PANELS

NOTE:

- I. Dimensions not labeled are in millimeters.
- 2. When a fence line approaches a ditch, aully, or depression, place the last post on level ground placed close enough to the edge of the dropoff that the wire may be strung to a post in the depression without touching the ground.
- 3. When the depth of a depression on a Type 1, 5, or II fence exceeds the total vertical wire spacing over a maximum horizontal run of 2 spaces, an extra fence shall be constructed through the depression. Extra line braces and a deadman are included in this application. See the special applications for barbed wire detail.
- 4. When a Type I gate is used in a special application as shown, extra line braces and the attached under timber, wire, and wire stays are included. The horizontal wires on the under timber are not to be stapled but wrapped around brace post, twice then around the wire itself.
- 5. The special applications for barbed wire fences may be used for woven wire fence Types 2, 3, and 33 with approval or as directed. A Type 2 gate should be used with these fences. Barbed wire may be used through the depressions or etc., however the wires must match the woven wire spacing as nearly as possible. The under timber should not be attached directly to a Type 2 gate.
- 6. When wood braces are used and the fence corner angle exceeds 30° in the exterior angle of the fence, use double panels on the corner brace. Install double panels for line and terminal braces according to the fence brace table.
- 7. Use metal braces as shown in the metal brace details or the fence brace table.



(See note no. 4) SPECIAL APPLICATIONS FOR TYPE I, 5, & II BARBED WIRE FENCES

300 mm (max.)

clearance Attached under timber

FEDERAL HIGHWAY ADMINISTRATION WESTERN FEDERAL LANDS HIGHWAY DIVISION

METRIC DETAIL IDAHO STANDARD

BARBED, WOVEN, MESH,


COMBINATION WIRE FENCES AND FENCING APPLICATIONS

DETAIL APPROVED FOR USE 3/1996

REVISED:

DETAIL WM619-53





TYPE I-4W TYPE I-5W TYPE I-3W TYPE 1-6W

450 mm sq

or 550 mm

round (min.)

TYPE 2


(min. typ.)

450 mm sq or

550 mm round

(min.) concrete

footing (typ.)



END. GATE OR CORNER BRACE

--- Concrete

footing.

500 mm sq

or 550 mm

round (min.)

LINE BRACE

Concrete

footing

500 mm sq


or 550 mm

round (min.)

STEEL POSTS


Anchor

plate



NOTE:

- I. Dimensions not labeled are in millimeters.
- 2. Furnish either zinc coated (galvanized) or aluminum coated steel barbed wire. Fabricate zinc coated barbed wire with a Class I zinc coating except on 1.70 mm strand wire use a Class 3 zinc coating. Provide either 2 point or 4 point barbs of 2.03 mm zinc coated wire. Fabricate aluminum coated barbed wire with 4 point barbs of 2.03 mm aluminum coated or aluminum alloy wire. Use strand wire with a minimum breaking strength of 430 kg.
- 3. Furnish 2.51 mm or heavier gage tie wire or wire clamps for fasteners in metal posts and 3.61 mm by 45 mm long wire staples of the barbed U-shape type for wood posts and wood stays. Galvanize wire stays, tie wire, wire loops, and wire clamps with a Class I zinc coating according to ASTM A 641.
- 4. Furnish either painted or galvanized steel fence posts, braces and anchor plates.
- 5. Fabricate metal fence stays from 3.61 mm wire twisted to form a 2-wire unit. Place stays halfway between posts. Use wire stays on all fences unless wood stays are specified. When specified, provide either 50 mm round, rough sawn 50x50 mm or 50x100 mm (S4S) wood stays of sufficient length to be placed on the ground with the top of the stay extending 50 mm above the top wire. Attach each wire to the stay using wire staples.
- 6. Furnish Douglas fir, Western larch, Lodgepole or Ponderosa pine for fence posts, brace rails, and wood stays if applicable. Treat the posts and brace rails with pentachlorophenal, ACZA, or CCA, Type I, A, B, or C.




U.S. DEPARTMENT OF TRANSPORTATION FEDERAL HIGHWAY ADMINISTRATION WESTERN FEDERAL LANDS HIGHWAY DIVISION

METRIC DETAIL


MONTANA FENCE

DETAIL APPROVED FOR USE 3/1996 DETAIL REVISED: 5/2000 WM619-60



DETAIL WM619-61

SHEE T NUMBE



DOUBLE END PANEL (FOR ANGLES GREATER THAN 30° AND RUN GREATER THAN 100 m FOR WOVEN AND 200 m FOR BARBED.)

<u>L</u> !=	<u>L</u>	L	
SINGLE PANEL	SINGLE PANEL	END PANEL	

(END OF RUN)

NOTE:

Use double end panels only when the angle is greater than 30° and the run requires a double panel.

FENCE LAYOUT ON SHARP VERTICAL CURVES

STATE	PROJECT	SHEET NUMBER

NOTE:

Woven and barbed

To avoid trying to conform woven


wire to uneven terrain, space a minimum

of 10 barbed wires spaced about the same as horizontal wire on combination.

- I. Dimensions not labeled are in millimeters.
- 2. Attach barbed wires to tie off posts by wrapping around the post at least two times then wrap wires around itself five
- 3. To attach woven wire to tie off end post remove two or three vertical stay wires from the end of the fence. Place first complete vertical stay wire against post. Start at middle of horizontal line wires and wrap around end post at least two times and then wrap wire around itself five times.

Tie off on all cross hatched posts. End panels require brace wires only in one direction.


FENCE PANELS






3.76 mm wire stay Two 3.76 mm wires Rock or concrete spliced to stay and minimum mass 70 kg bottom wire -

PRIMARY DEADMAN




Fasten fence wire securely to the wings and arrange so that animals cannot pass


FENCE CONNECTION TO CATTLE GUARD



FENCE LAYOUT AT STOCKPASS



FENCE LAYOUT AT CHANGE IN R/W WIDTH



-Combination woven

and barbed wire

Single


FENCE LAYOUT AT CROSS FENCE CONNECTION


U.S. DEPARTMENT OF TRANSPORTATION FEDERAL HIGHWAY ADMINISTRATION WESTERN FEDERAL LANDS HIGHWAY DIVISION


METRIC DETAIL

MONTANA FENCING APPLICATIONS


	DETAIL APPROVED FOR USE 3/1996	DETAIL
ED:		
		WM619-62











Metal

TYPICAL SAG SECTION - TYPE I & 2 FENCES

3.61 mm-

wire stay

450


-Wood post

Rock or concrete -

minimum mass 45 kg

TYPE I **FENCES**

design no. 726-6-121/2 or 141/2 AASHTO M 279



TYPE 2

			Intermediate End Post -		
End, gate or corner Post	3.6 m post spacing	300 m maximum ►	√	375	
	Este n	Line post	(min.)		M
(min.) 1350 375	70.07 (70.17.2)	350	2300 mm	350 mm (min. Brace	Li
	ace 300	Ground Jine 3)O Brace	Brace Brace	
	— Concrete footing	05 4	Concrete footing	E C 2	Off
225 900 mr (min.)	450 square	Anchor plate s	450 quare	0006	
0 300			30	450 mm squa concrete foot	
≈ round			rour		

Anchor

Metal post -

Two 3.76 mm wires

spliced to stay

and bottom wire


	POST DIMENSIONS							
	WOOD		STEEL					
MEMBER	ROUND	SQUARE		kg/m				
MEMBER	Dia. of small end (min.)	SIZE nominal	SHAPE	(min.)	SIZE nominal			
Line post	75	75x75	Tee, channel or U-bar	1.98	U.S. Comm. Standard			
Drano	150 1.	150x150	Round pipe	<i>3.38</i>	approx. 40 mm OD			
Brace	150	150x150	Angle	3. 63	51x51x6.4 mm			
044	150	150x150	Round pipe	5 . 43	60.3 mm OD			
Other posts	150	ISUXISU	Angle	6.10	64x64x6.4 mm			

END, GATE OR CORNER BRACE

LINE BRACE


post

STEEL POSTS



NOTE:

- I. Dimensions not labeled are in millimeters.
- 2. Furnish either zinc coated (galvanized) or aluminum coated steel barbed wire. Fabricate zinc coated barbed wire from two strands of 2.51 mm steel wire with a Class 3 zinc coating and 2 point or 4 point barbs of 2.03 mm zinc coated wire. Fabricate aluminum coated barbed wire from two strands of 2.51 mm aluminum coated steel wire with 4 point barbs of 2.03 mm aluminum coated or aluminum alloy wire.
- 3. Furnish either zinc coated (galvanized) or aluminum coated steel wire fence fabric. If zinc coated fabric is furnished, use Grade 60 fabric with a Class 3 coating.
- 4. Furnish 3.05 mm tie wire or wire clamps for fasteners on metal posts and 3.76 mm by 40 mm long wire staples for wood posts. Galvanize wire stays, tie wire, wire loops, and wire clamps with a Class I zinc coating according to ASTM A 641.
- 5. Furnish either painted or galvanized steel fence posts for tee, channel or U bar shapes. Furnish galvanized steel round pipe or steel angle for posts and braces. Fit round pipe posts with snug-fitting galvanized metal caps. Fabricate steel line posts and angles from Type A steel according to AASHTO M 281. Fabricate steel pipe posts and braces according to AASHTO M 160.
- 6. Furnish Douglas fir, Western red cedar, Hemlock or Larch for fence posts, brace rails, and wood stays. Treat the posts and brace rails with creosote, pentachlorophenal, ACZA, or CCA, Type I, A, B, or C.




DETAIL A

U.S. DEPARTMENT OF TRANSPORTATION FEDERAL HIGHWAY ADMINISTRATION WESTERN FEDERAL LANDS HIGHWAY DIVISION			
METRIC DETAIL			
	WASHINGTON	FEN	CE
	DETAIL APPROVED FOR USE 3/1996		DETAIL
REVISED:			WM619-80

NOTE:


- I. Dimensions not labeled are in millimeters.
- 2. Manufacture gates of galvanized steel pipe not less than 25 mm nominal diameter (nominal mass 0.76 kg per linear meter) for frame and vertical braces. For each gate, provide two upright braces of the same material as the frame, spaced at I/3 points in the gate. Place steel wire fence fabric conforming to design no. IO47-6-I2½ in AASHTO M 279 on the face of the gate. Equip each gate with adjustable 9.5 mm diameter diagonal truss rods from corner to corner. Provide hinges and 2-way self closing latch of an approved rust proof mallable iron or steel.
- 3. Where a single opening requires two gates, provide an approved drop bar and fastener between the gates. Where two metal gates are installed in a single opening both gates will be measured for payment.
- 4. Approved alternate gates may be used.



METAL GATE BRACE

WOOD GATE BRACE

SINGLE METAL ENTRANCE GATE



METAL GATE BRACE WOOD GATE BRACE

DOUBLE METAL ENTRANCE GATE

U.S. DEPARTMENT OF TRANSPORTATION
FEDERAL HIGHWAY ADMINISTRATION
WESTERN FEDERAL LANDS HIGHWAY DIVISION

METRIC DETAIL

WASHINGTON GATE

DETAIL APPROVED FOR USE 3/1996

DETAIL WM619-81