

Appendix L

Appendix L
Field Data Sheets and Results

*Field Data Sheets and Results
for Radiation Areas*

***Asbestos Survey Field Data Sheet-Reactor Containment
 NS-Savannah
 Fort Eustis, VA***

| Sample ID | Material Description | Location | Condition | Friable? | |
|-------------------------|--|-------------------------------------|-----------|----------|----|
| | | | | Yes | No |
| NSS-RC-TSI-1A, -1B, -1C | Straight run pipe insulation associated with electrical cord | Secondary Containment- Deck A Level | Good | x | |
| NSS-RC-TSI-2A, -2B, -2C | Straight run pipe insulation associated with UV tanks (12" diameter) | Secondary Containment | Good | x | |
| NSS-RC-TSI-3A, -3B, -3C | Elbow pipe insulation associated with UV tanks (12" diameter) | Secondary Containment | Good | x | |
| NSS-RC-TSI-4A, -4B, -4C | Straight run pipe insulation associated with 4" diameter pipes | Primary and Secondary Containment | Good | x | |
| NSS-RC-TSI-5A, -5B, -5C | Elbow pipe insulation associated with 4" diameter pipes | Primary and Secondary Containment | Good | x | |
| NSS-RC-TSI-6A, -6B, -6C | Straight run pipe insulation associated with 2" diameter pipes | Primary and Secondary Containment | Good | x | |
| NSS-RC-TSI-7A, -7B, -7C | Elbow pipe insulation associated with 2" diameter pipes | Primary and Secondary Containment | Good | x | |

**Asbestos Survey Field Data Sheet-Reactor Containment
 NS-Savannah
 Fort Eustis, VA**

| Sample ID | Material Description | Location | Condition | Friable? | |
|----------------------------|--|-----------------------------------|-----------|----------|----|
| | | | | Yes | No |
| NSS-RC-TSI-8A, -8B, -8C | Straight run pipe insulation associated with 10" diameter pipes | Primary and Secondary Containment | Good | x | |
| NSS-RC-TSI-9A, -9B, -9C | Elbow pipe insulation associated with 10" diameter pipes | Primary and Secondary Containment | Good | x | |
| NSS-RC-TSI-10A, -10B, -10C | Straight run pipe insulation associated with waste tanks | Lower Secondary Containment | Good | x | |
| NSS-RC-TSI-11A, -11B, -11C | Elbow pipe insulation associated with waste tanks | Lower Secondary Containment | Good | x | |
| NSS-RC-TSI-12A, -12B, -12C | Insulation associated with the secondary heat exchanger (purple in color) | Primary Containment | Good | x | |
| NSS-RC-TSI-13A, -13B, -13C | Straight run pipe insulation associated with pressurizer system (red in color) | Primary Containment | Good | x | |
| NSS-RC-TSI-14A, -14B, -14C | Elbows insulation associated with pressurizer system (red in color) | Primary Containment | Good | x | |

**Asbestos Survey Field Data Sheet-Reactor Containment
 NS-Savannah
 Fort Eustis, VA**

| Sample ID | Material Description | Location | Condition | Friable? | |
|----------------------------|--|-----------------------------------|-----------|----------|----|
| | | | | Yes | No |
| NS-RC-TSI-15A, -15B, -15C | Insulation associated with pressurizer system tank (red in color) | Primary Containment | Good | x | |
| NSS-RC-TSI-16A, -16B, -16C | Straight run pipe insulation associated with secondary heat exchanger (purple in color) | Primary Containment | Good | x | |
| NSS-RC-TSI-17A, -17B, -17C | Elbow insulation associated with secondary heat exchanger (purple in color) | Primary Containment | Good | x | |
| NSS-RC-TSI-18A, -18B, -18C | Straight run pipe insulation associated with primary heat exchanger system (24" in diameter and red in color) | Primary Containment | Good | x | |
| NSS-RC-TSI-19A, -19B, -19C | Elbow pipe insulation associated with primary heat exchanger system (24" in diameter and red in color) | Primary Containment | Good | x | |
| NSS-RC-TSI-20A, -20B, -20C | Canvas wrap associated with fiberglass insulation | Primary and Secondary Containment | Good | x | |

Note: All pipes are recorded as total diameter of the pipe and the associated insulation.

Asbestos Survey Sampling Data (4-15 April 2005)
NS-Savannah - Fort Eustis, Virginia
ERM Work Order No. 0028178

| <i>Sample #</i> | <i>Material Description</i> | <i>Sample Location(s)⁽¹⁾</i> | <i>Friable? (2)</i> | <i>Condition⁽³⁾</i> | <i>PLM Results⁽⁴⁾ (Asbestos Percent/Type)</i> |
|-------------------------|--|---|-------------------------|--------------------------------|--|
| NSS-RC-TSI-1A, -1B, -1C | Straight run pipe insulation associated with electrical cord | Secondary Containment- Deck A Level | Yes | Good | NAD |
| NSS-RC-TSI-2A, -2B, -2C | Straight run pipe insulation associated with UV tanks (12" diameter) | Secondary Containment | Yes | Good | 25% -Chrysotile and Amosite |
| NSS-RC-TSI-3A, -3B, -3C | Elbow pipe insulation associated with UV tanks (12" diameter) | Secondary Containment | Yes | Good | 35%-Amosite |
| NSS-RC-TSI-4A, -4B, -4C | Straight run pipe insulation associated with 4" diameter pipes | Primary and Secondary Containment | Yes | Good | 20%-Chrysotile and Amosite |
| NSS-RC-TSI-5A, -5B, -5C | Elbow pipe insulation associated with 4" diameter pipes | Primary and Secondary Containment | Yes | Good | 35%-Chrysotile and Amosite |
| NSS-RC-TSI-6A, -6B, -6C | Straight run pipe insulation associated with 2" diameter pipes | Primary and Secondary Containment | Yes | Good | 20%-Chrysotile and Amosite |
| NSS-RC-TSI-7A, -7B, -7C | Elbow pipe insulation associated with 2" diameter pipes | Primary and Secondary Containment | Yes | Good | 25%-Chrysotile and Amosite |

Asbestos Survey Sampling Data (4-15 April 2005)
NS-Savannah - Fort Eustis, Virginia
ERM Work Order No. 0028178

| <i>Sample #</i> | <i>Material Description</i> | <i>Sample Location(s)⁽¹⁾</i> | <i>Friable? (2)</i> | <i>Condition⁽³⁾</i> | <i>PLM Results⁽⁴⁾ (Asbestos Percent/Type)</i> |
|----------------------------|--|---|-------------------------|--------------------------------|--|
| NSS-RC-TSI-8A, -8B, -8C | Straight run pipe insulation associated with 10" diameter pipes | Primary and Secondary Containment | Yes | Good | 20%-Chrysotile and Amosite |
| NSS-RC-TSI-9A, -9B, -9C | Elbow pipe insulation associated with 10" diameter pipes | Primary and Secondary Containment | Yes | Good | 30%-Chrysotile and Amosite |
| NSS-RC-TSI-10A, -10B, -10C | Straight run pipe insulation associated with waste tanks | Lower Secondary Containment | Yes | Good | 25%-Chrysotile and Amosite |
| NSS-RC-TSI-11A, -11B, -11C | Elbow pipe insulation associated with waste tanks | Lower Secondary Containment | Yes | Good | 45%-Chrysotile and Amosite |
| NSS-RC-TSI-12A, -12B, -12C | Insulation associated with the secondary heat exchanger (purple in color) | Primary Containment | Yes | Good | 25%-Chrysotile and Amosite |
| NSS-RC-TSI-13A, -13B, -13C | Straight run pipe insulation associated with pressurizer system (red in color) | Primary Containment | Yes | Good | 40%-Amosite |
| NSS-RC-TSI-14A, -14B, -14C | Elbows insulation associated with pressurizer system (red in color) | Primary Containment | Yes | Good | 15%-Chrysotile and Amosite |

Asbestos Survey Sampling Data (4-15 April 2005)
NS-Savannah - Fort Eustis, Virginia
ERM Work Order No. 0028178

| <i>Sample #</i> | <i>Material Description</i> | <i>Sample Location(s)⁽¹⁾</i> | <i>Friable? (2)</i> | <i>Condition⁽³⁾</i> | <i>PLM Results⁽⁴⁾ (Asbestos Percent/Type)</i> |
|----------------------------|--|---|-------------------------|--------------------------------|--|
| NSS-RC-TSI-15A, -15B, -15C | Insulation associated with pressurizer system tank (red in color) | Primary Containment | Yes | Good | 20%-Chrysotile and Amosite |
| NSS-RC-TSI-16A, -16B, -16C | Straight run pipe insulation associated with secondary heat exchanger (purple in color) | Primary Containment | Yes | Good | 25%-Amosite |
| NSS-RC-TSI-17A, -17B, -17C | Elbow insulation associated with secondary heat exchanger (purple in color) | Primary Containment | Yes | Good | 15%-Amosite |
| NSS-RC-TSI-18A, -18B, -18C | Straight run pipe insulation associated with primary heat exchanger system (24" in diameter and red in color) | Primary Containment | Yes | Good | 40%-Amosite |
| NSS-RC-TSI-19A, -19B, -19C | Elbow pipe insulation associated with primary heat exchanger system (24" in diameter and red in color) | Primary Containment | Yes | Good | 5%-Chrysotile and Amosite |
| NSS-RC-TSI-20A, -20B, -20C | Canvas wrap associated with fiberglass insulation | Primary and Secondary Containment | Yes | Good | 30%-Chrysotile |

Information presented is based upon observations made during an asbestos survey conducted by ERM on 4-15 April 2005.

"NAD" - No Asbestos Detected

(1) Only the general locations from which samples were obtained are included in this table. Material may also be located in other areas of the buildings (see Tables 1 and 2 of the survey report). Where possible, floor tile and drywall samples were taken in areas of pre-existing localized damage.

(2) A non-friable material can become friable if the condition of the material has significantly diminished or if its structural integrity has been compromised.

Asbestos Survey Sampling Data (4-15 April 2005)
NS-Savannah - Fort Eustis, Virginia
ERM Work Order No. 0028178

(3) The condition of a material reported herein is based upon observations made by an accredited inspector. The condition of floor tile mastics are assumed equal to that of the tile to which they are adhered.

(4) A material that contains greater than one percent asbestos is classified, and therefore must be managed as an ACM.

Note: All pipes are recorded as total diameter of the pipe and the associated insulation.

Table 1 *Materials Classified as Non-ACMs Based on Sampling Results (4-15 April 2005)
NS-Savannah – Fort Eustis, Virginia*

| <i>Sample #</i> | <i>Material Description</i> | <i>Material Location</i> |
|-------------------------|--|-------------------------------------|
| NSS-RC-TSI-1A, -1B, -1C | Straight run pipe insulation associated with electrical cord | Secondary Containment- Deck A Level |

Information presented is based upon observations made during an asbestos survey conducted by ERM on 4-15 April 2005. Materials that contain one percent or less asbestos are classified as non-asbestos-containing materials (non-ACMs).

Note: All pipes are recorded as total diameter of the pipe and the associated insulation.

Table 2 **Materials Classified as ACMs Based on Sampling Results (4-15 April 2005)**
NS-Savannah – Fort Eustis, Virginia

| <i>Sample #</i> | <i>Material Description⁽¹⁾</i> | <i>Material Locations</i> | <i>% Asbestos⁽²⁾ (Type)</i> | <i>Estimated Quantity⁽³⁾</i> |
|-------------------------|--|-----------------------------------|--|---|
| NSS-RC-TSI-2A, -2B, -2C | Straight run pipe insulation associated with UV tanks (12" diameter) | Secondary Containment | 25% -Chrysotile and Amosite | 100 linear feet |
| NSS-RC-TSI-3A, -3B, -3C | Elbow pipe insulation associated with UV tanks (12" diameter) | Secondary Containment | 35%-Amosite | 20 elbows |
| NSS-RC-TSI-4A, -4B, -4C | Straight run pipe insulation associated with 4" diameter pipes | Primary and Secondary Containment | 20%-Chrysotile and Amosite | 500 linear feet |
| NSS-RC-TSI-5A, -5B, -5C | Elbow pipe insulation associated with 4" diameter pipes | Primary and Secondary Containment | 35%-Chrysotile and Amosite | 50 elbows |
| NSS-RC-TSI-6A, -6B, -6C | Straight run pipe insulation associated with 2" diameter pipes | Primary and Secondary Containment | 20%-Chrysotile and Amosite | 500 linear feet |
| NSS-RC-TSI-7A, -7B, -7C | Elbow pipe insulation associated with 2" diameter pipes | Primary and Secondary Containment | 25%-Chrysotile and Amosite | 20 elbows |
| NSS-RC-TSI-8A, -8B, -8C | Straight run pipe insulation associated with 10" diameter pipes | Primary and Secondary Containment | 20%-Chrysotile and Amosite | 800 linear feet |
| NSS-RC-TSI-9A, -9B, -9C | Elbow pipe insulation associated with 10" diameter pipes | Primary and Secondary Containment | 30%-Chrysotile and Amosite | 70 elbows |

Table 2 *Materials Classified as ACMs Based on Sampling Results (4-15 April 2005)*
NS-Savannah – Fort Eustis, Virginia (continued)

| <i>Sample #</i> | <i>Material Description⁽¹⁾</i> | <i>Material Locations</i> | <i>% Asbestos⁽²⁾ (Type)</i> | <i>Estimated Quantity⁽³⁾</i> |
|----------------------------|---|-----------------------------|--|---|
| NSS-RC-TSI-10A, -10B, -10C | Straight run pipe insulation associated with waste tanks | Lower Secondary Containment | 25%-Chrysotile and Amosite | 200 linear feet |
| NSS-RC-TSI-11A, -11B, -11C | Elbow pipe insulation associated with waste tanks | Lower Secondary Containment | 45%-Chrysotile and Amosite | 40 elbows |
| NSS-RC-TSI-12A, -12B, -12C | Insulation associated with the secondary heat exchanger (purple in color) | Primary Containment | 25%-Chrysotile and Amosite | 1600 square feet |
| NSS-RC-TSI-13A, -13B, -13C | Straight run pipe insulation associated with pressurizer system (red in color) | Primary Containment | 40%-Amosite | 150 linear feet |
| NSS-RC-TSI-14A, -14B, -14C | Elbows insulation associated with pressurizer system (red in color) | Primary Containment | 15%-Chrysotile and Amosite | 10 elbows |
| NSS-RC-TSI-15A, -15B, -15C | Insulation associated with pressurizer system tank (red in color) | Primary Containment | 20%-Chrysotile and Amosite | 1500 square feet |
| NSS-RC-TSI-16A, -16B, -16C | Straight run pipe insulation associated with secondary heat exchanger (purple in color) | Primary Containment | 25%-Amosite | 1,000 linear feet |
| NSS-RC-TSI-17A, 17B, -17C | Elbow insulation associated with secondary heat exchanger (purple in | Primary Containment | 15%-Amosite | 60 elbows |

Table 2 *Materials Classified as ACMs Based on Sampling Results (4-15 April 2005)*
NS-Savannah – Fort Eustis, Virginia (continued)

| <i>Sample #</i> | <i>Material Description⁽¹⁾</i> | <i>Material Locations</i> | <i>% Asbestos⁽²⁾ (Type)</i> | <i>Estimated Quantity⁽³⁾</i> |
|----------------------------|--|-----------------------------------|--|---|
| | color) | | | |
| NSS-RC-TSI-18A, -18B, -18C | Straight run pipe insulation associated with primary heat exchanger system (24" in diameter and red in color) | Primary Containment | 40%-Amosite | 500 linear feet |
| NSS-RC-TSI-19A, -19B, -19C | Elbow pipe insulation associated with primary heat exchanger system (24" in diameter and red in color) | Primary Containment | 5%-Chrysotile and Amosite | 60 elbows |
| NSS-RC-TSI-20A, -20B, -20C | Canvas wrap associated with fiberglass insulation | Primary and Secondary Containment | 30%-Chrysotile | 2,000 linear feet |

Materials that contain greater than one percent asbestos are classified as asbestos-containing materials (ACMs).

Information presented is based upon observations made during a building survey conducted by ERM from 4-15 April 2005.

- (1) The friability and condition of ACMs are reported as observed on 4-15 April 2005. A non-friable ACM can become friable if the condition of the material has significantly diminished or if its structural integrity has been compromised.
- (2) Asbestos-content determined by Polarized-light Microscopy (PLM) by AMA Analytical Services, Inc. of Lanham, Maryland.
- (3) Quantities are presented as plus or minus 50 percent.

Note: All pipes are recorded as total diameter of the pipe and the associated insulation.

Client: Environmental Resource Management, Inc. Job Name: NS - Savannah Chain Of Custody: 136891
 Address: 200 Harry S. Truman Drive, Suite 400 Job Location: Not Provided Date Analyzed: 4/26/2005
 Annapolis, Maryland 21401 Job Number: 0028178 Person Submitting: Matt Baxter
 P.O. Number: Not Provided

Attention: Matt Baxter

Summary of Polarized Light Microscopy

| AMA Sample Number | Client Sample # | Total Asbestos | Chrysotile Percent | Amosite Percent | Crocidolite Percent | Other Asbestos Percent | Mineral Wool Percent | Fiberglass Percent | Organic Percent | Synthetic Percent | Other Percent | Particulate Percent | Sample Color | Homogeneity | Analyst ID | Comments |
|-------------------|-----------------|----------------|--------------------|-----------------|---------------------|------------------------|----------------------|--------------------|-----------------|-------------------|---------------|---------------------|--------------|-------------|------------|-----------------------------------|
| 0533813 | NSS-RC-TSI-1A | NAD | -- | -- | -- | -- | -- | -- | 70 | -- | -- | 30 | Brown | Homogeneous | CK | |
| 0533814 | NSS-RC-TSI-1B | NAD | -- | -- | -- | -- | -- | -- | 70 | -- | -- | 30 | Brown | Homogeneous | CK | |
| 0533815 | NSS-RC-TSI-1C | NAD | -- | -- | -- | -- | -- | -- | 70 | -- | -- | 30 | Brown | Homogeneous | CK | |
| 0533816 | NSS-RC-TSI-2A | 25 | 5 | 20 | -- | -- | -- | -- | -- | -- | -- | 75 | Off-White | Homogeneous | CK | |
| 0533817 | NSS-RC-TSI-2B | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533818 | NSS-RC-TSI-2C | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533819 | NSS-RC-TSI-3A | 35 | -- | 35 | -- | -- | -- | -- | -- | -- | -- | 65 | Gray | Homogeneous | CK | |
| 0533820 | NSS-RC-TSI-3B | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533821 | NSS-RC-TSI-3C | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533822 | NSS-RC-TSI-4A | 20 | 5 | 15 | -- | -- | -- | -- | -- | -- | -- | 80 | Off-White | Homogeneous | CK | |
| 0533823 | NSS-RC-TSI-4B | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533824 | NSS-RC-TSI-4C | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client. NVLAP Accreditation applies only to polarized light microscopy of bulk samples and transmission electron microscopy of AHERA air samples. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government.

CERTIFICATE OF ANALYSIS



Client: Environmental Resource Management, Inc. Job Name: NS - Savannah
 Address: 200 Harry S. Truman Drive, Suite 400 Job Location: Not Provided
 Annapolis, Maryland 21401 Job Number: 0028178
 P.O. Number: Not Provided

Chain Of Custody: 136891
 Date Analyzed: 4/26/2005
 Person Submitting: Matt Baxter

Attention: Matt Baxter

Summary of Polarized Light Microscopy

| AMA Sample Number | Client Sample # | Total Asbestos | Chrysotile Percent | Amosite Percent | Crocidolite Percent | Other Asbestos Percent | Mineral Wool Percent | Fiberglass Percent | Organic Percent | Synthetic Percent | Other Percent | Particulate Percent | Sample Color | Homogeneity | Analyst ID | Comments |
|-------------------|-----------------|----------------|--------------------|-----------------|---------------------|------------------------|----------------------|--------------------|-----------------|-------------------|---------------|---------------------|--------------|-------------|------------|-----------------------------------|
| 0533825 | NSS-RC-TSI-5A | 35 | 30 | 5 | -- | -- | -- | -- | -- | -- | -- | 65 | Gray | Homogeneous | CK | |
| 0533826 | NSS-RC-TSI-5B | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533827 | NSS-RC-TSI-5C | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533828 | NSS-RC-TSI-6A | 20 | 6 | 14 | -- | -- | -- | -- | -- | -- | -- | 80 | Off-White | Homogeneous | CK | |
| 0533829 | NSS-RC-TSI-6B | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533830 | NSS-RC-TSI-6C | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533831 | NSS-RC-TSI-7A | 25 | 10 | 15 | -- | -- | -- | -- | -- | -- | -- | 75 | Off-White | Homogeneous | CK | |
| 0533832 | NSS-RC-TSI-7B | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533833 | NSS-RC-TSI-7C | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533834 | NSS-RC-TSI-8A | 20 | 10 | 10 | -- | -- | -- | -- | -- | -- | -- | 80 | Gray | Homogeneous | CK | |
| 0533835 | NSS-RC-TSI-8B | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533836 | NSS-RC-TSI-8C | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client. NVLAP Accreditation applies only to polarized light microscopy of bulk samples and transmission electron microscopy of AHERA air samples. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government.

All rights reserved. AMA Analytical Services, Inc.

AMA AIHA (00863), NVLAP (101143), NY ELAP (10920) Accredited Laboratory

CERTIFICATE OF ANALYSIS



Client: Environmental Resource Management, Inc. Job Name: NS - Savannah
 Address: 200 Harry S. Truman Drive, Suite 400 Job Location: Not Provided
 Annapolis, Maryland 21401 Job Number: 0028178
 P.O. Number: Not Provided

Chain Of Custody: 136891
 Date Analyzed: 4/26/2005
 Person Submitting: Matt Baxter

Attention: Matt Baxter

Summary of Polarized Light Microscopy

| AMA Sample Number | Client Sample # | Total Asbestos | Chrysotile Percent | Amosite Percent | Crocidolite Percent | Other Asbestos Percent | Mineral Wool Percent | Fiberglass Percent | Organic Percent | Synthetic Percent | Other Percent | Particulate Percent | Sample Color | Homogeneity | Analyst ID | Comments |
|-------------------|-----------------|----------------|--------------------|-----------------|---------------------|------------------------|----------------------|--------------------|-----------------|-------------------|---------------|---------------------|--------------|-------------|------------|-----------------------------------|
| 0533837 | NSS-RC-TSI-9A | 35 | 30 | 3 | 2 | -- | -- | -- | -- | -- | -- | 65 | Gray | Homogeneous | CK | |
| 0533838 | NSS-RC-TSI-9B | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533839 | NSS-RC-TSI-9C | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533840 | NSS-RC-TSI-10A | 25 | 5 | 20 | -- | -- | -- | -- | -- | -- | -- | 75 | Off-White | Homogeneous | CK | |
| 0533841 | NSS-RC-TSI-10B | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533842 | NSS-RC-TSI-10C | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533843 | NSS-RC-TSI-11A | 45 | 40 | 5 | -- | -- | -- | -- | -- | -- | -- | 55 | Gray | Homogeneous | CK | |
| 0533844 | NSS-RC-TSI-11B | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533845 | NSS-RC-TSI-11C | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533846 | NSS-RC-TSI-12A | 25 | 15 | 10 | -- | -- | 35 | -- | -- | -- | -- | 40 | Beige | Homogeneous | CK | |
| 0533847 | NSS-RC-TSI-12B | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533848 | NSS-RC-TSI-12C | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client. NVLAP Accreditation applies only to polarized light microscopy of bulk samples and transmission electron microscopy of AHERA air samples. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government.

Client: Environmental Resource Management, Inc. Job Name: NS - Savannah Chain Of Custody: 136891
 Address: 200 Harry S. Truman Drive, Suite 400 Job Location: Not Provided Date Analyzed: 4/26/2005
 Annapolis, Maryland 21401 Job Number: 0028178 Person Submitting: Matt Baxter
 P.O. Number: Not Provided

Attention: Matt Baxter

Summary of Polarized Light Microscopy

| AMA Sample Number | Client Sample # | Total Asbestos | Chrysotile Percent | Amosite Percent | Crocidolite Percent | Other Asbestos Percent | Mineral Wool Percent | Fiberglass Percent | Organic Percent | Synthetic Percent | Other Percent | Particulate Percent | Sample Color | Homogeneity | Analyst ID | Comments |
|-------------------|-----------------|----------------|--------------------|-----------------|---------------------|------------------------|----------------------|--------------------|-----------------|-------------------|---------------|---------------------|--------------|-------------|------------|-----------------------------------|
| | | | | | | | | | | | | | | | | |
| 0533849 | NSS-RC-TSI-13A | 40 | -- | 40 | -- | -- | -- | -- | -- | -- | -- | 60 | Gray | Homogeneous | CK | |
| 0533850 | NSS-RC-TSI-13B | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533851 | NSS-RC-TSI-13C | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533852 | NSS-RC-TSI-14A | 15 | 3 | 12 | -- | -- | 5 | -- | -- | -- | -- | 80 | Gray | Homogeneous | CK | |
| 0533853 | NSS-RC-TSI-14B | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533854 | NSS-RC-TSI-14C | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533855 | NSS-RC-TSI-15A | 20 | 15 | 5 | -- | -- | 15 | -- | -- | -- | -- | 65 | Gray | Homogeneous | CK | |
| 0533856 | NSS-RC-TSI-15B | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533857 | NSS-RC-TSI-15C | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533858 | NSS-RC-TSI-16A | 25 | -- | 25 | -- | -- | -- | -- | -- | -- | -- | 75 | Gray | Homogeneous | CK | |
| 0533859 | NSS-RC-TSI-16B | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533860 | NSS-RC-TSI-16C | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client. NVLAP Accreditation applies only to polarized light microscopy of bulk samples and transmission electron microscopy of AIHRA air samples. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government.

Client: Environmental Resource Management, Inc. **Job Name:** NS - Savannah **Chain Of Custody:** 136891
Address: 200 Harry S. Truman Drive, Suite 400 **Job Location:** Not Provided **Date Analyzed:** 4/26/2005
 Annapolis, Maryland 21401 **Job Number:** 0028178 **Person Submitting:** Matt Baxter
P.O. Number: Not Provided

Attention: Matt Baxter

Summary of Polarized Light Microscopy

| AMA Sample Number | Client Sample # | Total Asbestos | Chrysotile Percent | Amosite Percent | Crocidolite Percent | Other Asbestos Percent | Mineral Wool Percent | Fiberglass Percent | Organic Percent | Synthetic Percent | Other Percent | Particulate Percent | Sample Color | Homogeneity | Analyst ID | Comments |
|-------------------|-----------------|----------------|--------------------|-----------------|---------------------|------------------------|----------------------|--------------------|-----------------|-------------------|---------------|---------------------|--------------|-------------|------------|-----------------------------------|
| 0533861 | NSS-RC-TSI-17A | 15 | -- | 15 | -- | -- | -- | -- | -- | -- | -- | 85 | Gray | Homogeneous | CK | |
| 0533862 | NSS-RC-TSI-17B | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533863 | NSS-RC-TSI-17C | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533864 | NSS-RC-TSI-18A | 40 | -- | 40 | -- | -- | -- | -- | -- | -- | -- | 60 | Gray | Homogeneous | CK | |
| 0533865 | NSS-RC-TSI-18B | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533866 | NSS-RC-TSI-18C | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533867 | NSS-RC-TSI-19A | 5 | 3 | 2 | -- | -- | 55 | -- | -- | -- | -- | 40 | Gray | Homogeneous | CK | |
| 0533868 | NSS-RC-TSI-19B | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533869 | NSS-RC-TSI-19C | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533870 | NSS-RC-TSI-20A | 30 | 30 | -- | -- | -- | -- | -- | 30 | -- | -- | 40 | Off-White | Homogeneous | CK | |
| 0533871 | NSS-RC-TSI-20B | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |
| 0533872 | NSS-RC-TSI-20C | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | -- | | | CK | Sample Not Analyzed-Positive Stop |

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client. NVLAP Accreditation applies only to polarized light microscopy of bulk samples and transmission electron microscopy of AHERA air samples. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government.

CERTIFICATE OF ANALYSIS



Client: Environmental Resource Management, Inc.
Address: 200 Harry S. Truman Drive, Suite 400
 Annapolis, Maryland 21401

Job Name: NS - Savannah
Job Location: Not Provided
Job Number: 0028178
P.O. Number: Not Provided

Chain Of Custody: 136891
Date Analyzed: 4/26/2005
Person Submitting: Matt Baxter

Attention: Matt Baxter

Summary of Polarized Light Microscopy

| AMA Sample Number | Client Sample # | Total Asbestos | Chrysotile Percent | Amosite Percent | Crocidolite Percent | Other Asbestos Percent | Mineral Wool Percent | Fiberglass Percent | Organic Percent | Synthetic Percent | Other Percent | Particulate Percent | Sample Color | Homogeneity | Analyst ID | Comments |
|-------------------|-----------------|----------------|--------------------|-----------------|---------------------|------------------------|----------------------|--------------------|-----------------|-------------------|---------------|---------------------|--------------|-------------|------------|----------|
|-------------------|-----------------|----------------|--------------------|-----------------|---------------------|------------------------|----------------------|--------------------|-----------------|-------------------|---------------|---------------------|--------------|-------------|------------|----------|

The following footnotes only apply to those samples which the total asbestos result is flagged with a note number.

- 1 TEM RECOMMENDATION - Please note, due to resolution limitations with optical microscopy and/or interference from matrix components of this sample, results which are reported via PLM as negative or trace (<1%) for asbestos may contain a significant quantity of asbestos. It is recommended that the additional analytical technique of TEM be used to check for asbestos fibers below the resolution limits of optical microscopy.
- 2 MATRIX REDUCTION RECOMMENDATION - Please note, due to interference from the matrix components of this sample, results which are reported via PLM as negative or trace (<1%) for asbestos may contain a significant quantity of asbestos which is obscured from view. It is recommended that the additional preparation technique of gravimetric reduction be performed on this sample to minimize the obscuring effects of matrix components, followed by reanalysis by PLM and/or TEM.

Analysis Method - EPA/600/R-93/116 dated July 1993

NAD = "No Asbestos Detected" TR = "Trace equals less than 1% of this component"

Crystal Kellam
 Crystal Kellam

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client. NVLAP Accreditation applies only to polarized light microscopy of bulk samples and transmission electron microscopy of AHERA air samples. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government.

*Field Data Sheets for Non-
Radiation Areas*

***Asbestos Survey Field Data Sheet-Navigation Bridge Deck
 NS-Savannah
 Fort Eustis, VA***

| Sample ID | Material Description | Location | Condition | Friable? | |
|--------------------------|--|--|-----------|----------|----|
| | | | | Yes | No |
| NSS-NBD-FT-1A, -1B, -1C | Green ,9"x9" floor tile with white lines and associated mastics | Throughout Navigation Bridge Deck | Fair | | x |
| NSS-NBD-MM-2A, -2B, -2C | White wall board with pinhole pattern | Navigation Bridge Deck-Gyro Radar Room | Good | | x |
| NSS-NBD-TSI-3A, -3B, -3C | Straight run pipe insulation associated with piping above ceilings | Navigation Bridge Deck above ceiling | Good | x | |
| NSS-NBD-TSI-4A, -4B, -4C | Elbow pipe insulation associated with piping above ceiling | Navigation Bridge Deck above ceiling | Good | x | |
| NSS-NBD-MM-5A, -5B, -5C | White, drywall associated with walls (1' thickness) | Navigation Bridge Deck Staterooms | Good | x | |
| NSS-NBD-MM-6A, -6B, -6C | White, drywall associated with ceiling | Navigation Bridge Deck Staterooms | Good | x | |
| NSS-NBD-MM-7A, -7B, -7C | Brown mastic associated with baseboard molding | Throughout Navigation Bridge Deck | Good | | x |

*Asbestos Survey Field Data Sheet-Navigation Bridge Deck
 NS-Savannah
 Fort Eustis, VA*

| Sample ID | Material Description | Location | Condition | Friable? | |
|-----------------------------|--|---------------------------------------|-----------|----------|----|
| | | | | Yes | No |
| NSS-NBD-MM-8A, -8B, -8C | White sub-floor (baseboard) | Throughout Navigation Bridge Deck | Good | x | |
| NSS-NBD-TSI-9A, -9B, -9C | Straight run pipe insulation associated with generator | Navigation Bridge Deck-Generator Room | Good | x | |
| NSS-NBD-TSI-10A, -10B, -10C | Elbow pipe insulation associated with generator | Navigation Bridge Deck-Generator Room | Good | x | |

Due to time limitations, physical samples were not taken of this deck. The materials that were observed are similar to materials that are located on other decks of the ship. The table identifies samples that ERM would have sampled had time permitted.

Note: All pipes are recorded as total diameter of the pipe and the associated insulation.

Asbestos Survey Field Data Sheet-Boat Deck
NS-Savannah
Fort Eustis, VA

| Sample ID | Material Description | Location | Condition | Friable? | |
|-------------------------------|--|-------------------------|-----------|----------|----|
| | | | | Yes | No |
| NSS-BoatDeck-FT-1A, -1B, -1C | Black 18"x18" floor tile with white specks and associated mastic | Boat Deck stairwell | Good | | x |
| NSS-BoatDeck-MM-2A, -2B, -2C | White, drywall associated with the wall (1' thickness) | Boat Deck Cabins | Good | x | |
| NSS-BoatDeck-MM-3A, -3B, -3C | White, drywall associated with ceiling (1/2" thickness) | Boat Deck Staterooms | Good | x | |
| NSS-BoatDeck-MM-4A, -4B, -4C | White sub-floor (baseboard) | Throughout Boat Deck | Good | | x |
| NSS-BoatDeck-FT-5A, -5B, -5C | Green, 9x9 floor tile with white lines and associated mastic | Throughout Boat Deck | Poor | | x |
| NSS-BoatDeck-MM-6A, -6B, -6C | Brown mastic associated with baseboard molding | Throughout Boat Deck | Good | | x |
| NSS-BoatDeck-TSI-7A, -7B, -7C | Straight run pipe insulation above ceiling | Boat Deck above ceiling | Good | x | |

*Asbestos Survey Field Data Sheet-Boat Deck
NS-Savannah
Fort Eustis, VA*

| Sample ID | Material Description | Location | Condition | Friable? | |
|-------------------------------|-----------------------|-------------------------|-----------|----------|----|
| | | | | Yes | No |
| NSS-BoatDeck-TSI-8A, -8B, -8C | Elbow pipe insulation | Boat Deck above ceiling | Good | x | |

Note: All pipes are recorded as total diameter of the pipe and the associated insulation.

**Asbestos Survey Field Data Sheet-Promenade Deck
 NS-Savannah
 Fort Eustis, VA**

| Sample ID | Material Description | Location | Condition | Friable? | |
|------------------------------|---|--|-----------|----------|----|
| | | | | Yes | No |
| NSS-PromDeck-FT-1A, -1B, -1C | Dark green, 18" x18" floor tile with white lines and associated mastics | Promenade Deck-Veranda | Good | | x |
| NSS-PromDeck-FT-2A, -2B, -2C | White, 18"x18" floor tile with white lines and associated mastics | Promenade Deck-Veranda | Good | | x |
| NSS-PromDeck-MM-3A, -3B, -3C | Black sub-floor (baseboard) | Promenade Deck-Throughout floor | Good | | x |
| NSS-PromDeck-MM-4A, -4B, -4C | White, 4'x4' ceiling panels with pinholes | Promenade Deck-Veranda and Main Lounge | Good | | x |
| NSS-PromDeck-MM-5A, -5B, -5C | White drywall (1/2" thickness) associated with walls | Promenade Deck-Veranda | Good | x | |
| NSS-PromDeck-MM-6A, -6B, -6C | White drywall (1" thickness) associated with ceilings | Promenade Deck-Veranda | Good | x | |
| NSS-PromDeck-MM-7A, -7B, -7C | Brown mastic associated with baseboard molding | Promenade Deck-Veranda and Main Lounge | Good | | x |

Note: All pipes are recorded as total diameter of the pipe and the associated insulation.

*Asbestos Survey Field Data Sheet-Deck A
 NS-Savannah
 Fort Eustis, VA*

| Sample ID | Material Description | Location | Condition | Friable? | |
|---------------------------|---|---|-----------|----------|----|
| | | | | Yes | No |
| NSSDeckA-FT-1A, -1B, -1C | Green, 9"x9" floor tile with white lines and associated mastic | Deck A- Throughout infirmary | Good | | x |
| NSSDeckA-TSI-2A, -2B, -2C | Straight run pipe insulation | Deck A- Piping located above ceiling | Good | x | |
| NSSDeckA-TSI-3A, -3B, -3C | Elbow pipe insulation | Deck A- Piping located above ceiling | Good | x | |
| NSSDeckA-FT-4A, -4B, -4C | Brown, 9"x9" floor tile with white specks and associated mastic | Deck A-Throughout hallways adjacent to staterooms | Good | | x |
| NSSDeckA-FT-5A, -5B, -5C | Black, 9"x9" floor tile with white specks and associated mastic | Deck A-Throughout hallways adjacent to staterooms | Good | | x |
| NSSDeckA-FT-6A, -6B, -6C | Light brown, 9"x9" floor tile with white specks and associated mastic | Deck A-Throughout hallways adjacent to staterooms | Good | | x |
| NSSDeckA-FT-7A, -7B, -7C | Tan, "9x9" floor tile with white brown specks and associated mastic | Deck A-Throughout hallways adjacent to staterooms | Good | | x |

***Asbestos Survey Field Data Sheet-Deck A
 NS-Savannah
 Fort Eustis, VA***

| Sample ID | Material Description | Location | Condition | Friable? | |
|-----------------------------|---|---------------------------------------|-----------|----------|----|
| | | | | Yes | No |
| NSSDeckA-MM-8A, -8B, -8C | White drywall (1/2" thickness) associated with ceilings | Deck A | Good | x | |
| NSSDeckA-MM-9A, -9B, -9C | White drywall (1" thickness) associated with walls | Deck A | Good | x | |
| NSSDeckA-FT-10A, -10B, -10C | White, 9"x9" floor tile and associated mastic | Deck A- Main Lobby | Good | | x |
| NSSDeckA-FT-11A, -11B, -11C | Gray, 18"x18" floor tile and associated mastic | Deck A -Main Lobby | Good | | x |
| NSSDeckA-FT-12A, -12B, -12C | Black, 9"x9" floor tile and associated mastic | Deck A- Main Lobby | Good | | x |
| NSSDeckA-CT-13A, -13B, -13C | White, 2'x3' ceiling panel with pinholes | Deck A- Main Lobby | Good | | x |
| NSSDeckA-MM14A, -14B, -14C | Black sub-floor (baseboard) | Deck A - Main Lobby and forward areas | Good | | x |

*Asbestos Survey Field Data Sheet-Deck A
 NS-Savannah
 Fort Eustis, VA*

| Sample ID | Material Description | Location | Condition | Friable? | |
|-----------------------------|--|--|-----------|----------|----|
| | | | | Yes | No |
| NSSDeckA-FT-15A, -15B, -15C | Tan, 9"x9" floor tile and associated mastic | Deck A- Lab Assistant Office | Poor | | x |
| NSSDeckA-FT-16A, -16B, -16C | Orange, 9"x9" floor tile and associated mastic | Deck A- Barber Shop | Good | | x |
| NSSDeckA-FT-17A, -17B, -17C | Brown, 9" x9" floor tile with black and white specks and associated mastic | Deck A- Port and starboard side stairwells | Fair | | x |
| NSSDeckA-FT-18A, -18B, -18C | Tan, 9" x9" floor tile with brown specks and associated mastic | Deck A- Port and starboard side stairwells | Fair | | x |
| NSSDeckA-FT-19A, -19B, -19C | Tan, 9" x9" floor tile with brown specks and associated mastic | Deck A- Staterooms rear of Main Lobby and Pursers Office | Fair | | x |
| NSSDeckA-MM-20A, -20B, -20C | Brown mastic associated with baseboard molding | Deck A | Good | | x |
| NSSDeckA-MM-21A, -21B, -21C | White sub-floor (baseboard) | Deck A- Area rear of Main Lobby | Good | x | |
| NSSDeckA-FT-22A, -22B, -22C | Red, 9"x9" floor tile with white lines and associated mastic | Deck A- Forward port side stairwell | Good | | x |

Note: All pipes are recorded as total diameter of the pipe and the associated insulation.

***Asbestos Survey Field Data Sheet-Deck B
 NS-Savannah
 Fort Eustis, VA***

| Sample ID | Material Description | Location | Condition | Friable? | |
|--------------------------------|---|---|-----------|----------|----|
| | | | | Yes | No |
| NSS-B Deck-FT-1A, -1B, -1C | Blue, 9"x9" floor tile with white lines | Deck B- Dining Room | Fair | | x |
| NSS-B Deck-Mastic-2A, -2B, -2C | Mastic associated with blue 9"x9" floor tile with white lines | Deck B-Dining Room | Fair | | x |
| NSS-B Deck-FT-3A, -3B, -3C | White, 18" x18" floor tile | Deck B-Dining Room | Fair | | x |
| NSS-B Deck-Mastic-4A, -4B, -4C | Mastic associated with 18" x18" floor tile | Deck B-Dining Room | Fair | | x |
| NSS-B Deck-Mastic-5A, -5B, -5C | Brown mastic associated with baseboard molding | Deck B-Dining Room | Fair | | x |
| NSS-B Deck- FT-6A, -6B, -6C | Light green, 9" x9" floor tile with white specks | Deck B- Stateroom hallway rear of Cargo Loading Passage | Fair | | x |
| NSS-B Deck-Mastic-7A, -7B, -7C | Mastic associated with light green 9x9 floor tile with white specks | Deck B- Stateroom hallway rear of Cargo Loading Passage | Fair | | x |

*Asbestos Survey Field Data Sheet-Deck B
 NS-Savannah
 Fort Eustis, VA*

| Sample ID | Material Description | Location | Condition | Friable? | |
|-------------------------------------|---|--|-----------|----------|----|
| | | | | Yes | No |
| NSS-B Deck-MM-8A, -8B, -8C | Brown mastic associated with stair treads | Deck-B Dining Room | Good | | x |
| NSS-B Deck-Fiberboard-9A, -9B, -9C | White fiberboard padding beneath floor tile | Deck B- Area rear of Cargo Loading Passage | Fair | x | |
| NSS-B Deck-FT-10A, -10B, -10C | Dark green, 9" x9" floor tile with white lines | Deck B- Area rear of Cargo Loading Passage | Fair | | x |
| NSS-B Deck-Mastic-11A, -11B, -11C | Mastic associated with 9" x9" floor tile with white lines | Deck B- Area rear of Cargo Loading Passage | Fair | | x |
| NSS-B Deck-FT-12A, -12B, -12C | Gray, 9"x9" floor tiles with specks | Deck B- Throughout area forward of Cargo Loading Passage | Fair | | x |
| NSS-B Deck-Mastic-13A, -13B, -13C | Mastic associated with gray 9" x9" floor tile with specks | Deck B- Throughout area forward of Cargo Loading Passage | Fair | | x |
| NSS-B Deck-Subfloor-14A, -14B, -14C | Gray sub-floor (baseboard) | Deck B- Forward of Cargo Loading Passage | Fair | | x |

Asbestos Survey Field Data Sheet-Deck B
NS-Savannah
Fort Eustis, VA

| Sample ID | Material Description | Location | Condition | Friable? | |
|--------------------------------|---|---|-----------|----------|----|
| | | | | Yes | No |
| NSS-B Deck-MM-15A, -15B, -15C | White drywall (1/2" thickness) associated with ceiling | Deck B-Throughout staterooms and hallways | Fair | x | |
| NSS-B Deck-FT-16A, -16B, -16C | Tan, 9" x9" floor tile with brown lines and associated mastic | Deck B- Starboard side stateroom forward of the Cargo Loading Passage | Fair | | x |
| NSS-B Deck-MM-17A, -17B, -17C | White, 18"x18" ceiling panels with pinholes | Deck B- Dining room and office rear of Cargo Loading Passage | Good | | x |
| NSS-B Deck-TSI-18A, -18B, -18C | Straight run pipe insulation | Deck B- Piping that is located above ceiling | Good | x | |
| NSS-B Deck-TSI-19A, -19B, -19C | Elbow pipe insulation | Deck B- Piping that Is located above ceiling | Good | x | |
| NSS-B Deck-MM-20A, -20B, -20C | White drywall (1" thickness) associated with walls | Deck B - Throughout staterooms and hallways | Good | x | |

Note: All pipes are recorded as total diameter of the pipe and the associated insulation.

*Asbestos Survey Field Data Sheet-Deck C
 NS-Savannah
 Fort Eustis, VA*

| Sample ID | Material Description | Location | Condition | Friable? | |
|---------------------------|--|--------------------------------|-----------|----------|----|
| | | | | Yes | No |
| NSSDeckC-FT-1A, -1B, -1C | Tan, 9"x9" floor tiles with white lines and associated mastics | Deck C-Staterooms | Good | | x |
| NSSDeckC-MM-2A, -2B, -2C | White drywall (1/2" thickness) associated with state room ceiling | Deck C-Staterooms | Good | x | |
| NSSDeckC-MM-3A, -3B, -3C | White drywall (1" thickness) associated with state room walls | Deck C-Staterooms and Hallways | Good | x | |
| NSSDeckC-TSI-4A, -4B, -4C | Straight run pipe insulation associated with pipes above ceiling | Deck C | Good | x | |
| NSSDeckC-TSI-5A, -5B, -5C | Elbow pipe insulation associated with pipes above ceiling | Deck C | Good | x | |
| NSSDeckC-FT-6A, -6B, -6C | Brown, 9" x9" floor tile with black specks and associated mastic | Deck C- Hallways | Good | | x |
| NSSDeckC-FT-7A, -7B, -7C | Tan, 9" x9" floor tile with black and white specks and associated mastic | Deck C- Hallways | Good | | x |

Asbestos Survey Field Data Sheet-Deck C
NSS-Savannah
Fort Eustis, VA

| Sample ID | Material Description | Location | Condition | Friable? | |
|---------------------------|---|------------------------------|-----------|----------|----|
| | | | | Yes | No |
| NSSDeckC-TSI-8A, -8B, -8C | Straight run pipe insulation associated with piping | Deck C - Carpenters workshop | Good | x | |
| NSSDeckC-TSI-9A, -9B, -9C | Elbow pipe insulation associated with piping | Deck C- Carpenters workshop | Good | x | |

Note: All pipes are recorded as total diameter of the pipe and the associated insulation.

***Asbestos Survey Field Data Sheet-14 Flat and Deck D
 NS-Savannah
 Fort Eustis, VA***

| Sample ID | Material Description | Location | Condition | Friable? | |
|----------------------------|--|--------------------------|-----------|----------|----|
| | | | | Yes | No |
| NSS14Flat-TSI-1A, -1B, -1C | Straight run pipe insulation associated with heating system | Deck 14 Flat-Engine Room | Good | x | |
| NSS14Flat-TSI-2A, -2B, -2C | Elbow pipe insulation associated with heating system drain | Deck 14 Flat-Engine Room | Good | x | |
| NSS14Flat-TSI-3A, -3B, -3C | Straight run pipe insulation associated with heating system drain | Deck 14 Flat-Engine Room | Good | x | |
| NSS14Flat-TSI-4A, -4B, -4C | Elbow pipe insulation associated with heating system drain | Deck 14 Flat-Engine Room | Good | x | |
| NSS14Flat-TSI-5A, -5B, -5C | Straight run pipe insulation associated with auxiliary exhaust | Deck 14 Flat-Engine Room | Good | x | |
| NSS14Flat-TSI-6A, -6B, -6C | Elbow pipe insulation associated with auxiliary exhaust | Deck 14 Flat-Engine Room | Good | x | |
| NSS14Flat-TSI-7A, -7B, -7C | Straight run pipe insulation associated with fire station 37 (4" diameter) | Deck 14 Flat-Engine Room | Good | x | |

Asbestos Survey Field Data Sheet-14 Flat and Deck D
NS-Savannah
Fort Eustis, VA

| Sample ID | Material Description | Location | Condition | Friable? | |
|-------------------------------|---|--------------------------|-----------|----------|----|
| | | | | Yes | No |
| NSS14Flat-TSI-8A, -8B, -8C | Elbow pipe insulation associated with fire station 37 (4" diameter) | Deck 14 Flat-Engine Room | Good | x | |
| NSS14Flat-TSI-9A, -9B, -9C | Insulation (body) associated with HP/LP crossover system (60" diameter) | Deck 14 Flat-Engine Room | Good | x | |
| NSS14Flat-TSI-10A, -10B, -10C | Insulation (body) associated with HP/LP crossover system (36" diameter) | Deck 14 Flat-Engine Room | Good | x | |
| NSS14Flat-TSI-11A, -11B, -11C | Elbow pipe insulation associated with HP/LP crossover system (36" diameter) | Deck 14 Flat-Engine Room | Good | x | |
| NSS14Flat-TSI-12A, -12B, -12C | Elbow pipe insulation associated with steam dump pipe (24" diameter) | Deck 14 Flat-Engine Room | Good | x | |
| NSS14Flat-TSI-13A, -13B, -13C | Straight run pipe insulation associated with steam dump pipe (24" diameter) | Deck 14 Flat-Engine Room | Good | x | |
| NSS14Flat-TSI-14A, -14B, -14C | Straight run pipe insulation (4" diameter) | Deck 14 Flat-Shaft Alley | Good | x | |

Asbestos Survey Field Data Sheet-14 Flat and Deck D
NS-Savannah
Fort Eustis, VA

| Sample ID | Material Description | Location | Condition | Friable? | |
|-------------------------------|--|--------------------------|-----------|----------|----|
| | | | | Yes | No |
| NSS14Flat-TSI-15A, -15B, -15C | Elbow pipe insulation (4" diameter) | Deck 14 Flat-Shaft Alley | Good | x | |
| NSS14Flat-TSI-16A, -16B, -16C | Straight run pipe insulation associated with main feed pump | Deck 14 Flat-Engine Room | Good | x | |
| NSS14Flat-TSI-17A, -17B, -17C | Elbow pipe insulation associated with main feed pump | Deck 14 Flat-Engine Room | Good | x | |
| NSS14Flat-TSI-18A, -18B, -18C | Insulation associated with first stage water heater (body) | Deck 14 Flat-Engine Room | Good | x | |
| NSS14Flat-TSI-19A, -19B, -19C | Straight run pipe insulation associated with solenoid valve | Deck 14 Flat-Engine Room | Good | x | |
| NSS14Flat-TSI-20A, -20B, -20C | Elbow pipe insulation associated with solenoid valve | Deck 14 Flat-Engine Room | Good | x | |
| NSS14Flat-TSI-21A, -21B, -21C | Straight run pipe insulation associated with shell coil system | Deck 14 Flat-Engine Room | Good | x | |

Asbestos Survey Field Data Sheet-14 Flat and Deck D
NS-Savannah
Fort Eustis, VA

| Sample ID | Material Description | Location | Condition | Friable? | |
|-------------------------------|---|--------------------------|-----------|----------|----|
| | | | | Yes | No |
| NSS14Flat-TSI-22A, -22B, -22C | Elbow pipe insulation associated with shell coil system | Deck 14 Flat-Engine Room | Good | x | |
| NSS14Flat-TSI-23A, -23B, -23C | Straight run pipe insulation associated with crossover drain | Deck 14 Flat-Engine Room | Good | x | |
| NSS14Flat-TSI-24A, -24B, -24C | Elbow pipe insulation associated with crossover drain | Deck 14 Flat-Engine Room | Fair | x | |
| NSSDeckD-FT-25A, -25B, -25C | White, 9"x9" floor tile and associated mastics | Deck D-Control Room | Good | | x |
| NSSDeckD-FT-26A, -26B, -26C | Green, 9"x9" floor tile and associated mastics | Deck D-Control Room | Good | | x |
| NSSDeckD-TSI-27A, -27B, -27C | Straight run pipe insulation associated with cooling system (green) | Deck D-Engine Room | Good | x | |
| NSSDeckD-TSI-28A, -28B, -28C | Elbow pipe insulation associated with cooling system (green) | Deck D-Engine Room | Good | x | |

**Asbestos Survey Field Data Sheet-14 Flat and Deck D
 NS-Savannah
 Fort Eustis, VA**

| Sample ID | Material Description | Location | Condition | Friable? | |
|------------------------------|--|--------------------|-----------|----------|----|
| | | | | Yes | No |
| NSSDeckD-TSI-29A, -29B, -29C | Insulation associated with cooling system tank (green) | Deck D-Engine Room | Poor | x | |
| NSSDeckD-TSI-30A, -30B, -30C | Straight run pipe insulation associated with diesel engine exhaust | Deck D-Engine Room | Good | x | |
| NSSDeckD-TSI-31A, -31B, -31C | Elbow pipe insulation associated with diesel engine exhaust | Deck D-Engine Room | Good | x | |
| NSSDeckD-MM-32A, -32B, -32C | Gaskets associated with boiler | Deck D-Engine Room | Good | x | |
| NSSDeckD-TSI-33A, -33B, -33C | Insulation associated with steam generator (pink) | Deck D-Engine Room | Good | x | |
| NSSDeckD-TSI-34A, -34B, -34C | Straight run pipe insulation associated with steam generator | Deck D-Engine Room | Good | x | |
| NSSDeckD-TSI-35A, -35B, -35C | Elbow pipe insulation associated with steam generator | Deck D-Engine Room | Good | x | |

Asbestos Survey Field Data Sheet-14 Flat and Deck D
NS-Savannah
Fort Eustis, VA

| Sample ID | Material Description | Location | Condition | Friable? | |
|------------------------------|--|--------------------|-----------|----------|----|
| | | | | Yes | No |
| NSSDeckD-TSI-36A, -36B, -36C | Straight run pipe insulation associated with compressors | Deck D-Engine Room | Good | x | |
| NSSDeckD-TSI-37A, -37, -37C | Elbow pipe insulation associated with compressors | Deck D-Engine Room | Good | x | |
| NSSDeckD-TSI-38A, -38B, -38C | Pipe insulation associated with boiler duct | Deck D-Engine Room | Good | x | |
| NSSDeckD-TSI-39A, -39B, -39C | Elbow pipe insulation associated with ADT pipe system (green) | Deck D-Engine Room | Good | x | |
| NSSDeckD-TSI-40A, -40B, -40C | Straight run pipe insulation associated with ADT pipe system (green) | Deck D-Engine Room | Poor | x | |
| NSSDeckD-TSI-41A, -41B, -41C | Straight run pipe insulation associated with steam valve system | Deck D-Engine Room | Fair | x | |
| NSSDeckD-TSI-42A, -42B, -42C | Straight run pipe insulation associated with engine (red) | Deck D-Engine Room | Good | x | |

**Asbestos Survey Field Data Sheet-14 Flat and Deck D
 NS-Savannah
 Fort Eustis, VA**

| Sample ID | Material Description | Location | Condition | Friable? | |
|------------------------------|---|--------------------|-----------|----------|----|
| | | | | Yes | No |
| NSSDeckD-TSI-43A, -43B, -43C | Elbow pipe insulation associated with engine (red) | Deck D-Engine Room | Good | x | |
| NSSDeckD-TSI-44A, -44B, -44C | Straight run pipe insulation associated with evaporators | Deck D-Engine Room | Good | x | |
| NSSDeckD-TSI-45A, -45B, -45C | Elbow pipe insulation associated with evaporators | Deck D-Engine Room | Good | x | |
| NSSDeckD-TSI-46A, -46B, -46C | Straight run pipe insulation associated with generators | Deck D-Engine Room | Fair | x | |
| NSSDeckD-TSI-47A, -47B, -47C | Elbow pipe insulation associated with generators | Deck D-Engine Room | Poor | x | |
| NSSDeckD-TSI-48A, -48B, -48C | Straight run pipe insulation associated with steam valves | Deck D-Engine Room | Good | x | |
| NSSDeckD-TSI-49A, -49B, -49C | Elbow pipe insulation associated with steam valves | Deck D-Engine Room | Fair | x | |

**Asbestos Survey Field Data Sheet-14 Flat and Deck D
 NS-Savannah
 Fort Eustis, VA**

| Sample ID | Material Description | Location | Condition | Friable? | |
|------------------------------|--|---------------------------|-----------|----------|----|
| | | | | Yes | No |
| NSSDeckD-TSI-50A, -50B, -50C | Straight run pipe insulation associated with boiler water treatment system | Deck D-Engine Room | Fair | x | |
| NSSDeckD-TSI-51A, -51B, -51C | Insulation associated with vent to first stage heater (body) | Deck D-Engine Room | Good | x | |
| NSSDeckD-TSI-52A, -52B, -52C | Straight run pipe insulation associated with condensate line | Deck D-Engine Room | Good | x | |
| NSSDeckD-TSI-53A, -53B, -53C | Straight run pipe insulation associated with diesel engine exhaust (upper section) | Deck D-Engine Room | Good | x | |
| NSSDeckD-FT-54A, -54B, -54C | Tan, 9"x9" floor tile with black specks and associated mastic | Deck D- Food Storage Area | Poor | | x |
| NSSDeckD-FT-55A, -55B, -55C | Brown 9" x9" floor tile with black and white specks and associated mastic | Deck D- Food Storage Area | Poor | | x |
| NSSDeckD-TSI-56A, -56B, -56C | Straight run pipe insulation | Deck D-Food Storage Area | Good | x | |
| NSSDeckD-TSI-57A, -57B, -57C | Elbow pipe insulation | Deck D- Food Storage Area | Good | x | |

Note: All pipes are recorded as total diameter of the pipe and the associated insulation.

*Asbestos Survey Field Data Sheet-Surface Deck
NS-Savannah
Fort Eustis, VA*

| Sample ID | Material Description | Location | Condition | Friable? | |
|--------------------------------|--|--------------|-----------|----------|----|
| | | | | Yes | No |
| NSSSurfaceDeck-MM-1A, -1B, -1C | Black asphalt sealant associated with cargo hold doors | Surface Deck | Good | | x |