

§ 105.25-7

46 CFR Ch. I (10-1-02 Edition)

§ 105.25-7 Ventilation systems for cargo tank or pumping system compartment.

(a) Each compartment shall be provided with a mechanical exhaust system capable of ventilating such compartment with a complete change of air once in every 3 minutes. The intake duct or ducts shall be of sufficient size to permit the required air change. The exhaust duct or ducts shall be located so as to remove vapors from the lower portion of the space or bilges.

(b) The ventilation outlets shall terminate more than 10 feet from any opening to the interior of the vessel which normally contains sources of vapor ignition. The ventilation fan shall be explosion proof and unable to act as a source of ignition.

§ 105.25-10 Cargo pumping installation.

(a) Cargo pumps shall not be installed in the cargo tank compartment unless the drive system is outside the compartment.

(b) Suction pipelines from cargo tanks shall be run directly to the pump, but not through working or crew spaces of vessel.

§ 105.25-15 Spacings around tanks.

(a) Tanks shall be located so as to provide at least 15" space around tank, including top and bottom to permit external examination.

§ 105.25-20 Shutoff valves required.

(a) Shutoff valves shall be provided in the suction lines as close to the tanks as possible. The valves shall be installed so as to shut off against the flow.

(b) Remote control of this shutoff valve shall be provided where deemed necessary by the marine inspector.

Subpart 105.30—Electrical Requirements

§ 105.30-1 Electrical fittings and fixtures.

(a) In compartments or areas containing tanks or pumps handling other than Grade E petroleum products, no electrical fittings, fixtures, nor electrical equipment shall be installed or

used unless approved for a Class I, Group D hazardous location and so labeled by Underwriter's Laboratories, Inc., or other recognized laboratories. (See subpart 110.10 of subchapter J (Electrical Engineering) of this chapter for listings of standards.)

(b) All electrical equipment, fixtures and fittings within 10 feet of a vent outlet or a dispensing outlet shall be explosion proof and shall be labeled as explosion proof by Underwriter's Laboratories, Inc., or other recognized laboratory, as suitable for Class I, Group D atmospheres.

§ 105.30-5 Grounding of electrical equipment.

(a) All electrical equipment shall be grounded to the vessel's common ground.

Subpart 105.35—Fire Extinguishing Equipment

§ 105.35-1 General.

(a) In addition to the requirements in § 28.160 of subchapter C of this chapter, at least two B-II dry chemical or foam portable fire extinguishers bearing the marine type label of the Underwriter's Laboratories, Inc., shall be located at or near each dispensing area.

(b) This equipment shall be inspected prior to issuing a letter of compliance.

[CGFR 69-53, 34 FR 11265, July 4, 1969, as amended by CGD 95-028, 62 FR 51208, Sept. 30, 1997]

§ 105.35-5 Fire pumps.

(a) All vessels shall be provided with a hand operated portable fire pump having a capacity of at least 5 gallons per minute. This fire pump shall be equipped with suction and discharge hose suitable for use in firefighting. This pump may also serve as a bilge pump.

(b) A power-driven fire pump shall be installed on each vessel of more than 65 feet in length overall.

(1) The power fire pump shall be self-priming and of such size as to discharge an effective stream from a hose connected to the highest outlet.

(2) The minimum capacity of the power fire pump shall be 50 gallons per minute at a pressure of not less than 60