

**§ 108.469**

**46 CFR Ch. I (10-1-02 Edition)**

**§ 108.469 Quantity of foam producing materials.**

(a) Except as provided in paragraph (b) of this section, each foam extinguishing system with outlets—

(1) In a tank must have enough foam producing material to discharge foam for at least 5 minutes at each outlet; and

(2) In a space must have enough foam producing material to discharge foam for at least 3 minutes at each outlet.

(b) If a foam system has outlets in more than one tank or space, the system need have only enough foam producing material to cover the largest space that the system covers or, if the liquid surface of a tank covered by the system is larger, the tank with the largest liquid surface.

**§ 108.471 Water pump.**

Each water pump in a foam extinguishing system must be outside each machinery space in which the system has outlets and must not receive power from any of those spaces.

**§ 108.473 Foam system components.**

(a) Each foam agent, each tank for a foam agent, each discharge outlet, each control, and each valve for the operation of a foam extinguishing system must be approved by the Commandant.

(b) Each foam agent tank and each control and valve for the operation of a foam extinguishing system with outlets in a space must be outside the space and must not be in a space that may become inaccessible if a fire occurs in the space.

(c) Each control for a foam extinguishing system with outlets in a space must be near a main escape from the space.

**§ 108.474 Aqueous film forming foam systems.**

Aqueous film forming foam systems may be installed if approved by the Commandant.

**§ 108.475 Piping.**

(a) Each pipe, valve, and fitting in a foam extinguishing system must meet the applicable requirements in Subchapter F of this chapter.

(b) Each pipe, valve, and fitting made of ferrous material must be protected inside and outside from corrosion.

(c) Each pipe, valve, and fitting must have support and protection from damage.

(d) Each foam extinguishing system must have enough—

(1) Dirt traps to prevent the accumulation of dirt in its pipes; and

(2) Drains to remove liquid from the system.

(e) Piping in a foam extinguishing system must be used only for discharging foam.

**§ 108.477 Fire hydrants.**

(a) If a fixed foam extinguishing system has outlets in a main machinery space, at least 2 fire hydrants, in addition to the fire hydrants required by § 108.423 of this subpart, must be installed outside the entrances to the space with each at a separate entrance.

(b) Each hydrant must have enough hose to spray any part of the space.

(c) Each hydrant must have a combination nozzle and applicator.

**FIRE PROTECTION FOR HELICOPTER FACILITIES**

**§ 108.486 Helicopter decks.**

At least two of the accesses to the helicopter landing deck must each have a fire hydrant on the unit's fire main system located next to them.

**§ 108.487 Helicopter deck fueling operations.**

(a) Each helicopter landing deck on which fueling operations are conducted must have a fire protection system that discharges protein foam or aqueous film forming foam.

(b) a system that only discharges foam must—

(1) Have enough foam agent to discharge foam continuously for at least 5 minutes at maximum discharge rate;

(2) Have at least the amount of foam agent needed to cover an area equivalent to the swept rotor area of the largest helicopter for which the deck is designed with foam at—

(i) If protein foam is used, 6.52 liters per minute for each square meter (.16 gallons per minute for each square foot) of area covered for five minutes;