

(b) On a vessel without overnight accommodations, or with overnight accommodations for not more than 49 passengers, the fire pump must be capable of delivering a single hose stream from the highest hydrant, through the hose and nozzle required by § 118.320 of this part, at a pitot tube pressure of 345 kPa (50 psi).

(c) On a vessel carrying more than 600 passengers or with overnight accommodations for more than 49 passengers, the fire pump must meet § 76.10-5 of this chapter.

(d) A fire pump may be driven by a propulsion engine. A fire pump must be permanently connected to the fire main and may be connected to the bilge system to meet the requirements of § 119.520 of this subchapter.

(e) A fire pump must be capable of both remote operation from the operating station and local operation at the pump.

[CGD 85-080, 61 FR 917, Jan. 10, 1996; 61 FR 20556, May 7, 1996, as amended at 62 FR 51351, Sept. 30, 1997]

§ 118.310 Fire main and hydrants.

(a) Except as required by paragraph (d) of this section, a vessel must have a sufficient number of fire hydrants to reach any part of the vessel using a single length of fire hose.

(b) Piping, valves, and fittings in a fire main system must comply with part 119, subpart G of this subchapter.

(c) Each fire hydrant must have a valve installed to allow the fire hose to be removed while the fire main is under pressure.

(d) On a vessel carrying more than 600 passengers or with overnight accommodations for more than 49 passengers, the fire main and hydrants must meet § 76.10-10 of this chapter.

[CGD 85-080, 61 FR 917, Jan. 10, 1996, as amended at 62 FR 51351, Sept. 30, 1997]

§ 118.320 Fire hoses and nozzles.

(a) A fire hose with a nozzle must be attached to each fire hydrant at all times. For fire hydrants located on open decks or cargo decks, where no protection is provided, hoses may be temporarily removed during heavy weather or cargo handling operations,

respectively. Hoses so removed must be stored in nearby accessible locations.

(b) Each hose must:

(1) Be lined commercial fire hose that conforms to Underwriters Laboratory (UL) 19 "Lined Fire Hose and Hose Assemblies," or hose that is listed and labeled by an independent laboratory recognized by the Commandant as being equivalent in performance;

(2) Be 15.25 meters (50 feet) in length and 40 millimeters (1.5 inches) in diameter; and

(3) Have fittings of brass or other suitable corrosion-resistant material that comply with National Fire Protection Association (NFPA) 1963 "Fire Hose Connections," or other standard specified by the Commandant.

(c) Each nozzle must either:

(1) Be of a type approved in accordance with approval series 162.027; or

(2) Be of type recognized by the Commandant as being equivalent in performance.

[CGD 85-080, 61 FR 917, Jan. 10, 1996; 61 FR 24464, May 15, 1996, as amended at 62 FR 51351, Sept. 30, 1997; 62 FR 64305, Dec. 5, 1997]

Subpart D—Fixed Fire Extinguishing and Detecting Systems

§ 118.400 Where required.

(a) The following spaces must be equipped with a fixed gas fire extinguishing system, in compliance with § 118.410 of this part, or other fixed fire extinguishing system specifically approved by the Commandant, except as otherwise allowed by paragraph (b) of this section:

(1) A space containing propulsion machinery;

(2) A space containing an internal combustion engine of more than 50 hp;

(3) A space containing an oil fired boiler;

(4) A space containing combustible cargo or ship's stores inaccessible during the voyage (a carbon dioxide system must be installed in such a space, and Halon systems are not allowed);

(5) A paint locker; and

(6) A storeroom containing flammable liquids (including liquors of 80 proof or higher where liquor is packaged in individual containers of 9.5 liters (2.5 gallons) capacity or greater).