

# CASE STUDIES

- 1) Whitehorse WTP, NC - Rn, Ra, U, Po
- 2) Enchanted Mesa WTP, NM - U
- 3) Glen Ridge WTP, NH - U
- 4) Waldoboro, ME - Rn, CO<sub>2</sub>, & U
- 4) Cherry Valley, MA - As, Rn, CO<sub>2</sub>, & U
- 5) Summer Village, ME - Ra & U Removal

# Radon and Progeny

Isotope	half-life, days	mean life of atom, days	atoms/pCi	yrs to pump 1 mg at 500 gpm & 1000 pCi/L
Rn-222	3.82E+00	5.52E+00	1.7634E+04	1.55E+02
Po-218	2.16E-03	3.12E-03	9.9607E+00	2.79E+05
Pb-214	1.86E-02	2.69E-02	8.5835E+01	3.30E+04
Bi-214	1.38E-02	1.98E-02	6.3415E+01	4.47E+04
Po-214	1.89E-09	2.73E-09	8.7383E-06	3.24E+11
Pb-210	8.14E+03	1.17E+04	3.7539E+07	7.69E-02
Bi-210	5.01E+00	7.23E+00	2.3106E+04	1.25E+02
Po-210	1.38E+02	2.00E+02	6.3821E+05	4.52E+00
Pb-206	stable			

# SMALL UTILITY IN NC



- 100 gpm well/35 gpm treated
- 90,155 pCi/L Rn
- 547 pCi/L U
- 65.7 pCi/L Ra
- Treated U & Ra <2 pCi/L
- Treated Rn <60 pCi/L
- Cation and Anion Exch.
- Air Stripping
- Waste to sewer

# AWWARF-2695

- examined existing regs and guidelines
- sampled & monitored radiation levels at 18 WTP's
- modeled Rn emissions
- assessed worker & public exposure to radiation

# FIELD MEASUREMENTS

- Well and Treated Water: Ra, U, Rn
- Media: Ra, U, gamma, Pb-210
- Sludges: U, Ra, gross alpha, Rn emissions
- Vicinity of treatment units: gamma, Rn
- Vicinity of building, inside and out: Rn
- Regeneration events: Ra, U, TDS
- Dosimetry: personal TLD's and gamma survey meter

# RADON MONITORING



- Vent exit: 12.77 pCi/L
- Blower intake: 1.27 pCi/L
- 6' D/3.5' H: 1.28 pCi/L
- 28' D/4' H: 0.81 pCi/L
- 10' D/6' H: 1.38 pCi/L
- In IX Room: 0.47 pCi/L
- 34' D/8' H: 1.57 pCi/L
- 66' D/4' H: 0.97 pCi/L
- 115' D/10' H: 1.41 pCi/L

# GAMMA MONITORING



- IX vessel surface: 0.246 mR/hr
- Same after regen.: 0.240 mR/hr
- 30" D/18" H: 0.054 mR/hr
- Surface brine storage: 0.200 mR/hr
- Outdoor background: 0.018 mR/hr
- 35 days in IX room at 36" D/48" H: 30 mR

# CONCLUSIONS

- Sewer discharge, if available, is the most feasible option for Ra and U residuals
- IX is feasible for U in a throw-away operation using a LLRW facility
- RSC for radium removal may be a feasible once-use option using a LLRW facility
- Solids disposal on land is done on a case-by-case basis
- Results indicate that exposure to Rn levels at treatment plants is not a problem, with prudent location of air vent
- No problems with worker exposure at any of the monitored WTP's



# CONCLUSIONS

- Gamma exposure was not a problem with all measurements well below occupational dose stds and most near background exposure rate
- Human exposure was not a problem
- Radon emanation from sludge with Ra indicates that existing limits in some states may be too restrictive
- Need some practical perspective w/respect to sewer discharge of small quantities of radionuclides

# A PERSPECTIVE



≈1.0 Ci of Ra-226/sq mi in the top 6" of soil world-wide & more than 10 Ci/sq mi in some areas

>99% of all U and Ra WTP's are/will be very small systems ...for these systems:

all of the WTP's in NC removing U & Ra would total <1.0 Ci/yr

all of the WTP's in the entire U.S. removing U & Ra would total <5-10.0 Ci/yr

# Enchanted Mesa, NM - U Removal

Engineer's Report  
for  
Modifications  
to the  
Enchanted Mesa Mobile Home Park  
Water System

17 Jan 96


Lowry Environmental Engineering  
P.O. Box 14209  
Research Triangle Park, NC 27709




*Sylvia B. Adams*  
1/17/96



# Enchanted Mesa, NM - U Removal



# Enchanted Mesa, NM - U Removal



# Enchanted Mesa, NM - U Removal

## U Removal:

Inlet U at startup (1996): 73.4 pCi/L (35.7 & 36.0)

Treated U at startup (1996): 0.56 pCi/L (0.27 & 0.28)

Treated GA in 2000: 2.7 & 6.5 pCi/L (at each well)

“Working Well” in 2007



# Glen Ridge, NH - U Removal

50 gpm  
39,520 gpd  
U = 34.3  $\mu\text{g/L}$   
U = 22.9  $\text{pCi/L}$   
Service = 100,000 BV  
= 273 days  
Resin cu ft = 15  
pH = 7.25  
Sulfate,  $\text{mg/L}$  = 23




# Glen Ridge, NH - U Removal

OPERATION/DISPOSAL (treat 100% of flow)

PARAMETER	VALUE
U exchanged per cycle, lb	4.48
U on resin, pCi/gram	5,900
Time to 0.05% by weight, days	20
Time to 15 lb on resin, yr *	2.5 (not possible)*
U in brine/rinse, mg/L in 590 gal	912
U in brine/rinse waste, Ci/yr	0.00181
Approx. cost of regen, \$/yr	25
Approx. cost of once-use operation, \$/yr	2,500 - 10,000 **

\* - virgin resin may not go >300,000 BV;  
100%)

\*\* - variable with % by-passed (25-100%)





# Waldoboro, ME - Rn & U Removal



Radon  
< 300 pCi/L

U  
< 2 pCi/L

EBCT =  
1.28 min

250 gpm ( $\approx 120,000$  gpd)

U =  $39.4 \mu\text{g/L}$

U =  $39.4 \mu\text{g} / (1.315 \mu\text{g/pCi}) = 30 \text{ pCi/L}$


Radon  $\approx 6,600 \text{ pCi/L}$

# Waldoboro - Flow Chart

Wells - 250 gpm,  
120,000 gpd  
U = 30 pCi/L  
U = 0.00497 Ci/yr

Anion Exchange:  
EBCT = 1.28 min; 2 beds in parallel;  
36" diam. vessels; 6 month service  
cycle at 68,000 BV run length;  
Water treated per cycle = 21.7 MG

Treated Water U  
= 1-2 pCi/L;



Wastewater from Regeneration:  
2,240 gal/cycle or 12.4 gal/day;  
6.76 lbs U removed per cycle.  
Annual averages - 4,480 gal and  
13.52 lb U; 12.4 gal/day.  
Total U Discharged < 0.005 Ci/yr

Discharged  
over 4 days

Mixed Wastewater:

Must have >92X  
dilution to meet:

U, pCi/L/3000 < 1

Wastewater in  
Sewer:  
0.115 mgd

U, pCi/3000 < 1? NO;

275,421 pCi/L/3000 = 92 > 1



To WWTP & Land (60 acres)  
= 0.000078 Ci/acre/yr

# Cherry Valley, MA

## Rn, U, & As Removal



80-100 gpm  
57,600 gpd  
28,000 pCi/L Radon  
Uranium = 90  $\mu\text{g/L}$   
As = 19  $\mu\text{g/L}$   
Sulfate = 12.6 mg/L  
pH = 7.1

EBCT = 1.87 min  
Service Cycle = 130 days

Waste to WWTP:  
Approx. 1350 gal into  
55 mgd every 4 months





# Summer Village, MA

## Radon, Ra, & U Removal



100 gpm  
68,000 gpd  
81,000 pCi/L Radon  
Radium = 7.55 pCi/L  
Uranium = 43  $\mu\text{g/L}$

Stratified Bed IX  
EBCT = 3.0 min  
Service Cycle = 5 days  
Waste Hauled to WWTP

Under Construction