

## Environmental Protection Agency

## § 63.407

(d) Following a request, by the Administrator or delegated authority, under paragraph (a) for a water sample analysis, failure to either meet the concentration level specified in paragraph (b) or provide the records specified in paragraph (c) shall indicate a violation of § 63.402.

[59 FR 46350, Sept. 8, 1994, as amended at 63 FR 39519, July 23, 1998; 69 FR 18803, Apr. 9, 2004]

### § 63.405 Notification requirements.

(a) *Initial notification.* (1) In accordance with § 63.9(b) of subpart A, owners or operators of all affected IPCT's that have an initial startup before September 8, 1994, shall notify the Administrator in writing. The notification, which shall be submitted not later than 12 months after September 8, 1994, shall provide the following information:

(i) The name and address of the IPCT owner or operator;

(ii) The address (i.e., physical location) of the affected IPCT;

(iii) A statement that the notification is being submitted as required by this subpart; and

(iv) A description of the type of water treatment program used in the affected IPCT, including the chemical name of each corrosion inhibitor ingredient used; the average concentration of those corrosion inhibitor ingredients maintained in the cooling water; and the material safety data sheet for each water treatment chemical or chemical compound used in the IPCT.

(2) In accordance with § 63.9(b) of subpart A, owners or operators of all affected IPCT's that have an initial startup on or after September 8, 1994, shall notify the Administrator in writing that the source is subject to the relevant standard no later than 12 months after initial startup. The notification shall provide all the information required in paragraphs (a)(1)(i) through (a)(1)(iv) of this section.

(b) *Notification of compliance status.* (1) In accordance with § 63.9(h) of subpart A, owners or operators of affected IPCT's shall submit to the Administrator a notification of compliance status within 60 days of the date on which the IPCT is brought into compliance with § 63.402 of this subpart and not

later than 18 months after September 8, 1994.

(2) The notification of compliance status must:

(i) Be signed by a responsible official who also certifies the accuracy of the report;

(ii) Certify that source has complied with § 63.402 of this subpart; and

(iii) Include the information required in paragraph (a)(1)(iv) of this section.

(iv) Include the following statement:

I certify that no chromium-based water treatment chemicals have been introduced since (the initial compliance date) into any IPCT located within the facility for any purpose.

### § 63.406 Recordkeeping and reporting requirements.

To demonstrate continuing compliance with § 63.402 of this subpart, the owner or operator of each affected IPCT shall maintain copies of the initial notification and the notification of compliance status as required by § 63.405 of this subpart for a period of at least 5 years onsite.

### § 63.407 Implementation and enforcement.

(a) This subpart can be implemented and enforced by the U.S. EPA, or a delegated authority such as the applicable State, local, or Tribal agency. If the U.S. EPA Administrator has delegated authority to a State, local, or Tribal agency, then that agency, in addition to the U.S. EPA, has the authority to implement and enforce this subpart. Contact the applicable U.S. EPA Regional Office to find out if implementation and enforcement of this subpart is delegated to a State, local, or Tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or Tribal agency under subpart E of this part, the authorities contained in paragraph (c) of this section are retained by the Administrator of U.S. EPA and cannot be transferred to the State, local, or Tribal agency.

(c) The authorities that cannot be delegated to State, local, or Tribal agencies are as specified in paragraphs (c)(1) through (4) of this section.