

§ 410.64

Pollutant or pollutant property	BAT limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days
	Kg/kg (or pounds per 1,000 lb) of product	
COD	20.0	10.0

§ 410.64 Pretreatment standards for existing sources (PSES).

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

§ 410.65 New source performance standards (NSPS).

Any new source subject to this subject must achieve the following new source performance standards (NSPS):

Pollutant or pollutant property	NSPS limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days
	kg/kg (or pounds per 1,000 lb) of product	
BOD5	4.6	2.4
COD	26.6	17.1
TSS	8.6	3.8
Sulfide	0.08	0.04
Phenols	0.04	0.02
Total chromium	0.04	0.02
pH	(¹)	(¹)

¹ Within the range 6.0 to 9.0 at all times.

NOTE: Additional allocations for "commission finishers" are not available to new sources.

§ 410.66 Pretreatment standards for new sources (PSNS).

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

40 CFR Ch. I (7-1-06 Edition)

§ 410.67 Effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT). [Reserved]

Subpart G—Stock and Yarn Finishing Subcategory

§ 410.70 Applicability; description of the stock and yarn finishing subcategory.

The provisions of this subpart are applicable to process wastewater discharges resulting from the following types of textile mills: Stock or yarn dyeing or finishing, which may include any or all of the following unit operations and processes: Cleaning, scouring, bleaching, mercerizing, dyeing and special finishing.

§ 410.71 Specialized definitions. [Reserved]

§ 410.72 Effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT).

(a) Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Pollutant or pollutant property	BPT limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days
	Kg/kg (or pounds per 1,000 lb) of product	
BOD5	6.8	3.4
COD	84.6	42.3
TSS	17.4	8.7
Sulfide	0.24	0.12
Phenol	0.12	0.06
Total chromium	0.12	0.06
pH	(¹)	(¹)

¹ Within the range 6.0 to 9.0 at all times.

(b) [Reserved]