

Environmental Protection Agency

§ 408.206

source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

(a) Any Alaskan bottom fish processing facility located in population or processing centers including but not limited to Anchorage, Cordova, Juneau, Ketchikan, Kodiak, and Petersburg shall meet the following limitations:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
	Metric units (kg/kkg of seafood)	
TSS	3.1	1.9
Oil and grease	4.3	0.56
pH	(¹)	(¹)
	English units (lb/1,000 lb of seafood)	
TSS	3.1	1.9
Oil and grease	4.3	0.56
pH	(¹)	(¹)

¹ Within the range 6.0 to 9.0.

(b) Any Alaskan bottom-fish processing facility not covered under §408.202(a) shall meet the following limitations: No pollutants may be discharged which exceed 1.27 cm (0.5 inch) in any dimension.

[40 FR 55787, Dec. 1, 1975, as amended at 60 FR 33945, June 29, 1995]

§ 408.203 [Reserved]

§ 408.204 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.

Pollutant or pollutant property	Pretreatment standard
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55787, Dec. 1, 1975, as amended at 60 FR 33945, June 29, 1995]

§ 408.205 Standards of performance for new sources.

(a) The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

(1) Any Alaskan bottom fish processing facility located in population or processing centers including but not limited to Anchorage, Cordova, Juneau, Ketchikan, Kodiak, and Petersburg shall meet the following limitations:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
	Metric units (kg/kkg of seafood)	
TSS	1.9	1.1
Oil and grease	2.6	0.34
pH	(¹)	(¹)
	English units (lb/1,000 lb of seafood)	
TSS	1.9	1.1
Oil and grease	2.6	0.34
pH	(¹)	(¹)

¹ Within the range 6.0 to 9.0.

(2) Any Alaskan bottom-fish processing facility not covered under §408.205(a)(1) shall meet the following limitations: No pollutants may be discharged which exceed 1.27 cm (0.5 inch) in any dimension.

(b) [Reserved]

§ 408.206 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or