

Environmental Protection Agency

§ 408.220

§ 408.213 [Reserved]

§ 408.214 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55788, Dec. 1, 1975, as amended at 60 FR 33945, June 29, 1995]

§ 408.215 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
	Metric units (kilograms per 1,000 kg of seafood)	
BOD5	1.2	0.71
TSS	1.5	0.73
Oil and grease	0.077	0.042
pH	(¹)	(¹)
	English units (pounds per 1,000 lb of seafood)	
BOD5	1.2	0.71
TSS	1.5	0.73
Oil and grease	0.077	0.042
pH	(¹)	(¹)

¹ Within the range 6.0 to 9.0.

[40 FR 55788, Dec. 1, 1975, as amended at 41 FR 31823, July 30, 1976]

§ 408.216 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55788, Dec. 1, 1975, as amended at 60 FR 33945, June 29, 1995]

§ 408.217 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.212 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

Subpart V—Non-Alaskan Mechanized Bottom Fish Processing Subcategory

SOURCE: 40 FR 55789, Dec. 1, 1975, unless otherwise noted.

§ 408.220 Applicability; description of the non-Alaskan mechanized bottom fish processing subcategory.

The provisions of this subpart are applicable to discharges resulting from the processing of bottom fish outside of Alaska in which the unit operations

§ 408.221

(particularly the butchering and/or filleting operations) are carried out predominately through mechanized methods. The provisions of this subpart apply to the processing of bottom fish such as whiting and croaker.

§ 408.221 Specialized definitions.

For the purpose of this subpart:

(a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.

(b) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

§ 408.222 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
	Metric units (kilograms per 1,000 kg of seafood)	
TSS	22	12
Oil and grease	9.9	3.9
pH	(¹)	(¹)
	English units (pounds per 1,000 lb of seafood)	
TSS	22	12
Oil and grease	9.9	3.9
pH	(¹)	(¹)

¹ Within the range 6.0 to 9.0.

[40 FR 55789, Dec. 1, 1975, as amended at 41 FR 31823, July 30, 1976; 60 FR 33946, June 29, 1995]

40 CFR Ch. I (7-1-06 Edition)

§ 408.223 [Reserved]

§ 408.224 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55789, Dec. 1, 1975, as amended at 60 FR 33946, June 29, 1995]

§ 408.225 Standards of performance for new sources.

The following standards of performance establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a new source subject to the provisions of this subpart:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
	Metric units (kilograms per 1,000 kg of seafood)	
BOD5	13	7.5
TSS	5.3	2.9
Oil and grease	1.2	0.47
pH	(¹)	(¹)
	English units (pounds per 1,000 lb of seafood)	
BOD5	13	7.5
TSS	5.3	2.9
Oil and grease	1.2	0.47
pH	(¹)	(¹)

¹ Within the range 6.0 to 9.0.

[40 FR 55789, Dec. 1, 1975, as amended at 41 FR 31823, July 30, 1976]