

Environmental Protection Agency

§ 408.234

§ 408.226 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5	No limitation.
TSS	Do.
pH	Do.
Oil and grease	Do.

[40 FR 55789, Dec. 1, 1975, as amended at 60 FR 33946, June 29, 1995]

§ 408.227 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.222 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

Subpart W—Hand-Shucked Clam Processing Subcategory

SOURCE: 40 FR 55790, Dec. 1, 1975, unless otherwise noted.

§ 408.230 Applicability; description of the hand-shucked clam processing subcategory.

The provisions of this subpart are applicable to discharges resulting from existing hand-shucked clam processing facilities which process more than 1816 kg (4000 lbs) of raw material per day on

any day during a calendar year and all new sources.

§ 408.231 Specialized definitions.

For the purpose of this subpart:
 (a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.
 (b) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

§ 408.232 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
	Metric units (kg/kg of seafood)	
TSS	59	18
Oil and grease	0.60	0.23
pH	(¹)	(¹)
	English units (lb/1,000 lb of seafood)	
TSS	59	18
Oil and grease	0.60	0.23
pH	(¹)	(¹)

¹ Within the range 6.0 to 9.0.

[40 FR 55790, Dec. 1, 1975, as amended at 60 FR 33946, June 29, 1995]

§ 408.233 [Reserved]

§ 408.234 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following