

§ 422.60

[Milligrams per liter]

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
TSS	150	50
pH	(¹)	(¹)

¹ Within the range 6.0 to 9.5.

The total suspended solid limitation set forth in this paragraph shall be waived for process waste water from a calcium sulfate storage pile runoff facility, operated separately or in combination with a water recirculation system, which is chemically treated and then clarified or settled to meet the other pollutant limitations set forth in this paragraph.

(d) The concentration of pollutants discharged in contaminated non-process waste water shall not exceed the values listed in the following table:

[Milligrams per liter]

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
pH	(¹)	(¹)

¹ Within the range 6.0 to 9.5.

[44 FR 50743, Aug. 27, 1979]

Subpart F—Sodium Phosphates Subcategory

SOURCE: 41 FR 25979, June 23, 1976, unless otherwise noted.

§ 422.60 Applicability; description of the sodium phosphates subcategory.

The provisions of this subpart are applicable to discharges resulting from the manufacture of purified sodium phosphates from wet process phosphoric acid.

§ 422.61 Specialized definitions.

For the purpose of this subpart:

Except as provided below, the general definitions, abbreviations and methods of analysis set forth in 40 CFR part 401 shall apply to this subpart.

§ 422.62 Effluent limitations and guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

The following limitations establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a point source subject to the provisions of this subpart after application of the best practicable control technology currently available:

[Metric units (kg/kg of product); English units (lb/1,000 lb of product)]

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
TSS	0.50	0.25
Total phosphorus (as P)80	.40
Fluoride (as F)30	.15
pH	(¹)	(¹)

¹ Within the range 6.0 to 9.5.

§ 422.63 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best available technology economically achievable.

The following limitations establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a point source subject to the provisions of this subpart after application of the best available technology economically achievable:

[Metric units (kg/kg of product); English units (lb/1,000 lb of product)]

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
Total phosphorus (as P)	0.56	0.28
Fluoride (as F)21	.11

[44 FR 50744, Aug. 29, 1979]

§ 422.64 [Reserved]

§ 422.65 Standards of performance for new sources.

The following limitations establish the quantity or quality of pollutants or pollutant properties, controlled by this

Environmental Protection Agency

§ 423.11

section, which may be discharged by a point source subject to the provisions of this subpart after application of the standards of performance for new sources:

[Metric units (kg/kg of product); English units (lb/1,000 lb of product)]

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
TSS	0.35	0.18
Total phosphorus (as P)56	.28
Fluoride (as F)21	.11
pH	(¹)	(¹)

¹ Within the range 6.0 to 9.5.

§ 422.66 [Reserved]

§ 422.67 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology.

Except as provided in §§ 125.30 through 125.32, the following limitations establish the quantity or quality of pollutants or pollutant properties, controlled by this section, which may be discharged by a point source subject to the provisions of this subpart after application of the best conventional pollutant control technology:

[Metric units (kg/kg of product); English units (lb/1,000 lb of product)]

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
TSS	0.35	0.18
pH	(¹)	(¹)

¹ Within the range 6.0 to 9.5.

[51 FR 25000, July 9, 1986]

PART 423—STEAM ELECTRIC POWER GENERATING POINT SOURCE CATEGORY

Sec.

423.10 Applicability.

423.11 Specialized definitions.

423.12 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT).

423.13 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best available technology economically achievable (BAT).

423.14 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT). [Reserved]

423.15 New source performance standards (NSPS).

423.16 Pretreatment standards for existing sources (PSES).

423.17 Pretreatment standards for new sources (PSNS).

APPENDIX A TO PART 423—126 PRIORITY POLLUTANTS

AUTHORITY: Secs. 301; 304(b), (c), (e), and (g); 306(b) and (c); 307(b) and (c); and 501, Clean Water Act (Federal Water Pollution Control Act Amendments of 1972, as amended by Clean Water Act of 1977) (the "Act"; 33 U.S.C. 1311; 1314(b), (c), (e), and (g); 1316(b) and (c); 1317(b) and (c); and 1361; 86 Stat. 816, Pub. L. 92-500; 91 Stat. 1567, Pub. L. 95-217), unless otherwise noted.

SOURCE: 47 FR 52304, Nov. 19, 1982, unless otherwise noted.

§ 423.10 Applicability.

The provisions of this part are applicable to discharges resulting from the operation of a generating unit by an establishment primarily engaged in the generation of electricity for distribution and sale which results primarily from a process utilizing fossil-type fuel (coal, oil, or gas) or nuclear fuel in conjunction with a thermal cycle employing the steam water system as the thermodynamic medium.

§ 423.11 Specialized definitions.

In addition to the definitions set forth in 40 CFR part 401, the following definitions apply to this part:

(a) The term *total residual chlorine* (or total residual oxidants for intake water with bromides) means the value obtained using the amperometric method for total residual chlorine described in 40 CFR part 136.

(b) The term *low volume waste sources* means, taken collectively as if from one source, wastewater from all sources except those for which specific limitations are otherwise established in this part. Low volume waste sources include, but are not limited to: