## ENVIRONMENTAL PROTECTION AGENCY

40 CFR Parts 63

[AD-FRL

National Emission Standards for Hazardous Air Pollutants for Source Categories: Gasoline Distribution (Stage I)

AGENCY: Environmental Protection Agency (EPA).

ACTION: Final rule; correction.

SUMMARY: This document makes clarifications and corrects errors in the regulatory text of the final rule for National Emission Standards for Gasoline Distribution Facilities (Bulk Gasoline Terminals and Pipeline Breakout Stations) which appeared in the Federal Register on December 14, 1994 (59 FR 64303).

EFFECTIVE DATE: December 14, 1994.

FOR FURTHER INFORMATION CONTACT: For general and technical information concerning the final rule, contact Mr. Stephen Shedd, Waste and Chemical Processes Group, Emission Standards Division (MD-13), U.S. Environmental Protection Agency, Research Triangle Park, North Carolina

27711; telephone (919) 541-5397. For information regarding the test methods and procedures referenced in the rule, contact Mr. Roy Huntley, Emission Inventory and Factors Group, Emissions, Monitoring and Analysis Division (MD-14), U.S. Environmental Protection Agency, Research Triangle Park, NC 27704; telephone (919) 541-1060.

SUPPLEMENTARY INFORMATION: On December 14, 1994 (59 FR 64303), the EPA promulgated regulations requiring sources to achieve emission limits reflecting application of the maximum achievable control technology (MACT) consistent with section 112 of the Clean Air Act (Act). The final rule regulates all hazardous air pollutants (HAP) identified in the Act's list of 189 HAP that are emitted from new and existing bulk gasoline terminals and pipeline breakout stations at plant sites that are major sources of HAP. On February 8, 1995 (60 FR 7627), the Office of the Federal Register made three corrections to the regulatory text in the final rule. Today, four additional corrections are being made to correct and clarify requirements in the National Emission Standards for Gasoline Distribution Facilities (Bulk Gasoline Terminals and Pipeline Breakout Stations).

The affected public has requested that the EPA clarify the date of compliance for testing, reporting, and recordkeeping requirements for reducing vapor leakage from gasoline cargo tanks (tank trucks and railcars) loading at major source bulk gasoline terminals affected by this rule. The regulatory text provided compliance dates for the equipment that collects and processes the vapor displaced from cargo tanks and inadvertently did not specify compliance dates for the cargo tank leak testing, reporting, and recordkeeping requirements. vapor collection and processing equipment requirements in the final rule are required to be met by December 15, 1997 (three years from the effective date) for existing terminals and upon startup for new terminals. The EPA intended that the rule require that all the components of this vapor control system comply during the same compliance period, including cargo tanks. Today's notice is to clarify that the compliance date for both the cargo tank requirements and the other loading rack vapor control requirements occur no later than December 15, 1997 at existing terminals and upon startup at new terminals.

A typographical error was made on an equation in the regulatory text that calculates the minimum allowable final headspace pressure for the nitrogen pressure decay field test for cargo tanks. Additionally, the location of one variable in the subject equation was incorrectly specified.

Today's notice corrects the typographical error in both the equation and the location of one of the equation's variables.

## Notice of Correction for Gasoline Distribution (Stage I) Final Rule - Page 4 of 4

Dated:

Assistant Administrator for Air and Radiation

Signed by Mary D. Nichols on June 15, 1995

The following corrections are being made in the regulatory text for: National Emission Standards for Gasoline Distribution Facilities (Bulk Gasoline Terminals and Pipeline Breakout Stations) published in Fetcheral Registeron December 14, 1994 (59 FR 64303).

## §63.422 [Corrected]

- 1. In paragraph (b) of §63.422 on page 64320, column 1, line 27, remove the sentence "Each owner or operator shall comply as expeditiously as practicable, but no later than December 15, 1997 at existing facilities and upon startup for new facilities."
- 2. After paragraph (c)(2)(ii)(B) of §63.422 on page 64320, column 1, line 64, insert a new paragraph (d) of §63.422 as follows: "(d) Each owner or operator shall meet the requirements in all paragraphs of this section as expeditiously as practicable, but no later than December 15, 1997 at existing facilities and upon startup for new facilities."

## §63.425 [Corrected]

3. The equation in the paragraph (g)(3) of §63.425 on page 64321, column 3, is revised to read as follows:

$$P_F = 18 \left( \frac{(18 - N)}{18} \right)^{\left( \frac{V_s}{5(V_h)} \right)}$$

\* \* \* \* \*

4. The reference to Table 2 in paragraph (g)(3) of §63.425 on page 64322, column 1, first two lines, is revised to read as follows: "... column of Table 2 of §63.425(e)(1), incheşOH"