

Enclosure 3
Staff Responses to Public Comments on Draft Regulatory Guide DG-1169
(Proposed Revision 2 of Regulatory Guide 1.130)

Comments		NRC Comment Resolution
Originator	DG-1169 Section	Specific Comments
<p>Anvil Int'l. Inc. 12/22/2006 cover letter (ML063610047)</p>	<p>general comment 1</p>	<p>Throughout the draft regulatory guide, linear-type supports are referred to as “component supports.” This is an incorrect designation, since the term “component supports” was changed to “supports” with the issuance of the winter 1982 addenda to the 1980 edition of Subsection NF. In that addenda, Article NF-3000 was revised in its entirety to introduce the concept of “piping supports.” Previously, the term “component supports” encompassed the entire family of supports (i.e., supports on components such as tanks, vessels, and pumps, and supports on piping); thus, the title of Subsection NF originally (1974) was “component supports.”</p> <p>With the winter 1982 addenda rewrite, “component supports” no longer meant the family of supports, but meant only supports attached to components such as tanks, vessels, and pumps (NF-3500). Also at this time, supports attached to piping were referred to as “piping supports” (NF-3600). Over the next few years, the generic term “component supports” was changed to “component and piping supports” throughout Subsection NF, and the title on the cover of Subsection NF was changed from “component supports” to “supports” (1995 edition).</p> <p>If the draft regulatory guide is only supposed to</p>