



James Scarola  
Vice President  
Harris Nuclear Plant  
Progress Energy Carolinas, Inc.

Serial: HNP 03-023  
10 CFR 2.203

FEB 26 2003

Secretary, Office of the Secretary of the Commission  
U. S. Nuclear Regulatory Commission  
ATTN: Rulemakings and Adjudications Staff  
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1  
DOCKET NO. 50-400 / LICENSE NO. NPF-63

**TWENTY-DAY RESPONSE TO ORDER FOR ESTABLISHING INTERIM  
INSPECTION REQUIREMENTS FOR REACTOR PRESSURE VESSEL HEADS  
AT PRESSURIZED WATER REACTORS**

Ladies and Gentlemen:

On February 11, 2003, the Nuclear Regulatory Commission issued an Order letter, Subject: "Establishing Interim Inspection Requirements for Reactor Pressure Vessel Heads at Pressurized Water Reactors." In the order, Section V, the Nuclear Regulatory Commission requires that, within 20 days the licensee must, and any other person adversely affected by the Order may, submit an answer to the Order, and may request a hearing on the Order. In accordance with Section V of the Order, the Licensee may consent to the order or pursue alternate actions as described in the Order.


The Harris Nuclear Plant has reviewed the order and by this letter consents to the requirements therein. As clarified by the NRC in the public meeting held on February 24, 2003, in response to questions submitted by NEI, the scope of the bare metal visual inspection includes "the RPV head penetration nozzles and related areas of the RPV head that may be subject to external sources of boric acid." It does not include areas of the head not subject to external sources of boric acid, including, but not limited to, areas such as the inside of the head studs, the inside the lifting bolt holes, or the underside of the head.

P.O. Box 165  
New Hill, NC 27562

T > 919.362.2502  
F > 919.362.2095


Please refer any questions regarding this submittal to John Caves (919) 362-3137.

Sincerely,




RTG

James Scarola, having been first duly sworn, did depose and say that the information contained herein is true and correct to the best of his information, knowledge and belief, and the sources of his information are employees, contractors, and agents of Progress Energy Carolinas, Inc.



My commission expires: 2-21-2005

Notary (Seal)



c:

Mr. J. B. Brady, NRC Sr. Resident Inspector

Ms. Beverly Hall, Section Chief, Radiation Protection Section, N.C. DENR

Mr. C. P. Patel, NRC Project Manager

Mr. L. A. Reyes, NRC Regional Administrator

Director, Office of Nuclear Reactor Regulation

Assistant General Counsel for Materials Litigation and Enforcement