

# **QUALITY ASSURANCE PROJECT PLAN (QAPjP) and QA Report for Pacific 2001**

**Prepared by: Kevin Strawbridge**

● **Date:**

## Table of Contents

1.	Principal Investigator .....	3
2.	Team Members .....	3
3.	Measurement Program.....	3
4.	Measurement Species and Units .....	3
5.	Representative Size Range (if PM) .....	3
6.	Measurement Platform (surface, airborne).....	3
7.	Measurement Sites (surface only) .....	3
8.	Measurement Objective(s).....	3
9.	Measurement Details.....	3
9.1.	Field Measurements .....	3
9.1.1.	Measurement Principle.....	3
9.1.2.	Instrumentation (Manufacturer/Model) .....	3
9.1.3.	Flow System .....	4
9.1.4.	Inlet Height Above Ground (if surface).....	4
9.1.5.	Nominal Flow Rate.....	4
9.1.6.	Flow Measurement/Control.....	4
9.1.7.	Flow Temperature and Pressure .....	4
9.1.8.	Sampling Times/Period/Frequency .....	4
9.1.9.	Sampling Methods .....	4
9.1.10.	Filter Type/Coating Type/Reagent Type .....	4
9.1.11.	Planned Changes to Instruments or Methods During Study .....	4
9.2.	Laboratory Measurements (If Applicable).....	4
9.2.1.	Laboratory Name and Address .....	4
9.2.2.	Analytical Method(s).....	4
9.2.3.	Sample Extraction or Work-up .....	4
9.2.4.	Analytical Detection Limits .....	4
10.	Quality Assurance/Quality Control.....	5
10.1.	Field Quality Assurance/Quality Control.....	5
10.1.1.	Traceability .....	5
10.1.2.	Calibration .....	5
10.1.3.	Zeros and spans .....	5
N/A.	.....	5
10.1.4.	Blanks .....	5
N/A.	.....	5
10.1.5.	Field Quality Control procedures.....	5
10.1.6.	Precision determination .....	5
10.1.7.	Comparison with other measurements .....	5
10.1.8.	Inspections and Audits .....	5
10.2.	Laboratory Quality Assurance/Quality Control .....	5
10.2.1.	Traceability .....	5
10.2.2.	Calibration procedures.....	5
10.2.3.	Blanks .....	5
10.2.4.	Other lab QC.....	5
N/A.	.....	5
10.2.5.	Precision determination .....	5
10.2.6.	Comparison with other methods.....	6

10.2.7.	Audits .....	6
11.	Data Management and Quality Control .....	6
11.1.	Raw Data Recording .....	6
11.2.	Final Data Reporting .....	6
11.3.	Data Quality Control and Validation .....	6
11.4.	Validity Flags .....	6
11.5.	Below Method Detection Limit Values .....	6
11.6.	Derived Parameters .....	6
11.7.	Explanation of Zero or Negative Data .....	6
12.	Data Quality Objectives (Pre-Study) .....	6
12.1.	Accuracy .....	6
12.2.	Precision .....	6
12.3.	Comparability .....	7
12.4.	Representativeness .....	7
12.5.	Completeness .....	7
12.6.	Other Quality Information .....	7
13.	Significant Changes to Site, Instruments or Methods During Study .....	8
14.	Post-study Data Quality Indicators (DQIs) .....	8
14.1.1.	Accuracy .....	8
14.1.2.	Precision .....	8
14.1.3.	Comparability .....	8
14.1.4.	Representativeness .....	8
14.1.5.	Completeness .....	8
14.2.	Blank correction (describe whether done and method used): .....	8
14.3.	Other Quality Information .....	8
15.	References: .....	8

**1. Principal Investigator**

Kevin Strawbridge, Centre For Atmospheric Research Experiments (CARE),  
Meteorological Service of Canada, R.R. #1, Egbert, Ontario. L0L 1N0 (705)458-3314

**2. Team Members**

Michael Harwood (CARE), Marc Lilley (McGill University), Michael Travis (CARE)

**3. Measurement Program**

Aircraft Lidar: 1064 nm simultaneous upward/downward lidar (including depolarization channels) measurements of PM vertical profiles

Scanning Lidar: 1064 nm lidar to measure PM scanning profiles of the troposphere

**4. Measurement Species and Units**

Lidar measures Backscatter coefficient ( $\text{m}^{-1}\text{sr}^{-1}$ ) results are usually presented as a Backscatter Ratio (unitless)

**5. Representative Size Range (if PM)**

Measures optical quantity of particles present within a defined scattering volume.

**6. Measurement Platform (surface, airborne)**

Aircraft lidar: CV580 platform

Scanning lidar: Lidar mobile lab

**7. Measurement Sites (surface only)**

Scanning lidar: Langley

**8. Measurement Objective(s)**

**9. Measurement Details**

**9.1. Field Measurements**

**9.1.1. Measurement Principle**

The principle of lidar (LIght Detection And Ranging) is analogous with radar. A Nd:YAG pulsed laser operating at the fundamental wavelength of 1064 nm emits a burst of photons. The photons backscattered from atmospheric particulate as the pulse propagates through the atmosphere is measured by a telescope and detector package. The resolution of the lidar is variable but typically set to 3 m along the axis of propagation.

**9.1.2. Instrumentation (Manufacturer/Model)**

Aircraft/Scanning lidar:

Nd:YAG laser :Continuum (NY-61 –scanner, Surelite II – airborne)

14" Telescope : Celestron

log detectors : Optech Inc.

12 bit digitizer cards : GAGE 12100

All other components custom. (too numerous to list here)

**9.1.3. Flow System**

N/A

**9.1.4. Inlet Height Above Ground (if surface)**

N/A

**9.1.5. Nominal Flow Rate**

N/A

**9.1.6. Flow Measurement/Control**

N/A

**9.1.7. Flow Temperature and Pressure**

N/A

**9.1.8. Sampling Times/Period/Frequency**

Aircraft lidar: (20 Hz laser)

Horizontal average : ½ second or 1 second

Scanning lidar: (10 Hz laser)

Data collected every shot (10 Hz data), high resolution elevation scan – approx. 3 minutes.

**9.1.9. Sampling Methods**

N/A

**9.1.10. Filter Type/Coating Type/Reagent Type**

N/A

**9.1.11. Planned Changes to Instruments or Methods During Study**

None planned.

**9.2. Laboratory Measurements (If Applicable)**

**9.2.1. Laboratory Name and Address**

N/A

**9.2.2. Analytical Method(s)**

N/A

**9.2.3. Sample Extraction or Work-up**

N/A

**9.2.4. Analytical Detection Limits**

N/A

## **10. Quality Assurance/Quality Control**

### **10.1. Field Quality Assurance/Quality Control**

#### **10.1.1. Traceability**

N/A

#### **10.1.2. Calibration**

Lidar instrument calibration will be determined by obtaining measurements of “clear air”. Laser output power is monitored during data acquisition.

#### **10.1.3. Zeros and spans**

N/A

#### **10.1.4. Blanks**

N/A

#### **10.1.5. Field Quality Control procedures**

All optics will be kept pristine during lidar operation. This requires routine cleaning (usually the beginning of each day). Laser power monitored and flashlamp changes done when required.

#### **10.1.6. Precision determination**

N/A

#### **10.1.7. Comparison with other measurements**

Scanning lidar : optical closure obtained by comparing AOD with CIMELsunphotometer at Langley

#### **10.1.8. Inspections and Audits**

N/A

### **10.2. Laboratory Quality Assurance/Quality Control**

#### **10.2.1. Traceability**

N/A

#### **10.2.2. Calibration procedures**

N/A

#### **10.2.3. Blanks**

N/A

#### **10.2.4. Other lab QC**

N/A

#### **10.2.5. Precision determination**

N/A

**10.2.6. Comparison with other methods**

N/A

**10.2.7. Audits**

N/A

**11. Data Management and Quality Control**

**11.1. Raw Data Recording**

All data collected and stored is raw data obtained from the digitizer cards. Additional information is stored in the header file (including detector ID's, telescope ID's, block ID's etc.)

**11.2. Final Data Reporting**

Aircraft data: The aircraft data is merged with the nav. Data obtained from the Convair. A time sync. Is used to merge in Lat/Long , pitch, roll angle. Calibration factors are determined for each channel.

**11.3. Data Quality Control and Validation**

see above

**11.4. Validity Flags**

N/A

**11.5. Below Method Detection Limit Values**

Lidar software can eliminate data below a certain noise threshold if required.

**11.6. Derived Parameters**

Backscatter ratio plots are a first product. For aircraft data this will include time/height as well as Lat/Long / height plotted simultaneously. A number of products are also available (eg. PBL heights, AOD (variable extinction/backscatter ratios, average profile data, cloud height, etc.)

**11.7. Explanation of Zero or Negative Data**

N/A

**12. Data Quality Objectives (Pre-Study)**

**12.1. Accuracy**

Backscatter ratio – 15%  
Derived heights – 3 m vertical resolution

**12.2. Precision**

N/A

**12.3. Comparability**  
N/A

**12.4. Representativeness**  
Airborne lidar: flight tracks selected to maximize coverage of LFV.  
Provides a snapshot in time. Staggering east/west runs will help determine variability during flight.  
Scanning lidar: scans will be taken in three different directions (North, West, East) for approx. 16 hours a day (weather dependent).

**12.5. Completeness**  
Generally only weather dependent. System quite reliable.

**12.6. Other Quality Information**  
N/A

End of Pre-Study QAPjP

---

Start of Post-Study QA Report

13. Significant Changes to Site, Instruments or Methods During Study

14. Post-study Data Quality Indicators (DQIs)

14.1.1. Accuracy

14.1.2. Precision

14.1.3. Comparability

14.1.4. Representativeness

14.1.5. Completeness

14.2. Blank correction (describe whether done and method used):

14.3. Other Quality Information

15. References: