

**United States House of Representatives
Committee on Appropriations**

Project Request Summary

General Information

Member

The Honorable Robert E. Latta

Staff Contact

Allison Witt

Email Address

allison.witt@mail.house.gov

Subcommittee, Agency and Account Information

Subcommittee

Interior and Environment

Agency

Environmental Protection Agency

Account

STAG Water and Wastewater Infrastructure Project

Project Information

Grantee State

OH

Grantee Name

Northwestern Water and Sewer District

Project Name

Wise Street Sanitary Sewer Pump Station Replacement

Project Location

Purpose of Project

Detailed Project Description

The existing pump station is undersized and is in poor condition. The station is in need of a complete reconstruction. It was constructed in the early 1970s and is experiencing some corrosion on the steel shell of the station. The capacity of the pumps is approximately 60% of the rated capacity. The proposed project involves installation of approximately 5,000 lineal feet of 18" sanitary sewer and 15 sanitary manholes. Also included are the demolition, removal, and replacement of a pump station located on Wise Street at Hanson Road in the City of Northwood. The project will allow the Village to gain compliance with Sections 201, 208 and other provisions of the Clean Water Act.

Total estimated cost of the project based on facilities plan or preliminary engineering report

\$904,850

Amount requested (cannot be greater than 55% of the total project amount)

\$300,000

Amount received from past appropriations

None

Does the community have a financing plan certified by an authorized local official demonstrating how it will cover the 45% matching funds?

Yes

Intended Recipient of Funds

Northwestern Water and Sewer District

12560 Middleton Pike

Bowling Green, OH 43402

Is the recipient a for-profit entity?

No

Explanation of the request (must include purpose and why it is a valuable use of taxpayer funds)

The existing pump station is undersized and is in poor condition. The station is in need of a complete reconstruction. It was constructed in the early 1970s and is experiencing some corrosion on the steel shell of the station. The capacity of the pumps is approximately 60% of the rated capacity. The proposed project involves installation of approximately 5,000 lineal feet of 18" sanitary sewer and 15 sanitary manholes. Also included are the demolition, removal, and replacement of a pump station located on Wise Street at Hanson Road in the City of Northwood. The project will allow the Village to gain compliance with Sections 201, 208 and other provisions of the Clean Water Act.

URL where this information will be posted (please put the address of the specific page)

http://latta.house.gov/app_sub.shtml

Logout

Appropriator²⁰¹⁰ U.S. House of Representatives, Committee on Appropriations

Existing Requests New Requests Request Letters Expert Mode

**Project Request
Fiscal Year 2010**

Your request has been saved and is visible to Committee staff.

Please print out this request for your records.

The following is a copy of your request. | PDF Version

Information about your submission

ID 46983
 Date/Time Submitted Fri Apr 03 13:36:34 -0400 2009
 Submitted from IP Address 143.231.147.8

Project Request Summary**General Information**

Member The Honorable Robert E. Latta
 Staff Contact Allison Witt
 Phone Number 6-4329
 Email Address allison.witt@mail.house.gov

Subcommittee, Agency and Account Information

Subcommittee Interior and Environment
 Agency Environmental Protection Agency
 Account STAG Water and Wastewater Infrastructure Project

Project Information

Priority 6th
 Project Name Wise Street Sanitary Sewer Pump Station Replacement
 Project Description The existing pump station is undersized and is in poor condition. The station is in need of a complete reconstruction. It was constructed in the early 1970s and is experiencing some corrosion on the steel shell of the station. The capacity of the pumps is approximately 60% of the rated capacity. The proposed project involves installation of approximately 5,000 lineal feet of 18" sanitary sewer and 15 sanitary manholes. Also included are the demolition, removal, and replacement of a pump station located on Wise Street at Hanson Road in the City of Northwood. The project will allow the Village to gain compliance with Sections 201, 208 and other provisions of the Clean Water Act.
 Where is this authorized? None
 Request Amount \$300,000

President's

Budget
Request

Add another project

Review existing requests (requires username and password)

US House of Representatives, Committee on Appropriations, 2007-2009. This work governed by 17 USC 105.