

**HAZARD/DEFICIENCY INSPECTION RECORD**

For use of this form, see AR 420-90

**SUSPENSE DATE:**

17-Feb-08

<b>To:</b> Schoapke SOTF-Central Bldg. 11; Gate 1 Area	<b>From:</b> Radwanlyah Fire Department
<b>Type and Location of Fire Safety Violation:</b>	<b>Date of Violation:</b> 19-Nov-07

HAZARDS/DEFICIENCIES NOTED	CORRECTIVE ACTION TAKEN (Return to Chief)
<p style="text-align: center;">Section</p> <p><u>KITCHEN Room B</u>                      Electrical: NFPA 70                      1. Spliced wires near stove / oven</p> <p><u>Room D</u>                      Fuel Storage/ Spill Catch: NFPA 30 &amp; HD 1022A                      1. POL storage needs to be stored in appropriate diking outside</p> <p><u>Room H</u>                      Electrical: NFPA 70                      1. Hot Water Heater hard wired into outlet                      2. Dryer unit hard wired into outlet</p> <p>Smoke Detectors: NFPA 72                      1. One smoke detector needed in each room</p> <p>Fire Extinguishers: NFPA 10                      1. Recommend ABC type extinguisher placed at each exit and one in each berthing area</p> <p>Means of Egress: NFPA 101                      1. Evacuation Plan needs to be posted                      2. Exit signs need to be posted above all exits</p>	

<b>Date:</b> 19-Nov-07	<b>Report Done By:</b> Capt. James Cook
<b>Date:</b> 22-Nov-07	<b>Installation Fire Chief Signature:</b> John Garber
<b>Date:</b> 22-Nov-07	<b>Installation Fire Marshall Signature:</b> [Signature]
<b>Date:</b> 17 Feb 08	<b>Organization or Activity Representative Signature:</b> [Signature]

HOSR Request of March 19, 2008 - 3rd Production

Satisfactory

Follow up Inspection:

Inspected By: [Signature]