Central Region Public Power Partners (CPPP) and Stakeholders Second Meeting

April 9, 2008 - Nashville
Ian Grant, David Till, David Marler
(isgrant@tva.gov, bdtill@tva.gov, demarler@tva.gov)

Agenda

- Recap Order 890 & TVA Response
- Reliability Planning & Schedule for 2008
- What's Next
- Economic Studies
- Data, Assumptions, Criteria, Results

Recap

• FERC Order 890 - 9 Principles

Coordination
Openness
Transparency
Information Exchange
Comparability
Dispute Resolution
Regional Participation
Economic Planning Studies
Cost Allocation

TVA Response

Within Central region -

- CPPP AECI, BREC, EKPC, TVA
- Stakeholders transmission customers, distribution customers, direct served industrial customers, generation owners/developers, neighbor utilities, regional transmission organizations, interested regulatory agencies.


Inter-regional -

SIRPP, TVA/PJM/MISO/SPP, SERC/ERAG


TVA Response

- Attachment K posted on OASIS Dec 7
- http://www.oatioasis.com/tva/tva docs.htm
- Seeking Board approval for inclusion in "Transmission Guidelines"

Interregional Area



TVA Interfaces



Reliability Planning

Annual cycle of stakeholder involvement

- 1st meeting data, criteria, assumptions
- 2nd meeting preliminary studies identify needs, discuss solutions & stakeholder options
- 3rd meeting final studies, comparison of solutions

Stakeholder Interface with Reliability Process

- Access to study models
- Preliminary results and "30-second" solutions presented
- Input on project alternatives accepted and considered until RS date

TVA Planning Milestones

- "Project Launch":
 - There is a problem requiring solution
 - Need date (e.g., Summer '09)
- "Recommend Solution" (RS):
 - Selection of best alternative
 - Planning VP approval
- "Concept Approval" (CA):
 - Construction VP approval
- "Scoping":
 - Detailed scope, schedule, budget

Schedule for 2008

First year - compressed cycle


- 1st meeting Nov 14. Introduce CPPP, seek stakeholder comments
- Data availability announcement Feb 19
- 2nd meeting April 9. Combined data, assumptions, criteria, results
- 3rd (& 4th?) meeting TBD

What's Next

- Administration of stakeholder group
 - CPPP Members presently administering
- Schedule of meetings, future locations
 - locations throughout region
 - set schedule for reliability studies
 - economic studies depends on need
- Communications
 - email
 - TVA OASIS site http://www.oatioasis.com/tva/tva docs.htm

Economic Studies

- Initial screening studies within region
 - fast response
 - presently no limit to number
 - will reach outside region if feasible
 - no charge
- Inter-regional and detailed studies
 - stakeholder can bring to TVA or other region
- Collaborative interaction during studies
 - dependent on stakeholder capabilities
 - what's reasonable?



Data and Assumptions

Data

 Loadflow base cases available upon request and completion of Non-Disclosure Agreement


Assumptions

- Load Forecast
- Generation Resource Plan
- Transmission Configuration

Criteria

Performance Requirements for N-1


- Normal facility ratings
- Voltage > 95%
- No loss of load




Summer 2011 Details

	Contingency					Thermal Overload Violation						
Мар#	From#	From Name	To#	To Name	Ckt#	From#	From Name	To#	To Name	Ckt#	%	30 Second Solutions
1	48	8DAVIDSON TN	339	5DAVIDSON#2	1	39	5JVILLE FP#2	313	5DICKSON TN	1	104.3	Johnsonville - Dickson 161-kV TL - UPRATE to 100 C
3	43	5PARADISE FP	331	5BOWLING GRN	1	331	5BOWLING GRN	540	5LOSTCITY KY	1	112.9	Bowling Green - Lost City 161-kV TL - UPRATE to 100 C
4	43	5PARADISE FP	331	5BOWLING GRN	1	43	5PARADISE FP	1032	5ABERD KY TP	1	100.7	Paradise - E. Bowling Grn 161-kV TL - UPRATE to 100 C
	45	5MONTGOMERY	492	5BARKERSMILL	1	325	5HOPKINSV KY	1302	5SUP GRAPH T	1	111.0	
6	45	5MONTGOMERY	492	5BARKERSMILL	1	1302	5SUP GRAPH T	329	5CASKY KY	1	104.3	Hopkinsville - Casky 161-kV TL - RECONDUCTOR
7	127	5KENTUCKY HP	572	∛E CALVERT T	1	125	5CALVERT KY	126	5SCALVERT KY	1	109.8	Calvert - KY Hydro 161-kV TL - UPRATE to 100 C
8	16	5MARSHALL KY	1163	5N STAR KY	1	16	5MARSHALL KY	125	5CALVERT KY	1	115.2	Marshall - Calvert #1 161-kV TL - UPRATE to 100 C
	16	5MARSHALL KY	125	5CALVERT KY	1	16	5MARSHALL KY	1163	5N STAR KY	1	109.0	
	16	5MARSHALL KY	125	5CALVERT KY	1	1163	5N STAR KY	1180	5PENNWALT TP	1	108.4	
9	16	5MARSHALL KY	125	5CALVERT KY	1	1180	5PENNWALT TP	125	5CALVERT KY	1	105.4	Marshall - Calvert #2 161-kV TL - UPRATE to 100 C
	341	5BANGHAM TN	1236	5GAINSBRO TP	1	445	5BRAYTOWN TN	1542	5WINDROCK	1	114.8	
10	341	5BANGHAM TN	1236	5GAINSBRO TP	1	442	5ELZA TN	1542	5WINDROCK	1	124.7	Elza - Huntsville 161-kV TL - RECONDUCTOR
	651	3TRAFFORD AL	661	3FULTONDALE	1	279	5GUNTERSV HP	280	3GUNTERSV HP	1	137.1	Guntersville 161-kV HP - INCREASE TRANSFORMER
14	651	3TRAFFORD AL	661	3FULTONDALE	1	279	5GUNTERSV HP	280	3GUNTERSV HP	2	136.1	CAPACITY
	Contingency					Bus Voltage Violation						
Мар#	From#	From Name	To#	To Name	Ckt#	Bus#	Bus Name					30 Second Solutions
	391	5FAYETTVL TN	1033	5HAMILTN FAY	1	1033	5HAMILTN FAY	0.92				
	391	5FAYETTVL TN	1033	5HAMILTN FAY	1	1303	5MCBURG TN	0.94				
	299	5LAWRENCB TN	1260	5WALTER ANDR	1	1103	5PULASKI TN	0.93				Pulaski 161-kV Sub - INSTALL ADDITIONAL CAPACITOR
2	299	5LAWRENCB TN	1260	5WALTER ANDR	1	1260	5WALTER ANDR	0.93				BANK
	325	5HOPKINSV KY	1302	5SUP GRAPH T	1	329	5CASKY KY	0.93				
	325	5HOPKINSV KY	1302	5SUP GRAPH T	1	564	5COMMERCE PK	0.93				
	325	5HOPKINSV KY	1302	5SUP GRAPH T	1	534	5SUP GRAPH	0.92				
	45	5MONTGOMERY	492	5BARKERSMILL	1	492	5BARKERSMILL	0.91				
5	45	5MONTGOMERY	492	5BARKERSMILL	1	324	5EDGOTEN TN	0.91				Edgoten 161-kV Sub - INSTALL CAPACITOR BANK
	455	5NORRIS HP	1330	5JACKSBRO TP	1	454	5CARYVILL TN	0.92				
	455	5NORRIS HP	1330	5JACKSBRO TP	1	1331	5JACKSBRO TN	0.92				Lafollette, Jellico, Norris - INSTALL 161-kV CAPACITOR
11	455	5NORRIS HP	1330	5JACKSBRO TP	1	145	5ROYAL BLUE	0.93				BANKS
	87	5WBHP	1041	5DAYTON TAP	1	461	5BRUSHCRK TN	0.94				
	87	5WBHP	1041	5DAYTON TAP	1	426	5DAYTON TN	0.92				
	87	5WBHP	1041	5DAYTON TAP	1	1238	5SKYLINE TN	0.93				
12	87	5WBHP	1041	5DAYTON TAP	1	1183	5SMITHMTN TN	0.94				Dayton 161-kV Sub - CONSTRUCT ALTERNATE FEED
	341	5BANGHAM TN	1236	5GAINSBRO TP	1	341	5BANGHAM TN	0.91				
	341	5BANGHAM TN	1236	5GAINSBRO TP	1	1287	5JAMESTWN TN	0.93				
	341	5BANGHAM TN	1236	5GAINSBRO TP	1	342	5LIVINGST TN	0.92				Livingston / Bangham 161-kV Sub - INSTALL CAPACITOR
13	341	5BANGHAM TN	1236	5GAINSBRO TP	1	1136	5MONROE	0.92				BANK

TVA Transmission Service Centers (TSC)








IN


II


- 3. Lost City-Bowling Green 161-kV TL Uprate to 100 Deg C
- 4. Paradise FP-E. Bowling Green 161-kV TL Uprate to 100 Deg C
- 5. Edgoten 161-kV Sub Install 161-kV Caps
- 6. Hopkinsville-Casky 161-kV TL Reconductor














60,000 MW Plan - Resources Assumed

