

TEXAS DEPARTMENT OF INSURANCE

Engineering Services / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104
Phone No. (512) 322-2212 Fax No. (512) 463-6693

PRODUCT EVALUATION

Effective October 1, 2003

WIN-318

*The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**. This product shall be subject to reevaluation 3 years after the effective date.*

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

Series 2040/8040 Vinyl Picture Windows, Non-impact Resistant, manufactured by

Kensington Windows, Inc.
1136 Industrial Road
Vandergrift, PA 15690
(724) 845-8133

will be acceptable in designated catastrophe areas along the Texas Gulf Coast when installed in accordance with the manufacturer's installation instructions and this product evaluation.

PRODUCT DESCRIPTION

The vinyl fixed windows evaluated in this report are non-impact resistant. This evaluation report includes fixed windows with dimensions of 48" x 72". This report includes the following configuration: O.

Description of System Tested:

Overall Size: 48" x 72"

Configuration: O

Frame Construction and Hardware:

The frame is constructed of extruded vinyl. The frame corners are mitered and welded.

Glazing:

Glazing Material: Picture windows are constructed with insulating glass units. The sealed insulating glass units are $\frac{7}{8}$ " thick and are comprised of two double strength ($\frac{1}{8}$ ") annealed monolithic glass lites with a "heat mirror" film suspended between the two lites of double strength glass. The glass is separated by a desiccant filled steel spacer system.

Glazing Method: The lite is interior glazed against an adhesive foam tape backbedding and secured with snap-in glazing beads.

Reinforcement: None.

PRODUCT DESCRIPTION (continued)

Product Identification: A label will be affixed to the window. The label includes the manufacturer's name, performance characteristics and approved inspection agency to indicate compliance with AAMA/NWWDA 101/I.S.2.

LIMITATIONS

| Max. Overall Size | | Design Pressures (psf) |
|-------------------|--------------|------------------------|
| Width (in.) | Height (in.) | |
| 48 | 72 | ± 75 |

Impact Resistance: These window assemblies do not satisfy the Texas Department of Insurance's criteria for protection from windborne debris. These window assemblies will need to be protected with an impact protective system.

Acceptance of Smaller Assemblies: Window assemblies with dimensions equal to or smaller than those specified above are acceptable within the limitations specified in this report. This evaluation report applies to single unit applications.

INSTALLATION INSTRUCTIONS

General: The window assembly shall be installed in accordance with the manufacturer's installation instructions. The wood framing members shall be minimum Spruce-Pine-Fir lumber. All assemblies must comply with the limitations specified in this report.

Installation:

The windows shall be mounted to the wood framing members with a No. 8 x 2 ½" long pan head sheet metal screws through the pre-drilled installation holes in the jambs and a No. 8 x 3 ½" long pan head screw in a pre-drilled installation hole in the head. The screws are located 10" from each end of both jambs and one screw is located at the midspan of the head. There are no fasteners in the sill. The fasteners shall penetrate through the window frame and into the wood framing members.

In addition, a ½" x ¾" wood stop is placed around the interior and exterior perimeter of the window frame. The wood stop is fastened with #6 x 1 ⅝" long coarse thread drywall screws spaced 8" on center around the perimeter.

Note: The manufacturer's installation instructions shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC) and the International Building Code (IBC).