

Bay Area Air Quality Management District

939 Ellis Street
San Francisco, CA 94109
(415) 771-6000

Proposed

MAJOR FACILITY REVIEW PERMIT

Issued To:

**City of Sunnyvale Water Pollution Control
Facility #A0733**

Facility Address:

1444 Borregas Ave.
Sunnyvale, CA 94089

Mailing Address:

P.O. Box 3707
Sunnyvale, CA 94088

Responsible Official

~~Lorrie Gervin,~~
Marvin A. Rose
~~Environmental Division Manager~~
Director of Public Works
~~(408) 730-7268~~
(408) 730-7441

Facility Contact

~~Rosanna Lacarra~~
John Addeo
~~Water Pollution Control Supervisor~~
Operations Manager
~~(408) 730-7260~~
(408) 730-7261

Type of Facility: Public-Owned Treatment Works

~~BAAQMD Permit Division~~
Engineering Contact

Primary SIC: 4952

~~Allen Chiu~~ Hon Man

Product: Municipal Wastewater Treatment Facility

ISSUED BY THE BAY AREA AIR QUALITY MANAGEMENT DISTRICT

Jack P. Broadbent, Executive Officer /Air Pollution Control Officer

Date

TABLE OF CONTENTS

I.	STANDARD CONDITIONS	1
II.	EQUIPMENT LIST.....	5
III.	GENERALLY <u>APPLICABLE</u> REQUIREMENTS	8
IV.	SOURCE-SPECIFIC APPLICABLE REQUIREMENTS.....	11
V.	SCHEDULE OF COMPLIANCE	20
VI.	PERMIT CONDITIONS	22
VII.	APPLICABLE EMISSION LIMITS & COMPLIANCE MONITORING REQUIREMENTS	28
VIII.	TEST METHODS	38
IX.	GLOSSARY	41

I. STANDARD CONDITIONS

A. Administrative Requirements

The permit holder shall comply with all applicable requirements in the following regulations:

BAAQMD Regulation 1 - General Provisions and Definitions
(as amended by the District Board on ~~5/2/01~~10/7/98);

SIP Regulation 1 - General Provisions and Definitions
(as approved by EPA through ~~8/27/99~~ 6/28/99);

BAAQMD Regulation 2, Rule 1 - Permits, General Requirements
(as amended by the District Board on ~~8/1/01~~10/7/98);

SIP Regulation 2, Rule 1 - Permits, General Requirements
(as approved by EPA through 1/26/99);

BAAQMD Regulation 2, Rule 2 - Permits, New Source Review
(as amended by the District Board on ~~5/17/00~~ 10/7/98);

SIP Regulation 2, Rule 2 - Permits, New Source Review and Prevention of Significant Deterioration
(as approved by EPA through 1/26/99);

BAAQMD Regulation 2, Rule 4 - Permits, Emissions Banking
(as amended by the District Board on ~~10/7/98~~ 5/17/00), and

SIP Regulation 2, Rule 4 - Permits, Emissions Banking
(as approved by EPA through 1/26/99), and

BAAQMD Regulation 2, Rule 6 - Permits, Major Facility Review
(as amended by the District Board on 4/16/03).

B. Conditions to Implement Regulation 2, Rule 6, Major Facility Review

- ~~1. This Major Facility Review Permit was issued on [] and expires on []. The permit holder shall submit a complete application for renewal of this Major Facility Review Permit no later than [] and no earlier than []. **If a complete application for renewal has not been submitted in accordance with this deadline, the facility may not operate after [].** (Regulation 2-6-307, 404.2, & 409.6; MOP Volume II, Part 3, §4.2)~~

This Major Facility Review Permit was issued on [] and expires on [when issued, enter 5th anniversary of issue date]. The permit holder shall submit a complete application for renewal of this Major Facility Review Permit no later than [when issued, enter date 6 months prior to permit expiration date] and no earlier than [when issued, enter date 12 months prior to expiration date]. **If a complete application for renewal has not been submitted in accordance with this deadline, the facility may not operate after [when issued, enter 5th anniversary of issue date].** If the permit renewal has not been issued by [], but a complete application for renewal has been submitted in accordance with the above deadlines, the existing permit will continue in force until the District takes final action on the renewal application. (Regulation 2-6-307, 404.2, 407, & 409.6; MOP Volume II, Part 3, §4.2)

2. The permit holder shall comply with all conditions of this permit. The permit consists of this document and all appendices. Any non-compliance with the terms and

I. Standard Conditions

- conditions of this permit will constitute a violation of the law and will be grounds for enforcement action; permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. (Regulation 2-6-307; MOP Volume II, Part 3, §4.11)
3. In the event any enforcement action is brought as a result of a violation of any term or condition of this permit, the fact that it would have been necessary for the permittee to halt or reduce the permitted activity in order to maintain compliance with such term or condition shall not be a defense to such enforcement action. (MOP Volume II, Part 3, §4.11)
 4. This permit may be modified, revoked, reopened and reissued, or terminated for cause. (Regulation 2-6-307, 409.8, 415; MOP Volume II, Part 3, §4.11)
 5. The filing of a request by the facility for a permit modification, revocation and reissuance, or termination, or the filing of a notification of planned changes or anticipated non-compliance does not stay the applicability of any permit condition. (Regulation 2-6-409.7; MOP Volume II, Part 3, §4.11)
 6. This permit does not convey any property rights of any sort, nor any exclusive privilege. (Regulation 2-6-409.7; MOP Volume II, Part 3, §4.11)
 7. The permit holder shall supply within 30 days any information that the District requests in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. (Regulation 1-441, Regulation 2-6-409.4 & 501; MOP Volume II, Part 3, §4.11)
 8. Any records required to be maintained pursuant to this permit ~~which~~ that the permittee considers to contain proprietary or trade secret information shall be prominently designated as such. Copies of any such proprietary or trade secret information which are provided to the District shall be maintained by the District in a locked confidential file, provided, however, that requests from the public for the review of any such information shall be handled in accordance with the District's procedures set forth in Section 11 of the District's Administrative Code. (Regulation 2-6-419; MOP Volume II, Part 3, §4.11)
 9. Proprietary or trade secret information provided to EPA will be subject to the requirements of 40 CFR Part 2, Subpart B - Public Information, Confidentiality of Business Information. (40 CFR Part 2)
 10. The emissions inventory submitted with the application for this Major Facility Review Permit is an estimate of actual emissions or the potential to emit for the time period stated and is included only as one means of determining applicable requirements for emission sources. It does not establish, or constitute a basis for establishing, any new emission limitations. (MOP Volume II, Part 3, §4.11)
 11. The responsible official shall certify all documents submitted by the facility pursuant to the major facility review permit. The certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. The certifications shall be signed by a responsible official for the facility. (MOP Volume II, Part 3, §4.11)

C. Requirement to Pay Fees

I. Standard Conditions

The permit holder shall pay annual fees in accordance with District Regulation 3, including Schedule P. (Regulation 2-6-402 & 409.13, Regulation 3; MOP Volume II, Part 3, §4.12)

D. Inspection and Entry

Access to Facility: The permit holder shall provide reasonable access to the facility and equipment ~~which-that~~ is subject to this permit to the APCO and/or to his or her designee. (Regulation 1-440, Regulation 2-6-409.3; MOP Volume II, Part 3, §4.14)

E. Records

1. The permit holder must provide any information, records, and reports requested or specified by the APCO. (Regulation 1-441, Regulation 2-6-409.4)
2. Notwithstanding the specific wording in any requirement, all records for federally enforceable requirements shall be maintained for at least five years from the date of entry. (Regulation 2-6-501, Regulation 3; MOP Volume II, Part 3, §4.7)

F. Monitoring Reports

Reports of all required monitoring must be submitted to the District at least once every six months, except where an applicable requirement specifies more frequent reporting. Monitoring reports shall be for the following periods: July 1st through December 31st and January 1st through June 30th of each year, and are due on the last day of the month after the end of the reporting period. All instances of non-compliance shall be clearly identified in these reports. The reports shall be certified by the responsible official as true, accurate, and complete. In addition, all instances of non-compliance with the permit shall be reported in writing to the District's Compliance and Enforcement Division within 10 calendar days of the discovery of the incident. Within 30 calendar days of the discovery of any incident of non-compliance, the facility shall submit a written report including the probable cause of non-compliance and any corrective or preventative actions. The reports shall be sent to the following address:

Director of Compliance and Enforcement
Bay Area Air Quality Management District
939 Ellis Street
San Francisco, CA 94109
Attn: Title V Reports

(Regulation 2-6-502, Regulation 3; MOP Volume II, Part 3, §4.7)

G. Compliance Certification

Compliance certifications shall be submitted annually by the responsible official of this facility to the Bay Area Air Quality Management District and to the Environmental Protection Agency. The certification period will be July 1st to June 30th of each year. The certification shall be submitted by July 31st of each year. The certification must list each applicable requirement, the compliance status, whether compliance was continuous or intermittent, the method used to determine compliance, and any other specific information required by the permit. The permit holder may satisfy this requirement through submittal of District-generated Compliance Certification forms. The certification should be directed to the District's Compliance and Enforcement Division at the address above, and a copy of the certification should be sent to the Environmental Protection Agency at the following address:

I. Standard Conditions

Director of the Air Division
USEPA, Region IX
75 Hawthorne Street
San Francisco, CA 94105
Attention: Air-3

(MOP Volume II, Part 3, §4.5 and 4.15)

H. Emergency Provisions

1. The permit holder may seek relief from enforcement action in the event of a breakdown, as defined by Regulation 1-208 of the District's Rules and Regulations, by following the procedures contained in Regulations 1-431 and 1-432. The District will thereafter determine whether breakdown relief will be granted in accordance with Regulation 1-433. (MOP Volume II, Part 3, §4.8)
2. The permit holder may seek relief from enforcement action for a violation of any of the terms and conditions of this permit ~~caused by conditions beyond the permit holder's reasonable control~~ by applying to the District's Hearing Board for a variance pursuant to Health and Safety Code Section 42350. The Hearing Board will determine after notice and hearing whether variance relief should be granted in accordance with the procedures and standards set forth in Health and Safety Code Section 42350 et seq. ~~Any variance granted by the Hearing Board from any term or condition of this permit which lasts longer than 90 days will be subject to EPA approval.~~ (MOP Volume II, Part 3, §4.8)
3. ~~Notwithstanding the foregoing,~~ The granting by the District of breakdown relief or the issuance by the Hearing Board of a variance will not provide relief from federal enforcement. (MOP Volume II, Part 3, §4.8)

I. Severability

In the event that any provision of this permit is invalidated by a court or tribunal of competent jurisdiction, or by the Administrator of the EPA, all remaining portions of the permit shall remain in full force and effect. (Regulation 2-6-409.5; MOP Volume II, Part 3, §4.10)

J. Miscellaneous Conditions

1. The maximum capacity for each source as shown in Table II-A is the maximum allowable capacity. Exceedance of the maximum allowable capacity for any source is a violation of Regulation 2, Rule 1, Section 301. (Regulation 2-1-301)

JK. Accidental Release

This facility is subject to 40 CFR Part 68, Chemical Accident Prevention Provisions. The permit holder shall submit a risk management plan (RMP) by the date specified in §68.10. The permit holder shall also certify compliance with the requirements of Part 68 as part of the annual compliance certification, as required by Regulation 2, Rule 6. (40 CFR Part 68, Regulation 2, Rule 6)

II. EQUIPMENT LIST

A. ~~Permitted Source List~~

~~Each of the following sources has been issued a permit to operate pursuant to the requirements of BAAQMD Regulation 2-1-302. The capacities in this table are the maximum allowable capacities for each source, pursuant to Standard Condition I.J and Regulation 2-1-301.~~

Table II-A

Each of the following sources has been issued a permit to operate pursuant to the requirements of BAAQMD Regulation 2, Permits. The capacities in this table are the maximum allowable capacities for each source, pursuant to Standard Condition I.J and Regulation 2-1-301.

S-#	Description	Make or Type	Model	Capacity
S-12	Waste Gas Burner, Pedestal Type	Pacific Flush Tank	4D-1348	5.8 MM Btu/hr
S-13	Digester Waste Gas Flare	John Zink	EEF V-3	7.5 MMbtu/hr
S-14	Engine Generator (landfill gas, digester gas, natural gas) (Existing after 6/15/97)	Caterpillar	3516	8.2 MMbtu/hr, 1150 hp
S-15	Engine Generator (landfill gas, digester gas, natural gas) (Existing after 6/15/97)	Caterpillar	3516	8.2 MMbtu/hr, 1150 hp
S16	<u>Influent pump #1 – IC Engine</u> (Digester gas)	<u>Waukesha</u>	<u>NKR 1905</u>	<u>2.52 MMbtu/hr, 224 HP,</u> <u>Displacement 1905</u> <u>cubic inches</u>
S-17	<u>Influent pump #2 – IC Engine</u> (Digester gas)	<u>Waukesha</u>	<u>NKR 1905</u>	<u>2.52 MMbtu/hr, 224 HP,</u> <u>Displacement 1905</u> <u>cubic inches</u>
S-18	<u>Influent pump #3 – IC Engine</u> (Digester gas)	<u>Waukesha</u>	<u>NKR 1905</u>	<u>2.52 MMbtu/hr, 224 HP,</u> <u>Displacement 1905</u> <u>cubic inches</u>
S-19	<u>Emergency Natural Gas</u> <u>Standby Generator</u>	<u>Ford</u>	<u>LSG875</u>	<u>1.7 MMbtu/hr, 200 HP,</u> <u>Displacement 460 cubic</u> <u>inches</u>
S-20	<u>Parts Washer</u>	<u>Model I</u>	<u>52150</u>	<u>20 Gallons</u>
S-100	Municipal Wastewater Treatment Plant	custom		
S-110	Preliminary Treatment	custom		19.5 MM gal/day

II. Equipment

Table II-A

Each of the following sources has been issued a permit to operate pursuant to the requirements of BAAQMD Regulation 2, Permits. The capacities in this table are the maximum allowable capacities for each source, pursuant to Standard Condition I.J and Regulation 2-1-301.

S-120	Primary Treatment	custom		19.5 MM gal/day
S-130	Secondary Treatment	custom		19.5 MM gal/day
S-140	Tertiary Treatment	custom		19.5 MM gal/day
S-150	Disinfection	custom		19.5 MM gal/day
S-161	Solids Dewatering System	custom		19.5 MM gal/day
S-170	Anaerobic Digesters	custom		19.5 MM gal/day

II. Equipment

B. Abatement Device List

Table II B – Abatement Devices

A-#	Description	Source(s) Controlled	Applicable Requirement	Operating Parameters	Limit or Efficiency
<u>A-12</u>	<u>Waste Gas Burner, Pedestal Type, Digester gas</u>	<u>S-170</u>	<u>BAAQMD Regulation 8- 2-30</u>	<u>None</u>	<u>15 lb/day or 300 PPM total carbon on a dry basis</u>
<u>A-13</u>	<u>Waste Gas Flare, Digester gas</u>	<u>S-170</u>	<u>BAAQMD Regulation 8- 2-30</u>	<u>None</u>	<u>15 lb/day or 300 PPM total carbon on a dry basis</u>

III. GENERALLY APPLICABLE REQUIREMENTS

The permit holder shall comply with all applicable requirements, including those specified in the BAAQMD and SIP rules and regulations and other federal requirements cited below. These requirements apply in a general manner to the facility and/or to sources exempt from the requirement to obtain a District Permit to Operate. The District has determined that these requirements will not be violated under normal, routine operations, and that no additional periodic monitoring or reporting to demonstrate compliance is warranted. In cases where a requirement, in addition to being generally applicable, is also specifically applicable to one or more sources, the requirement and the source are also included in Section IV, Source-Specific Applicable Requirements, of this permit. This section also contains provisions that may apply to temporary sources.

The dates in parentheses in the Title column identify the versions of the regulations being cited and are, as applicable:

1. BAAQMD regulation(s): The date(s) of adoption or most recent amendment of the regulation by the District Board of Directors
2. Any federal requirement, including a version of a District regulation that has been approved into the SIP: The most recent date of EPA approval of any portion of the rule, encompassing all actions on the rule through that date

The full language of SIP requirements is on EPA Region 9's website. The address is <http://yosemite1.epa.gov/r9/r9sips.nsf/California?ReadForm&Start=1&Count=30&Expand=3.1>.

~~The full language of SIP requirements is included in Appendix A of this permit if the SIP requirement is different from the current BAAQMD requirement.~~

NOTE:

There are differences between the current BAAQMD rules and the version of the rules in the SIP. ~~For specific information, contact the District's Rule Development Section of the Enforcement Division.~~ All sources must comply with both versions of the rule until US EPA has reviewed and approved the District's revision of the regulation.

**Table III
 Generally Applicable Requirements**

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)
BAAQMD Regulation 1	General Provisions and Definitions (5/2/01)	N
SIP Regulation 1	General Provisions and Definitions (8/27/99 6/28/99)	Y

III. Generally Applicable Requirements

Table III
Generally Applicable Requirements

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)
<u>BAAQMD Regulation 2, Rule 1</u>	<u>General Requirements (8/1/01)</u>	<u>N</u>
<u>SIP Regulation 2, Rule 1</u>	<u>General Requirements (8/27/99 1/26/99)</u>	<u>Y</u>
<u>BAAQMD Regulation 2-1-429</u>	<u>Federal Emissions Statement (6/7/95)</u>	<u>Y</u>
BAAQMD Regulation 4	Air Pollution Episode Plan (3/20/91)	N
SIP Regulation 4	Air Pollution Episode Plan (8/06/90)	Y
BAAQMD Regulation 5	Open Burning (11/2/94)	Y
BAAQMD Regulation 6	Particulate Matter and Visible Emissions (12/19/90)	Y
BAAQMD Regulation 7	Odorous Substances (3/17/82)	N
BAAQMD Regulation 8, Rule 1	Organic Compounds - General Provisions (6/15/94)	Y
<u>BAAQMD Regulation 8, Rule 2</u>	<u>Organic Compounds – Miscellaneous Operations (6/15/94)</u>	<u>Y</u>
BAAQMD Regulation 8, Rule 3	Organic Compounds - Architectural Coatings (12/20/95 11/21/01)	Y
BAAQMD Regulation 8, Rule 4	Organic compounds - General Solvent and Surface Coating Operations (5/15/96 10/16/02)	N
SIP Regulation 8, Rule 4	Organic compounds - General Solvent and Surface Coating Operations (12/20/95 12/23/97)	Y
BAAQMD Regulation 8, Rule 16	Organic Compounds-Solvent Cleaning Operation (9/16/98 12/20/95)	Y
SIP Regulation 8, Rule 16	Organic Compounds-Solvent Cleaning Operation (9/16/98)	Y
<u>BAAQMD Regulation 8, Rule 40</u>	<u>Organic Compounds - Aeration of Contaminated Soil and Removal of Underground Storage Tanks (12/15/99)</u>	<u>Y</u>
<u>BAAQMD Regulation 8, Rule 47</u>	<u>Organic Compounds - Air Stripping and Soil Vapor Extraction Operations (6/15/94)</u>	<u>Y</u>
BAAQMD Regulation 8, Rule 49	Organic Compounds - Aerosol Paint Products (12/20/95)	N
SIP Regulation 8, Rule 49	Organic Compounds - Aerosol Paint Products (3/22/95)	Y
BAAQMD Regulation 8, Rule 51	Organic Compounds - Adhesive and Sealant Products (12/20/95)	N
BAAQMD Regulation 9, Rule 1	Inorganic Gaseous Pollutants-Sulfur Dioxide (3/15/95)	Y
BAAQMD Regulation 9, Rule 2	Inorganic Gaseous Pollutants-Hydrogen Sulfide (10/6/99 3/17/82)	N
BAAQMD Regulation 11, Rule 2	Hazardous Pollutants - Asbestos Demolition, Renovation and Manufacturing (12/4/91 10/7/98)	Y

III. Generally Applicable Requirements

Table III
Generally Applicable Requirements

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)
BAAQMD Regulation 12, Rule 4	Miscellaneous Standards of Performance - Sandblasting (7/11/90)	N
SIP Regulation 12, Rule 4	Miscellaneous Standards of Performance - Sandblasting (9/2/81)	Y
<u>California Health and Safety Code Section 41750 et seq.</u>	<u>Portable Equipment</u>	<u>N</u>
<u>California Health and Safety Code Section 44300 et seq.</u>	<u>Air Toxics “Hot Spots” Information and Assessment Act of 1987</u>	<u>N</u>
<u>EPA Regulation 40 CFR 82</u>	<u>Protection of Stratospheric Ozone (2/21/95)</u>	
<u>40 CFR Part 61, Subpart M</u>	<u>National Emission Standards for Hazardous Air Pollutants – National Emission Standard for Asbestos (6/19/95)</u>	<u>Y</u>

IV. SOURCE-SPECIFIC APPLICABLE REQUIREMENTS

The permit holder shall comply with all applicable requirements, including those specified in the BAAQMD and SIP Rules and Regulations and other federal requirements cited below. The requirements cited in the following tables apply in a specific manner to the indicated source(s).

The dates in parentheses in the Title column identify the versions of the regulations being cited and are, as applicable:

1. BAAQMD regulation(s):
 The date(s) of adoption or most recent amendment of the regulation by the District Board of Directors
2. Any federal requirement, including a version of a District regulation that has been approved into the SIP:
 The most recent date of EPA approval of any portion of the rule, encompassing all actions on the rule through that date

The full text of each permit condition cited is included in Section VI, Permit Conditions, of this permit. The full language of SIP requirements is on EPA Region 9's website. The address is:

<http://yosemite1.epa.gov/r9/r9sips.nsf/California?ReadForm&Start=1&Count=30&Expand=3.1>. All other text may be found in the regulations themselves.

Table IV-A
Source-specific Applicable Requirements
S-14 Engine Generator
S-15 Engine Generator

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
<u>BAAQMD</u>			
<u>Regulation 1</u>	<u>General Provisions and Definitions (5/2/01)</u>		
<u>1-107</u>	<u>Combinations of Emissions</u>	<u>Y</u>	
<u>1-523</u>	<u>Parametric Monitoring and Recordkeeping Procedures</u>	<u>N</u>	
<u>1-523.1</u>	<u>Reporting requirement for periods of in-operation > 24 hours</u>	<u>Y</u>	
<u>1-523.2</u>	<u>Limit on duration of in operation</u>	<u>Y</u>	
<u>1-523.3</u>	<u>Reporting requirement for violations of any applicable limits</u>	<u>N</u>	
<u>1-523.4</u>	<u>Records of in-operation, tests, calibrations, adjustments, & maintenance</u>	<u>Y</u>	
<u>1-523.5</u>	<u>Maintenance and calibration</u>	<u>N</u>	
<u>SIP</u>			
<u>Regulation 1</u>	<u>General Provisions and Definitions (6/28/99)</u>		

IV. Source Specific Applicable Requirements

Table IV-A
Source-specific Applicable Requirements
S-14 Engine Generator
S-15 Engine Generator

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
<u>1-523</u>	<u>Parametric Monitoring and Recordkeeping Procedures</u>	<u>Y</u> ¹	
<u>1-523.3</u>	<u>Reports of Violations</u>	<u>Y</u> ¹	
<u>BAAQMD</u> <u>Regulation 6</u>	<u>Particulate Matter and Visible Emissions (12/19/90)</u>		
<u>6-301</u>	<u>Ringelmann No. 1 Limitation</u>	<u>Y</u>	
<u>6-305</u>	<u>Visible Particles</u>	<u>Y</u>	
<u>6-310</u>	<u>Particle Weight Limitation</u>	<u>Y</u>	
<u>6-401</u>	<u>Appearance of Emissions</u>	<u>Y</u>	
<u>BAAQMD</u> <u>Regulation 8</u>	<u>Organic Compounds</u>		
<u>8-2-301</u>	<u>15 lb/day or 300 PPM total carbon on a dry basis</u>	<u>Y</u>	
<u>BAAQMD</u> <u>Regulation 8,</u> <u>Rule 34</u>	<u>Organic Compounds - Solid Waste Disposal Sites (10/6/99)</u>		
<u>8-34-113</u>	<u>Limited Exemption, Inspection and Maintenance</u>	<u>Y</u>	
<u>8-34-113.1</u>	<u>Emission Minimization Requirement</u>	<u>Y</u>	
<u>8-34-113.2</u>	<u>Shutdown Time Limitation</u>	<u>Y</u>	
<u>8-34-113.3</u>	<u>Record keeping Requirement</u>	<u>Y</u>	
<u>8-34-301</u>	<u>Landfill Gas Collection and Emission Control System Requirements</u>	<u>Y</u>	
<u>8-34-301.1</u>	<u>Continuous Operation</u>	<u>Y</u>	
<u>8-34-301.2</u>	<u>Collection and Control Systems Leak Limitations</u>	<u>Y</u>	
<u>8-34-301.4</u>	<u>Limits for Other Emission Control Systems</u>	<u>Y</u>	
<u>8-34-412</u>	<u>Compliance Demonstration Tests</u>	<u>Y</u>	
<u>8-34-413</u>	<u>Performance Test Report</u>	<u>Y</u>	
<u>8-34-501</u>	<u>Operating Records</u>	<u>Y</u>	
<u>8-34-501.2</u>	<u>Emission Control System Downtime</u>	<u>Y</u>	
<u>8-34-501.4</u>	<u>Testing</u>	<u>Y</u>	
<u>8-34-501.6</u>	<u>Leak Discovery and Repair Records</u>	<u>Y</u>	
<u>8-34-501.10</u>	<u>Gas Flow Rate Records for All Emission Control Systems</u>	<u>Y</u>	
<u>8-34-501.11</u>	<u>Records of Key Emission Control System Operating Parameters</u>	<u>Y</u>	
<u>8-34-501.12</u>	<u>Records Retention for 5 Years</u>	<u>Y</u>	
<u>8-34-503</u>	<u>Landfill Gas Collection and Emission Control System Leak Testing</u>	<u>Y</u>	

IV. Source Specific Applicable Requirements

Table IV-A
Source-specific Applicable Requirements
S-14 Engine Generator
S-15 Engine Generator

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
<u>8-34-504</u>	<u>Portable Hydrocarbon Detector</u>	<u>Y</u>	
<u>8-34-508</u>	<u>Gas Flow Meter</u>	<u>Y</u>	
<u>8-34-509</u>	<u>Key emission control system operating parameters</u>	<u>Y</u>	
<u>BAAQMD Regulation 9, Rule 1</u>	<u>Inorganic Gaseous Pollutants, Sulfur Dioxide (March 15, 1995)</u>		
<u>9-1-301</u>	<u>Ground level of SO₂ < 0.5 PPM for 3 consecutive minutes, or 0.25 PPM averaged over 60 consecutive minutes, or 0.05 PPM averaged over 24 hours</u>	<u>Y</u>	
<u>9-1-302</u>	<u>Concentration of SO₂ at the outlet < 300 PPM (dry)</u>	<u>Y</u>	
<u>BAAQMD Regulation 9, Rule 2</u>	<u>Inorganic Gaseous Pollutants, Hydrogen Sulfide (October 6, 1999)</u>		
<u>9-2-301</u>	<u>Ground level concentration of hydrogen sulfide < 0.03 PPM averaged over 60 consecutive minutes</u>	<u>Y</u>	
<u>BAAQMD Regulation 9 Rule 8</u>	<u>NO_x and CO requirements for Stationary Internal Combustion Engines (8/1/01 1/20/93)</u>	Y	
<u>9-8-301</u>	<u>Emission Limits - Fossil Derived Fuel Gas</u>	<u>Y</u>	
<u>9-8-301.2</u>	<u>NO_x Emission Limit for Lean Burn Engines</u>	<u>Y</u>	
<u>9-8-301.3</u>	<u>CO Emission Limit for Lean Burn Engines</u>	<u>Y</u>	
<u>9-8-302</u>	<u>Emission Limits - Waste Derived Fuel Gas</u>	<u>Y</u>	
<u>9-8-302.1</u>	<u>NO_x Emission Limit for Lean Burn Engines</u>	<u>Y</u>	
<u>9-8-302.3</u>	<u>CO Emission Limit for Lean Burn Engines</u>	<u>Y</u>	
<u>BAAQMD Cond #10844</u>			
<u>Part 1</u>	<u>Emission Limits (basis: BACT, Offsets)</u>	<u>Y</u>	<u>6/15/97</u>
<u>Part 4</u>	<u>Periodic monitoring (basis: Regulation 2-6-409.2)</u>	<u>Y</u>	<u>6/15/97</u>
<u>Part 1</u>	<u>Fuel Restrictions (Offsets and Cumulative Increase)</u>	<u>Y</u>	
<u>Part 2</u>	<u>Heat Input Limits (Offsets and Cumulative Increase)</u>	<u>Y</u>	
<u>Part 3</u>	<u>Continuous operating requirement (Regulation 8-34-301.1)</u>	<u>Y</u>	
<u>Part 4</u>	<u>Emission rate Requirements for POC, CO and NO_x (BACT, Offset)</u>	<u>Y</u>	

IV. Source Specific Applicable Requirements

Table IV-A
Source-specific Applicable Requirements
S-14 Engine Generator
S-15 Engine Generator

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
<u>Part 5</u>	<u>Gas flow meter and recorder requirement (Offsets and Cumulative Increase)</u>	<u>Y</u>	
<u>Part 6</u>	<u>Annual source test requirement (BACT and Regulations 8-34-301.4, 8-34-412, 9-8-302.1, and 9-8-302.3)</u>	<u>Y</u>	
<u>Part 7</u>	<u>Record keeping requirements (BACT, Offsets, Cumulative Increase, and Regulation 8-34-501)</u>	<u>Y</u>	
<u>Part 8</u>	<u>Establish air to fuel ratio setting range and exhaust gas oxygen content range, or other proposed key emission control system operating parameters to be approved by the APCO, and establish monitoring requirements</u>	<u>Y</u>	
<u>Part 9</u>	<u>Sulfur content limit of landfill gas and digester gas, and monitoring requirements (Regulation 9-1-302)</u>	<u>Y</u>	

1. This section has been removed from BAAQMD Regulations because it has been superseded. Nevertheless, the source must comply with this regulation until US EPA has reviewed and approved (or disapproved) the District's revision of the regulation

IV. Source Specific Applicable Requirements

Table IV – B
Source-specific Applicable Requirements
S-16 Influent Pump #1 – IC Engine
S-17 Influent Pump #2 – IC Engine
S-18 Influent Pump #3 – IC Engine

<u>Applicable Requirement</u>	<u>Regulation Title or Description of Requirement</u>	<u>Federally Enforceable (Y/N)</u>	<u>Future Effective Date</u>
<u>BAAQMD Regulation 1</u>	<u>General Provisions and Definitions (5/2/01)</u>	N	
1-107	<u>Combination of Emissions</u>	N	
<u>BAAQMD Regulation 6</u>	<u>Particulate Matter and Visible Emissions</u>	Y	
6-301	<u>Ringelmann No. 1 Limitation</u>	Y	
6-305	<u>Visible particles</u>	Y	
6-310	<u>Particulate weight limitation</u>	Y	
6-401	<u>Appearance of emissions</u>	Y	
<u>BAAQMD Regulation 8</u>	<u>Organic Compounds</u>		
8-2-301	<u>15 lb/day or 300 PPM total carbon on a dry basis</u>	Y	
<u>BAAQMD Regulation 9, Rule 1</u>	<u>Inorganic Gaseous Pollutants, Sulfur Dioxide (March 15, 1995)</u>	Y	
9-1-301	<u>Limitations on Ground Level Concentrations of sulfur dioxide</u>	Y	
9-1-302	<u>General Emission Limitation</u>	Y	
<u>BAAQMD Regulation 9, Rule 2</u>	<u>Inorganic Gaseous Pollutants, Hydrogen Sulfide (October 6, 1999)</u>	Y	
9-2-301	<u>Ground level concentration of hydrogen sulfide < 0.03 PPM averaged over 60 consecutive minutes</u>	N	
<u>BAAQMD Cond #19978</u>			
Part 1	<u>Visible emissions of particulate matter</u>	Y	

IV. Source Specific Applicable Requirements

Table IV – C
Source-specific Applicable Requirements
S-19 EMERGENCY NATURAL GAS FIRED STANDBY GENERATOR

<u>Applicable Requirement</u>	<u>Regulation Title or Description of Requirement</u>	<u>Federally Enforceable (Y/N)</u>	<u>Future Effective Date</u>
<u>BAAQMD Regulation 6</u>	<u>Particulate Matter and Visible Emissions (December 19, 1990)</u>	<u>Y</u>	
<u>6-303</u>	<u>Ringelmann No. 2 Limitation</u>	<u>Y</u>	
<u>6-305</u>	<u>Shall not emit particles to cause annoyance to other person</u>	<u>Y</u>	
<u>6-310</u>	<u>Particulate matter < 343 mg per dscm of exhaust gas volume</u>	<u>Y</u>	
<u>6-401</u>	<u>Operator shall be able to know the appearance of the emission at all times</u>	<u>Y</u>	
<u>BAAQMD Regulation 9 Rule 1</u>	<u>Inorganic Gaseous Pollutants, Sulfur Dioxide (March 15, 1995)</u>	<u>Y</u>	
<u>9-1-301</u>	<u>Limitations on Ground Level Concentrations of sulfur dioxide</u>	<u>Y</u>	
<u>9-1-302</u>	<u>General Emission Limitation</u>	<u>Y</u>	
<u>BAAQMD Regulation 9 Rule 8</u>	<u>Inorganic Gaseous Pollutants, NOx and CO from IC engines (August 1, 2001)</u>	<u>Y</u>	
<u>9-8-331</u>	<u>200 hours of operation limit on reliability-related activities</u>	<u>N</u>	
<u>9-8-530</u>	<u>Monitoring and recordkeeping requirements</u>	<u>N</u>	
<u>BAAQMD Cond #19929</u>			
<u>Part 1</u>	<u>Hours of operation limit on reliability-related activities (Basis: Regulation 9-8-331)</u>	<u>Y</u>	
<u>Part 2</u>	<u>Recording equipment (Basis: Regulation 9-8-530)</u>	<u>Y</u>	
<u>Part 3</u>	<u>Record of hours of operation (Basis: Regulation 9-8-530)</u>	<u>Y</u>	

IV. Source Specific Applicable Requirements

Table IV – D
Source-specific Applicable Requirements
S-20 PARTS WASHERS

<u>Applicable Requirement</u>	<u>Regulation Title or Description of Requirement</u>	<u>Federally Enforceable (Y/N)</u>	<u>Future Effective Date</u>
<u>BAAQMD Regulation 8 Rule 16</u>	<u>Solvent Cleaning Operations (10/16/02)</u>	<u>Y</u>	
<u>8-16-303</u>	<u>Cold Cleaner Requirements</u>	<u>Y</u>	
<u>8-16-501</u>	<u>Solvent Records</u>	<u>Y</u>	
<u>SIP Regulation 8, Rule 16</u>	<u>Organic Compounds-Solvent Cleaning Operation (9/16/98)</u>	<u>Y</u>	
<u>BAAQMD Cond #19929</u>			
<u>Part 1</u>	<u>Usage limit (Basis: Plant Cumulative Increase)</u>	<u>Y</u>	
<u>Part 2</u>	<u>Record keeping (Basis: Plant Cumulative Increase)</u>	<u>Y</u>	

IV. Source Specific Applicable Requirements

Table IV-E
Source-specific Applicable Requirements
S-100 Municipal Wastewater Treatment Plant
S-110 Preliminary Treatment
S-120 Primary Treatment
S-130 Secondary Treatment
S-140 Tertiary Treatment
S-150 Disinfection
S-161 Solids Dewatering System
S-170 Anaerobic Digestors

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
BAAQMD Regulation 8, Rule 2	Organic Compounds-Miscellaneous Operation (6/15/94)		
8-2-301	Miscellaneous Operations Standards	Y	

IV. Source Specific Applicable Requirements

Table IV - F
Source-specific Applicable Requirements
S-170 Anaerobic Digesters

<u>Applicable Requirement</u>	<u>Regulation Title or Description of Requirement</u>	<u>Federally Enforceable (Y/N)</u>	<u>Future Effective Date</u>
<u>BAAQMD Regulation 8, Rule 2</u>	<u>Organic Compounds-Miscellaneous Operation (6/15/94)</u>	<u>Y</u>	
<u>8-2-301</u>	<u>Miscellaneous Operations Standards</u>	<u>Y</u>	
<u>BAAQMD Regulation 9, Rule 2</u>	<u>Inorganic Gaseous Pollutants-Hydrogen Sulfide (10/6/99)</u>		
<u>9-2-301</u>	<u>Limitations of Hydrogen Sulfide</u>	<u>N</u>	

V. SCHEDULE OF COMPLIANCE

A. STANDARD SCHEDULE OF COMPLIANCE

The permit holder shall ~~continue to~~ comply with all applicable requirements cited in ~~Parts III and IV~~ of this permit. The permit holder shall also comply with applicable requirements that become effective during the term of this permit on a timely basis.

B. CUSTOM SCHEDULE OF COMPLIANCE

The owner/operator is out of compliance with the requirements in BAAQMD Regulation 8, Rule 34, because Sources S-14 and S-15, Engines, are used to abate the landfill at Facility A5095, but the equipment is not in complete compliance.

The section with which the facility does not comply is 509. Therefore, the District is imposing the following Schedule of Compliance.

Milestones

By ~~March 31, 2005~~ **within three months of issuance of MFR renewal permit**

Submit a source test protocol to the Source Test Section at the District for determination of key emission control system operating parameters pursuant to BAAQMD Regulations 8-34-301.4 and 509 for Sources S-14 and S-15, Engines.

By ~~June 30, 2005~~ **within six months of issuance of MFR renewal permit**

Conduct source tests to determine key emission control system operating parameters pursuant to BAAQMD Regulations 8-34-301.4 and 509 for Sources S-14 and S-15, Engines.

Initiate recordkeeping for key emission control system operating parameters.

By ~~July 31, 2005~~ **within seven months of issuance of MFR renewal permit**

Submit application for a revision of the District and Title V permits to include key emission control system operating parameters pursuant to BAAQMD Regulations 8-34-301.4 and 509 for Sources S-14 and S-15, Engines.

Within 3 months of approval of key emission control system operating parameters

Purchase and/or install monitoring equipment to monitor key emission control system operating parameters pursuant to BAAQMD Regulations 8-34-301.4 and 509. Initiate recordkeeping for key emission control system operating parameters

Reporting Requirements

Progress reports shall be submitted on the last day of every month to the Director of Enforcement until the above actions are completed. The progress reports shall contain the date by which the item in the custom schedule of compliance was achieved or an

V. Schedule of Compliance

explanation of why the item was not achieved by the above date and any corrective measures adopted.

The period of non-compliance with these requirements is automatically terminated on the date that all items above are complete. Significant revision procedures will be used to delete the Custom Schedule of Compliance after completion.

VI. PERMIT CONDITIONS

Any condition that is preceded by an asterisk is not federally enforceable.

A. ~~Source Specific Permit Conditions~~

Condition 10844

For Sources S-14 and S-15, Engine Generators

Effective ~~6/15/97~~

1. The Engine Generators (S-14 and S-15) shall be fired on landfill gas, digester gas and natural gas exclusively. (Basis: Offsets and Cumulative Increase)
- ~~2. The owner/operator shall ensure that an annual performance test is conducted in accordance with the District test procedures to demonstrate compliance with the NOx and CO limits. The owner/operator may submit an alternative monitoring plan to the District for approval. If the alternative monitoring plan is approved, the plan shall supersede the annual source test requirement. Approvals shall be processed using the permit modification procedure contained in Regulation 2, Rule 6.~~
2. The heat input to S-14 and S-15 shall not exceed 200 million BTUs per day per generator nor 72,000 million BTUs per generator during any consecutive 12-month period. (Basis: Offsets and Cumulative Increase)
3. S-14 and S-15 shall operate continuously during all times that landfill gas and digester gas are vented to them. (Basis: Regulation 8-34-301.1)
4. ~~1. The emission factors of rates from the Engine/Generator Engine Generator No. 4 (S-14) and Engine/Generator Engine Generator No. 5 (S-15) shall not exceed:~~
 - a. 0.3 gram/bhp-hr for POC,
 - b. 2.5 gram/bhp-hr for CO; and
 - c. 1.5 gram/bhp-hr for NOx. (Basis: BACT, Offsets)

VI. Permit Conditions

5. In order to demonstrate compliance with part 2, S-14 and S-15 shall be equipped with gas flow meters and recorders that record the gas flow rates of landfill gas, digester gas and natural gas at least every 15 minutes. (Basis: Offsets and Cumulative Increase)

6. In order to demonstrate compliance with part 4 above and Regulations 8-2-301, 8-34-301.4, 9-8-302.1, and 9-8-302.3, the Permit Holder shall ensure that a District approved source test is conducted annually on S-14 and S-15. Source tests shall be conducted no sooner than 9 months and no later than 12 months after the previous source test. The Source Test Section of the District shall be contacted to obtain their approval of the source test procedures at least 14 days in advance of each source test. They shall be notified of the scheduled test date at least 7 days in advance of each source test. The source test report shall be submitted to the Compliance and Enforcement Division of the District within 45 days of the test date. The report shall include the following information:
 - a. landfill gas and digester gas flow rates to S-14 and S-15 (dry basis);
 - b. concentrations (dry basis) of carbon dioxide (CO₂), nitrogen (N₂), oxygen (O₂), methane (CH₄), and non-methane organic compounds (NMOC) in the landfill gas and digester gas;
 - c. exhaust gas flow rates from S-14 and S-15 (dry basis);
 - d. concentrations (dry basis) of NO_x, CO, NMOC, and O₂ in the exhaust gas from S-14 and S-15;
 - e. the NMOC destruction efficiency achieved by S-14 and S-15; and
 - f. the average air to fuel ratio setting range and exhaust gas oxygen content range, or other proposed key emission control system operating parameters approved by the APCO, for S-14 and S-15 that is required to maintain compliance with part 4 above and Regulation 8-34-301.4.
(Basis: BACT, and Regulations 8-34-301.4, 8-34-412, 9-8-302.1, and 9-8-302.3)

7. The Permit Holder shall maintain the following records:
 - a. Records of all start up and shut down dates and times and the reason for any shut downs for S-14 and S-15.
 - b. Records of landfill gas, digester gas and natural gas throughputs to S-14 and S-15.
 - c. On a monthly basis calculate and record the maximum daily and total monthly heat input rate (in BTU) to each engine based on the average methane concentrations in the landfill gas and digester gas (as measured during the most recent source test), a high heating value for methane of 1013 BTU/ft³ at 60 degrees F, and the amounts of landfill gas and digester gas burned in each generator.

VI. Permit Conditions

d. Records of all compliance demonstration test data.

All records shall be retained on site for a minimum of 5 years and shall be made available to District staff upon request. (Basis: BACT, Offsets, Cumulative Increase, and Regulation 8-34-501)

8. Within 3 months of renewal of the MFR Permit, the permit holder of S-14 and S-15 shall submit a source test protocol to the District to establish the air to fuel ratio setting range and exhaust gas oxygen content range, or other proposed key emission control system operating parameters to be approved by the APCO, that S-14 and S-15 shall be operated at to demonstrate compliance with Regulation 8-34-301.4 NMOC reduction efficiency. Within 3 months, the permit holder shall identify monitoring equipment, procedures and monitoring frequency for those agreed key parameter measurements. The Engineering Division and Source Test Section of the District shall review and approve these key parameters, source test protocols, and monitoring requirements.

Within 3 months of receiving the APCO's approval of the above, the permit holder shall conduct source tests to determine source specific ranges for the key parameters and shall submit test results within 60 days of conducting source test. The Source Test Section of the District shall review and approve test results. The Engineering Division of the District shall modify permit conditions to include the source key parameters, operating ranges/limits, and the final monitoring procedures and frequency using minor permit revision procedures in accordance with BAAQMD Regulation 2-6-414. The MFR Permit shall be modified to reflect these condition revisions.

9. Total reduced sulfur compounds in the collected landfill gas and digester gas shall be monitored as a surrogate for monitoring sulfur dioxide in control system's exhaust. The concentrations of total reduced sulfur compounds in the collected landfill gas and digester gas shall not exceed 1300 ppmv (dry). In order to demonstrate compliance with this part, the permit holder shall measure the total sulfur content in collected landfill gas and digester gas on a quarterly basis using a Draeger Tube. The samples of landfill gas and digester gas shall be taken from their respective main gas headers. The permit holder shall follow the manufacturer's recommended procedures for using the Draeger Tube and interpreting the results. The permit holder shall conduct the first Draeger Tube test no later than 3 months after the renewal date of the MFR Permit and quarterly thereafter. (Basis: Regulation 9-1-302)

VI. Permit Conditions

Condition 19929

S-19 Emergency Natural Gas Fired Standby Generator

REQUIREMENTS FOR ESSENTIAL EMERGENCY ENGINES: An essential emergency engine is one that is used in the service of an essential public service. An essential public service is defined in Reg. 9-8-233 as: a sewage treatment facility, and associated collection system, which is publicly owned and operated; water treatment and delivery operations; public transit; police or fire fighting facility; airport runway lights; or a hospital or other medical emergency facility.

1. Hours of Operation: The owner/operator shall operate the emergency standby engine(s) only to mitigate emergency conditions or for reliability- related activities. Operating while mitigating emergency conditions is unlimited. Operating for reliability-related activities is limited to 200 hours per any calendar year. [Basis: Reg. 9-8-331]

"Emergency Conditions" is defined as any of the following:

- a. Loss of regular natural gas supply.
- b. Failure of regular electric power supply.
- c. Flood mitigation.
- d. Sewage overflow mitigation.
- e. Fire.
- f. Failure of a primary motor, but only for such time as needed to repair or replace the primary motor.

[Basis: Reg. 9-8-231]

"Reliability-related activities" is defined as any of the following:

- a. Operation of an emergency standby engine to test its ability to perform for an emergency use, or
- b. Operation of an emergency standby engine during maintenance of a primary motor.

[Basis: Reg. 9-8-232]

2. The owner/operator shall equip the emergency standby engine(s) with either:
 - a. non-resettable totalizing meter that measures and records the hours of operation for the engine.
 - b. a non-resettable fuel usage meter.

[Basis: Reg. 9-8-530]

3. Records: The owner/operator shall maintain the following monthly records in a District-approved log for at least 52 years and shall make the log available for District inspection upon request:
 - a. Hours of operation (total).
 - b. Hours of operation (emergency).

VI. Permit Conditions

- c. For each emergency, the nature of the emergency condition.

[Basis: Reg. 9-8-530]

Condition 19930

S-20 Parts Washer, Model I-52150, 20 Gallons

1. The net solvent usage at the Parts Washer (S-20) shall not exceed 50 gallons during any rolling 12 consecutive month period. [Basis: Cumulative Increase]
2. To demonstrate compliance with Part #1, the monthly net usage of solvent shall be maintained in a District approved log. These usage records shall be kept on site and made available for District inspection for a period of at least 5 years from the date on which a record is made.

[Basis: Plant Cumulative Increase]

Condition 19978

S-16 Influent Pump: Digester Gas Engine, Make: Waukesha, Model: NKR 1905, Horsepower Rating: 224 HP.

S-17 Influent Pump: Digester Gas Engine, Make: Waukesha, Model: NKR 1905, Horsepower Rating: 224 HP.

S-18 Influent Pump: Digester Gas Engine, Make: Waukesha, Model: NKR 1905, Horsepower Rating: 224 HP.

1. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour that is as dark or darker than Ringelmann 1 or equivalent to 20% opacity. [Regulation 6]
2. Total reduced sulfur compounds in the collected digester gas shall be monitored as a surrogate for monitoring sulfur dioxide in control system's exhaust. The concentrations of total reduced sulfur compounds in the collected digester gas shall not exceed 1300 ppmv (dry). In order to demonstrate compliance with this part, the permit holder shall measure the total sulfur content in collected digester gas on a quarterly basis using a Draeger Tube. The samples of digester gas shall be taken from their respective main gas headers. The permit holder shall follow the manufacturer's recommended procedures for using the Draeger Tube and interpreting the results. The permit holder shall conduct the first Draeger Tube test no later than 3 months after the renewal date of the MFR Permit and quarterly thereafter. (Basis: Regulation 9-1-302)

VI. Permit Conditions

~~B. Facility-wide Permit Conditions~~
None

|

VII. APPLICABLE EMISSION LIMITS & COMPLIANCE MONITORING REQUIREMENTS

This section has been included only to summarize the applicable emission limits contained in Section IV, Source-Specific Applicable Requirements, of this permit. The following tables show the relationship between each emission limit and the associated compliance monitoring provisions, if any. The monitoring frequency column indicates whether periodic (P) or continuous (C) monitoring is required. For periodic monitoring, the frequency of the monitoring has also been shown ~~either~~ using the following codes: annual (A), quarterly (Q), monthly (M), daily (D), or on an event basis (E). No monitoring (N) has been required if the current applicable rule or regulation does not require monitoring, and the operation is unlikely to deviate from the applicable emission limit based upon the nature of the operation.

Table VII-A
Applicable Limits and Compliance Monitoring Requirements
S-14 Engine Generator
S-15 Engine Generator

<u>Type of Limit</u> <u>Pollutant</u>	<u>Emission Limit Citation</u> <u>Citation of Limit</u>	FE Y/N	Future Effective Date	<u>Emission Limit</u>	<u>Monitoring Requirement Citation</u>	<u>Monitoring Frequency (P/C/N)</u>	<u>Monitoring Type</u>
Opacity	BAAQMD 6-301	Y		Ringelmann 1.0 for < 3 minutes in any hour	N	N	N
FP	BAAQMD 6-310	Y		0.15 gr/dscf	N	N	N
NOX	BAAQMD 9-8-301.2	Y		140 ppmv @ 15% O ₂ , dry	BAAQMD cond #10844, part 4 6	P/A	Source test
	BAAQMD 9-8-302.1	Y		140 ppmv @ 15% O ₂ , dry	BAAQMD cond #10844, part 4 6	P/A	Source test
	BAAQMD cond #10844, part 4 c	Y		1.5 gram/bhp-hr	BAAQMD cond #10844, part 4 6	P/A	Source test or alternate monitoring plan

VII. Applicable Emission Limits & Compliance Monitoring Requirements

Table VII-A
Applicable Limits and Compliance Monitoring Requirements
S-14 Engine Generator
S-15 Engine Generator

<u>Type of Limit</u> <u>Pollutant</u>	<u>Emission Limit Citation</u> <u>Citation of Limit</u>	<u>FE</u> <u>Y/N</u>	<u>Future Effective Date</u>	<u>Emission Limit</u>	<u>Monitoring Requirement Citation</u>	<u>Monitoring Frequency (P/C/N)</u>	<u>Monitoring Type</u>
CO	BAAQMD 9-8-301.3	Y		2000 ppmv @ 15% O ₂ , dry	<u>BAAQMD</u> <u>cond #10844,</u> <u>part 4 6</u>	P/A	<u>Source test</u>
	BAAQMD 9-8-302.3	Y		2000 ppmv @ 15% O ₂ , dry	<u>BAAQMD</u> <u>cond #10844,</u> <u>part 4 6</u>	P/A	<u>Source test</u>
	BAAQMD cond #10844, part 4 4b	Y		2.5 gram/bhp-hr	BAAQMD cond #10844, part 4 6	P/A	<u>Source test</u> or <u>alternate</u> <u>monitoring</u> <u>plan</u>
POC	BAAQMD cond #10844, part 4 4a	Y		0.3 gram/bhp-hr	<u>BAAQMD</u> <u>cond #10844,</u> <u>part 6</u>	N P/A	<u>Source test</u>
POC	<u>BAAQMD</u> <u>8-2-301</u>	<u>Y</u>		<u>15 lb/day or 300 PPM</u> <u>total carbon (dry basis)</u>	<u>BAAQMD</u> <u>cond #10844,</u> <u>part 6</u>	<u>P/A</u>	<u>Source test</u>
<u>Non-</u> <u>Methane</u> <u>Organic</u> <u>Com-</u> <u>pounds</u> <u>(NMOC)</u>	<u>BAAQMD</u> <u>8-34-301.4</u>	<u>Y</u>		<u>> 98% removal by</u> <u>weight</u> <u>OR</u> <u>< 120 ppmv,</u> <u>dry basis @ 3% O₂,</u> <u>expressed as methane</u>	<u>BAAQMD</u> <u>8-34-412 and</u> <u>8-34-501.4</u> <u>and</u> <u>BAAQMD</u> <u>Condition #</u> <u>10844,</u> <u>Part 6</u>	<u>P/A</u>	<u>Initial and</u> <u>Annual</u> <u>Source Tests</u> <u>and Records</u>

VII. Applicable Emission Limits & Compliance Monitoring Requirements

Table VII-A
Applicable Limits and Compliance Monitoring Requirements
S-14 Engine Generator
S-15 Engine Generator

<u>Type of Limit</u> <u>Pollutant</u>	<u>Emission Limit Citation</u> <u>Citation of Limit</u>	<u>FE</u> <u>Y/N</u>	<u>Future Effective Date</u>	<u>Emission Limit</u>	<u>Monitoring Requirement Citation</u>	<u>Monitoring Frequency (P/C/N)</u>	<u>Monitoring Type</u>
<u>TOC (Total Organic Compounds Plus Methane)</u>	<u>BAAQMD 8-34-301.2</u>	<u>Y</u>		<u>< 1000 ppmv as methane (component leak limit)</u>	<u>BAAQMD 8-34-501.6 and 8-34-503</u>	<u>P/Q</u>	<u>Quarterly Inspection and Records</u>
<u>Total Sulfur Content in Landfill Gas</u>	<u>BAAQMD Condition # 10844, Part 9</u>	<u>Y</u>		<u>< 1300 ppmv</u>	<u>BAAQMD Condition # 10844, Part 9</u>	<u>P/Q</u>	<u>Sulfur analysis of landfill gas</u>
<u>Total Sulfur Content in Digester Gas</u>	<u>BAAQMD Condition # 10844, Part 9</u>	<u>Y</u>		<u>< 1300 ppmv</u>	<u>BAAQMD Condition # 10844, Part 9</u>	<u>P/Q</u>	<u>Sulfur analysis of landfill gas</u>
<u>H₂S</u>	<u>BAAQMD 9-2-301</u>	<u>N</u>		<u>Property Line ground level limits < 0.06 ppm Averaged over 3 minutes and < 0.03 ppm Averaged over 60 minutes</u>	<u>None</u>	<u>N</u>	<u>NA</u>

VII. Applicable Emission Limits & Compliance Monitoring Requirements

Table VII-A
Applicable Limits and Compliance Monitoring Requirements
S-14 Engine Generator
S-15 Engine Generator

<u>Type of Limit</u> <u>Pollutant</u>	<u>Emission Limit Citation of Limit</u>	<u>FE Y/N</u>	<u>Future Effective Date</u>	<u>Emission Limit</u>	<u>Monitoring Requirement Citation</u>	<u>Monitoring Frequency (P/C/N)</u>	<u>Monitoring Type</u>
<u>SO2</u>	<u>BAAQMD 9-1-301</u>	<u>Y</u>		<u>Ground level concentration of 0.5 ppm continuously for 3 consecutive minutes, or 0.25 ppm averaged over 60 consecutive minutes, or 0.05 ppm averaged over 24 hours</u>	<u>N</u>	<u>N</u>	<u>N</u>
<u>SO2</u>	<u>BAAQMD 9-1-302</u>	<u>Y</u>		<u>SO2 shall not exceed 300 ppm (dry)</u>	<u>BAAQMD Condition # 10844, part 9</u>	<u>P/Q</u>	<u>Sulfur analysis of landfill gas and digester gas</u>
<u>Reduced sulfur</u>	<u>BAAQMD Condition # 10844, Part 9</u>	<u>Y</u>		<u>1300 ppmv (dry) total reduced sulfur</u>	<u>BAAQMD Condition # 10844, Part 9</u>	<u>P/Q</u>	<u>Reduced sulfur analysis</u>
<u>Heat Input</u>	<u>BAAQMD Condition # 10844, Part 2</u>	<u>Y</u>		<u>< 200 MM BTU per generator per day and < 72.000 MM BTU per generator per consecutive 12-month period</u>	<u>BAAQMD Condition # 10844, part 5</u>	<u>C</u>	<u>Gas Flow Meter and Recorder and Records</u>
<u>Gas Flow</u>	<u>BAAQMD 8-34-301 and 301.1</u>	<u>Y</u>		<u>Vent all collected gases to a properly operating control system and operate control system continuously.</u>	<u>BAAQMD 8-34-501.10 and 508</u>	<u>C</u>	<u>Gas Flow Meter and Recorder (every 15 minutes)</u>

VII. Applicable Emission Limits & Compliance Monitoring Requirements

Table VII-A
Applicable Limits and Compliance Monitoring Requirements
S-14 Engine Generator
S-15 Engine Generator

<u>Type of Limit</u> <u>Pollutant</u>	<u>Emission Limit Citation</u> <u>Citation of Limit</u>	<u>FE</u> <u>Y/N</u>	<u>Future Effective Date</u>	<u>Emission Limit</u>	<u>Monitoring Requirement Citation</u>	<u>Monitoring Frequency (P/C/N)</u>	<u>Monitoring Type</u>
<u>Emission Control System Shutdown Time</u>	<u>BAAQMD 8-34-113.2</u>	<u>Y</u>		<u>< 240 hours/year</u>	<u>BAAQMD 8-34-501.2 and BAAQMD Condition # 10844, Part 7a</u>	<u>P/D</u>	<u>Records</u>
<u>Air to fuel ratio setting</u>	<u>BAAQMD Condition # 10844, Part 8</u>	<u>Y</u>		<u>To be established during first source test conducted after permit issuance</u>	<u>BAAQMD 8-34-507 and 8-34-509</u>	<u>P/D</u>	<u>Inspection and record keeping</u>
<u>exhaust O2 content</u>	<u>BAAQMD Condition # 10844, Part 8</u>	<u>Y</u>		<u>To be established during first source test conducted after permit issuance</u>	<u>BAAQMD 8-34-507 and 8-34-509</u>	<u>C</u>	<u>O2 meter</u>
<u>Periods of Inoperation for Parametric Monitors</u>	<u>BAAQMD 1-523.2</u>	<u>Y</u>		<u>< 15 consecutive days per incident and < 30 calendar days per 12 month period</u>	<u>BAAQMD 1-523.4</u>	<u>P/D</u>	<u>Records of occurrence and duration</u>

VII. Applicable Emission Limits & Compliance Monitoring Requirements

Table VII-B
Applicable Limits and Compliance Monitoring Requirements
S-16 Influent Pump #1 – IC Engine, 224 HP
S-17 Influent Pump #2 – IC Engine, 224 HP
S-18 Influent Pump #3 – IC Engine, 224 HP

<u>Pollutant</u>	<u>Emission Limit Citation</u>	<u>FE Y/N</u>	<u>Future Effective Date</u>	<u>Emission Limit</u>	<u>Monitoring Requirement Citation</u>	<u>Monitoring Frequency (P/C/N)</u>	<u>Monitoring Type</u>
Opacity	BAAQMD 6-301	Y		No. 1 on Ringelmann Chart for 3 minutes in any hour	N	N	N
Opacity	BAAQMD cond #19978, part 1	Y		No. 1 on Ringelmann Chart or 20% opacity for 3 minutes in any hour	N	N	N
FP	BAAQMD 6-310	Y		0.15 gr/dscf	N	N	
POC	BAAQMD 8-2-301	Y		15 lb/day or 300 PPM total carbon (dry basis)	N	N	N
SO2	BAAQMD 9-1-301	Y		Ground level concentration of 0.5 ppm continuously for 3 consecutive minutes, or 0.25 ppm averaged over 60 consecutive minutes, or 0.05 ppm averaged over 24 hours	N	N	N
SO2	BAAQMD 9-1-302	Y		300 ppm in the gas stream	BAAQMD Condition 19978 Part 2	P/Q	Sulfur analysis of digester gas

VII. Applicable Emission Limits & Compliance Monitoring Requirements

Table VII-C
Applicable Limits and Compliance Monitoring Requirements
S-19 EMERGENCY NATURAL GAS FIRED STANDBY GENERATOR

<u>Pollutant</u>	<u>Emission Limit Citation</u>	<u>FE Y/N</u>	<u>Future Effective Date</u>	<u>Emission Limit</u>	<u>Monitoring Requirement Citation</u>	<u>Monitoring Frequency (P/C/N)</u>	<u>Monitoring Type</u>
<u>Opacity</u>	<u>6-303</u>	<u>Y</u>		<u>No. 2 on Ringelmann Chart for 3 minutes in any hour</u>	<u>N</u>	<u>N</u>	<u>N</u>
<u>FP</u>	<u>BAAQMD 6-310</u>	<u>Y</u>		<u>0.15 gr/dscf</u>	<u>N</u>	<u>N</u>	<u>N</u>
<u>SO2</u>	<u>BAAQMD 9-1-301</u>	<u>Y</u>		<u>Ground level concentration of 0.5 ppm continuously for 3 consecutive minutes, or 0.25 ppm averaged over 60 consecutive minutes, or 0.05 ppm averaged over 24 hours</u>		<u>N</u>	
<u>SO2</u>	<u>BAAQMD 9-1-302</u>	<u>Y</u>		<u>300 ppm in the gas stream</u>	<u>N</u>	<u>N</u>	<u>N</u>

VII. Applicable Emission Limits & Compliance Monitoring Requirements

Table VII-D
Applicable Limits and Compliance Monitoring Requirements
S-20 PARTS WASHERS

<u>Pollutant</u>	<u>Emission Limit Citation</u>	<u>FE Y/N</u>	<u>Future Effective Date</u>	<u>Emission Limit</u>	<u>Monitoring Requirement Citation</u>	<u>Monitoring Frequency (P/C/N)</u>	<u>Monitoring Type</u>
VOC	BAAQMD cond #19930, part 1	Y		50 gallons of solvent a year	BAAQMD cond #19930, part 2	Monthly	Record keeping

VII. Applicable Emission Limits & Compliance Monitoring Requirements

Table VII- B E
Applicable Limits and Compliance Monitoring Requirements
S-100 Municipal Wastewater Treatment Plant
S-110 Preliminary Treatment
S-120 Primary Treatment
S-130 Secondary Treatment
S-140 Tertiary Treatment
S-150 Disinfection
S-161 Solids Dewatering System
~~S-170 Anaerobic Digestors~~

Pollutant	Emission Limit Citation	FE Y/N	Future Effective Date	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
VOC	BAAQMD 8-2-301	Y		15 lb/day & 300 ppm total carbon on dry basis	N	N	N

VII. Applicable Emission Limits & Compliance Monitoring Requirements

Table VII-F
Applicable Limits and Compliance Monitoring Requirements
S-170 Anaerobic Digesters

<u>Pollutant</u>	<u>Emission Limit Citation</u>	<u>FE Y/N</u>	<u>Future Effective Date</u>	<u>Emission Limit</u>	<u>Monitoring Requirement Citation</u>	<u>Monitoring Frequency (P/C/N)</u>	<u>Monitoring Type</u>
<u>VOC</u>	<u>BAAQMD 8-2-301</u>	<u>Y</u>		<u>Emissions may not exceed 300 ppm total carbon, dry, and 15 lb/day/source</u>	<u>None</u>	<u>N</u>	<u>None</u>
<u>Odors</u>	<u>None</u>	<u>N</u>		<u>None</u>	<u>None</u>	<u>P/E</u>	<u>Records</u>
<u>H₂S</u>	<u>BAAQMD Regulation 9-2-301</u>	<u>N</u>		<u>0.06 ppm H₂S over 3 min or 0.03 ppm H₂S over 60 min</u>	<u>None</u>	<u>N</u>	<u>None</u>

VIII. TEST METHODS

The test methods associated with the emission limit of a District regulation are generally ~~referenced~~ found in Section 600 et seq. of the regulation. The following table indicates only the test methods associated with the emission limits ~~referenced~~ included in Section VII - Applicable Emission Limits & Compliance Monitoring Requirements, of this permit.

Table VIII
Test Methods

Applicable Requirement	Description of Requirement	Acceptable Test Methods
BAAQMD 6-301	Ringelmann No. 1 Limitation	Manual of Procedures, Volume I, Evaluation of Visible Emissions
BAAQMD 6-303	Ringelmann No. 2 Limitation	Manual of Procedures, Volume I, Evaluation of Visible Emissions
BAAQMD 6-310	Particulate Weight Limitation	Manual of Procedures, Volume IV, ST-15, Particulates Sampling; or USEPA Method 5, Determination of Particulate Matter Emissions from Stationary Sources
<u>BAAQMD 6-311</u>	<u>Process Weight Rate Based Emissions Limits</u>	<u>Manual of Procedures, Volume IV, ST-15, Particulates Sampling, or Calculate Emissions in Accordance with EPA AP-42 Procedures</u>
BAAQMD 7-303	Limit on Odorous Compounds	Manual of Procedures, Volume IV, ST-1, ST-8, ST-11, ST-16, ST-22, Sampling of Odorous Compounds
BAAQMD 8-2-301	Miscellaneous Operations	Manual of Procedures, Volume IV, ST-7, Non-Methane Organic Carbon Sampling or EPA Method 25 or 25A.
<u>BAAQMD 8-34-301.2</u>	<u>Collection and Control System Leak Limitations</u>	<u>EPA Reference Method 21, Determination of Volatile Organic Compound Leaks</u>
<u>BAAQMD 8-34-301.4</u>	<u>Limits for Other Emission Control Systems</u>	<u>Manual of Procedures, Volume IV, ST-7, Organic Compounds and ST-14, Oxygen, Continuous Sampling; or EPA Reference Method 18, 25, 25A, or 25C</u>
<u>BAAQMD 8-34-412</u>	<u>Compliance Demonstration Test</u>	<u>EPA Reference Method 18, Measurement of Gaseous Organic Compound Emissions by Gas Chromatography, Method 25, Determination of Total Gaseous Nonmethane Organic Emissions as Carbon, Method 25A, Determination of Total Gaseous Organic Concentration Using a Flame Ionization Analyzer, or Method 25C, Determination of Nonmethane Organic Compounds (NMOC) in MSW Landfill Gases</u>
<u>BAAQMD 9-1-301</u>	<u>Limitations on Ground Level Concentrations (SO₂)</u>	<u>Manual of Procedures, Volume VI, Part 1, Ground Level Monitoring for Hydrogen Sulfide and Sulfur Dioxide</u>

VIII. Test Methods

**Table VIII
 Test Methods**

Applicable Requirement	Description of Requirement	Acceptable Test Methods
BAAQMD 9-1-302	General Emission Limitation (SO ₂)	Manual of Procedures, Volume IV, ST-19A, Sulfur Dioxide, Continuous Sampling, or ST-19B, Total Sulfur Oxides, Integrated Sample
BAAQMD 9-1-304	Fuel Burning (Liquid and Solid Fuels) Fuel Sulfur Content	Manual of Procedures, Volume III, Method 10, Determination of Sulfur in Fuel Oils.
<u>BAAQMD</u> <u>9-2-301</u>	<u>Limitations on Hydrogen Sulfide</u>	<u>Manual of Procedures, Volume VI, Part 1, Ground Level Monitoring for Hydrogen Sulfide and Sulfur Dioxide</u>
BAAQMD 9-8-301.2	NO _x Limit	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, Continuous Sampling Limit on Odorous Compounds and ST-14, Oxygen, Continuous Sampling
BAAQMD 9-8-301.3	CO Limit	Manual of Procedures, Volume IV, ST-6, Carbon Monoxide, Continuous Sampling and ST-14, Oxygen, Continuous Sampling
BAAQMD 9-8-302.1	NO _x Limit	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, Continuous Sampling Limit on Odorous Compounds and ST-14, Oxygen, Continuous Sampling
BAAQMD 9-8-302.30	CO Limit	Manual of Procedures, Volume IV, ST-6, Carbon Monoxide, Continuous Sampling and ST-14, Oxygen, Continuous Sampling
BAAQMD Condition #10844, Part 4 4c	NO _x Limit	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, Continuous Sampling Limit on Odorous Compounds and ST-14, Oxygen, Continuous Sampling
BAAQMD Condition #10844, Part 4 4b	CO Limit	Manual of Procedures, Volume IV, ST-6, Carbon Monoxide, Continuous Sampling and ST-14, Oxygen, Continuous Sampling
BAAQMD Condition #10844, Part 4 4a	POC Limit	Manual of Procedures, Volume IV, ST-7, Non-Methane Organic Carbon Sampling or EPA Method 25 or 25A.
<u>BAAQMD</u> <u>Condition #</u> <u>10844, Part 2</u>	<u>Heat Input Limits</u>	<u>APCO approved gas flow meter and APCO approved calculation procedure described in BAAQMD Condition # 10844, Part 7c</u>

VIII. Test Methods

Table VIII
Test Methods

Applicable Requirement	Description of Requirement	Acceptable Test Methods
<u>BAAQMD Condition # 10844, Part 6</u>	<u>Engine Source Test</u>	<u>Outlet: Manual of Procedures, Volume IV, ST-17, Stack Gas Velocity and Volumetric Flow Rate; ST-23 Water Vapor; ST-14, Oxygen, Continuous Sampling; ST-13A, Oxides of Nitrogen, Continuous Sampling; ST-6, Carbon Monoxide, Continuous Sampling; Manual of Procedures, Volume IV, ST-19A, Sulfur Dioxide, Continuous Sampling; and Manual of Procedures, Volume IV, ST-7, Organic Compounds or EPA Reference Methods 18, 25, 25A, or 25C;</u> <u>Inlet: EPA Reference Method 3C</u>
<u>BAAQMD Condition # 10844, Part 8</u>	<u>Air to fuel ratio setting and exhaust O2 content</u>	<u>APCO Approved O2 meter</u>
<u>BAAQMD Condition # 10844, Part 9</u>	<u>Landfill Gas Sulfur Content Limit</u>	<u>Draeger Tube: used in accordance with manufacturer's recommended procedures, or Manual of Procedures, Volume III, Method 44 Determination of Reduced Sulfur Gases and Sulfur Dioxide in Effluent Samples by Gas Chromatographic Methods, or ASTM D 1072-80 or 90, D 3031-81, D 4084-82 or 94, or D 3246-81, 92, or 96</u>

IX. GLOSSARY

ACT

Federal Clean Air Act

BAAQMD

Bay Area Air Quality Management District

Basis

The underlying authority ~~which~~that allows the District to impose requirements.

CO

Carbon Monoxide

Cumulative Increase

The sum of permitted emissions from each new or modified source since a specified date pursuant to BAAQMD Rule 2-1-403, Permit Conditions (as amended by the District Board on 7/17/91) and SIP Rule 2-1-403, Permit Conditions (as approved by EPA on 6/23/95). Used to determine whether threshold-based requirements are triggered.

District

The Bay Area Air Quality Management District

EPA

The federal Environmental Protection Agency.

Excluded

Not subject to any District Regulations.

FE, Federally Enforceable,

All limitations and conditions which are enforceable by the Administrator of the EPA including those requirements developed pursuant to 40 CFR Part 51, subpart I (NSR), Part 52.21 (PSD), Part 60, (NSPS), Part 61, (NESHAPs), Part 63 (HAP), and Part 72 (Permits Regulation, Acid Rain), and also including limitations contained in operating permits issued under an EPA-approved program that has been incorporated into the SIP.

FP

Filterable Particulate as measured by BAAQMD Method ST-15, Particulate.

HAP

Hazardous Air Pollutant. Any pollutant listed pursuant to Section 112(b) of the Act. Also refers to the program mandated by Title I, Section 112, of the Act and implemented by 40 CFR Part 63.

Major Facility

A facility with potential emissions of regulated air pollutants greater than 100 tons per year, greater than 10 tons per year of any single hazardous air pollutant, and/or greater than 25 tons per year of any combination of hazardous air pollutants, or such lesser quantity as determined

IX. Glossary

by the EPA administrator.

MFR

Major Facility Review. The District's term for the federal operating permit program mandated by Title V of the Act and implemented by District Regulation 2, Rule 6.

MOP

The District's Manual of Procedures.

NESHAPS

National Emission Standards for Hazardous Air Pollutants. See in 40 CFR Parts 61 and 63

NMHC

Non-methane Hydrocarbons (same as NMOC).

NMOC

Non-methane Organic Compounds (same as NMHC).

NO_x

Oxides of nitrogen.

NSR

New Source Review. A federal program for preconstruction review and permitting of new and modified sources of air pollutants for which the District is classified "non-attainment". Mandated by Title I of the Clean Air Act and implemented by 40 CFR Parts 51 and 52 as well as District Regulation 2, Rule 2. (Note: There are additional NSR requirements mandated by the California Clean Air Act.)

POC

Precursor Organic Compounds

SIP

State Implementation Plan. State and District programs and regulations approved by EPA and developed in order to attain the National Air Ambient Quality Standards. Mandated by Title I of the Act.

SO₂

Sulfur dioxide

THC

Total Hydrocarbons includes all NMHC plus methane (same as TOC).

Title V

Title V of the federal Clean Air Act. Requires a federally enforceable operating permit program for major and certain other facilities.

TOC

IX. Glossary

Total Organic Compounds includes all NMOC plus methane (same as THC).

TRMP

Toxic Risk Management Policy.

TSP

Total Suspended Particulate

VOC

Volatile Organic Compounds

Units of Measure:

bhp	=	brake-horsepower
btu	=	British Thermal Unit
g	=	grams
gal	=	gallon
hp	=	horsepower
hr	=	hour
lb	=	pound
in	=	inches
max	=	maximum
m ²	=	square meter
min	=	minute
mm	=	million
ppmv	=	parts per million, by volume
ppmw	=	parts per million, by weight
psia	=	pounds per square inch, absolute
psig	=	pounds per square inch, gauge
scfm	=	standard cubic feet per minute
yr	=	year

~~**X. APPENDIX A - STATE IMPLEMENTATION PLAN**~~

~~See Attachment~~

|