

September 19, 2007

Ms. Deborah Jordan  
Director, Air Division  
**United States Environmental Protection Agency**  
75 Hawthorne Street  
San Francisco, CA 94105

Dear Ms. Jordan:

This to advise you that the Bay Area Air Quality Management District is issuing a minor revision to the Major Facility Review Permit for the following facility.

**ALAMEDA COUNTY**

Tom Bates  
Scott Haggerty  
Janet Lockhart  
Nate Miley

**CONTRA COSTA COUNTY**

John Gioia  
Mark Ross  
(Chair)  
Michael Shimansky  
Gayle B. Uilkema

**MARIN COUNTY**

Harold C. Brown, Jr.

**NAPA COUNTY**

Brad Wagenknecht

**SAN FRANCISCO COUNTY**

Chris Daly  
Jake McGoldrick  
Gavin Newsom

**SAN MATEO COUNTY**

Jerry Hill  
(Vice-Chair)  
Carol Klatt

**SANTA CLARA COUNTY**

Erin Garner  
Yoriko Kishimoto  
Liz Kniss  
Patrick Kwok

**SOLANO COUNTY**

John F. Silva

**SONOMA COUNTY**

Tim Smith  
Pamela Torliatt  
(Secretary)

Jack P. Broadbent  
**EXECUTIVE  
OFFICER/APCO**

Facility	Facility Name	Application	Permit Engineer	City	County
A2740	City of Mountain View	15609	C. Allen	Mountain View	Santa Clara

The District proposed a minor permit revision for this facility on July 18, 2007. The main purpose of this minor revision was to correct applicable requirements, increase the maximum firing capacity, and clarify other limits for two microturbines (S-12 and S-13). Specifically, the District proposed to remove all federal requirements from Tables IV-C and VII-C, because the microturbines are no longer subject to 40 CFR, Part 60.752(b)(2)(iii)(B) based on EPA's June 2006 determination. The District proposed to increase the maximum permitted firing capacity for each microturbine to 1.6 MM BTU/hour. The District also proposed to remove several unnecessary limits and monitoring requirements and proposed to delete the obsolete custom schedule of compliance. These actions will result in the following emission increases: 0.63 tons/year of PM<sub>10</sub>, 0.17 tons/year of POC, 0.12 tons/year of SO<sub>2</sub>, and 0.02 tons/year of HAPs.

The EPA comment period ended on August 31, 2007. No comments on this proposed minor revision were received from EPA or the facility.

The District has decided to issue the revised permit incorporating the proposed minor revision. The final revised permit can be viewed on the BAAQMD website at [http://www.baaqmd.gov/pmt/title\\_v/public\\_notices.htm](http://www.baaqmd.gov/pmt/title_v/public_notices.htm). We will also send a copy of the final permit to you via the Electronic Permit Submittal System. If you have any questions regarding this permit, please call Dennis Jang, Senior Air Quality Engineer, at: (415) 749-4707.

Sincerely yours,

Signed by Jack P. Broadbent

Jack P. Broadbent  
Executive Officer/Air Pollution Control Officer