

May 28, 2002

Mr. Ted C. Feigenbaum
Executive Vice President and
Chief Nuclear Officer
North Atlantic Energy Service Corporation
c/o Mr. James M. Peschel
P.O. Box 300
Seabrook, NH 03874

SUBJECT: BULLETIN 2002-01, "REACTOR PRESSURE VESSEL HEAD DEGRADATION AND REACTOR COOLANT PRESSURE BOUNDARY INTEGRITY," 15-DAY RESPONSE FOR SEABROOK STATION, UNIT NO. 1 (TAC NO. MB4577)

On March 18, 2002, the staff issued Bulletin 2002-01, "Reactor Pressure Vessel Head Degradation and Reactor Coolant Pressure Boundary Integrity," to the industry requesting that addressees provide information related to the structural integrity of the reactor coolant pressure boundary, including the reactor pressure vessel head, and the extent to which inspections have been undertaken to satisfy applicable regulatory requirements. Bulletin 2002-01 also required licensees to provide the basis for concluding that plans for future inspections of the reactor coolant pressure boundary will satisfy applicable regulatory requirements at their respective pressurized water reactor (PWR) plants. All addressees were requested to respond to Items 1.A. through E. within 15 days of the Bulletin's issuance, or to provide a written response to the NRC in accordance with the provisions of Title 10, Section 50.54(f), of the *Code of Federal Regulations* (10 CFR 50.54(f)) if they are unable to provide the information, or they cannot meet the requested completion dates.

You provided your 15-day Bulletin response by letter dated April 2, 2002. The staff finds that you have provided the requested information, and has concluded that your plant does not appear to have conditions similar to those which lead to the degradation at Davis-Besse. However, the staff may issue questions to confirm or verify the information that was provided in your 15-day response to Bulletin 2002-01.

We will complete a full review of your response to Bulletin 2002-01 after we review your response to Items 2 and 3 of the Bulletin.

Sincerely,

/RA/

Robert D. Starkey, Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor

Docket No. 50-443

cc: See next page

Mr. Ted C. Feigenbaum
Executive Vice President and
Chief Nuclear Officer
North Atlantic Energy Service Corporation
c/o Mr. James M. Peschel
P.O. Box 300
Seabrook, NH 03874

SUBJECT: BULLETIN 2002-01, "REACTOR PRESSURE VESSEL HEAD DEGRADATION AND REACTOR COOLANT PRESSURE BOUNDARY INTEGRITY," 15-DAY RESPONSE FOR SEABROOK STATION, UNIT NO. 1 (TAC NO. MB4577)

On March 18, 2002, the staff issued Bulletin 2002-01, "Reactor Pressure Vessel Head Degradation and Reactor Coolant Pressure Boundary Integrity," to the industry requesting that addressees provide information related to the structural integrity of the reactor coolant pressure boundary, including the reactor pressure vessel head, and the extent to which inspections have been undertaken to satisfy applicable regulatory requirements. Bulletin 2002-01 also required licensees to provide the basis for concluding that plans for future inspections of the reactor coolant pressure boundary will satisfy applicable regulatory requirements at their respective pressurized water reactor (PWR) plants. All addressees were requested to respond to Items 1.A. through E. within 15 days of the Bulletin's issuance, or to provide a written response to the NRC in accordance with the provisions of Title 10, Section 50.54(f), of the *Code of Federal Regulations* (10 CFR 50.54(f)) if they are unable to provide the information, or they cannot meet the requested completion dates.

You provided your 15-day Bulletin response by letter dated April 2, 2002. The staff finds that you have provided the requested information, and has concluded that your plant does not appear to have conditions similar to those which lead to the degradation at Davis-Besse. However, the staff may issue questions to confirm or verify the information that was provided in your 15-day response to Bulletin 2002-01.

We will complete a full review of your response to Bulletin 2002-01 after we review your response to Items 2 and 3 of the Bulletin.

Sincerely,

/RA/

Robert D. Starkey, Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor

Docket No. 50-443

cc: See next page

DISTRIBUTION:

PUBLIC	JClifford	OGC	WBateman
PDI-2 R/F	DStarkey	ACRS	ALee
EMCB R/F	SBloom	CCowgill, RI	SCoffin
TClark			

ACCESSION NO. ML021430500

OFFICE	PDI-2/PM	PDI-2/LA	EMCB	PDI-2/SC
NAME	DStarkey	TClark	SBloom	JClifford
DATE	5/28/02	5/28/02	5/28/02	5/28/02

OFFICIAL RECORD COPY

Seabrook Station, Unit No. 1
cc:

William J. Quinlan, Esq.
Assistant General Counsel
Northeast Utilities Service Company
P.O. Box 270
Hartford, CT 06141-0270

Mr. Peter Brann
Assistant Attorney General
State House, Station #6
Augusta, ME 04333

Resident Inspector
U.S. Nuclear Regulatory Commission
Seabrook Nuclear Power Station
P.O. Box 1149
Seabrook, NH 03874

Town of Exeter
10 Front Street
Exeter, NH 03823

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Office of the Attorney General
One Ashburton Place
20th Floor
Boston, MA 02108

Board of Selectmen
Town of Amesbury
Town Hall
Amesbury, MA 01913

Mr. Dan McElhinney
Federal Emergency Management Agency
Region I
J.W. McCormack P.O. &
Courthouse Building, Room 401
Boston, MA 02109

Mr. Stephen McGrail, Director
ATTN: James Muckerheide
Massachusetts Emergency Management Agency
400 Worcester Road
Framingham, MA 01702-5399

Philip T. McLaughlin, Attorney General
Steven M. Houran, Deputy Attorney
General
33 Capitol Street
Concord, NH 03301

Mr. Donald Bliss, Director
New Hampshire Office of Emergency
Management
State Office Park South
107 Pleasant Street
Concord, NH 03301

Mr. Daniel G. Roy
Nuclear Training Manager
Seabrook Station
North Atlantic Energy Service Corp.
P.O. Box 300
Seabrook, NH 03874

Mr. James M. Peschel
Manager - Regulatory Programs
Seabrook Station
North Atlantic Energy Service Corp.
P.O. Box 300
Seabrook, NH 03874

Mr. Gene F. St. Pierre
Station Director
Seabrook Station
North Atlantic Energy Service Corporation
P.O. Box 300
Seabrook, NH 03874

Mr. Frank W. Getman, Jr.
President and Chief Executive Officer
BayCorp Holdings, LTD
20 International Drive, Suite 301
Portsmouth, NH 03801-6809

Seabrook Station, Unit No. 1
cc:

Mr. Bruce D. Kenyon
President and Chief Executive Officer
Northeast Utilities Service Company
P.O. Box 270
Hartford, CT 06141-0270

Mr. Steve Allen
Polestar Applied Technology, Inc.
77 Franklin Street, Suite 507
Boston, MA 02110