



Entergy Nuclear South
Entergy Operations, Inc.
17265 River Road
Killona, LA 70066
Tel 504 739 6660
Fax 504 739 6678
jvenabl@entergy.com

Joseph E. Venable
Vice President, Operations
Waterford 3

W3F1-2002-0037

April 16, 2002

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

SUBJECT: Waterford Steam Electric Station, Unit 3
Docket No. 50-382
30 Day Response to NRC Bulletins 2001-01 and 2002-01 for Vessel Head
Inspection Findings

REFERENCES:

1. Bulletin 2001-01, "Circumferential Cracking of Vessel Head Penetration Nozzles"
2. Entergy Letter Dated September 4, 2001, "30 Day Response To NRC Bulletin 2001-01 For Waterford 3; Circumferential Cracking of VHP Nozzles" (W3F1-2001-0081)
3. Entergy Letter Dated November 8, 2001, "Supplement to 30 Day Response To NRC Bulletin 2001-01 For Waterford 3; Circumferential Cracking of VHP Nozzles" (W3F1-2001-0104)
4. Bulletin 2002-01, "Reactor Pressure Vessel Head Degradation and Reactor Coolant Pressure Boundary Integrity"
5. Entergy Letter Dated April 1, 2002, "15 Day Response to NRC Bulletin 2002-01, Reactor Pressure Vessel Head Degradation and Reactor Coolant Pressure Boundary Integrity" (W3F1-2002-0032)

Dear Sir or Madam:

By letters dated August 3, 2001 and March 18, 2002, the NRC issued Bulletins 2001-01 (Reference 1) and 2002-01 (Reference 4) requiring licensees to provide the results of their reactor pressure vessel head inspections within 30 days after plant startup. This letter provides the Entergy Operations, Inc. (Entergy) response to Bulletin 2001-01 item 5 and Bulletin 2002-01 item 2 for the Waterford Steam Electric Station, Unit 3 (Waterford 3).


As previously committed in References 2 and 5, Entergy completed a bare metal effective visual examination of 100% of the Waterford 3 vessel head penetrations between March 31, 2002 and April 1, 2002. No vessel head penetration leakage, cracking, or degradation was identified. Additionally, the reactor vessel head was found to be free of boric acid deposits and in good condition.

This letter is submitted pursuant to 10 CFR 50.54(f) and contains information responding to NRC Bulletins 2001-01 and 2002-01, for Waterford 3. This letter does not include any commitments.

If you have any questions or require additional information, please contact D. Bryan Miller at 504-739-6692.

I declare under penalty of perjury that the foregoing is true and correct. Executed on April 16, 2002.

Sincerely,

A handwritten signature in black ink that reads "Joe Venable". The signature is written in a cursive style with a large, looped initial "J".

J. E. Venable
Vice President, Operations
Waterford Steam Electric Station, Unit 3

JEV/DBM/cbh

cc: E.W. Merschoff, NRC Region IV
N. Kalyanam, NRC-NRR
J. Smith
N.S. Reynolds
NRC Resident Inspectors Office
Louisiana DEQ/Surveillance Division
American Nuclear Insurers