

January 22, 2002

Mr. Craig G. Anderson
Vice President, Operations ANO
Entergy Operations, Inc.
1448 S. R. 333
Russellville, AR 72801

SUBJECT: CLOSEOUT OF BULLETIN 2001-01 REVIEW FOR ARKANSAS NUCLEAR
ONE, UNIT 2 (ANO-2) (TAC MB2609)

Dear Mr. Anderson:

On August 3, 2001, the staff issued Bulletin 2001-01, "Circumferential Cracking of Reactor Pressure Vessel Head Penetration Nozzles," to the industry requesting that addressees provide information related to the structural integrity of the reactor pressure vessel head penetration (VHP) nozzles for their respective facilities, including the extent of VHP nozzle leakage and cracking that has been found to date, the inspections and repairs that have been undertaken to satisfy applicable regulatory requirements, and the basis for concluding that their plans for future inspections will ensure compliance with applicable regulatory requirements at their respective pressurized water reactor (PWR) plants. You were requested to respond to Items 1 and 4 of Bulletin 2001-01 within 30 days of its issuance.

You provided your response by letters dated September 4 and November 15, 2001. The staff finds that you have provided the requested information and there is reasonable assurance that the public health and safety will be maintained. Your proposed inspection scope and schedule described in your responses, which include the description of your plan to examine "all" or "100%" of the VHPs at your facility during the next scheduled outage, were integral to the staff's finding. It is the staff's expectation that you will submit a revised response to Bulletin 2001-01 if you make any substantive changes to the schedule and/or scope of future inspections for your plant. If warranted by such changes, the staff will reevaluate this issue for ANO-2.

Addressees are reminded that Item 5 of Bulletin 2001-01 requested the following information within 30 days after plant restart following the next refueling outage:

- a. a description of the extent of VHP nozzle leakage and cracking detected at your plant, including the number, location, size, and nature of each crack detected;

- b. if cracking is identified, a description of the inspections (type, scope, qualification requirements, and acceptance criteria), repairs, and other corrective actions you have taken to satisfy applicable regulatory requirements. This information is requested only if there are any changes from prior information submitted in accordance with this bulletin.

Sincerely,

/RA/

Thomas W. Alexion, Project Manager, Section 1
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-368

cc: See next page

- b. if cracking is identified, a description of the inspections (type, scope, qualification requirements, and acceptance criteria), repairs, and other corrective actions you have taken to satisfy applicable regulatory requirements. This information is requested only if there are any changes from prior information submitted in accordance with this bulletin.

Sincerely,

/RA/

Thomas W. Alexion, Project Manager, Section 1
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-368

cc: See next page

DISTRIBUTION:

PUBLIC

PDIV-1 Reading

RidsOgcRp

RidsAcrsAcnwMail Center

RidsNrrDlpmLpdiv1 (RGramm)

RidsNrrPMTAlexion

RidsNrrLADJohnson

K. Brockman, RIV

JZimmerman

AHiser

Accession No.: ML020220391

| OFFICE | PDIV-1/PM | PDIV-1/LA | EMCB/BC | PDIV-1/SC |
|--------|-----------|-----------|----------|-----------|
| NAME | TAlexion | DJohnson | WBateman | RGramm |
| DATE | 01/04/02 | 01/17/02 | 01/08/02 | 01/18/02 |

OFFICIAL RECORD COPY

Arkansas Nuclear One

cc:

Executive Vice President
& Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1995

Director, Division of Radiation
Control and Emergency Management
Arkansas Department of Health
4815 West Markham Street, Slot 30
Little Rock, AR 72205-3867

Winston & Strawn
1400 L Street, N.W.
Washington, DC 20005-3502

Mike Schoppman
Framatome ANP, Richland, Inc.
Suite 705
1911 North Fort Myer Drive
Rosslyn, VA 22209

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 310
London, AR 72847

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

County Judge of Pope County
Pope County Courthouse
Russellville, AR 72801

Vice President, Operations Support
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1995

Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, MS 39205