

January 3, 2002

Mr. Mark E. Warner
Vice President - TMI Unit 1
AmerGen Energy Company, LLC
P.O. Box 480
Middletown, PA 17057

SUBJECT: THREE MILE ISLAND NUCLEAR STATION UNIT 1 (TMI-1) - NRC BULLETIN
2001-01, "CIRCUMFERENTIAL CRACKING OF REACTOR PRESSURE
VESSEL HEAD PENETRATION NOZZLES" (TAC NO. MB2669)

Dear Mr. Warner:

On August 3, 2001, the U.S. Nuclear Regulatory Commission (NRC) staff issued Bulletin 2001-01, "Circumferential Cracking of Reactor Pressure Vessel Head Penetration Nozzles," to the industry requesting that addressees provide information related to the structural integrity of the reactor pressure vessel head penetration (VHP) nozzles for their respective facilities, including the extent of VHP nozzle leakage and cracking that has been found to date, the inspections and repairs that have been undertaken to satisfy applicable regulatory requirements, and the basis for concluding that their plans for future inspections will ensure compliance with applicable regulatory requirements at their respective pressurized water reactor (PWR) plants. You were requested to respond to Items 1 and 3 of the Bulletin within 30 days of its issuance.

You provided your Bulletin response by letter dated August 31, 2001, indicating that your plant is in the category of plants considered as having high susceptibility to VHP nozzle cracking, based on a relative susceptibility ranking of less than five effective full power years from the Oconee Nuclear Station, Unit 3, condition. The NRC staff finds that you have provided the requested information. Your Bulletin response stated your intent to perform a visual examination of 100 percent of the VHP nozzles at the next refueling outage, which began October 9, 2001. Since your response states that each of your VHP nozzles has a gap between the nozzle and the reactor pressure vessel head, this visual examination is consistent with the qualified visual examination described in the Bulletin. The NRC staff has concluded that the inspection schedule and scope described in your Bulletin response provide reasonable assurance that public health and safety will be maintained at your plant.

Addressees are reminded that Item 5 of the Bulletin requested the following information within 30 days after plant restart following the next refueling outage (TMI-1 restarted December 5, 2001):

- a. a description of the extent of VHP nozzle leakage and cracking detected at your plant, including the number, location, size, and nature of each crack detected;

M. Warner

- 2 -

- b. if cracking is identified, a description of the inspections (type, scope, qualification requirements, and acceptance criteria), repairs, and other corrective actions you have taken to satisfy applicable regulatory requirements. This information is requested only if there are any changes from prior information submitted in accordance with this bulletin.

If you have any questions, please contact me at (301) 415-1402.

Sincerely,

/RA/

Timothy G. Colburn, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-289

cc: See next page

M. Warner

- 2 -

- b. if cracking is identified, a description of the inspections (type, scope, qualification requirements, and acceptance criteria), repairs, and other corrective actions you have taken to satisfy applicable regulatory requirements. This information is requested only if there are any changes from prior information submitted in accordance with this bulletin.

If you have any questions, please contact me at (301) 415-1402.

Sincerely,

/RA/

Timothy G. Colburn, Senior Project Manager, Section 1
 Project Directorate I
 Division of Licensing Project Management
 Office of Nuclear Reactor Regulation

Docket No. 50-289

cc: See next page

DISTRIBUTION:

PUBLIC
 PD1-1 R/F
 E. Adensam
 MO'Brien
 TColburn
 B. Platchek, RI
 ACRS
 OGC
 LRaghavan
 LBurkhart
 JZimmerman
 AHiser
 WBateman

Accession No. ML013410173

OFFICE	PDI-1\PM	PDI-2\LA	LPM	EMCB\BC	PD1-1/(A)SC
NAME	TColburn	MO'Brien	JZimmerman	WBateman	LRaghavan
DATE	12/11/01	12/13/01	12/13/01	12/21/01	1/3/02

OFFICIAL RECORD COPY

Three Mile Island Nuclear Station, Unit No. 1

cc:

George H. Gellrich
Plant Manager
AmerGen Energy Company, LLC
P. O. Box 480
Middletown, PA 17057

Michael P. Gallagher
Director - Licensing
Exelon Generation Company, LLC
Nuclear Group Headquarters
Correspondence Control
P.O. Box 160
Kennett Square, PA 19348

Edwin C. Fuhrer
Manager - Regulatory Engineering
AmerGen Energy Company, LLC
P.O. Box 480
Middletown, PA 17057

Edward J. Cullen, Jr.
Vice President and General Counsel
Exelon Generation Company, LLC
300 Exelon Way
KSB 3-W
Kennett Square, PA 19348

Jeffrey A. Benjamin
Licensing - Vice President
Exelon Corporation
1400 Opus Place, Suite 900
Downers Grove, IL 60521

Chairman
Board of County Commissioners
of Dauphin County
Dauphin County Courthouse
Harrisburg, PA 17120

Chairman
Board of Supervisors
of Londonderry Township
R.D. #1, Geyers Church Road
Middletown, PA 17057

Senior Resident Inspector (TMI-1)
U.S. Nuclear Regulatory Commission
P.O. Box 219
Middletown, PA 17057

Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Michael A. Schoppman
Framatome ANP
Suite 705
1911 North Ft. Myer Drive
Rosslyn, VA 22209

David J. Allard, Director
Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
P.O. Box 2063
Harrisburg, PA 17120

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
433 Orlando Avenue
State College, PA 16803

John F. Rogge, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Eric Epstein
TMI Alert
4100 Hillsdale Road
Harrisburg, PA 17112