



Commercial Ice Maker Users

During a boil water advisory

Discard ice made prior to the boil water advisory issuance and discontinue making ice. Use commercially-manufactured ice.

When the boil water advisory is cancelled

A. Flush the water line to the machine inlet:

1. Close the valve on the water line behind the machine and disconnect the water line from the machine inlet.
2. Open the valve, run 5 gallons of water through the valve, and dispose of the water.
3. Close the valve.

B. Replace any in-line filters.

C. Flush the water lines in the machine:

1. Reconnect the water line to the machine outlet.
2. Open the valve.
3. Turn on the machine.
4. Make ice for 1 hour and dispose of the ice.

D. Clean and disinfect all parts and surfaces that come in contact with water and ice, following the manufacturer's instructions.

Note: This information supersedes the "Issuing and Rescinding a Boil Water Advisory" portion of the *Cryptosporidium* and Water Handbook.

From <http://www.cdc.gov/crypto/bwa/icemaker.html>

