

# Tampa Electric Company



## Biomass Test Burn Report

## Polk Power Station Unit 1

April 2002

<b>1.0</b>	<b>INTRODUCTION.....</b>	<b>2</b>
<b>2.0</b>	<b>BACKGROUND.....</b>	<b>2</b>
<b>2.1</b>	<b>BIOMASS FUEL HANDLING.....</b>	<b>2</b>
<b>2.2</b>	<b>PROCESS DATA COLLECTION .....</b>	<b>3</b>
<b>2.3</b>	<b>EMISSIONS DATA COMPARISON .....</b>	<b>3</b>
<b>2.4</b>	<b>STATISTICAL METHODS FOR COMPARING EMISSIONS DATA.....</b>	<b>3</b>
<b>3.0</b>	<b>RESULTS AND DISCUSSION .....</b>	<b>4</b>
<b>3.1</b>	<b>PROCESS.....</b>	<b>5</b>
<b>3.2</b>	<b>MASS BALANCE.....</b>	<b>5</b>
<b>3.3</b>	<b>PROCESS STREAM FLOWS AND COMPOSITIONS .....</b>	<b>6</b>
<b>3.4</b>	<b>FEEDSTOCK ANALYSIS.....</b>	<b>8</b>
<b>3.5</b>	<b>EMISSIONS .....</b>	<b>9</b>
<b>4.0</b>	<b>CONCLUSION.....</b>	<b>12</b>

## 1.0 Introduction

Tampa Electric Company (TEC) conducted a test burn on December 31, 2001 at the Polk Power Station (PPS) Unit 1. The purpose of this test burn was to investigate the effects of gasifying a small portion of biomass as a constituent of the feedstock that is processed to form the synthetic gas (syngas) fired in the combustion turbine (CT). TEC performed this test under the authority of the temporary permit issued by the Florida Department of Environmental Protection (the Department) dated December 21, 2001. The data from this test indicate there is no increase in monitored air emissions ( $\text{NO}_x$  and  $\text{SO}_2$ ) from PPS Unit 1 as a result of the addition of a small amount of biomass as a constituent of the feedstock for PPS Unit 1. This report constitutes the required Test Burn Report for the biomass test burn. The background for this test including materials and methods used for the test are presented within. Also, the results of the test are presented and discussed.

## 2.0 Background

PPS Unit 1 uses an Integrated Gasification Combined Cycle Process (IGCC) to convert solid fuels into a syngas that can be fired in a CT. The IGCC process is capable of handling a variety of fuels as feedstock to the gasification process. Currently, PPS Unit 1 is typically fired on a blend of 55% petcoke and 45% coal. Thus, a similar blend was used during the test burn with biomass fuel added to allow for direct comparisons. This biomass test burn fired a fuel blend that consisted of approximately 55% petcoke, 44% coal, and 1% biomass.

The test conducted on December 31, 2001 was conducted:

- To determine if any technical impediments exist to co-firing biomass as a small portion of the feedstock to the gasifier, and
- To characterize the emissions resulting from co-firing biomass.


The IGCC process consists of several steps that ultimately result in the production of electrical power (Figure 1). Solid fuel is homogenized and mixed with water to produce slurry. The slurry is then passed to the gasifier that produces a high-pressure combustible gas (synthetic gas or “syngas”). After cooling the syngas, residual material from the gasification process is separated, the slag is rejected and the water and combustible fines are recycled back into the gasifier. Cooled syngas is passed through scrubbers that remove any remaining particulate matter. The syngas then is subjected to a series of steps that remove sulfur and convert the removed sulfur to  $\text{H}_2\text{SO}_4$ . This clean syngas is then fired in a CT that turns an electrical generator. Hot exhaust gasses from the CT are used to create steam that powers a steam turbine that also produces electrical power. This system is an efficient means to produce electrical power on a commercial scale.

## 2.1 Biomass Fuel Handling

This test used 8.8 tons of coarsely ground eucalyptus as the biomass fuel. Approximately 60 eucalyptus trees were harvested from the Common Purpose, Inc. grove located on land provided by the Tampa Airport Authority. The felled trees were sectioned into 4 foot lengths and passed through a portable hammer mill and trommel screen up to 5 times to produce material fine enough to avoid fouling the pumps and screens of PPS Unit 1’s slurry feed system. The biomass fuel was transported to PPS in an enclosed trailer.

Biomass fuel was stored, handled, at processed at PPS. Biomass fuel was staged in a cleaned bin. Approximately 800 pounds of biomass fuel were loaded with a small loader into each of 22 tote sacks. The tote sacks were suspended individually over the recycled fines tank (Figure 1). The biomass fuel was introduced into the process via a stirred recycle tank and mixed with water over a period of 8 ½ hours. The mixed biomass fuel was blended with the normal coal and petcoke mixture to form slurry that was fed to the gasifier.

**Figure 1. Block flow diagram of PPS Unit 1 gasifier section showing process stream designations.**



## 2.2 Process Data Collection

Data were collected for key variables throughout IGCC process to allow for analysis of air quality impacts of this test burn. Feedstock analyses were conducted on both the standard petcoke/coal blend and the biomass fuel. Feedstock analyses include elemental, metals, and ash mineral compositions and heating value for each fuel type. Process streams were analyzed for elemental and ash composition, mass flow, and heat content at 12 points in the IGCC process corresponding to the 12 numerical labels shown in Figure 1. An overall mass balance for the gasifier was calculated during the test burn for each of the 12 process points indicated in Figure 1. Stack emissions data were collected for  $\text{NO}_x$  and  $\text{SO}_2$  by the Continuous Emissions Monitoring System (CEMS) and reported at one-hour intervals throughout the test burn. Emissions data were reported in parts per million (ppm) for each pollutant.

## 2.3 Emissions data comparisons

Emissions data obtained during the test burn were compared to representative emissions data from December 29, 2001. The baseline data from December 29, 2001 were chosen as representative since those data are from the same petcoke/coal feedstock, were obtained immediately prior to the test burn, and Unit 1 was functioning normally and operating under similar conditions as those during the test burn. Larger baseline data sets were examined for possible comparison, but it was found that variability in process parameters such as heat input made statistical comparisons problematic for data that were obtained more than a few days prior to the test burn. For example, for the time period of December 26, 2001 to December 30, 2001 the sample variance for heat input in MMBtu was 12.4 times higher than the sample variance for the period December 29, 2001 to December 30, 2001 ( $\sigma^2_{5\text{-day}} = 1639$  compared to  $\sigma^2_{1\text{-day}} = 133$ ). Sample variance increased with time for heat input, power output, and for  $\text{NO}_x$  and  $\text{SO}_2$  emissions levels.

## 2.4 Statistical Methods for Comparing Emissions Data

Emissions data from the test burn were analyzed and compared to the baseline data using a variety of statistical measures. Emissions data from both the test burn and the baseline periods were evaluated using the same statistical measures. Data from the CEMS were reported as the variables Heat Input (MMBtu), Power Output (MW),  $\text{SO}_2$  (lb/MMBtu),  $\text{SO}_2$  (ppm),  $\text{NO}_x$  (lb/MMBtu),  $\text{NO}_x$  (ppm). The statistics mean ( $\mathbf{m}$ ), variance ( $\mathbf{S}^2$ ), kurtosis, skewness, range, and 95% confidence interval were calculated for each variable. The mean and variance were used to compare the test burn emissions data to the baseline emissions data. Kurtosis, skewness, range, and 95% confidence interval were used to evaluate the quality of the emissions data and to make decisions about which comparative methods were appropriate to use in comparing test burn and baseline data. To compare test burn data to baseline data, each set of variables was examined using a two-sample F-test to make inferences about population variances and a two-sample t-test assuming unequal variances to make inferences about population means.

The comparative statistical methods used in this report require that certain assumptions be met before the results of these methods can be considered valid. Comparisons between the means of the test burn data and the baseline data are most useful in determining if there is a change in a process after a treatment is applied.

The statistic that is used to make comparisons between sample means is called a two-sample t-test. A t-test can be used to determine if two populations' means are equal at a given significance level. The significance level for this report is 95% ( $\alpha = 0.05$ ) in all cases. A t-test compares the ratio of the sample means and variances to expected frequency distribution of a normal population at a specified error rate. The two-sample t-test is used to evaluate the hypothesis that two populations' means are equal against the alternative hypothesis that the two populations' means are unequal. The hypothesis of equal means is rejected when the calculated t-statistic is greater than the t-critical value at a given significance level. The validity of the t-test is based on several assumptions.

First, the two samples are independent. In practical terms, the assumption of independence means that the two samples are drawn from two different populations and that the elements of one sample are unrelated to those of the second sample. This assumption is met since the data for the test burn and the baseline emissions were taken by a discrete sampling device at different times with all variables controlled except for biomass used as a feedstock in the test burn.

Second, the two samples are drawn from a normally distributed population. Though the assumption of a normal population distribution is less critical than the assumption of independent samples it is still important to verify that the assumption is met. Since each data point collected by the CEMS is actually a discrete point sample of a continuously variable exhaust stream the potential sample population is quite large. For modest-sized samples (combined sample size  $\geq 30$ ) drawn from a large population the distribution approaches normal even with modest skewness in the two populations. The tendency of a relative frequency histogram to approach normal when samples are repeatedly drawn from a large population is called the Central Limit Theorem. Since the combined sample size of the test burn and baseline data is 28, it is prudent to verify that the Central Limit Theorem applies by calculating the skewness and kurtosis for each variable in each data set. Skewness is a measure of the central tendency of a frequency distribution that relates to the symmetry of the peak in relation to the mean, mode, and median of the distribution. Normal distributions have a skewness of 0. Kurtosis is a measure of the size of the tails of a frequency distribution. Normal distributions have a kurtosis of 0. If the sample's frequency distribution does not approximate normality, then the non-parametric Wilcoxon rank sum statistic can be used to compare population means. The Wilcoxon rank sum test is not as likely to declare a difference in population means when it exists as is a t-test since the Wilcoxon rank sum is based on relative magnitudes rather than the magnitudes of the observations.

Third, variances are assumed to be equal. Since the t-test pools sample variances when computing the test statistic, unequal variances can have an effect on the nominal significance and confidence probabilities of the statistical test, especially when sample sizes are different. However, a computationally more difficult version of the t-test that allows for the use of separate variances for each sample can be used when variances are not equal.

A statistical test for comparing two population variances is the F-test. The F-test is used to check the validity of the equal variance assumption for a two-sample t-test. The F-test compares the ratio of the sample variances to an expected population variance frequency distribution that is defined by the degrees of freedom associated with the samples. The F-test can be used to test the hypothesis that two sample variances are equal against the alternative hypothesis that two sample variances are not equal. The hypothesis of equal sample variances is rejected when the calculated F-statistic exceeds the F-critical value of the frequency distribution that is defined by the degrees of freedom for the two samples.

### **3.0 Results and Discussion**

Biomass fuel comprised approximately 1.2% of PPS Unit 1's fuel during the 8-½ hour test burn. Biomass fuel generated approximately 860 kW of electrical power during the test burn. The addition of biomass into the feedstock tended cause a decrease in the heat content of the feedstock due to biomass' elemental composition relative to the composition of the base fuel. Emissions from Unit 1 did not increase with respect to baseline

during the test burn. There were no major technical impediments to the introduction of biomass into the feedstock of Unit 1. Logs of the biomass feed rate and certified truck scale tickets of the biomass delivery were maintained, and are provided in Appendix A.

### 3.1 Process

Biomass was introduced to the gasifier at a rate of 1,945 lb/hr. The biomass feed rate was approximately 1.2% of the base fuel feed rate of 164,840 lb/hr. The biomass fuel accounted for approximately 860 kW of electrical power out of a total of 220.5 MW generated during the test burn based on relative heating value and feed rates of the biomass fuel and the base fuel. Process results are summarized in Table 1. Plant performance from the operators' standpoint was indistinguishable from the normal petcoke/coal feedstock. Heat input to the CT during the test burn was on average  $1667 \pm 9.5$  MMBtu compared to the heat input during the baseline period of  $1681 \pm 11.5$  MMBtu, which were obtained from CEM data. (Note: The actual LHV to the CT during the test was 1473 mmbtu/hr, and HHV was 1583 mmbtu/hr. The CEMS reported HHV to the CT has a large error and this is why it should not be used.) Average CT power output was steady at  $167.6 \pm 0.1$  MW during the test burn compared to  $167.5 \pm 0.08$  MW during the baseline period.

**Table 1. General process parameters for biomass and base fuels during the biomass test burn.**

Parameter	Base Fuel	Biomass Fuel	Total or Weighted Average
Feed Rate (lb/hr)	164,840	1,945	166,786 Total
Moisture Content (Wt%)	7.82%	46.8%	8.27% Avg
Higher Heating Value (Btu/lb)	13,322	4,424	13,218 Avg
Higher Heating Value (MMBtu/hr)	2,196	8.6	2,205 Avg
Net Power Production (kW)	219,640	860	220,500 Total

### 3.2 Mass Balance

The overall mass balance for the gasification process was estimated at 12 different process points. The mass balance is presented in Table 2 and the stream numbers correspond to the numerical labels in Figure 1. Process streams 1-2 and 4-8 are feed streams and have a total flow rate of 381 thousand pounds per hour (KPPH). Process streams 9-12 are output streams and have a total flow rate of 381 KPPH. Process streams 3 and 5 are key internal streams and have flow rates of 81 and 264 KPPH, respectively.

**Table 2. Overall mass balance for PPS Unit 1 gasifier section during biomass test burn. Units are in thousand pounds per hour (KPPH). Stream number corresponds to numerical labels in Figure 1.**

<b>Input (Feed) Streams</b>		
Stream Number	Stream Description	Flow (KPPH)
1	Coal / Petroleum Coke Blend	164.84
2	Biomass	1.95
4	Make-Up Water To Slurry	16.5
6	Oxygen To Gasifier	166.94
7	High Pressure Purge/Sootblowing N <sub>2</sub>	11.07
8	Pump Seal/Instrument Flush Water	19.49
<b>TOTAL SYSTEM INPUT</b>		<b>380.79</b>

<b>Product (Output) Streams</b>		
Stream Number	Stream Description	Flow (KPPH)
9	Slag	17.36
10	Brine	0.02
11	Clean Syngas To Combustion Turbine	337.78
12	Acid and NH <sub>3</sub> Gas To Sulfuric Acid Plant	25.62
<b>TOTAL SYSTEM OUTPUT STREAMS</b>		<b>380.78</b>

<b>Key Internal Streams</b>		
5	Slurry To Gasifier	264.4
3	Recycle Solids To Slurry Preparation	81.12

### 3.3 Process Stream Flows and Compositions

Each of the 12 process streams identified by numerical labels in Figure 1 was analyzed for composition and mass flows (Tables 3 and 4). Table 3 presents the stream flows and compositions for the slurry preparation area (streams 1-5). Table 3 also presents the heat content of streams 1-3 and 5. Calculated and analytically derived values for all parameters of stream 1 (base fuel) are presented in Table 3 for comparison purposes. Calculated and laboratory analytical values agree within the sampling and analytical accuracy range of the measurements. The addition of the biomass fuel to the base fuel resulted in a net decrease in composition (as a dry weight %) for all constituents except oxygen which increased by 0.25% and ash which increased by 0.01% over the calculated base fuel composition. Table 4 presents the flows and compositions for the gasification system (streams 3 and 5-12). Table 4 presents the compositional analysis of the clean syngas (stream 11) and residual materials from the gasification process (streams 9 and 3) as requested by the Department.

**Table 3. Slurry preparation area stream flows and compositions during test burn. KPPH = thousand pounds per hour, AR = as received.**

Stream Number		1	1	2	3	4	5	
Units		COKE + COAL (Lab)	COKE + COAL (Calculated)	BIOMASS	COMBINED FRESH FUELS	RECYCLE SOLIDS	MAKE-UP WATER	SLURRY TO GASIFIER
<b>COMPOSITION</b>								
C	Wt % Dry	82.88	82.24	49.18	82.02	66.26		80.68
H	"	4.5	4.71	5.78	4.71	0.29		4.34
N	"	1.85	1.83	0.24	1.81	0.95		1.74
S	"	2.99	3.15	0.06	3.13	2.31		3.06
O	"	3.53	3.67	39.42	3.92	0		3.58
ASH	"	4.25	4.4	5.32	4.41	30.19		6.6
TOTAL	"	100	100	100	100	100		100
SUBTOTAL KPPH DRY FLOW		151.95	151.95	1.035	152.985	14.196		167.181
H2O	Wt % AR	7.82	7.82	46.8	8.27	82.5		36.77
H2O	KPPH	12.891	12.891	0.91	13.801	66.924	16.496	97.22
TOTAL FLOW	KPPH AR	164.841	164.841	1.945	166.786	81.12		264.401
<b>MASS FLOW</b>								
C	Dry Lb/Hr	125936	124962	509	125471	9406		134877
H	"	6838	7150	60	7210	41		7251
N	"	2811	2774	2	2777	135		2911
S	"	4543	4791	1	4791	328		5119
O	"	5364	5582	408	5990	0		5990
ASH	"	6458	6691	55	6746	4286		11031
Ar	"	0	0	0	0	0		0
SUBTOTAL-Dry Solids		151950	151950	1035	152985	14196		167181
WATER / MOISTURE	lb/hr	12891	12891	910	13801	66924	16496	97220
TOTAL	"	164841	164841	1945	166786	81120		264401
<b>HEAT CONTENT</b>								
Calculated HHV BTU/Lb (Dry)		14491	14511	8419	14470	9698		14065
Measured HHV BTU/Lb (Dry)		14435		8213		9811		13990
Balance HHV BTU/Lb (Dry)		14452	14452	8315	14411	9701		14011
Balance HHV BTU/Lb (AR)		13322	13322	4424	13218	1698		
Balance HHV MMBTU/Hr		2196	2196	8.6	2205	138		2342



**Table 4. Gasification system stream flows and compositions during test burn. KPPH = thousand pounds per hour.**

STREAM NUMBER	GASIFICATION SYSTEM INPUTS					GASIFICATION SYSTEM OUTPUTS						
	5	6	7	8		9	3	10	11	12		
GAS STREAMS	UNITS	SLURRY TO GASIFIER	OXYGEN	HP PURGE NITROGEN	SEAL & FLUSH WATER	TOTAL SYSTEM INPUT	SLAG	RECYCLE SOLIDS	BRINE (NH <sub>4</sub> Cl)	CLEAN SYNGAS	ACID GASES	TOTAL SYSTEM OUTPUT
CO	VOL. %		0		0					44.72	2.06	
H <sub>2</sub>	VOL. %		0		0					36.02	0.52	
CH <sub>4</sub>	VOL. %		0		0					0.02	0.02	
CO <sub>2</sub>	VOL. %		0		0					15.01	66.42	
N <sub>2</sub>	VOL. %		1.08		99.99					3.33	0	
Ar	VOL. %		2.01		0					0.65	0	
H <sub>2</sub> O	VOL. %		0		0					0.21	5.26	
H <sub>2</sub> S	VOL. %		0		0					0.01	21.02	
COS	VOL. %		0		0					0.01	0.06	
NH <sub>3</sub>	VOL. %		0		0					0	4.62	
O <sub>2</sub>	VOL. %		96.9		0.01					0	0.01	
TOTAL	VOL. %		100		100					100	100	
MOLECULAR WEIGHT	LB/MOL		32.12		28.02					21.1	38.76	
FLOW	KSCFH		1972.6		149.9					6075.5	250.9	
<b>SOLID AND LIQUID STREAMS</b>												
C	WT %	80.68					42.37	66.26				
H	WT %	4.34					0.31	0.29	7.49			
N	WT %	1.74					0.44	0.95	26.22			
S	WT %	3.06					1.47	2.31				
O	WT %	3.58					0	0				
ASH	WT %	6.6					55.41	30.19	66.29			
TOTAL	WT %	100					100	100	100			
DRY FLOW	KPPH	167.181					12.149	14.196	0.021			
H <sub>2</sub> O	WT %	36.77					30	82.5				
H <sub>2</sub> O FLOW	KPPH	97.22			19.489		5.207	66.924				
TOTAL FLOW	KPPH	264.401					17.356	81.12				
<b>ELEMENTAL FLOWS / BALANCE:</b>												
C	LB/HR	134877	0	0		<b>134877</b>	5148	9406		114880	5443	<b>134877</b>
H	LB/HR	18130	0	0	2181	<b>20311</b>	620	7530	2	11709	450	<b>20311</b>
N	LB/HR	2911	1580	11066		<b>15558</b>	53	135	6	14936	428	<b>15558</b>
S	LB/HR	5119	0	0		<b>5119</b>	179	328		144	4469	<b>5119</b>
O	LB/HR	92331	161177	1	17308	<b>270817</b>	4624	59435		191926	14832	<b>270817</b>
ASH	LB/HR	11031	0	0		<b>11031</b>	6732	4286	14	0	0	<b>11031</b>
Ar	LB/HR	0	4184	0		<b>4184</b>				4184	0	<b>4184</b>
TOTAL	LB/HR	264401	166941	11067	19489	461898	17356	81120	21	337779	25623	461898

### 3.4 Feedstock Analysis

A complete feedstock laboratory analysis is presented in Table 5. Both the base fuel and the biomass fuel were analyzed for elemental composition, ash composition, metal, and heat content. Compared to the base fuel, biomass fuel has greater moisture content, ash, hydrogen, oxygen, and some metals. Compared to the base fuel, biomass fuel has lesser carbon, nitrogen, and sulfur content. The difference in elemental composition results in a much lesser heat content for biomass fuel than for the base fuel (biomass fuel heat content was 56.8% of the heat content of the base fuel) and accounts for the dilution effect observed when the fuels are blended.

**Table 5. Feed stock analysis of fuels used during test burn.**


		<b>Fuel</b>	<b>Coal/Coke Blend</b>	<b>Biomass</b>
<b>Total Moisture</b>		Units		
<b>Ultimate Analysis</b>		Wt %	7.82	46.8
	Ash	Wt % (Dry Basis)	4.25	5.32
	C	Wt % (Dry Basis)	82.88	49.18
	H	Wt % (Dry Basis)	4.5	5.78
	N	Wt % (Dry Basis)	1.85	0.24
	S	Wt % (Dry Basis)	2.99	0.06
	O	Wt % (Dry Basis)	3.53	39.42
<b>Heating Value</b>				
	Measured HHV	BTU/Lb (Dry Basis)	14435	8213
	Calculated HHV	BTU/Lb (Dry Basis)	14490	8419
<b>Miscellaneous</b>				
	T <sub>250</sub>	Deg F	2560	2188
	Chlorine	Wt % (Dry Basis in Coal)	0.02	0.07
	Fluorine	Wt % (Dry Basis in Coal)	<0.01	34
	Chromium	PPM (Wt) In Ash	136	85.9
	Vanadium	Wt % In Ash	2.286	0.63
	Nickel	ug/g dry coal	166	1300
	Arsenic	ug/g dry coal	2.1	35.3
	Mercury	ug/g dry coal	0.03	0.02
	Lead	ug/g dry coal	2.6	116
	Beryllium	ug/g dry coal	1.3	9.2
<b>Ash Minerals</b>				
	CrO	Wt % In Ash	0.02	0.01
	V <sub>2</sub> O <sub>5</sub>	Wt % In Ash	4.08	1.12
	NiO	Wt % In Ash	0.50	0.17
	As <sub>2</sub> O <sub>3</sub>	Wt % In Ash	0.0065	0.0050
	Hg	Wt % In Ash	0.000071	0.000002
	PbO	Wt % In Ash	0.0066	0.0120
	BeO	Wt % In Ash	0.0085	0.0030
	SiO <sub>2</sub>	Wt % In Ash	49.21	40.70
	Al <sub>2</sub> O <sub>3</sub>	Wt % In Ash	20.52	4.98
	TiO <sub>2</sub>	Wt % In Ash	0.93	0.29
	Fe <sub>2</sub> O <sub>3</sub>	Wt % In Ash	12.89	6.12
	CaO	Wt % In Ash	3.34	22.31
	MgO	Wt % In Ash	1.91	1.85
	Na <sub>2</sub> O	Wt % In Ash	0.57	1.41
	K <sub>2</sub> O	Wt % In Ash	2.04	3.64
	P <sub>2</sub> O <sub>5</sub>	Wt % In Ash	0.16	1.44
	SO <sub>3</sub>	Wt % In Ash	3.4	3.67
	Sum of Determined Minerals	Wt % In Ash	99.07	87.73
	Undetermined Ash Minerals	Wt % In Ash	0.93	12.27

### 3.5 Emissions


A statistical analysis was performed comparing the mean NO<sub>x</sub> and SO<sub>2</sub> emissions from the test burn to baseline emissions obtained immediately prior to the test burn. NO<sub>x</sub> and SO<sub>2</sub> emissions were analyzed for both baseline and test burn periods on a volumetric (ppm) and mass flow (lb/hr) basis. The statistical analyses consisted of calculating descriptive statistics and making pair-wise comparisons of each pollutant's variance and mean for the baseline data and the test burn data. The results of the analyses conducted using volumetric data were consistent with the results obtained using mass data.

NO<sub>x</sub> and SO<sub>2</sub> emissions during the test burn were found to be slightly lower than NO<sub>x</sub> and SO<sub>2</sub> emissions during the baseline period. Figures 2 and 3 show graphs of test burn emissions compared to baseline emissions for NO<sub>x</sub> and SO<sub>2</sub>, respectively. Tables 6 and 7 present the summary results of the statistical analyses for the test burn and baseline emissions data for NO<sub>x</sub> and SO<sub>2</sub>, respectively. The results presented are in volumetric units (ppm), but identical relationships and statistical conclusions are obtained using mass flow units (lb/hr). Table 8 summarizes the statistics for NO<sub>x</sub> and SO<sub>2</sub> emissions for the baseline and test burn periods in both volumetric and mass- flow units, for comparison.

**Figure 2. NO<sub>x</sub> emissions (ppm) from PPS Unit 1 during baseline and test burn periods.**



**Figure 3. SO<sub>2</sub> emissions (ppm) from PPS Unit 1 during baseline and test burn periods.**



Populations' mean and variance frequency distributions as measured by skewness and kurtosis approximated a normal distribution for both NO<sub>x</sub> and SO<sub>2</sub> when the sizes of the data sets were considered. Two sample t-tests, assuming unequal variances, were used to test if the mean values for NO<sub>x</sub> and SO<sub>2</sub> emissions were equal between the test burn and baseline emissions data. This was done because the F-tests rejected the hypothesis that the variances were equal between the test burn and the baseline emissions for

both NO<sub>x</sub> and SO<sub>2</sub>. The two sample t-tests results indicate that the observed differences in means are not due to chance at the 95% confidence level.

**Table 6. Statistical analysis comparing variances and means of baseline and test burn data for NO<sub>x</sub> emissions (ppm).**

Parameter	Baseline	Biomass
Mean (ppm)	23.44	21.25
Variance	3.89	0.06
Observations	18	11
Hypothesized Difference in Variance or Mean	0	
df F-test (t-test)	17 (18)	10
F <sub>calc</sub>	66.41	
Probability that calculated F is less than or equal to F <sub>crit</sub>	5.02E-08	
F <sub>Crit</sub>	2.81	
t <sub>calc</sub>	4.64	
Probability that calculated t <sub>calc</sub> is less than or equal to t <sub>crit</sub>	2.03E-04	
t <sub>crit</sub>	2.10	

Conclusion: Reject hypothesis that Variances or Means are equal.

**Table 7. Statistical analysis comparing variances and means of baseline and test burn data for SO<sub>2</sub> emissions (ppm).**

Parameter	Baseline	Biomass
Mean (ppm)	30.36	27.95
Variance	2.73	0.05
Observations	18	11
Hypothesized Difference in Variance or Mean	0	
df F-test (t-test)	17 (18)	10
F <sub>calc</sub>	51.99	
Probability that calculated F is less than or equal to F <sub>crit</sub>	1.66E-07	
F <sub>Crit</sub>	2.81	
t <sub>calc</sub>	6.11	
Probability that calculated t <sub>calc</sub> is less than or equal to t <sub>crit</sub>	9.00E-06	
t <sub>crit</sub>	2.10	

Conclusion: Reject hypothesis that Variances or Means are equal.

**Table 8. Comparison of baseline and test burn emissions in volumetric and mass flow units.**

Parameter	NO <sub>x</sub>				SO <sub>2</sub>			
	ppm		lb/hr		ppm		lb/hr	
	Baseline	Test	Baseline	Test	Baseline	Test	Baseline	Test
Mean	23.4	21.3	134.1	123.2	30.4	27.9	241.6	225.1
Number of Observations	18	11	18	11	18	11	18	11
Standard Deviation	1.97	0.24	11.35	2.2	1.7	0.2	13.1	2.5
Range	6	0.7	32.8	7.1	4.8	0.8	40.9	8.3
Minimum	19.9	20.8	114.75	119.1	28.1	27.5	221.9	221.3
Maximum	25.9	21.5	147.6	126.2	32.9	28.3	262.8	229.6
95% Confidence Interval	22.4 - 24.4	21.1 - 21.5	128.5 - 139.8	121.7 - 124.7	29.6 - 31.2	27.7 - 28.1	235.1 - 248.1	223.4 - 226.8

## 4.0 Conclusion

The test burn data indicates that the gasification of biomass is technically feasible and will not adversely impact emissions from PPS Unit 1. PPS requests the flexibility to gasify non- treated biomass. TEC understands that an air construction permit application is be required to accommodate the changes necessary to handle the biomass fuel. TEC appreciates the Department’s attention to this process.