

**CO-FIRING EUCALYPTUS BIOMASS
WITH PULVERIZED COAL**

Lakeland Electric & Water
McIntosh Power Plant
Unit 3

Michael H. Tate, P.E.

The McBurney Corporation
Norcross, GA
November 1998

219287-2

Introduction

Lakeland Electric & Water is investigating co-firing biomass with coal in existing coal fired units. This technique involves the direct injection of shredded wood fiber material into a pulverized coal fired furnace. Biomass was shredded to the consistency of fine mulch and blown into the furnace through existing refuse fuel injection ports. Coal and wood handling processing are separate. The McIntosh Plant has the unique benefit that the original system was designed to fire 10% (heat input basis) refuse derived fuel. It includes an existing solid waste processing facility and fuel transport system.

On August 26, 1998, tests were conducted at Lakeland's McIntosh Plant to test the biomass co-firing concept. Approximately 125 tons of shredded whole Eucalyptus trees were acquired from a local supplier. Tests were conducted by Lakeland Electric, co-firing this unit with a combination wood and coal. During a single continuous performance test, plant data was collected to evaluate the effect of co-firing the wood fuel.

In these tests, a co-firing level approaching 5% by heating value was achieved at full load. Average wood consumption rate during the test was about 21 tons/hour. Comprehensive stack tests were performed to determine the effect of co-firing wood compared to the same load on coal only. Results of the stack test are included in this report.

Boiler efficiency was lower with wood co-firing, due predominantly to fuel moisture and increased excess air associated with the wood fuel injection. With wood co-firing, boiler efficiency was reduced from baseline condition (100% coal blend) by approximately one boiler efficiency percentage point.

The test period was short for establishing effects on operations and maintenance. However, for the six hour test duration unusual slagging or fouling of the furnace was not noted.

This report presents the results of this test

Objectives

The objectives of this test were:

1. Determine if the existing refuse injection system is suitable for direct injecting shredded wood waste.
2. Evaluate the system performance when co-firing wood waste compared to 100% coal firing.
3. Obtain stack emissions data with and without the co-firing:

Fuel Analyses

Wood fuel samples were taken and ultimate analysis and heating value were determined by lab analysis. Copies of the lab results are attached. Following is a table of these analyses:

		Eucalyptus	Coal/Pet Coke
Carbon	(% wt.)	24.91	74.24
Hydrogen	(% wt.)	2.73	4.57
Oxygen	(% wt.)	19.81	5.33
Nitrogen	(% wt.)	0.11	1.43
Sulfur	(% wt.)	0.04	2.14
Ash	(% wt.)	0.94	7.45
Moisture	(% wt.)	51.46	4.83
Higher Heating Value	(Btu/lb)	4,238	13,305

Stack Test Results

Three hour stack tests were run for each of the firing conditions. The test data is attached to this report. A summary of the results is as follows:

		Coal Only	Co-Firing
NO _x	ppmv, dry basis	249.4	238.6
	lbs/MMBtu	0.504	0.481
SO ₂	ppmv, dry basis	199.6	248.7
	lbs/MMBtu	0.561	0.697
PM	grams/DSCF	0.00009	0.00011
	lbs/MMBtu	0.0035	0.0040

Effect on Boiler Efficiency

The boiler efficiency decreased by about 1% when coal heat input was replaced by biomass. Following is a summary of the approximated heat losses:

		Coal Only	Co-Firing
Dry Gas	(%)	5.61	5.74
H ₂ & H ₂ O in Fuel	(%)	3.94	4.76
Moisture in Air	(%)	0.15	0.15
Unburned Carbon	(%)	0.50	0.50
Radiation	(%)	0.16	0.16
Total Heat Loss	(%)	10.37	11.32
Boiler Efficiency	(%)	89.63	88.68

Fuel Handling

The existing fuel transport system handled the wood waste without problems. The plant personnel commented that the feed rate was extremely stable compared to refuse derived fuel.

Conclusions

Based upon tests conducted at the McIntosh Plant, the following conclusions can be made:

1. Wood was successfully co-fired by direct injection into the furnace. Co-firing levels approaching 5% by heating value were achieved with the plant at full load.
2. Wood consumption rate with the existing system was about 21 tons/hour.
3. With co-firing the stack emissions indicated a reduction in NOX and an increase in SO2 and particulate. However, due to the low percentage heat input from biomass these results are not conclusive. The nitrogen, sulfur and ash content of eucalyptus fuel was lower than the coal on an as fired basis.
4. Boiler efficiency decreased with wood co-firing.
5. The shredded eucalyptus trees flowed easily through the existing system.
6. Unusual slagging or fouling was not noted in the short course of this test.
7. Particles of unburned wood were present to some degree on the dump grate. Combustion of these unburned particles can be completed prior to dumping the grate.

Acknowledgments

This study was partially funded by the U.S. Department of Energy with funds from the Southeastern Regional Biomass Energy Program (SERBEP). SERBEP is administered for the U.S. Department of Energy by the Tennessee Valley Authority.

The success of this test is a result of the active participation and support of the following individuals: Jerry Burse, Tommy Dixon, Ed Colter, Billy Haywood, Dr. Alex Green and Steve Segrest. In addition, plant operators were instrumental in ensuring the safe and stable operation of the plant.



PHOTO 1

Eucalyptus Chips As Received on Tipping Floor




PHOTO 2

Eucalyptus Chip Pile Prepared for Firing




PHOTO 3
Closeup View of Eucalyptus Chips



PHOTO 4
Atlas Storage Bin with Drag Chain Discharge Conveyors
and Pneumatic Transport Lines



PHOTO 5

Baghouse for Dust Suppression System
and Pneumatic Transport Pipes



PHOTO 6

Center Cone and Fuel Sweep Inside Atlas
Fuel Storage Bin



PHOTO 7

Atlas Bin Floor Opening to Discharge Drag Chain
with Fuel Sweep Approaching Opening



PHOTO 8

End View of 1 of 4 Drag Chain Discharge Conveyors
from Atlas Fuel Storage Bin



PHOTO 9
Top View of Drag Chain Discharge
While Conveying Eucalyptus Chips



PHOTO 10
Fuel Transport Pipes



PHOTO 11
Fuel Transport Pipes




PHOTO 12
1 of 4 Rotary Air Locks Between
Drag Chain Discharge and
Fuel Transport Pipe




PHOTO 13
Atlas Fuel Storage Bin
Coal Silos and Boiler in Background

COAL AND BIOMASS CO-FIRING DATA

Boiler Duty Data		Units	14:29	15:29	16:29	17:29	18:29	Average
Main Steam Temp @ Blr	(°F)	Single Data Point Available						1007.4
Econ Water Inlet Temp	(°F)		355.5	355.9	356.4	355.9	355.4	355.8
31 PSH Outlet Temperature	(°F)		835.3	846.1	848.9	838.5	838.9	841.5
32 PSH Outlet Temperature	(°F)		850.1	862.9	865.9	851.9	851.9	856.5
31 1st DES Steam Out Temperature	(°F)		732.1	733.7	733.2	734.3	736.6	734.0
32 1st DES Steam Out Temperature	(°F)		715.6	716.7	715.6	716.2	716.5	716.1
31 Platen SH Out Temp.	(°F)		813.0	814.4	814.1	812.9	814.6	813.8
32 Platen SH Out Temp.	(°F)		813.2	814.5	814.1	813.2	814.9	814.0
Hot Reheat Stm Temp	(°F)	Single Data Point Available						1122.0
Cold RH Attemp In Temp	(°F)		665.7	668.4	668.7	666.1	666.7	667.1
Cold RH Attemp Out Temp	(°F)		647	634.2	630.5	642.9	648.3	640.6
RH Spray Water Temp	(°F)	Single Data Point Available						408.0
Main Stm Flow	(Klbh)		2215.2	2210.5	2210.6	2208.7	2209.3	2210.9
31 2 ST Attemp Flow	(Klbh)		26.6	30.4	30.5	23.6	24.3	27.1
32 2 ST Attemp Flow	(Klbh)		22.8	26.2	25.6	18	18.3	22.2
31 1 ST Attemp Flow	(Klbh)		141.2	148.1	152.1	141.1	141.6	144.8
32 1 ST Attemp Flow	(Klbh)		116.1	122.0	125.9	115.4	113.4	118.6
Reheat Attemp Flow	(Klbh)		19.9	47.1	53.9	26.4	20.8	33.6
FW Flow	(Klbh)		1896.9	1866.4	1868.0	1903.0	1906.8	1888.2
Main Stm Press	(psig)		2174.2	2170.0	2170.3	2169.1	2171.0	2170.9
Cold RH Stm Press	(psig)		589.4	593.2	594.9	589.4	588.6	591.1
Hot RH Stm Press	(psig)		560.2	563.9	565.3	559.6	559.7	561.7
Boiler Drum Press	(psig)		2465.0	2459.4	2460.5	2460.9	2463.3	2461.8

COAL AND BIOMASS CO-FIRING DATA

Combustion Data	Units	14:29	15:29	16:29	17:29	18:29	Average
31 SCAH In Temp	(°F)	107.7	108.3	108.8	107.9	106.3	107.8
32 SCAH In Temp	(°F)	105.4	105.1	105.4	105.5	107.1	105.7
31 APH Air In Temp	(°F)	112.5	106.8	106.8	112.7	104.4	108.6
32 APH Air In Temp	(°F)	111.9	111.3	111.8	112.1	113.5	112.1
31 APH Air Out Temp	(°F)	444.4	443.0	443.8	447.2	445.2	444.7
32 APH Air Out Temp	(°F)	503.4	504.2	503.7	504.7	507.0	504.6
31 APH Gas In Temp	(°F)	609.4	608.6	606.9	606.7	609.6	608.2
32 APH Gas In Temp	(°F)	609.7	608.2	606.0	607.3	610.3	608.3
31 APH Gas Out Temp	(°F)	276.9	273.1	275.0	279.4	273.1	275.5
32 APH Gas Out Temp	(°F)	309.1	306.5	306.7	306.3	305.9	306.9
31 Boiler O2	(%)	2.6	2.6	2.6	2.6	2.6	2.6
32 Boiler O2	(%)	3.5	3.5	3.5	3.5	3.5	3.5
Total Boiler Air Flow	(Klbh)	184182	185570	185670	181921	182429	183954
31 Coal Flow	(Klbh)	66.6	66.0	66.0	66.0	66.4	66.2
32 Coal Flow	(Klbh)	65.5	64.7	65.1	64.8	65.3	65.1
33 Coal Flow	(Klbh)	65.2	64.5	64.5	64.5	64.9	64.7
34 Coal Flow	(Klbh)	66.4	65.7	65.8	65.7	66.2	66.0

COAL FIRING DATA

Boiler Duty Data		Units	9:29	10:29	11:29	12:29	13:29	Average
Main Steam Temp @ Blr	(°F)	Single Data Point Available						1010.1
Econ Water Inlet Temp	(°F)		354.5	355.3	355.2	354.6	355.3	355.0
31 PSH Outlet Temperature	(°F)		844.5	850.9	852.0	829.3	839.5	843.2
32 PSH Outlet Temperature	(°F)		854.6	861.2	863.1	842.6	850.6	854.4
31 1st DES Steam Out Temperature	(°F)		736.2	734.7	731.4	724.6	726.4	730.7
32 1st DES Steam Out Temperature	(°F)		714.5	713.5	710.3	704.3	706.6	709.8
31 Platen SH Out Temp.	(°F)		814.1	814.1	814.2	813.5	814.2	814.0
32 Platen SH Out Temp.	(°F)		814.7	814.4	814.4	813.9	814.3	814.3
Hot Reheat Stm Temp	(°F)	Single Data Point Available						1122.0
Cold RH Attemp In Temp	(°F)		666.4	667.4	667.4	666.3	667.2	666.9
Cold RH Attemp Out Temp	(°F)		649.7	641.1	638.5	651.2	640.0	644.1
RH Spray Water Temp	(°F)	Single Data Point Available						408.0
Main Stm Flow	(Klbh)		2214.2	2215.3	2213.2	2210.6	2211.1	2212.9
31 2 ST Attemp Flow	(Klbh)		20	22.3	25.2	35.9	35.7	27.8
32 2 ST Attemp Flow	(Klbh)		18	19.7	22.2	31.4	30.8	24.4
31 1 ST Attemp Flow	(Klbh)		146.2	152.6	159.1	153.0	153.9	153.0
32 1 ST Attemp Flow	(Klbh)		119.3	126.2	132.4	121.6	127.0	125.3
Reheat Attemp Flow	(Klbh)		17.5	33.4	37.2	18.1	35.2	28.3
FW Flow	(Klbh)		1890.8	1868.7	1863.5	1878.9	1848.3	1870.0
Main Stm Press	(psig)		2169.2	2170.1	2169.3	2168.6	2169.2	2169.3
Cold RH Stm Press	(psig)		586.9	590.0	590.2	586.2	590.4	588.7
Hot RH Stm Press	(psig)		558.3	561.1	561.0	557.6	561.4	559.9
Boiler Drum Press	(psig)		2458.9	2458.6	2457.5	2456.8	2456.7	2457.7

COAL FIRING DATA

Combustion Data	Units	9:29	10:29	11:29	12:29	13:29	Average
31 SCAH In Temp	(°F)	94.1	98.7	103.3	105.4	106.8	101.7
32 SCAH In Temp	(°F)	97.5	100.4	102.7	104.5	106.1	102.2
31 APH Air In Temp	(°F)	97.1	100.5	105.6	106.6	105.0	103.0
32 APH Air In Temp	(°F)	104.2	106.9	109.2	110.7	112.8	108.8
31 APH Air Out Temp	(°F)	437.3	437.4	437.5	443.5	437.2	438.6
32 APH Air Out Temp	(°F)	500.9	501.2	501.9	503.5	498.9	501.3
31 APH Gas In Temp	(°F)	608.9	607.3	607.9	610.7	605.2	608.0
32 APH Gas In Temp	(°F)	614.3	612.2	611.7	612.4	607.1	611.5
31 APH Gas Out Temp	(°F)	263.2	264.2	266.6	272.5	266.5	266.6
32 APH Gas Out Temp	(°F)	303.6	303.1	307.4	311.6	298.2	304.8
31 Boiler O2	(%)	2.6	2.6	2.6	2.6	2.6	2.6
32 Boiler O2	(%)	3.5	3.5	3.5	3.5	3.5	3.5
Total Boiler Air Flow	(Klbh)	182756	182291	182350	182904	182527	182566
31 Coal Flow	(Klbh)	67.9	67.4	68.1	68.2	66.3	67.6
32 Coal Flow	(Klbh)	66.7	66.7	66.8	67.2	67.2	66.9
33 Coal Flow	(Klbh)	66.5	66.2	66.6	66.7	66.9	66.6
34 Coal Flow	(Klbh)	67.6	67.4	67.8	68.0	68.1	67.8



COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210 B, LOMBARD, ILLINOIS 60148 • TEL: 708-953-9300 FAX: 708-953-9308

SINCE 1908

Member of the SGS Group (Société Générale de Surveillance)

PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD.
SOUTH HOLLAND, IL 60473
TEL: (708) 531-2900
FAX: (708) 333-3060

April 13, 1998

CITY OF LAKELAND
3030 E. Lake Parker Dr.
Lakeland, FL 33805
Attn: Steven Parrish

Sample identification by
City of Lakeland

Kind of sample reported to us *Petroleum Coke / Coal blend*

Sample ID: 480-98

Sample taken at -----

Sample taken by -----

Date sampled March 8, 1998

Date received April 3, 1998

P.O. No. 42727

Analysis Report No. 71-64516

Page 1 of 1

ULTIMATE ANALYSIS

	<u>As Received</u>	<u>Dry Basis</u>	
% Moisture	4.83	XXXXXX	
% Carbon	74.24	78.01	
% Hydrogen	4.57	4.80	
% Nitrogen	1.43	1.50	
% Sulfur	2.14	2.25	
% Ash	7.45	7.84	
% Oxygen (diff)	<u>5.33</u>	<u>5.60</u>	
	100.00	100.00	
Btu/lb	13305	13980	MAF Btu 15169
% Chlorine	0.12	0.13	
Fluorine, ug/g		68	

METHODS

Moisture: ASTM D 3302; Carbon, Hydrogen & Nitrogen: ASTM D 5373; Sulfur: ASTM D 4239 (Method C); Ash: ASTM D 3174
Oxygen: Calculated Value (Difference); Btu/lb: ASTM D 3286; Chlorine: ASTM D 4208; Fluorine: ASTM D 3761

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Manager, South Holland Laboratory



OVER 40 BRANCH LABORATORIES STRATEGICALLY LOCATED IN PRINCIPAL COAL MINING AREAS, TIDEWATER AND GREAT LAKES PORTS, AND RIVER LOADING FACILITIES

F-465/071/95
Original Watermarked For Your Protection

TERMS AND CONDITIONS ON REVERSE

GENERAL TEST LABORATORY
 P.O. Box 2041
 BIRMINGHAM, ALABAMA 35291
 (205) 664-0081



CERTIFICATE OF ANALYSIS

TO:

Address:

Description: McBurney Corp. Eucalyptus Fuel

Customer Account

Sample Date : 26-Aug-98

Laboratory Account : CSDIG

Received Date : 03-Sep-98

Laboratory ID Number AC24135

Test Name	Reference	Result	Units
<i>Dry Basis</i>			
Ash, Dry	ASTM D 5142	1.83	% By Weight
Heat of Combustion, Dry	ASTM D 5865	8730	Btu/lb
Carbon, Dry Basis	ASTM D 5373	51.32	% By Weight
Hydrogen, Dry Basis	ASTM D 5373	5.62	% By Weight
Nitrogen, Dry Basis	ASTM D 5373	0.23	% By Weight
Chlorine, Dry Basis	ASTM D 3761	499	mg/kg
Sulfur, Dry Basis	ASTM D 4239	0.08	% By Weight
<i>As Received</i>			
Moisture, Total	ASTM D 2013	51.48	% By Weight
Ash, As Received	ASTM D 5142	0.94	% By Weight
Heat of Combustion, As Received	ASTM D 5865	4238	Btu/lb
Carbon, As Received	ASTM D 5373	24.91	% By Weight
Hydrogen, As Received	ASTM D 5373	2.73	% By Weight
Nitrogen, As Received	ASTM D 5373	0.11	% By Weight
Chlorine, As Received	ASTM D 3761	242	mg/kg
Sulfur, As Received	ASTM D 4239	0.04	% By Weight
<i>General</i>			
Heat of Combustion, MAF	ASTM D 5865	8902	Btu/lb
Coal Contract Sulf - #/mmBtu	ASTM D 3180	0.092	lbs/mmBTU
Sulfur - lbs/mmBTU	ASTM D 3180	0.092	lbs/mmBTU

This Certificate states the physical and/or chemical characteristics of the sample as submitted.

Comments:

Quality Control _____ Supervision _____ Date : 9/25/98
 CC _____

Company: The City of Lakeland, EPD
 From: C.D. McIntosh, Jr. Power Plant
 Location: Lakeland, Polk County, Florida
 Technicians: LJK, DKV, RPO
 Source: Unit 3, 4364 MW Steam Boiler

Preliminary Results PM, SO₂, and NO_x Unit M-3 Boimass

Test Run Description		Normal	Emergency		
Date		8/26/98	8/26/98		
Start Time (24 hr. CEMS time)		10:55	15:45	18:00	
Stop Time (24 hr. CEMS time)		13:18	14:52		
Unit Operational Data					
Fuel Flow (tons/hr of coal + petroleum coke)		130.93	132.94	131.94	
Fuel Flow (tons/hr of refuse derived fuel)		4.08	1.31	2.70	
Heat Input (MMBtu/hr, coal + coke + refuse)		3426.3	3420.2	3423.3	
Unit Load (% capacity, based upon 3640 MMBtu/hr maximum)		94.1	94.0	94.0	
Generator Output (MW, average for the tests)		367	367	367.0	
Stack Gas Sampling Data					
PM Hot/Cold Box No.		C-1	C-3	-	
Dry Gas Meter Factor		0.9888	0.9888	0.9888	
Atmospheric Pressure (" Hg, absolute)		29.46	29.44	29.45	
Average ΔH (meter differential pressure @ orifice)		2.29	2.37	2.33	
Average Meter Temperature (°R)		549.6	554.5	552.0	
Sample Volume at STP, dry basis (SCF)		88.799	93.659	91.229	
Moisture (% volume)		11.76	10.65	11.21	
O ₂ (% volume, dry basis)		8.82	8.80	8.81	
CO ₂ (% volume, dry basis)		10.71	10.74	10.73	
Stack Velocity (ft/sec @ stack conditions)		86.15	87.56	86.86	
Stack Flow - wet (kSCFM)		1158.87	1166.71	1162.79	
Stack Flow - dry (SCFD)		6.14E+07	6.25E+07	6.20E+07	
Sample Run Time (minutes)		120	120	120	
PM Sample Nozzle Area (ft ²)		0.0001917	0.0001917	0.000192	
% of Isokinetic Sampling		102.7	106.2	104.4	
Particulate Matter Filter Analysis (1)					
Filter Blank					
Average Tare Weight		0.3792	0.3641	0.3716	
Average Final Weight		0.3831	0.3684	0.3758	
Filter Weight Gain		0.0040	0.0044	0.0042	
Filter Blank Number					
Average Tare Weight		0.3677	0.3677	0.3677	
Average Final Weight		0.3677	0.3677	0.3677	
Filter Blank Weight Gain		0.0000	0.0000	0.0000	
Nozzle and Loose PM (1) - Loose PM - Grav					
Volume (Acetone)		100	100	100.0	
Average Tare Weight		97.4350	96.1587	96.7968	
Average Final Weight		97.4400	96.1651	96.8025	
Nozzle Weight Gain		0.0050	0.0064	0.0057	
Nozzle and Loose PM (1) - Loose PM - Grav					
Volume (Acetone)		100	100	100	
Average Tare Weight		101.6676	101.6676	101.6676	
Average Final Weight		101.6682	101.6682	101.6682	
Acetone Blank Residue Concentration (mg/mg)		0.0000076	0.0000076	0.0000076	
Particulate Matter Weight Gain					
Total Collected Blank Weight Correction (Acetone + Filter)		0.00060	0.00060	0.0006	
Total Collected Sample Weight (Filter + Nozzle + Loose PM)		0.00960	0.01075	0.0099	
Total Collected Particulate Matter, Blank Corrected (g)		0.00840	0.01015	0.0093	
Measured Emissions					
NO _x (ppmv, dry basis)		249.4	238.6	244.0	
NO _x (lbs/MMBtu, per EPA Method 19 O ₂ "F ₁ Factor")		0.504	0.481	0.493	0.70
SO ₂ (ppmv, dry basis)		199.6	248.7	224.2	
SO ₂ (lbs/MMBtu, per EPA Method 19 O ₂ "F ₁ Factor")		0.561	0.697	0.629	1.20
PM (grams PM/DSCF flue gas)		0.00009	0.00011	0.00010	
PM (lbs/MMBtu, per EPA Method 19 O ₂ "F ₁ Factor")		0.0035	0.0040	0.0038	0.050