

(A0006892)

Burk-Kleinpeter, Inc.

Engineers, Architects, Planners, Environmental Scientists
4176 Canal Street, New Orleans, LA 70119

CANAL ST. CANAL PUMP STATION

Job No.

Design By:

Date:

Checked By:

Page

1

9104


R.A.G.

Aug/91


of 10

Given: (from previous analysis)

* TEE WALL



PLAN
SCALE: 1/8" = 1'-0"



| | | | | |
|-----------------|----------------------|-----------------|-------------|-----------------|
| Job No. 9104 | Design By: P.A.G. | Date: Aug/91 | Checked By: | Page 2 of 10 |
|-----------------|----------------------|-----------------|-------------|-----------------|

LOAD DETERMINATIONS: (UNFACTORED)

$$W_1 = 1.75 \times 9.33 \times 40' \times 150 \#/\#^3 = 98^k \downarrow \text{STEM } \checkmark$$

$$W_2 = 2' \times 11' \times 40' \times 150 \#/\#^3 = 132^k \downarrow \text{slab } \checkmark$$

$$W_3 = 5' \times 9.33' \times 40' \times 62.4 \#/\#^3 = 116.4^k \downarrow \text{H}_2\text{O } \checkmark$$

$$W_4 = 11.33 \times 62.4 \#/\#^3 \times 40 \times 5.875 = 166^k \uparrow \checkmark$$

$$W_5 = W_6 = \text{pipe saddle + EQUIVALENT pipe load (4 pipes REQUIRED)}$$

$$\text{pipe saddle} = 1.5' \times 1' \times 150 \#/\#^3 \times 3.5' \times 4 = 3.2^k \downarrow \checkmark$$


$$W_5 \text{ EQUIVALENT pipe load} = 470 \#/\#^3 \times 15' \times 4 = 28^k \downarrow \text{(protected side)}$$

$$W_5 = 3.2^k + 28^k = 31.2^k \downarrow \checkmark$$

$$W_6 \text{ EQUIVALENT pipe load} = 470 \#/\#^3 \times 17' \times 4 = 32^k \downarrow \text{(Flood side)}$$

$$W_6 = 3.2^k + 32^k = 35.2^k \downarrow \checkmark$$

$$P = 62.4 \#/\#^3 \times 40' \times \frac{(11.33)^2}{2} = 160.2^k \rightarrow \checkmark$$



Burk-Kleinpeter, Inc.

Engineers, Architects, Planners, Environmental Scientists
4176 Canal Street, New Orleans, LA 70119

CSCPS


Job No.
9104

Design By:
R.A.G.

Date:
Aug/91

Checked By:

Page 3
of 10



$$P_1 = 120 \# / ft^2 \times 7.5' \times (2) \frac{2}{2} = 1.8^k @ 0.67' \quad \text{VARIES W/ DECREASE IN DEPTH}$$

$$W_7 = 120 \# / ft^2 \times 5' \times (2) \frac{2}{2} = 1.2^k @ 1.67' \quad \text{" " " "}$$

$$W_8 = 120 \# / ft^2 \times 4.25' \times (2) \frac{2}{2} = 1.02^k @ 1.42'$$

CASE I (Fully Loaded)

$$P_2 = W_1 + W_2 + W_3 - W_4 + W_5 + W_6 + W_7 + W_8 = 98 + 132 + 116.4 - 166 + 31.2 + 35.2 + 1.2 + 1.02 = 249^k \downarrow$$

$$\begin{aligned} \odot M_y &= W_2 \times 0.375 + W_3 \times 3.375 - W_4 \times 2.9375 - W_5 \times 4.625' \\ &\quad + W_6 \times 4.375 + W_7 \times 2.55' - W_8 \times 2.3' - P \times 3.78 \\ &= 132 \times 0.375 + 116.4 \times 3.375 - 166 \times 2.9375 - 31.2 \times 4.625 \\ &\quad + 35.2 \times 4.375 + 1.2 \times 2.55 - 1.02 \times 2.3 - 160.2 \times 3.78 \\ M_y &= 640.4^k \curvearrowright \end{aligned}$$

$$P_y = 160.2^k \rightarrow \leftarrow$$

Burk-Kleinpeter, Inc.

Engineers, Architects, Planners, Environmental Scientists
4176 Canal Street, New Orleans, LA 70119

CSCPS

| | | | | |
|-----------------|-------------------|-----------------|-------------|-----------------|
| Job No. 9104 | Design By: RAG | Date: Aug/91 | Checked By: | Page 4 of 10 |
|-----------------|-------------------|-----------------|-------------|-----------------|

CASE II

($W_4, W_6, W_7 = 0$)

$P_z = 379^k$ ↓

$M_x = 310^k$ ↻

$P_y = 160.2^k$ →

CASE III

(Pumps NOT in place)

$W_5 = 3.2^k$ $W_6 = 0$

$P_z = 186^k$ ↓


$M_x = 665^k$ ↻

$P_y = 160.2^k$ →

Based on soil REPORT from Eustis:

pile tip 73

$K_h(B)/CD = 2760 \text{ psi}$ (see bottom of page)



$B = 12 \text{ in}$ (width)
 $C = 0.3$ (cyclic loading)
 $D = \text{Group efficiency factor}$
 $ps = 7B = 84 \therefore D = \sqrt{0.85}$

$E_s = K_h(B) = 2760 \times 0.3 \times 0.85 = 703.8 \text{ psi}$

$AC = 50^k$ $AT = 25^k$ $Lu = 0'$

Based on Gulf Coast Pie-STRESS: 6-1/2" 250^k 12" # PCP

$P_B = 151.2^k$ $FPC = 0.868 \text{ ksi}$ (17.37% losses)

$P_0 = 537^k$ $M_0 = 331 \text{ in-k}$ $M_B = 959 \text{ in-k}$ $P_T = 491.92^k$

$E = 4074 \text{ ksi}$ $I_x = I_y = 1728 \text{ in}^4$ $A = 144 \text{ in}^2$

* ASSUME pinned *

* Note $K_h(B)/CD = 2760 = (3840 + 1920 + 2520) / 3$

667 @ 73' is for conservative pile will fail in bending

Burk-Kleinpeter, Inc.

Engineers, Architects, Planners, Environmental Scientists
4176 Canal Street, New Orleans, LA 70119

CSCPS

| | | | | |
|---------|------------|--------|-------------|-------|
| Job No. | Design By: | Date: | Checked By: | Page |
| 9104 | RAG | Aug/91 | | 5 |
| | | | | of 10 |

* For Abbreviations SEE CPGA program *

Determine FPC: ✓

$$\text{TOTAL Losses} = ES + SR_1 + C + SH + SR_2$$

$$7791 + 6009 + 3273 + 4430 + 8891 = 30,394 \text{ psi}$$

$$17.37\% \text{ Losses} + 83.63\% \text{ } 100\%$$

∴ Design load after losses is 83.63% of tensioning load
Strands tensioned to 70% of ultimate

$$\text{Design Load} = 250^k \times 0.7 \times 0.8363 \times \underset{\text{STRANDS}}{6} \times 0.144 = 126.4486^k$$

$$\text{FPC} = \frac{126.4486}{144} = 0.878 \text{ ksi use } 0.869 \text{ ksi}$$

Determine IPC:

$$\text{Tensioning Load} = 250^k \times 0.7 \times 6 \times 0.144 = 151.2^k$$

$$\text{(Initial Prestress)} = IP = \frac{151.2}{144} = 1.050 \text{ ksi}$$


Assume 5% immediate losses due to ES

$$IPC = 0.95 \times 1.05 = 0.9975 \text{ ksi}$$

Determine FA:

$$FA = 0.35 f'_c = 0.35 \times 5 = 1.75 \text{ ksi}$$

$$FT = 0$$



MODULUS OF HORIZONTAL SUBGRADE REACTION

JEFFERSON PARISH
 PUMP STATION AT CANAL STREET CANAL
 METAIRIE, LOUISIANA

DEFINITIONS

K_h (PCI) = MODULUS OF HORIZONTAL SUBGRADE REACTION

CLAY : $K_h = \frac{C D}{B} (0.2222 q_u)$

SAND : $K_h = \frac{C D}{B} (z \eta_h)$

q_u (PSF) = UNCONFINED COMPRESSION SHEAR STRENGTH

B (IN.) = WIDTH OR DIAMETER OF PILE

C = 0.3 (CYCLIC LOADING); 1.0 (INITIAL LOADING)

D = GROUP EFFICIENCY FACTOR

| <u>PS</u> | <u>D</u> |
|-----------|----------|
| 8B | 1.0 |
| 7B | 0.85 |
| 6B | 0.7 |
| 5B | 0.55 |
| 4B | 0.4 |
| 3B | 0.25 |

η_h (PCI) = COEFFICIENT OF HORIZONTAL SUBGRADE REACTION

= 5 (LOOSE SAND); 10 (DENSE SAND)

PS (IN.) = PILE SPACING IN DIRECTION OF LOAD

Z (IN.) = DEPTH BELOW EQUIVALENT GROUND

50/k

**STEEL PIPE AND PRECAST CONCRETE PILE LOAD CAPACITIES
FOR SUPPORT OF DISCHARGE PIPES**

| TYPE AND SIZE OF PILE | PILE TIP ELEVATION IN FEET NGVD | ESTIMATED ALLOWABLE SINGLE PILE LOAD CAPACITY IN TONS FACTOR OF SAFETY=2 |
|-------------------------------------|---------------------------------|--|
| 12-In. Diameter Open-End Steel Pipe | -70 | 38 |
| | -80 | 49 |
| | -90 | 59 |
| 14-In. Diameter Open-End Steel Pipe | -70 | 44 |
| | -80 | 57 |
| | -90 | 69 |
| 12-In. Square Precast Concrete | -70 | 50 <i>100K</i> |
| | -80 | 62 |
| | -90 | 75 |
| 14-In. Square Precast Concrete | -70 | 57 <i>114K</i> |
| | -80 | 73 |
| | -90 | 88 |

PILE LOAD CAPACITIES .

**JEFFERSON PARISH
PUMP STATION AT CANAL STREET CANAL
METAIRIE, LOUISIANA**

GULF COAST PRE-STRESS, INC.

Pass Christian, Mississippi

12" PILE DESIGN

CONCRETE RELEASE STRENGTH (f'cI) 4000 psi

CONCRETE DESIGN STRENGTH (F'c) 5000 psi

AREA CONC (Ac) = 144 sq

6 - 1/2" 250k S/R Strand

As 0.144

ULTIMATE 250 k

LOSSES 70%

P = 151,200 k _{P_B}

CALCULATE RESIDUAL STRESSES (Losses calculated per "Recommendations for Estimating Prestress Losses" PCI Committee on prestress loss as published in PCI Journal July / August 1975.

TOTAL LOSS = ES + CR + SH + RET

ELASTIC SHORTENING .63fs = 10% LOSSES (STRESS RELIEVED STRAND)

ES = fcr(Es/Eci) USE 9.25 % LOSSES LOW RELAXATION STRANDS

fci = 4000 Eci = 33fci^{1/2} * W^{3/2} = 3.64E+06

W = 145 Es = 28 x 10⁶

6 - 1/2" 250k S/R Strand

ES = 7791 psi

STEEL RELAXATION (RET_1) fpy = 0.90fpu (Low-Relaxation Strand)

(1st 18 hours) fpy = 0.85fpu (Stress Relieved Strand)

RET = fst{[log24t-log24t1]/45}*[fst/fpy-0.55] (Low-Relaxation Strand)

RET = fst{[log24t-log24t1]/10}*[fst/fpy-0.55] (Stress-Relieved Strand)

RET = 6009 175000 - 6009 = 168991 psi for 6-1/2" 250k S/R Strand

CREEP CR = (UCR)(SCF)(MCF)*(PCR)(fc) Volumn to surface Ratio

UCR = 63-20Ec/10⁶=>11 (use 11) SCF = 3

MCF = Accelerated Cure = 1 PCR = 0.35

6 - 1/2" 250k S/R Strand

CRc = 3273

SHRINKAGE SH = (USH)(SSF)(PSH) = 4430 psi

USH = 27,000-3000Ec/10⁶ = 12000

SSF Effect. Size and Shape = 0.879

PSH = (Shrink. Coeff. 30 days) = 0.42

STEEL RELAXATION (RET_2)

(30 days)

RET = fst{[log24t-log24t1]/45}*[fst/fpy-0.55] (Low-Relaxation Strands)

RET = fst{[log24t-log24t1]/45}*[fst/fpy-0.55] (Stress-Relieved Strands)

RET = 8891 6 - 1/2" 250k S/R Strand

TOTAL LOSSES = ES + RET_1 + RET_2 + CR + SH

6 - 1/2" 250k S/R Strand

Losses = 30,393 psi 30,394

Losses = 17.37% 83.63% Tension Loss

EFFECTIVE PRESTRESS AFTER ALL LOSSES

Using 6 - 1/2" 250k S/R Strand fpc = 868 psi = FPC = 0.868

5E/k

12" PILE DESIGN

Prestressed with 6-1/2" 250k S/R Strand

DIRECT LOAD:

$N = (.33f'c - 0.27 fpc) A_c$

N = 1416 * A_c
N = 204 kips or
N = 102 tons

NOMINAL STRENGTH:

$P_n = (.85f'c - 0.60fpc) A_c$

$P_n = 537 \text{ kips}$
FACTOR OF SAFETY = 2.63

MOMENT CAPACITY:

A_c = 144 sq in
I = 1,728 in⁴
I/c = 288 in³

Allowable tension = $4 * \sqrt{f'c} = 282.84 \text{ psi}$

M = f_c I/c = 331 in.-kips * M₀

NOMINAL MOMENT STRENGTH:

MOMENT M_n = 0.37t A_{ps} F_{pu} (solid piles)
F_{pu} = 250 ksi (ult. strength of the tendons)
A_{ps} = 0.864 sq in (area tendons)

M_n = 959 in.-kips * M₀
FACTOR OF SAFETY = 2.89

TENSILE CAPACITY OF PILE

Effective Prestress f_{pc} = 888.00 psi
Area of Concrete A_c = 144 sq in
Tensile Capacity of Pile = f_{pc} + 6 * sqrt(f'c) * A_c = 191.92 kips or P_T
Tensile Capacity of Pile = 98 tons

ALLOWABLE UNSUPPORTED LENGTH: (piles fixed at both ends)

h/r = 60
l_u = 60r / 0.5
l_u = 415.69 in. = 34.64 ft.
r = 3.46 in.

MAXIMUM LENGTH FOR 2-POINT & 3-POINT HANDLING:

W = 150 lbs/ft.
f'ci = 4000 psi
S = I/c = 288 in³
fpc = 868 psi
Allowable tension for 2-POINT = 6 * sqrt(f'ci)
Allowable tension for 3-POINT = 3 * sqrt(f'ci)
f_s (2-POINT LIFT) = f + 6 * sqrt(f'ci) = 1247 psi
f_s (3-POINT LIFT) = f + 3 * sqrt(f'ci) = 1058 psi
l = sqrt(f_s * S / 1.5 * 6 * W)
L <= 79 ft. for 2-POINT HANDLING
L <= 116 ft. for 3-POINT HANDLING

5F/4

* TEE3

```

*****
* CORPE PROGRAM * X0020 * CPGA - CASE FILE GROUP ANALYSIS PROGRAM
* VERSION NUMBER * 66/09/02-C * RUN DATE 09-04-91 RUN TIME 09:36:17
*****

```

CANAL STREET CANAL PUMP STATION (Teewa1) By Roy A. Glapion August 91

THERE ARE 20 FILES AND 3 LOAD CASES IN THIS RUN.

ALL FILE COORDINATES ARE CONTAINED WITHIN A BOX

```

          X          Y          Z
-----
WITH DIAGONAL COORDINATES = (  -19.33 ,  -4.58 ,  .00 )
                             (   18.33 ,   2.63 ,  .00 )

```

FILE PROPERTIES AS INPUT

| E | I1 | I2 | A | CS | Re |
|------------|------------|------------|------------|------------|------------|
| KBI | IN**4 | IN**4 | IN**2 | | |
| .40740E+04 | .17280E+04 | .17280E+04 | .14400E+03 | .20000E+01 | .05000E+00 |

THESE FILE PROPERTIES APPLY TO THE FOLLOWING FILES -

All

SOIL DESCRIPTIONS AS INPUT

| ES | SOIL | LENGTH | L | LU |
|----|------------|--------|------------|------------|
| | K/IN**1 | | FT | FT |
| | .70380E+00 | L | .73000E+02 | .00000E+00 |

THIS SOIL DESCRIPTION APPLIES TO THE FOLLOWING FILES -

All

FILE STIFFNESSES AS CALCULATED FROM PROPERTIES

| | | | | | |
|------------|------------|------------|------------|------------|------------|
| .27997E+07 | .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 |
| .00000E+00 | .27767E+02 | .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 |
| .00000E+00 | .00000E+00 | .13394E+04 | .00000E+00 | .00000E+00 | .00000E+00 |
| .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 |
| .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 |
| .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 |

THIS MATRIX APPLIES TO THE FOLLOWING FILES -

FILE GEOMETRY AS INPUT AND/OR GENERATED

| NUM | X FT | Y FT | Z FT | BATTER | ANGLE | LENGTH FT | FIXITY |
|-----|---------|---------|---------|--------|--------|--------------|--------|
| 1 | 2.04 | -4.38 | .00 | 3.00 | 180.00 | 73.00 | F |
| 2 | 6.11 | -4.38 | .00 | 3.00 | 180.00 | 73.00 | F |
| 3 | 10.18 | -4.38 | .00 | 3.00 | 180.00 | 73.00 | F |
| 4 | 14.26 | -4.38 | .00 | 3.00 | 180.00 | 73.00 | F |
| 5 | 18.33 | -4.38 | .00 | 3.00 | 180.00 | 73.00 | F |
| 6 | -2.04 | -4.38 | .00 | 3.00 | 180.00 | 73.00 | F |
| 7 | -6.11 | -4.38 | .00 | 3.00 | 180.00 | 73.00 | F |
| 8 | -10.18 | -4.38 | .00 | 3.00 | 180.00 | 73.00 | F |
| 9 | -14.26 | -4.38 | .00 | 3.00 | 180.00 | 73.00 | F |
| 10 | -18.33 | -4.38 | .00 | 3.00 | 180.00 | 73.00 | F |
| 11 | 2.04 | 2.63 | .00 | 3.00 | 90.00 | 73.00 | F |
| 12 | 6.11 | 2.63 | .00 | 3.00 | 90.00 | 73.00 | F |
| 13 | 10.18 | 2.63 | .00 | 3.00 | 90.00 | 73.00 | F |
| 14 | 14.26 | 2.63 | .00 | 3.00 | 90.00 | 73.00 | F |
| 15 | 18.33 | 2.63 | .00 | 3.00 | 90.00 | 73.00 | F |
| 16 | -2.04 | 2.63 | .00 | 3.00 | 90.00 | 73.00 | F |
| 17 | -6.11 | 2.63 | .00 | 3.00 | 90.00 | 73.00 | F |
| 18 | -10.18 | 2.63 | .00 | 3.00 | 90.00 | 73.00 | F |
| 19 | -14.26 | 2.63 | .00 | 3.00 | 90.00 | 73.00 | F |
| 20 | -18.33 | 2.63 | .00 | 3.00 | 90.00 | 73.00 | F |
| | | | | | | 1460.00 | |

APPLIED LOADS

| LOAD CASE | PX K | PY K | PZ K | MX FT-K | MY FT-K | MZ FT-K |
|--------------|---------|---------|---------|------------|------------|------------|
| 1 | .0 | 160.2 | 249.0 | 640.4 | .0 | .0 |
| 2 | .0 | 160.2 | 379.0 | 310.0 | .0 | .0 |
| 3 | .0 | 160.2 | 186.0 | 680.0 | .0 | .0 |

ORIGINAL PILE GROUP STIFFNESS MATRIX

| | | | | | |
|-------------|-------------|-------------|-------------|-------------|-------------|
| .10712E+04 | .57324E-04 | -.39342E+04 | .20655E+06 | .78125E-02 | .74726E+05 |
| .57324E-04 | .18712E+04 | .39342E+04 | .12393E+06 | -.78125E-02 | .15735E+01 |
| -.39342E+04 | .39342E+04 | .24165E+05 | -.25373E+06 | .31250E-01 | -.20605E+06 |
| .20655E+06 | .12393E+06 | -.25373E+06 | .45291E+08 | -.25000E+01 | .10844E+08 |
| .78125E-02 | -.78125E-02 | .31250E-01 | .30000E+01 | .47648E+09 | -.77574E+08 |
| .74726E+05 | .78125E-02 | -.20655E+06 | .10844E+08 | -.77574E+08 | .41559E+08 |

LOAD CASE 1. NUMBER OF FAILURES = 0. NUMBER OF PILES IN TENSION = 0.

LOAD CASE 2. NUMBER OF FAILURES = 0. NUMBER OF PILES IN TENSION = 0.

LOAD CASE 3. NUMBER OF FAILURES = 0. NUMBER OF PILES IN TENSION = 0.

| LOAD CASE | TX IN | DY IN | DZ IN | RX RAD | RY RAD | RZ RAD |
|-----------|------------|-----------|------------|------------|------------|------------|
| 1 | .1030E-02 | .1351E+00 | -.1452E-01 | -.2863E-03 | .1577E-06 | .9685E-06 |
| 2 | .5335E-01 | .1163E+00 | .7416E-03 | -.4873E-03 | .8166E-05 | .5014E-04 |
| 3 | -.1377E-01 | .1549E+00 | -.2315E-01 | -.3114E-03 | -.2107E-05 | -.1294E-04 |

PILE FORCES IN LOCAL GEOMETRY

M1 & M2 NOT AT PILE HEAD FOR PINNED FILES
 * INDICATES PILE FAILURE
 # INDICATES CBF BASED ON MOMENTS DUE TO (F3&EMIN) FOR CONCRETE PILES
 B INDICATES BUCKLING CONTROLS

LOAD CASE - 1

| PILE | F1 K | F2 K | F3 K | M1 IN-K | M2 IN-K | M3 IN-K | ALF | CBF | APC KSI | AGT KSI |
|------|------|------|------|---------|---------|---------|-----|-----|---------|---------|
| 1 | .0 | -3.8 | .2 | -96.9 | .8 | .0 | .00 | .93 | 1.34 | .53 |
| 2 | .0 | -3.8 | .2 | -96.9 | .8 | .0 | .00 | .93 | 1.34 | .53 |
| 3 | .0 | -3.8 | .2 | -96.9 | .8 | .0 | .00 | .93 | 1.34 | .53 |
| 4 | .0 | -3.8 | .2 | -97.0 | .8 | .0 | .00 | .93 | 1.34 | .53 |
| 5 | .0 | -3.8 | .1 | -97.0 | .4 | .0 | .00 | .93 | 1.34 | .53 |
| 6 | .0 | -3.8 | .2 | -96.8 | .9 | .0 | .00 | .93 | 1.34 | .53 |
| 7 | .0 | -3.8 | .2 | -96.8 | .9 | .0 | .00 | .93 | 1.34 | .53 |
| 8 | .0 | -3.8 | .2 | -96.8 | .9 | .0 | .00 | .93 | 1.34 | .53 |
| 9 | .0 | -3.8 | .2 | -96.7 | .9 | .0 | .00 | .93 | 1.34 | .53 |
| 10 | .0 | -3.8 | .2 | -96.7 | .9 | .0 | .00 | .92 | 1.34 | .53 |
| 11 | 3.8 | .0 | 27.3 | -.7 | -97.2 | .0 | .27 | .61 | 1.53 | .72 |
| 12 | 3.8 | .0 | 27.3 | -.7 | -97.3 | .0 | .27 | .61 | 1.53 | .72 |
| 13 | 3.8 | .0 | 27.3 | -.7 | -97.3 | .0 | .27 | .61 | 1.53 | .72 |
| 14 | 3.8 | .0 | 27.3 | -.7 | -97.3 | .0 | .27 | .61 | 1.53 | .72 |
| 15 | 3.8 | .0 | 27.4 | -.7 | -97.4 | .0 | .27 | .61 | 1.53 | .72 |
| 16 | 3.8 | .0 | 27.3 | -.7 | -97.2 | .0 | .27 | .61 | 1.53 | .72 |
| 17 | 3.8 | .0 | 27.3 | -.7 | -97.2 | .0 | .27 | .61 | 1.53 | .72 |
| 18 | 3.8 | .0 | 27.3 | -.7 | -97.1 | .0 | .27 | .61 | 1.53 | .72 |
| 19 | 3.8 | .0 | 27.3 | -.7 | -97.1 | .0 | .27 | .61 | 1.53 | .72 |
| 20 | 3.8 | .0 | 27.3 | -.7 | -97.1 | .0 | .27 | .61 | 1.53 | .72 |

LOAD CASE - 2

| PILE | F1 K | F2 K | F3 K | M1 IN-K | M2 IN-K | M3 IN-K | ALF | CBF | APC KSI | AGT KSI |
|------|------|------|------|---------|---------|---------|-----|-----|---------|---------|
| 1 | -1.7 | -3.3 | 9.5 | -64.3 | 44.0 | .0 | .09 | .84 | 1.51 | .44 |
| 2 | -1.7 | -3.4 | 9.0 | -66.0 | 43.7 | .0 | .09 | .85 | 1.51 | .44 |
| 3 | -1.7 | -3.4 | 8.5 | -67.8 | 43.8 | .0 | .08 | .86 | 1.51 | .47 |
| 4 | -1.7 | -3.5 | 8.0 | -69.5 | 43.7 | .0 | .08 | .87 | 1.51 | .46 |
| 5 | -1.7 | -3.6 | 7.5 | -91.3 | 43.6 | .0 | .07 | .88 | 1.51 | .47 |
| 6 | -1.7 | -3.2 | 10.0 | -82.5 | 44.1 | .0 | .10 | .87 | 1.51 | .50 |
| 7 | -1.7 | -3.2 | 10.5 | -80.2 | 44.2 | .0 | .11 | .88 | 1.51 | .52 |
| 8 | -1.7 | -3.1 | 11.0 | -79.0 | 44.3 | .0 | .11 | .89 | 1.51 | .52 |
| 9 | -1.7 | 3.0 | 11.5 | -77.2 | 44.3 | .0 | .12 | .89 | 1.51 | .52 |
| 10 | -1.7 | 3.0 | 12.0 | -75.5 | 44.4 | .0 | .12 | .90 | 1.51 | .52 |
| 11 | -1.7 | 3.0 | 12.0 | -75.5 | 44.4 | .0 | .12 | .90 | 1.51 | .52 |

| | | | | | | | | | | |
|----|-----|------|------|-------|-------|----|-----|-----|------|-----|
| 11 | 3.0 | -1.4 | 31.5 | -37.1 | -68.0 | .0 | .32 | .57 | 1.64 | -68 |
| 12 | 3.4 | -1.4 | 32.0 | -37.1 | -68.6 | .0 | .33 | .57 | 1.64 | -68 |
| 13 | 3.5 | -1.4 | 32.6 | -37.1 | -68.6 | .0 | .33 | .57 | 1.64 | -68 |
| 14 | 3.5 | -1.4 | 33.1 | -37.1 | -90.3 | .0 | .33 | .56 | 1.67 | -68 |
| 15 | 3.5 | -1.4 | 33.4 | -37.1 | -81.5 | .0 | .30 | .57 | 1.67 | -67 |
| 16 | 3.2 | -1.4 | 29.9 | -37.1 | -79.8 | .0 | .30 | .58 | 1.61 | -67 |
| 17 | 3.1 | -1.4 | 29.4 | -37.1 | -78.0 | .0 | .29 | .58 | 1.61 | -67 |
| 18 | 3.0 | -1.4 | 28.9 | -37.1 | -76.3 | .0 | .29 | .58 | 1.77 | -68 |
| 19 | 3.0 | -1.4 | 28.3 | -37.1 | -74.5 | .0 | .28 | .58 | 1.88 | -68 |
| 20 | 2.9 | -1.4 | | | | | | | | |

LOAD CASE - 3

| FILE | F1 K | F2 K | F3 K | M1 IN-K | M2 IN-K | M3 IN-K | ALF | CBF | ACI PSI | AST KSI |
|------|---------|---------|---------|------------|------------|------------|-----|-----|------------|------------|
| 1 | .4 | -4.3 | -2.4 | -110.5 | -11.4 | .0 | .05 | .98 | 1.40 | .43 |
| 2 | .4 | -4.3 | -2.3 | -110.3 | -11.3 | .0 | .05 | .96 | 1.40 | .43 |
| 3 | .4 | -4.3 | -2.2 | -107.9 | -11.3 | .0 | .04 | .95 | 1.40 | .43 |
| 4 | .4 | -4.3 | -2.1 | -109.4 | -11.3 | .0 | .04 | .94 | 1.40 | .44 |
| 5 | .4 | -4.3 | -1.9 | -109.0 | -11.3 | .0 | .04 | .94 | 1.40 | .44 |
| 6 | .4 | -4.3 | -2.0 | -111.3 | -11.4 | .0 | .05 | .97 | 1.41 | .43 |
| 7 | .4 | -4.4 | -2.7 | -111.7 | -11.4 | .0 | .05 | .97 | 1.41 | .42 |
| 8 | .4 | -4.4 | -2.8 | -112.2 | -11.4 | .0 | .05 | .98 | 1.41 | .42 |
| 9 | .4 | -4.4 | -3.0 | -112.6 | -11.4 | .0 | .06 | .98 | 1.41 | .42 |
| 10 | .4 | -4.4 | -3.1 | -113.1 | -11.5 | .0 | .06 | .99 | 1.41 | .42 |
| 11 | 4.4 | .4 | 23.7 | 9.6 | -112.6 | .0 | .24 | .70 | 1.57 | .61 |
| 12 | 4.4 | .4 | 23.6 | 9.6 | -112.1 | .0 | .24 | .70 | 1.56 | .61 |
| 13 | 4.4 | .4 | 23.4 | 9.6 | -111.7 | .0 | .23 | .70 | 1.55 | .61 |
| 14 | 4.3 | .4 | 23.3 | 9.6 | -111.2 | .0 | .23 | .70 | 1.55 | .61 |
| 15 | 4.3 | .4 | 23.1 | 9.6 | -110.8 | .0 | .23 | .70 | 1.55 | .61 |
| 16 | 4.4 | .4 | 23.6 | 9.6 | -113.0 | .0 | .24 | .70 | 1.57 | .61 |
| 17 | 4.4 | .4 | 23.9 | 9.6 | -113.5 | .0 | .24 | .70 | 1.57 | .61 |
| 18 | 4.4 | .4 | 24.1 | 9.6 | -113.9 | .0 | .24 | .70 | 1.57 | .61 |
| 19 | 4.5 | .4 | 24.2 | 9.6 | -114.4 | .0 | .24 | .70 | 1.58 | .61 |
| 20 | 4.5 | .4 | 24.4 | 9.6 | -114.8 | .0 | .24 | .70 | 1.57 | .61 |

PILE FORCES IN GLOBAL GEOMETRY

LOAD CASE - 1

| FILE | PX K | PY K | PZ K | MX IN-K | MY IN-K | MZ IN-K |
|------|---------|---------|---------|------------|------------|------------|
| 1 | .0 | 3.8 | .2 | .0 | .0 | .0 |
| 2 | .0 | 3.8 | .2 | .0 | .0 | .0 |
| 3 | .0 | 3.8 | .2 | .0 | .0 | .0 |
| 4 | .0 | 3.8 | .2 | .0 | .0 | .0 |
| 5 | .0 | 3.8 | .1 | .0 | .0 | .0 |
| 6 | .0 | 3.8 | .2 | .0 | .0 | .0 |
| 7 | .0 | 3.8 | .2 | .0 | .0 | .0 |
| 8 | .0 | 3.8 | .2 | .0 | .0 | .0 |
| 9 | .0 | 3.8 | .2 | .0 | .0 | .0 |
| 10 | .0 | 3.8 | .2 | .0 | .0 | .0 |
| 11 | .0 | 12.2 | 24.7 | .0 | .0 | .0 |
| 12 | .0 | 12.2 | 24.7 | .0 | .0 | .0 |
| 13 | .0 | 12.2 | 24.7 | .0 | .0 | .0 |
| 14 | .0 | 12.3 | 24.7 | .0 | .0 | .0 |
| 15 | .0 | 12.3 | 24.8 | .0 | .0 | .0 |
| 16 | .0 | 12.2 | 24.7 | .0 | .0 | .0 |
| 17 | .0 | 12.2 | 24.7 | .0 | .0 | .0 |
| 18 | .0 | 12.2 | 24.7 | .0 | .0 | .0 |
| 19 | .0 | 12.2 | 24.7 | .0 | .0 | .0 |
| 20 | .0 | 12.2 | 24.7 | .0 | .0 | .0 |

55/k

| | | | | | | |
|----|----|------|------|----|----|----|
| 18 | .0 | 12.2 | 24.7 | .0 | .0 | .0 |
| 19 | .0 | 12.2 | 24.7 | .0 | .0 | .0 |
| 20 | .0 | 12.2 | 24.7 | .0 | .0 | .0 |

160.2^k 249^k

LOAD CASE - 2

| FILE | PX K | PY K | PZ K | MX IN-K | MY IN-K | MZ IN-K |
|------|---------|---------|---------|------------|------------|------------|
| 1 | -1.4 | 3.3 | 9.5 | .0 | .0 | .0 |
| 2 | -1.2 | 3.4 | 9.1 | .0 | .0 | .0 |
| 3 | -1.1 | 3.4 | 8.4 | .0 | .0 | .0 |
| 4 | -.9 | 3.5 | 8.1 | .0 | .0 | .0 |
| 5 | -.7 | 3.6 | 7.6 | .0 | .0 | .0 |
| 6 | -1.5 | 3.2 | 10.0 | .0 | .0 | .0 |
| 7 | -1.7 | 3.2 | 10.5 | .0 | .0 | .0 |
| 8 | -1.8 | 3.1 | 11.0 | .0 | .0 | .0 |
| 9 | -2.0 | 3.0 | 11.5 | .0 | .0 | .0 |
| 10 | -2.2 | 2.9 | 12.0 | .0 | .0 | .0 |
| 11 | 1.4 | 12.9 | 28.4 | .0 | .0 | .0 |
| 12 | 1.4 | 13.1 | 28.8 | .0 | .0 | .0 |
| 13 | 1.4 | 13.3 | 29.3 | .0 | .0 | .0 |
| 14 | 1.4 | 13.6 | 29.6 | .0 | .0 | .0 |
| 15 | 1.4 | 13.8 | 30.3 | .0 | .0 | .0 |
| 16 | 1.4 | 12.6 | 27.9 | .0 | .0 | .0 |
| 17 | 1.4 | 12.4 | 27.4 | .0 | .0 | .0 |
| 18 | 1.4 | 13.2 | 28.9 | .0 | .0 | .0 |
| 19 | 1.4 | 11.9 | 28.4 | .0 | .0 | .0 |
| 20 | 1.4 | 11.7 | 28.9 | .0 | .0 | .0 |

-0.5^k 160.1^k 379^k

LOAD CASE - 3

| FILE | PX K | PY K | PZ K | MX IN-K | MY IN-K | MZ IN-K |
|------|---------|---------|---------|------------|------------|------------|
| 1 | .4 | 4.3 | -2.8 | .0 | .0 | .0 |
| 2 | .3 | 4.3 | -2.3 | .0 | .0 | .0 |
| 3 | .3 | 4.3 | -2.2 | .0 | .0 | .0 |
| 4 | .2 | 4.3 | -2.1 | .0 | .0 | .0 |
| 5 | .2 | 4.3 | -2.0 | .0 | .0 | .0 |
| 6 | .4 | 4.3 | -2.4 | .0 | .0 | .0 |
| 7 | .4 | 4.4 | -2.7 | .0 | .0 | .0 |
| 8 | .5 | 4.4 | -2.8 | .0 | .0 | .0 |
| 9 | .5 | 4.4 | -3.0 | .0 | .0 | .0 |
| 10 | .6 | 4.4 | -3.1 | .0 | .0 | .0 |
| 11 | -.4 | 11.7 | 21.1 | .0 | .0 | .0 |
| 12 | -.4 | 11.6 | 20.9 | .0 | .0 | .0 |
| 13 | -.4 | 11.5 | 20.8 | .0 | .0 | .0 |
| 14 | -.4 | 11.5 | 20.7 | .0 | .0 | .0 |
| 15 | -.4 | 11.4 | 20.6 | .0 | .0 | .0 |
| 16 | -.4 | 11.7 | 21.2 | .0 | .0 | .0 |
| 17 | -.4 | 11.8 | 21.3 | .0 | .0 | .0 |
| 18 | -.4 | 11.8 | 21.4 | .0 | .0 | .0 |
| 19 | -.4 | 11.9 | 21.6 | .0 | .0 | .0 |
| 20 | -.4 | 12.0 | 21.7 | .0 | .0 | .0 |

-0.2^k 160.3^k 186^k

1000 CANAL STREET CANAL PUMP STATION (Teewall) By Roy A. Blapion August 4.
1010 PRO 4074 1728 1728 144 2.0 0 ALL
1020 BOT ES 0.7038 L 73 0 ALL
1030 PIN ALL
1040 DLS S 100 50 537.0 191.92 151.20 959.0 331.0 H 12 ALL
1050 ABC S 144 288 0.87 0.9975 1.75 0 ALL
1070 BAT 3.0 ALL
1080 ANG 180 1 TO 10
1084 ANG 90 11 TO 20
1100 FIL 1 2.037 -4.375 0
1110 FIL 11 2.037 2.625 0
1112 FIL 6 -2.037 -4.375 0
1114 FIL 16 -2.037 2.625 0
1120 ROW X 5 1 4 AT 4.0740
1130 ROW X 5 11 4 AT 4.0740
1132 ROW X 5 6 4 AT -4.0740
1134 ROW X 5 16 4 AT -4.0740
1150 LOA 1 0 180.2 249 640.4 0 0
1160 LOA 2 0 180.2 377 310 0 0
1170 LOA 3 0 180.2 186 665 0 0
1180 FOU 1 2 3 4 5 6 7 TEES
1190 PFD 1
1200 PFD ALL
1210 TPL N

Burk-Kleinpeter, Inc.

Engineers, Architects, Planners, Environmental Scientists
4176 Canal Street, New Orleans, LA 70119

CHILL STREET CANAL PUMP STATION

Job No.

9104

Design By:

RAG

Date:

Aug/91

Checked By:


Page

6

of

10

Flexure:



$$\frac{P}{\text{ft of wall}} =$$

$$\frac{62.4 \text{ #/ft}^3 \times 1' \times (11.33)^2}{2} = 4 \text{ K}$$

$$M_y = 1.7 \times 4 \text{ K} \times 3.78' = 25.7 \text{ K} \approx 26 \text{ K}$$

$$f'_c = 3000 \text{ psi}$$

$$f_y = 60 \text{ ksi}$$

$$K = \frac{M_y \times 12,000}{\phi b d^2}$$

$$\phi = 0.9$$

$$b = 12 \text{ in}$$

$$d = 18.56$$

Assume 2" cover + #7 BARS

$$K = \frac{26 \text{ K} \times 12,000}{0.9 \times 12 \times (18.56)^2} = 84 \text{ psi} < K_{min}$$

$$\rho_{min} = 0.0033 = \frac{200}{f_y}$$

$$\Delta_s = \rho b d = 0.0033 \times 12 \times 17.56 = 0.695 \text{ in}^2/\text{ft}$$

USE #7 BARS @ 9" O.C $\Delta_s = 0.80 \text{ in}^2/\text{ft}$ vert.

Horizontal: Assume #5 bars use #5 @ 7" O.C.

Burk-Kleinpeter, Inc.

Engineers, Architects, Planners, Environmental Scientists
4176 Canal Street, New Orleans, LA 70119

CSCPS


| | | | | |
|-----------------|-------------------|-----------------|-------------|-----------------------|
| Job No. 9104 | Design By: RAG | Date: Aug/91 | Checked By: | Page 7 of 10 |
|-----------------|-------------------|-----------------|-------------|-----------------------|

Slab Design:

Thickness = 2'-0" $d = 24" - 3 - \frac{7}{8} \times \frac{1}{2} = 20.56$

min steel = $A_s = 0.0033 \times 12 \times 20.56 = 0.814 \text{ in}^2 / \text{ft of slab}$

USE # 8 @ 9" O.C. $A_s = 1.05 \text{ in}^2 / \text{ft of slab}$ (MIN.)



Refer to pg. 2 (4' strip) NTS

$W_1 = \frac{98^k}{40} = 2.45^k$ DL $\downarrow \times (1.4) = 3.43^k \times 4 = 13.72^k$

$W_2 = \frac{132^k}{40 \times 11} = 0.3^k / \text{ft}$ DL $\downarrow \times (1.4) = 0.42^k = 1.68^k$

$W_3 = \frac{116.4}{5 \times 40} = 0.6^k / \text{ft}$ LL OVER 5' $\downarrow \times (1.7) = 1.02^k / \text{ft} = 4.08^k / \text{ft}$

$W_4 = \frac{166^k}{40 \times 5.875} = 0.71^k / \text{ft}$ LL OVER 5.875' $\times (1.7) = 1.21^k / \text{ft} = 4.8^k / \text{ft}$

$V_5 = \frac{31.2^k}{4} = 7.8^k \times (1.4) = 10.9^k = 43.6^k$
1 supp. it: 1 pipe

$V_6 = \frac{352^k}{4} = 8.8^k \times (1.4) = 12.3^k = 49.2^k$
1 supp. it: 1 pipe

$M_4 = \frac{160.5^k}{40} \times 3.78' = 15.1^k \times (1.7) = 26^k = 104^k$
* ASSUME $W_7, W_8 : P=0$

Burk-Kleinpeter, Inc.

Engineers, Architects, Planners, Environmental Scientists
4176 Canal Street, New Orleans, LA 70119

CSCPS

Job No.

9104

Design By:

PLG

Date:


Aug/91

Checked By:

Page 8

of 10

CASE I (fully loaded)



$f_c = 2000 \text{ psi}$

$E = 3160 \text{ ksi}$

$E = 455,040 \text{ ksf}$

$I = \frac{1}{12} 1 \times (2)^3 = 0.667 \text{ ft}^4$ very conservative

MAX. $M_y = -97.917 \text{ k} @ x = 5.72 \text{ ft}$


$K = \frac{97.917 \text{ k} \cdot 12,000}{0.9 \times 48 \times (20.5)^2} = < K_{allow}$

MAX. $V_y = 47.751 \text{ k}$

MAX. $R_y = 87.124 \text{ k}$

$P = 0.0033$

CASE II $W_4 = 0$ $W_6 = 0$ $W_7 = 0$ $W_8 = 0$ $P_1 = 0$



MAX. $M_y = -91.122 \text{ k}$

MAX. $V_y = 47.75 \text{ k}$

MAX. $R_y = 92.96 \text{ k}$

| | | | | |
|-----------------|-------------------|-----------------|-------------|-----------------|
| Job No. 9104 | Design By: RAG | Date: Aug/91 | Checked By: | Page 9 of 10 |
|-----------------|-------------------|-----------------|-------------|-----------------|

$M_{y\max} = 97 \text{ k}$ use 100 k
 $V_{y\max} = 47.5 \text{ k}$ use 50 k
 $R_{y\max} = 92.9 \text{ k}$ use 94 k

Flexure:

$M_y = 100 \text{ k}$ $b = 48''$ COVER = 3'' Assume #8 BARS


$d = 24' - 0'' - 1/2'' = 20.5''$

$k = \frac{100 \text{ k} \times 12000}{0.9 \times 48 \times 20.5^2} = 66 \ll k_{\min}$

$A_s = \frac{0.0033 \times 48'' \times 20.5''}{4/4} = \frac{3.247 \text{ in}^2}{4/4} = 0.81 \text{ in}^2/4/4$

USE #8 @ 9" O.C $A_s = 1.05 \text{ in}^2/4/4$ T.B. conservative

USE #6 @ 12" Long Direction



***** RUN *****

INPUT DATA

CASE I

9A/E

NO. OF SPANS = 3
NO. OF SUPPORTS = 2
NO. OF CONCENTRATED LOADS = 3
NO. OF DISTRIBUTED LOAD AREAS = 3
NO. OF CONCENTRATED COUPLES = 1

MODULUS OF ELASTICITY, E = 455040
MOMENT OF INERTIA, I = .667

LEFT END IS FREE
RIGHT END IS FREE

BEAM LENGTH = 11
LENGTH SPAN 1 = 1.5
LENGTH SPAN 2 = 7
LENGTH SPAN 3 = 2.5

SUPPORT NO. 1 AT X = 1.5
SUPPORT NO. 2 AT X = 8.5

CONCENTRATED LOAD NO. 1 IS 49.200 AT X = 1.5
CONCENTRATED LOAD NO. 2 IS 13.720 AT X = 5.675
CONCENTRATED LOAD NO. 3 IS 43.600 AT X = 10.5

DISTRIBUTED LOAD NO. 1 IS 1.760 AT X = 0
TO 1.760 AT X = 5
DISTRIBUTED LOAD NO. 2 IS 1.850 AT X = 5
TO 1.600 AT X = 10
DISTRIBUTED LOAD NO. 3 IS 4.840 AT X = 0
TO 4.840 AT X = 2.675

CONCENTRATED COUPLE NO. 1 IS 104.000 AT X = 5.675

SUPPORT REACTIONS

R(1) = 29.841 AT X = 1.500
R(2) = 87.124 AT X = 8.500

M(0) = 0
M(L) = 0

CRITICAL VALUES

SHEAR(MAX) = 47.751 AT X = 6.529
SHEAR(MIN) = -39.275 AT X = 8.471
MOMENT(MAX) = 4.731 AT X = 5.632
MOMENT(MIN) = -97.917 AT X = 5.824
SLOPE(MAX) = 4.583E-04 AT X = 0.000
SLOPE(MIN) = -9.247E-04 AT X = 10.941
LEFL(MAX) = 0.001070 AT X = 5.000
DEFL(MIN) = -0.002110 AT X = 11.000

9c/f

***** BEAM *****

RESULTS

| X | SHEAR | MOMENT | SLOPE (RAD) | DEFLECTION |
|--------|---------|---------|-------------|------------|
| 0.000 | -0.000 | -0.000 | 4.553E-04 | -0.000687 |
| 1.000 | -0.920 | -0.460 | 4.578E-04 | -0.000229 |
| 2.000 | -21.199 | -11.520 | 4.463E-04 | 0.000226 |
| 3.000 | -22.119 | -33.179 | 3.729E-04 | 0.000647 |
| 4.000 | -23.039 | -55.758 | 2.267E-04 | 0.000948 |
| 5.000 | -23.959 | -79.257 | 4.496E-06 | 0.001070 |
| 6.000 | -25.124 | 0.611 | -2.519E-04 | 0.000934 |
| 7.000 | -26.804 | -35.354 | -3.087E-04 | 0.000663 |
| 8.000 | -28.484 | -72.898 | -4.867E-04 | 0.000276 |
| 9.000 | 45.960 | -66.760 | -7.557E-04 | -0.000346 |
| 10.000 | 45.200 | -23.640 | -9.058E-04 | -0.001190 |
| 11.000 | 0.000 | 0.000 | -9.247E-04 | -0.002110 |

***** BEAM *****

INPUT DATA

NO. OF SPANS = 3
 NO. OF SUPPORTS = 2
 NO. OF CONCENTRATED LOADS = 2
 NO. OF DISTRIBUTED LOAD AREAS = 2
 NO. OF CONCENTRATED COUPLES = 1

MODULUS OF ELASTICITY, E = 455040
 MOMENT OF INERTIA, I = .667

LEFT END IS FREE
 RIGHT END IS FREE

BEAM LENGTH = 11
 LENGTH SPAN 1 = 1.5
 LENGTH SPAN 2 = 7
 LENGTH SPAN 3 = 2.5

SUPPORT NO. 1 AT X = 1.5
 SUPPORT NO. 2 AT X = 8.5

CONCENTRATED LOAD NO. 1 IS 13.720 AT X = 5.875
 CONCENTRATED LOAD NO. 2 IS 43.600 AT X = 10.3

DISTRIBUTED LOAD NO. 1 IS 5.760 AT X = 0
 TO 5.760 AT X = 5
 DISTRIBUTED LOAD NO. 2 IS 1.680 AT X = 5
 TO 1.680 AT X = 11

CONCENTRATED COUPLE NO. 1 IS 104.000 AT X = 5.875

SUPPORT REACTIONS

R(1) = 3.236 AT X = 1.500
R(2) = 92.964 AT X = 8.500

N(O) = 0
N(L) = 0

CRITICAL VALUES

SHEAR (MAX) = 47.731 AT X = 8.529
SHEAR (MIN) = -45.114 AT X = 8.471
MOMENT (MAX) = 20.017 AT X = 8.662
MOMENT (MIN) = -91.122 AT X = 8.471
SLOPE (MAX) = 3.405E-04 AT X = 0.000
SLOPE (MIN) = -8.024E-04 AT X = 11.000
DEFL (MAX) = 0.001779 AT X = 8.039
DEFL (MIN) = -0.001804 AT X = 11.000

***** BEAM *****

RESULTS

| X | SHEAR | MOMENT | SLOPE (RAD) | DEFLECTION |
|--------|---------|---------|-------------|------------|
| 0.000 | -0.001 | -0.000 | 3.406E-04 | -0.000507 |
| 1.000 | -5.760 | -2.880 | 3.377E-04 | -0.000167 |
| 2.000 | -8.284 | -9.902 | 3.169E-04 | 0.000167 |
| 3.000 | -14.044 | -21.065 | 2.674E-04 | 0.000457 |
| 4.000 | -19.504 | -37.989 | 1.717E-04 | 0.000681 |
| 5.000 | -25.564 | -49.673 | 1.077E-05 | 0.000779 |
| 6.000 | -40.964 | 15.209 | -1.897E-04 | 0.000678 |
| 7.000 | -42.644 | -26.595 | -2.080E-04 | 0.000991 |
| 8.000 | -44.324 | -70.078 | -3.668E-04 | 0.001215 |
| 9.000 | 46.960 | -68.760 | -6.334E-04 | -0.000253 |
| 10.000 | 48.280 | -22.640 | -7.835E-04 | -0.001106 |
| 11.000 | 0.002 | 0.000 | -8.024E-04 | -0.001304 |

Burk-Kleinpeter, Inc.

Engineers, Architects, Planners, Environmental Scientists
4176 Canal Street, New Orleans, LA 70119

CSCPS

Job No.

9104

Design By:

RLG

Date:

Aug/91

Checked By:

Page


10

of

10

$$R_{y_{max}} = 94^k$$

$$d = 20.5" - 6" = 14.5$$



$$b_0 = 4 \times (12 + 14.5) = 106$$


$$V_y \leq \phi \times 4 \sqrt{f_c'} b_0 d$$

$$0.85 \times 4 \sqrt{3000} \times 106 \times 14.5 = 286^k \text{ OK}$$


| | | | | |
|------------------|----------------------|-----------------|-------------|-----------------------|
| Job No. 9/104 | Design By: R.A.G. | Date: Aug/91 | Checked By: | Page 1 of 10 |
|------------------|----------------------|-----------------|-------------|-----------------------|

Given: (from previous analysis)

* TEE WALL



PLAN
 SCALE: 1/8" = 1'-0"



ELEVATION
 SCALE: 1/4" = 1'-0"

Burk-Kleinpeter, Inc.

Engineers, Architects, Planners, Environmental Scientists
4176 Canal Street, New Orleans, LA 70119

CANAL ST. CANAL PUMP STATION

Job No.
9104

Design By:
P.A.G.

Date:
Aug/91

Checked By:

Page 2
of 10

LOAD DETERMINATIONS: (UNFACTORED)

$$W_1 = 1.75 \times 9.33 \times 40' \times 150 \#/\#^3 = 98^k \downarrow \text{STEM} \checkmark$$

$$W_2 = 2' \times 11' \times 40' \times 150 \#/\#^3 = 132^k \downarrow \text{SLAB} \checkmark$$

$$W_3 = 5' \times 9.33' \times 40' \times 62.4 \#/\#^3 = 116.4^k \downarrow \text{H}_2\text{O} \checkmark$$

$$W_4 = 11.33 \times 62.4 \#/\#^3 \times 40 \times 5.875 = 166^k \uparrow \checkmark$$

$$W_5 = W_6 = \text{pipe saddle} + \text{EQUIVALENT pipe load (4 pipes REQUIRED)}$$

$$\text{pipe saddle} = 1.5' \times 1' \times 150 \#/\#^3 \times 3.5' \times 4 = 3.2^k \downarrow \checkmark$$


$$W_5 \text{ EQUIVALENT pipe load} = 470 \#/\#^3 \times 15' \times 4 = 28^k \downarrow \text{(protected side)}$$

$$W_5 = 3.2^k + 28^k = 31.2^k \downarrow \checkmark$$

$$W_6 \text{ EQUIVALENT pipe load} = 470 \#/\#^3 \times 17' \times 4 = 32^k \downarrow \text{(Flood side)}$$

$$W_6 = 3.2^k + 32^k = 35.2^k \downarrow \checkmark$$

$$P = 62.4 \#/\#^3 \times 40' \times \frac{(11.33)^2}{2} = 160.2^k \rightarrow \checkmark$$



Burk-Kleinpeter, Inc.

Engineers, Architects, Planners, Environmental Scientists
4176 Canal Street, New Orleans, LA 70119

CSCPS

Job No.

9104

Design By:

R.A.G.

Date:

Aug/91


Checked By:

Page

3

of

10



$$P_1 = 120 \frac{\#}{ft^3} \times 7.5' \times \frac{(2')^2}{2} = 1.8^k @ 0.67' \quad \text{VARIES W/ DECREASE IN DEPTH}$$

$$W_7 = 120 \frac{\#}{ft^3} \times 5' \times \frac{(2')^2}{2} = 1.2^k @ 1.67' \quad \text{'' '' ''}$$

$$W_8 = 120 \frac{\#}{ft^3} \times 4.25' \times \frac{(2')^2}{2} = 1.02^k @ 1.42'$$

CASE I (Fully Loaded)

$$P_2 = W_1 + W_2 + W_3 - W_4 + W_5 + W_6 + W_7 + W_8 = 98 + 132 + 116.4 - 166 + 31.2 + 35.2 + 1.2 + 1.02 = 249^k \downarrow$$

$$\begin{aligned} \odot M_y &= W_2 \times 0.375 + W_3 \times 3.375 - W_4 \times 2.9375 - W_5 \times 4.625' \\ &\quad + W_6 \times 4.375 + W_7 \times 2.55' - W_8 \times 2.3' - P \times 3.78 \\ &= 132 \times 0.375 + 116.4 \times 3.375 - 166 \times 2.9375 - 31.2 \times 4.625 \\ &\quad + 35.2 \times 4.375 + 1.2 \times 2.55 - 1.02 \times 2.3 - 160.2 \times 3.78 \\ M_y &= 640.4^k \end{aligned}$$

$$P_y = 160.2^k \rightarrow$$

Burk-Kleinpeter, Inc.

Engineers, Architects, Planners, Environmental Scientists
4176 Canal Street, New Orleans, LA 70119

CSCPS

| | | | | |
|-----------------|-------------------|-----------------|-------------|---------------|
| Job No. 9104 | Design By: RAG | Date: Aug/91 | Checked By: | Page of 10 |
|-----------------|-------------------|-----------------|-------------|---------------|

CASE II

($W_4, W_6, W_7 = 0$)

$P_2 = 379^k$ ↓ ✓

$M_x = 310^k$ ↻ ✓

$P_y = 160.2^k$ → ✓

CASE III

(Pumps not in place)

$W_5 = 3.2^k$ $W_6 = 0$


$P_2 = 186^k$ ↓ ✓

$M_x = 665^k$ ↻ ✓

$P_y = 160.2^k$ → ✓

Based on soil REPORT from Eustis:

pile tip 73 $K_h(B)/CD = 2760 \text{ psi}$ (see bottom of page)



$B = 12 \text{ in}$ (width)
 $C = 0.3$ (cyclic loading)
 $D = \text{Group efficiency factor}$
 $ps = 7B = 84 \therefore D = \sqrt{0.85}$

$E_s = K_h(B) = 2760 \times 0.3 \times 0.85 = 703.8 \text{ psi}$

$AC = 50^k$ $AT = 25^k$ $Lu = 0'$

Based on Gulf Coast P_{ie} - STRESS: 6-1/2" 250^k 12" #1 PEP

$P_B = 151.2^k$ $FPC = 0.868 \text{ ksi}$ (17.37% losses)

$P_0 = 537^k$ $M_0 = 331 \text{ in-k}$ $M_B = 959 \text{ in-k}$ $P_T = 191.92^k$

$E = 4074 \text{ ksi}$ $I_x = I_y = 1728 \text{ in}^4$ $A = 144 \text{ in}^2$

* ASSUME PINNED *

* Note $K_h(B)/CD = 2760 = (3840 + 1920 + 2520) / 3$

667 @ 73' is fo conservative pile will fail in bending

Burk-Kleinpeter, Inc.

Engineers, Architects, Planners, Environmental Scientists
4176 Canal Street, New Orleans, LA 70119

CSCPS

| Job No. | Design By: | Date: | Checked By: | Page |
|---------|------------|--------|-------------|------------|
| 9104 | RAG | Aug/91 | | 5 of 10 |

Determine FPC: ✓

* FOR ABBREVIATIONS SEE CPGA PROGRAM *

$$\text{TOTAL LOSSES} = ES + SR_1 + C + SH + SR_2$$

$$7791 + 6009 + 3273 + 4430 + 8891 = 30,394 \text{ psi}$$

$$17.37\% \text{ Losses} + 83.63\% \text{ } 100\%$$

∴ Design load after losses is 83.63% of Tensioning Load
Strands tensioned to 70% of ultimate

$$\text{Design Load} = 250^k \times 0.7 \times 0.8363 \times 6 \text{ STRANDS} \times 0.144 = 126.4486^k$$

$$FPC = \frac{126.4486}{144} = 0.878 \text{ Ksi USE } 0.868 \text{ Ksi}$$

Determine IPC:

$$\text{Tensioning Load} = 250^k \times 0.7 \times 6 \times 0.144 = 151.2^k$$

$$(\text{Initial Prestress}) = IP = \frac{151.2}{144} = 1.050 \text{ Ksi}$$

Assume 5% immediate losses due to ES


$$IPC = 0.95 \times 1.05 = 0.9975 \text{ Ksi}$$

Determine FA:

$$FA = 0.35 f'_c = 0.35 \times 5 = 1.75 \text{ Ksi}$$

$$FT = 0$$

5A/k



MODULUS OF HORIZONTAL SUBGRADE REACTION

JEFFERSON PARISH
PUMP STATION AT CANAL STREET CANAL
METAIRIE, LOUISIANA

DEFINITIONS

K_h (PCI) = MODULUS OF HORIZONTAL SUBGRADE REACTION

CLAY : $K_h = \frac{C D}{B} (0.2222 q_u)$

SAND : $K_h = \frac{C D}{B} (z \eta_h)$

q_u (PSF) = UNCONFINED COMPRESSION SHEAR STRENGTH

B (IN.) = WIDTH OR DIAMETER OF PILE

C = 0.3 (CYCLIC LOADING); 1.0 (INITIAL LOADING)

D = GROUP EFFICIENCY FACTOR

| <u>PS</u> | <u>D</u> |
|-----------|----------|
| 8B | 1.0 |
| 7B | 0.85 |
| 6B | 0.7 |
| 5B | 0.55 |
| 4B | 0.4 |
| 3B | 0.25 |

η_h (PCI) = COEFFICIENT OF HORIZONTAL SUBGRADE REACTION

= 5 (LOOSE SAND); 10 (DENSE SAND)

PS (IN.) = PILE SPACING IN DIRECTION OF LOAD

Z (IN.) = DEPTH BELOW EQUIVALENT GROUND

50/k

**STEEL PIPE AND PRECAST CONCRETE PILE LOAD CAPACITIES
FOR SUPPORT OF DISCHARGE PIPES**

| TYPE AND SIZE OF PILE | PILE TIP ELEVATION IN FEET NGVD | ESTIMATED ALLOWABLE SINGLE PILE LOAD CAPACITY IN TONS FACTOR OF SAFETY=2 |
|--|--|---|
| 12-In. Diameter Open-End Steel Pipe | -70 | 38 |
| | -80 | 49 |
| | -90 | 59 |
| 14-In. Diameter Open-End Steel Pipe | -70 | 44 |
| | -80 | 57 |
| | -90 | 69 |
| 12-In. Square Precast Concrete | -70 | 50 <i>100K</i> |
| | -80 | 62 |
| | -90 | 75 |
| 14-In. Square Precast Concrete | -70 | 57 <i>114K</i> |
| | -80 | 73 |
| | -90 | 88 |

PILE LOAD CAPACITIES

**JEFFERSON PARISH
PUMP STATION AT CANAL STREET CANAL
METAIRIE, LOUISIANA**

50/k

GULF COAST PRE-STRESS, INC.

Pass Christian, Mississippi

12 PILE DESIGN AREA CONC (Ac) = 144 sq ft
 CONCRETE RELEASE STRENGTH (f'ci) 4000 psi
 CONCRETE DESIGN STRENGTH (F'c) 5000 psi

6 - 1/2" 250k S/R Strand

As 0.144
 ULTIMATE 250 k
 LOSSES 70%
 P = 151,200 k P_B

CALCULATE RESIDUAL STRESSES (Losses calculated per "Recommendations for Estimating Prestress Losses" PCI Committee on prestress loss as published in PCI Journal July / August 1975. TOTAL LOSS = ES + CR + SH + RET)

ELASTIC SHORTENING .63fs = 10% LOSSES (STRESS RELIEVED STRAND)
 USE 9.25 % LOSSES LOW RELAXATION STRANDS
 ES = fcr(Es/Eci)
 fci = 4000 Eci = 33fci^{1/2}*W^{3/2} = 3.64E+06
 W = 145 Es = 28 x 10⁶

6 - 1/2" 250k S/R Strand
 ES = 779 psi

STEEL RELAXATION (RET_1) fpy = 0.90fpu (Low-Relaxation Strand)
 (1st 18 hours) fpy = 0.85fpu (Stress Relieved Strand)
 RET = fst{[log24t-log24t1]/45}*[fst/fpy-0.55] (Low-Relaxation Strand)
 RET = fst{[log24t-log24t1]/10}*[fst/fpy-0.55] (Stress-Relieved Strand)
 RET = 6009 175000 - 6009 = 168991 psi for 6-1/2" 250k S/R Strand

CREEP CR = (UCR)(SCF)(MCF)*(PCR)(fc) Volume to surface Ratio
 UCR = 63-20Ec/10⁶=>11 (use 11) SCF = 3
 MCF = Accelerated Cure = 1 PCR = 0.35
 6 - 1/2" 250k S/R Strand
 CRc = 3273

SHRINKAGE SH = (USH)(SSF)(PSH) = 4430 psi
 USH = 27,000-3000Ec/10⁶ = 12000
 SSF Effect. Size and Shape = 0.879
 PSH = (Shrink. Coeff. 30 days) = 0.42

STEEL RELAXATION (RET_2)
 (30 days)
 RET = fst{[log24t-log24t1]/45}*[fst/fpy-0.55] (Low-Relaxation Strands)
 RET = fst{[log24t-log24t1]/45}*[fst/fpy-0.55] (Stress-Relieved Strands)
 RET = 8891 6 - 1/2" 250k S/R Strand

TOTAL LOSSES = ES + RET_1 + RET_2 + CR + SH
 6 - 1/2" 250k S/R Strand
 Losses = 30,393 psi 30,394
 Losses = 17.37% 83.63% Tension
 Load

EFFECTIVE PRESTRESS AFTER ALL LOSSES

Using 6 - 1/2" 250k S/R Strand fpc = 868 psi = FPC = 0.868

5E/k

12" PILE DESIGN

Prestressed with 6-1/2" 250k S/R Strand

DIRECT LOAD:

$$N = (.93f'c - 0.27 fpc) A_c$$

| | |
|-----|-----------------------|
| N = | 1416 * A _c |
| N = | 204 kips or |
| N = | 102 tons |

NOMINAL STRENGTH:

$$P_n = (.85f'c - 0.60fpc) A_c$$

~~P_n = 537 kips~~ P_o
 FACTOR OF SAFETY = 2.63

MOMENT CAPACITY:

| | |
|------------------|-----------------------|
| A _c = | 144 si |
| I = | 1,728 in ⁴ |
| I/c = | 288 in ³ |

$$\text{Allowable tension} = 4 * \text{sqrt}(F'c) = 282.84 \text{ psi}$$

$$M = f_c I/c = 331 \text{ in-kips } M_o$$

NOMINAL MOMENT STRENGTH:

MOMENT $M_n = 0.37t A_{ps} F_{pu}$ (solid piles)
 $A_{ps} = 0.864 \text{ si}$ (area tendons)
 $F_{pu} = 250 \text{ ksi}$ (ult. strength of the tendons)

$M_n = 959 \text{ in-kips } M_o$
 FACTOR OF SAFETY = 2.89

TENSILE CAPACITY OF PILE

Effective Prestress $f_{pc} = 868.00 \text{ psi}$
 Area of Concrete $A_c = 144 \text{ si}$
 Tensile Capacity of Pile = $f_{pc} + 6 * \text{sqrt}(f'c) * A_c = 191.92 \text{ kips or } P_T$
 Tensile Capacity of Pile = 96 tons

ALLOWABLE UNSUPPORTED LENGTH: (piles fixed at both ends)

| | | | |
|------------------|--------------|-----|-----------|
| h/r = | 80 | r = | 3.46 in. |
| l _u = | 60r/0.5 | | |
| l _u = | 415.69 in. = | | 34.64 ft. |

MAXIMUM LENGTH FOR 2-POINT & 3-POINT HANDLING:

| | | | |
|-----------|---------------------|-----------------------------------|---|
| W = | 150 lbs/ft. | Allowable tension for 2-POINT = | $6 * \text{sqrt}(f'c) i$ |
| f'ci = | 4000 psi | Allowable tension for 3-POINT = | $3 * \text{sqrt}(f'c) i$ |
| S = I/c = | 288 in ³ | f _s (2-POINT LIFT) = | $f + 6 * \text{sqrt}(f'c) i = 1247 \text{ psi}$ |
| fpc = | 868 psi | f _s (3-POINT LIFT) = | $f + 3 * \text{sqrt}(f'c) i = 1058 \text{ psi}$ |
| | | l = | $\text{sqrt}(f_s * S / 1.5 * 6 * W)$ |
| | | L <= | 79 ft. for 2-POINT HANDLING |
| | | L <= | 116 ft. for 3-POINT HANDLING |

SF/K

* TEE3

```

*****
* CORPS PROGRAM # X0080 * CP94 - CASE FILE GROUP ANALYSIS PROGRAM
* VERSION NUMBER # 86/09/02-C * RUN DATE 09-04-91 RUN TIME 09:36:17
*****

```

CANAL STREET CANAL PUMP STATION (Teewall) By Roy A. Glapion August 91

THERE ARE 20 FILES AND
3 LOAD CASES IN THIS RUN.

ALL FILE COORDINATES ARE CONTAINED WITHIN A BOX

```

                X                Y                Z
                -----
WITH DIAGONAL COORDINATES = (  -18.33 ,   -4.36 ,   .00 )
                            (   18.33 ,    2.63 ,   .00 )

```

PILE PROPERTIES AS INPUT

| E | I1 | I2 | A | CS | Def |
|------------|------------|------------|------------|------------|------------|
| KSI | IN**4 | IN**4 | IN**2 | | |
| .40740E+04 | .17280E+04 | .17280E+04 | .14400E+03 | .28000E+01 | .00000E+00 |

THESE PILE PROPERTIES APPLY TO THE FOLLOWING PILES -

ALL

SOIL DESCRIPTIONS AS INPUT

| ES | ESoil | LENGTH | L | LU |
|----|------------|--------|------------|------------|
| | K/IN**2 | | FT | FT |
| | .70380E+00 | L | .73000E+02 | .00000E+00 |

THIS SOIL DESCRIPTION APPLIES TO THE FOLLOWING PILES -

ALL

PILE STIFFNESSES AS CALCULATED FROM PROPERTIES

| | | | | | |
|------------|------------|------------|------------|------------|------------|
| .27987E+02 | .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 |
| .00000E+00 | .27987E+02 | .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 |
| .00000E+00 | .00000E+00 | .13394E+04 | .00000E+00 | .00000E+00 | .00000E+00 |
| .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 |
| .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 |
| .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 | .00000E+00 |

THIS MATRIX APPLIES TO THE FOLLOWING PILES -

PILE GEOMETRY AS INPUT AND/OR GENERATED

| NUM | X FT | Y FT | Z FT | BATTER | ANGLE | LENGTH FT | FIXITY |
|-----|---------|---------|---------|--------|--------|--------------|--------|
| 1 | 2.04 | -4.38 | .00 | 3.00 | 180.00 | 73.00 | F |
| 2 | 6.11 | -4.38 | .00 | 3.00 | 180.00 | 73.00 | F |
| 3 | 10.18 | -4.38 | .00 | 3.00 | 180.00 | 73.00 | F |
| 4 | 14.26 | -4.38 | .00 | 3.00 | 180.00 | 73.00 | F |
| 5 | 18.33 | -4.38 | .00 | 3.00 | 180.00 | 73.00 | F |
| 6 | -2.04 | -4.38 | .00 | 3.00 | 180.00 | 73.00 | F |
| 7 | -6.11 | -4.38 | .00 | 3.00 | 180.00 | 73.00 | F |
| 8 | -10.18 | -4.38 | .00 | 3.00 | 180.00 | 73.00 | F |
| 9 | -14.26 | -4.38 | .00 | 3.00 | 180.00 | 73.00 | F |
| 10 | -18.33 | -4.38 | .00 | 3.00 | 180.00 | 73.00 | F |
| 11 | 2.04 | 2.63 | .00 | 3.00 | 90.00 | 73.00 | F |
| 12 | 6.11 | 2.63 | .00 | 3.00 | 90.00 | 73.00 | F |
| 13 | 10.18 | 2.63 | .00 | 3.00 | 90.00 | 73.00 | F |
| 14 | 14.26 | 2.63 | .00 | 3.00 | 90.00 | 73.00 | F |
| 15 | 18.33 | 2.63 | .00 | 3.00 | 90.00 | 73.00 | F |
| 16 | -2.04 | 2.63 | .00 | 3.00 | 90.00 | 73.00 | F |
| 17 | -6.11 | 2.63 | .00 | 3.00 | 90.00 | 73.00 | F |
| 18 | -10.18 | 2.63 | .00 | 3.00 | 90.00 | 73.00 | F |
| 19 | -14.26 | 2.63 | .00 | 3.00 | 90.00 | 73.00 | F |
| 20 | -18.33 | 2.63 | .00 | 3.00 | 90.00 | 73.00 | F |

1460.00

APPLIED LOADS

| LOAD CASE | PX K | PY K | PZ K | MX FT-K | MY FT-K | MZ FT-K |
|--------------|---------|---------|---------|------------|------------|------------|
| 1 | .0 | 160.2 | 249.0 | 640.4 | .0 | .0 |
| 2 | .0 | 160.2 | 379.0 | 310.0 | .0 | .0 |
| 3 | .0 | 160.2 | 186.0 | 668.0 | .0 | .0 |

ORIGINAL PILE GROUP STIFFNESS MATRIX

| | | | | | |
|-------------|-------------|-------------|-------------|-------------|-------------|
| .10712E+04 | .57324E-04 | -.39342E+04 | .20655E+06 | .78125E-02 | .74726E+05 |
| .57324E-04 | .18712E+04 | .39342E+04 | .12393E+06 | -.78125E-02 | .15725E-01 |
| -.39342E+04 | .39342E+04 | .24165E+05 | -.25373E+06 | .31250E-01 | -.20655E+06 |
| .20655E+06 | .12393E+06 | -.25373E+06 | .45291E+08 | -.25000E+01 | .10844E+05 |
| .78125E-02 | -.78125E-02 | .31250E-01 | .30000E+01 | .47648E+09 | -.77574E+05 |
| .74726E+05 | .78125E-02 | -.20655E+06 | .10844E+05 | -.77574E+05 | .41559E+05 |

LOAD CASE 1. NUMBER OF FAILURES = 0. NUMBER OF PILES IN TENSION = 0.

LOAD CASE 2. NUMBER OF FAILURES = 0. NUMBER OF PILES IN TENSION = 0.

LOAD CASE 3. NUMBER OF FAILURES = 0. NUMBER OF PILES IN TENSION = 0.

PILE CAP DISPLACEMENTS

5H/K

| LOAD CASE | DX IN | DY IN | DZ IN | RX RAD | RY RAD | RZ RAD |
|-----------|------------|-----------|------------|------------|------------|------------|
| 1 | .1030E-02 | .1351E+00 | -.1452E-01 | -.2863E-03 | .1577E-06 | .9685E-06 |
| 2 | .5335E-01 | .1163E+00 | .7416E-03 | -.4873E-03 | .8166E-05 | .5006E-04 |
| 3 | -.1377E-01 | .1549E+00 | -.2315E-01 | -.3114E-03 | -.2107E-05 | -.1294E-04 |

PILE FORCES IN LOCAL GEOMETRY

M1 & M2 NOT AT PILE HEAD FOR PINNED PILES
 * INDICATES PILE FAILURE
 # INDICATES CBF BASED ON MOMENTS DUE TO (F3*EMIN) FOR CONCRETE PILES
 B INDICATES BUCKLING CONTROLS

LOAD CASE - 1

| PILE | F1 K | F2 K | F3 K | M1 IN-K | M2 IN-K | M3 IN-K | ALF | CBF | AFC KSI | AST KSI |
|------|------|------|------|---------|---------|---------|-----|-----|---------|---------|
| 1 | .0 | -3.8 | .2 | -96.9 | .8 | .0 | .00 | .93 | 1.34 | .53 |
| 2 | .0 | -3.8 | .2 | -96.9 | .8 | .0 | .00 | .93 | 1.34 | .53 |
| 3 | .0 | -3.8 | .2 | -96.9 | .8 | .0 | .00 | .93 | 1.34 | .53 |
| 4 | .0 | -3.8 | .2 | -97.0 | .8 | .0 | .00 | .93 | 1.34 | .53 |
| 5 | .0 | -3.8 | .1 | -97.0 | .8 | .0 | .00 | .93 | 1.34 | .53 |
| 6 | .0 | -3.8 | .2 | -96.8 | .9 | .0 | .00 | .93 | 1.34 | .53 |
| 7 | .0 | -3.8 | .2 | -96.8 | .9 | .0 | .00 | .93 | 1.34 | .53 |
| 8 | .0 | -3.8 | .2 | -96.8 | .9 | .0 | .00 | .93 | 1.34 | .53 |
| 9 | .0 | -3.8 | .2 | -96.7 | .9 | .0 | .00 | .93 | 1.34 | .53 |
| 10 | .0 | -3.8 | .2 | -96.7 | .9 | .0 | .00 | .92 | 1.34 | .53 |
| 11 | 3.8 | .0 | 27.3 | -.7 | -97.2 | .0 | .27 | .61 | 1.53 | .72 |
| 12 | 3.8 | .0 | 27.3 | -.7 | -97.3 | .0 | .27 | .61 | 1.53 | .72 |
| 13 | 3.8 | .0 | 27.3 | -.7 | -97.3 | .0 | .27 | .61 | 1.53 | .72 |
| 14 | 3.8 | .0 | 27.3 | -.7 | -97.3 | .0 | .27 | .61 | 1.53 | .72 |
| 15 | 3.8 | .0 | 27.4 | -.7 | -97.4 | .0 | .27 | .61 | 1.53 | .72 |
| 16 | 3.8 | .0 | 27.3 | -.7 | -97.2 | .0 | .27 | .61 | 1.53 | .72 |
| 17 | 3.8 | .0 | 27.3 | -.7 | -97.2 | .0 | .27 | .61 | 1.53 | .72 |
| 18 | 3.8 | .0 | 27.3 | -.7 | -97.1 | .0 | .27 | .61 | 1.53 | .72 |
| 19 | 3.8 | .0 | 27.3 | -.7 | -97.1 | .0 | .27 | .61 | 1.53 | .72 |
| 20 | 3.8 | .0 | 27.3 | -.7 | -97.1 | .0 | .27 | .61 | 1.53 | .72 |

LOAD CASE - 2

| PILE | F1 K | F2 K | F3 K | M1 IN-K | M2 IN-K | M3 IN-K | ALF | CBF | AFC KSI | AST KSI |
|------|------|------|------|---------|---------|---------|-----|-----|---------|---------|
| 1 | -1.7 | -3.3 | 9.5 | -64.3 | 44.0 | .0 | .09 | .84 | 1.51 | .46 |
| 2 | -1.7 | -3.4 | 9.0 | -66.0 | 43.9 | .0 | .09 | .85 | 1.51 | .46 |
| 3 | -1.7 | -3.4 | 8.5 | -67.8 | 43.8 | .0 | .08 | .86 | 1.51 | .47 |
| 4 | -1.7 | -3.5 | 8.0 | -69.5 | 43.7 | .0 | .08 | .87 | 1.51 | .46 |
| 5 | -1.7 | -3.6 | 7.5 | -91.3 | 43.6 | .0 | .07 | .88 | 1.51 | .47 |
| 6 | -1.7 | -3.2 | 10.0 | -82.5 | 44.1 | .0 | .10 | .85 | 1.51 | .47 |
| 7 | -1.7 | -3.2 | 10.5 | -80.7 | 44.2 | .0 | .11 | .82 | 1.51 | .46 |
| 8 | -1.7 | -3.1 | 11.0 | -79.0 | 44.3 | .0 | .11 | .81 | 1.51 | .47 |
| 9 | -1.7 | -3.0 | 11.5 | -77.2 | 44.3 | .0 | .12 | .80 | 1.51 | .46 |
| 10 | -1.7 | -2.9 | 12.0 | -75.5 | 44.4 | .0 | .12 | .79 | 1.51 | .46 |

| | | | | | | | | | | |
|----|-----|------|------|-------|-------|----|-----|-----|------|-----|
| 12 | 3.3 | -1.4 | 31.5 | -37.1 | -86.0 | .0 | .32 | .87 | 1.64 | .66 |
| 13 | 3.4 | -1.4 | 32.0 | -37.1 | -86.6 | .0 | .32 | .87 | 1.65 | .66 |
| 14 | 3.5 | -1.4 | 32.6 | -37.1 | -88.6 | .0 | .33 | .87 | 1.66 | .66 |
| 15 | 3.5 | -1.4 | 33.1 | -37.1 | -90.3 | .0 | .33 | .86 | 1.67 | .66 |
| 16 | 3.2 | -1.4 | 30.4 | -37.1 | -81.5 | .0 | .30 | .87 | 1.62 | .67 |
| 17 | 3.1 | -1.4 | 29.9 | -37.1 | -79.8 | .0 | .30 | .88 | 1.61 | .67 |
| 18 | 3.0 | -1.4 | 29.4 | -37.1 | -78.0 | .0 | .29 | .88 | 1.60 | .67 |
| 19 | 3.0 | -1.4 | 28.9 | -37.1 | -76.3 | .0 | .29 | .88 | 1.59 | .68 |
| 20 | 2.9 | -1.4 | 28.3 | -37.1 | -74.5 | .0 | .28 | .88 | 1.58 | .68 |

LOAD CASE - 3

| FILE | F1 K | F2 K | F3 K | M1 IN-K | M2 IN-K | M3 IN-K | ALF | DBF | ASC KBY | AST KBT |
|------|---------|---------|---------|------------|------------|------------|-----|-----|------------|------------|
| 1 | .4 | -4.3 | -2.4 | -110.8 | -11.4 | .0 | .03 | .96 | 1.40 | .43 |
| 2 | .4 | -4.3 | -2.3 | -110.3 | -11.3 | .0 | .03 | .96 | 1.40 | .43 |
| 3 | .4 | -4.3 | -2.2 | -109.9 | -11.3 | .0 | .04 | .95 | 1.40 | .43 |
| 4 | .4 | -4.3 | -2.1 | -109.4 | -11.3 | .0 | .04 | .94 | 1.40 | .44 |
| 5 | .4 | -4.3 | -1.9 | -109.0 | -11.3 | .0 | .04 | .94 | 1.40 | .44 |
| 6 | .4 | -4.3 | -2.6 | -111.3 | -11.4 | .0 | .05 | .97 | 1.41 | .43 |
| 7 | .4 | -4.4 | -2.7 | -111.7 | -11.4 | .0 | .05 | .97 | 1.41 | .42 |
| 8 | .4 | -4.4 | -2.8 | -112.2 | -11.4 | .0 | .06 | .96 | 1.41 | .42 |
| 9 | .4 | -4.4 | -3.0 | -112.6 | -11.4 | .0 | .06 | .96 | 1.41 | .42 |
| 10 | .4 | -4.4 | -3.1 | -113.1 | -11.5 | .0 | .05 | .99 | 1.41 | .42 |
| 11 | 4.4 | .4 | 23.7 | 9.6 | -112.6 | .0 | .24 | .70 | 1.59 | .61 |
| 12 | 4.4 | .4 | 23.3 | 9.6 | -112.1 | .0 | .24 | .70 | 1.58 | .61 |
| 13 | 4.4 | .4 | 23.4 | 9.6 | -111.7 | .0 | .23 | .70 | 1.58 | .61 |
| 14 | 4.3 | .4 | 23.3 | 9.6 | -111.2 | .0 | .23 | .70 | 1.58 | .61 |
| 15 | 4.3 | .4 | 23.1 | 9.6 | -110.8 | .0 | .23 | .70 | 1.58 | .61 |
| 16 | 4.4 | .4 | 23.8 | 9.6 | -113.0 | .0 | .24 | .70 | 1.59 | .61 |
| 17 | 4.4 | .4 | 23.9 | 9.6 | -113.5 | .0 | .24 | .70 | 1.59 | .61 |
| 18 | 4.4 | .4 | 24.1 | 9.6 | -113.9 | .0 | .24 | .70 | 1.59 | .61 |
| 19 | 4.5 | .4 | 24.2 | 9.6 | -114.4 | .0 | .24 | .70 | 1.60 | .61 |
| 20 | 4.5 | .4 | 24.4 | 9.6 | -114.8 | .0 | .24 | .70 | 1.60 | .61 |

FILE FORCES IN GLOBAL GEOMETRY

LOAD CASE - 1

| FILE | PX K | PY K | PZ K | MX IN-K | MY IN-K | MZ IN-K |
|------|---------|---------|---------|------------|------------|------------|
| 1 | .0 | 3.8 | .2 | .0 | .0 | .0 |
| 2 | .0 | 3.8 | .2 | .0 | .0 | .0 |
| 3 | .0 | 3.8 | .2 | .0 | .0 | .0 |
| 4 | .0 | 3.8 | .2 | .0 | .0 | .0 |
| 5 | .0 | 3.8 | .1 | .0 | .0 | .0 |
| 6 | .0 | 3.8 | .2 | .0 | .0 | .0 |
| 7 | .0 | 3.8 | .2 | .0 | .0 | .0 |
| 8 | .0 | 3.8 | .2 | .0 | .0 | .0 |
| 9 | .0 | 3.8 | .2 | .0 | .0 | .0 |
| 10 | .0 | 3.8 | .2 | .0 | .0 | .0 |
| 11 | .0 | 12.2 | 24.7 | .0 | .0 | .0 |
| 12 | .0 | 12.2 | 24.7 | .0 | .0 | .0 |
| 13 | .0 | 12.2 | 24.7 | .0 | .0 | .0 |
| 14 | .0 | 12.3 | 24.7 | .0 | .0 | .0 |
| 15 | .0 | 12.3 | 24.8 | .0 | .0 | .0 |
| 16 | .0 | 12.2 | 24.7 | .0 | .0 | .0 |
| 17 | .0 | 12.2 | 24.7 | .0 | .0 | .0 |

| | | | | | | |
|----|----|------|------|----|----|----|
| 18 | .0 | 12.2 | 24.7 | .0 | .0 | .0 |
| 19 | .0 | 12.5 | 24.7 | .0 | .0 | .0 |
| 20 | .0 | 12 | 24.7 | .0 | .0 | .0 |

55/k

160.2^k 249^k

LOAD CASE - 2

| PILE | PX K | PY K | PZ K | MX IN-K | MY IN-K | MZ IN-K |
|------|---------|---------|---------|------------|------------|------------|
| 1 | -1.4 | 3.3 | 9.5 | .0 | .0 | .0 |
| 2 | -1.2 | 3.4 | 9.1 | .0 | .0 | .0 |
| 3 | -1.1 | 3.4 | 8.6 | .0 | .0 | .0 |
| 4 | -.9 | 3.5 | 8.1 | .0 | .0 | .0 |
| 5 | -.7 | 3.6 | 7.6 | .0 | .0 | .0 |
| 6 | -1.5 | 3.2 | 10.0 | .0 | .0 | .0 |
| 7 | -1.7 | 3.2 | 10.5 | .0 | .0 | .0 |
| 8 | -1.8 | 3.1 | 11.0 | .0 | .0 | .0 |
| 9 | -2.0 | 3.0 | 11.5 | .0 | .0 | .0 |
| 10 | -2.2 | 2.9 | 12.0 | .0 | .0 | .0 |
| 11 | 1.4 | 12.9 | 28.4 | .0 | .0 | .0 |
| 12 | 1.4 | 13.1 | 28.8 | .0 | .0 | .0 |
| 13 | 1.4 | 13.3 | 29.3 | .0 | .0 | .0 |
| 14 | 1.4 | 13.6 | 29.8 | .0 | .0 | .0 |
| 15 | 1.4 | 13.8 | 30.3 | .0 | .0 | .0 |
| 16 | 1.4 | 12.6 | 27.9 | .0 | .0 | .0 |
| 17 | 1.4 | 12.4 | 27.4 | .0 | .0 | .0 |
| 18 | 1.4 | 12.2 | 26.9 | .0 | .0 | .0 |
| 19 | 1.4 | 11.9 | 26.4 | .0 | .0 | .0 |
| 20 | 1.4 | 11.7 | 25.9 | .0 | .0 | .0 |

-0.5^k 160.1^k 379^k

LOAD CASE - 3

| PILE | PX K | PY K | PZ K | MX IN-K | MY IN-K | MZ IN-K |
|------|---------|---------|---------|------------|------------|------------|
| 1 | .4 | 4.3 | -2.5 | .0 | .0 | .0 |
| 2 | .3 | 4.3 | -2.3 | .0 | .0 | .0 |
| 3 | .3 | 4.3 | -2.2 | .0 | .0 | .0 |
| 4 | .2 | 4.3 | -2.1 | .0 | .0 | .0 |
| 5 | .2 | 4.3 | -2.0 | .0 | .0 | .0 |
| 6 | .4 | 4.3 | -2.6 | .0 | .0 | .0 |
| 7 | .4 | 4.4 | -2.7 | .0 | .0 | .0 |
| 8 | .5 | 4.4 | -2.8 | .0 | .0 | .0 |
| 9 | .5 | 4.4 | -3.0 | .0 | .0 | .0 |
| 10 | .6 | 4.4 | -3.1 | .0 | .0 | .0 |
| 11 | -.4 | 11.7 | 21.1 | .0 | .0 | .0 |
| 12 | -.4 | 11.6 | 20.9 | .0 | .0 | .0 |
| 13 | -.4 | 11.5 | 20.8 | .0 | .0 | .0 |
| 14 | -.4 | 11.5 | 20.7 | .0 | .0 | .0 |
| 15 | -.4 | 11.4 | 20.6 | .0 | .0 | .0 |
| 16 | -.4 | 11.7 | 21.2 | .0 | .0 | .0 |
| 17 | -.4 | 11.8 | 21.3 | .0 | .0 | .0 |
| 18 | -.4 | 11.8 | 21.4 | .0 | .0 | .0 |
| 19 | -.4 | 11.9 | 21.6 | .0 | .0 | .0 |
| 20 | -.4 | 12.0 | 21.7 | .0 | .0 | .0 |

-0.2^k 160.3^k 186^k


~ * TEEWALL3

5K/K

1000 CANAL STREET CANAL PUMP STATION (Teewall) By Roy A. Clapton August 9,
1010 PRD 4074 1728 1728 144 2.0 0 ALL
1020 SOI ES 0.7038 L 73 0 ALL
1030 PIN ALL
1040 DLS S 100 50 537.0 191.92 151.20 959.0 331.0 H 12 ALL
1050 ABC S 144 288 0.87 0.9975 1.75 0 ALL
1070 BAT 3.0 ALL
1080 ANG 180 1 TO 10
1084 ANG 90 11 TO 20
1100 PIL 1 2.037 -4.375 0
1110 PIL 11 2.037 2.625 0
1112 PIL 6 -2.037 -4.375 0
1114 PIL 16 -2.037 2.625 0
1120 ROW X 5 1 4 AT 4.0740
1130 ROW X 5 11 4 AT 4.0740
1132 ROW X 5 5 4 AT -4.0740
1134 ROW 1 5 16 4 AT -4.0740
1150 LDA 1 C 160.2 249 640.4 0 0
1160 LDA 2 0 160.2 377 310 0 0
1170 LDA 3 0 160.2 186 665 0 0
1170 FOU 1 2 3 4 5 6 7 TEEK
1190 PSD 1
1200 PFC ALL
1210 FPL N

| | | | | |
|-----------------|-------------------|-----------------|-------------|-----------------------|
| Job No. 9104 | Design By: RAG | Date: Aug/91 | Checked By: | Page 6 of 10 |
|-----------------|-------------------|-----------------|-------------|-----------------------|

Flow e:



$\frac{P}{\text{Slot wall}} =$

$$\frac{62.4 \#/\text{ft}^3 \times 1' \times (11.33')^2}{2} = 4^{\text{K}}$$

$$M_y = 1.7 \times 4^{\text{K}} \times 3.78' = 25.7^{\text{K}} \approx 26^{\text{K}}$$

$f_c = 3000 \text{ psi}$
 $f_y = 60 \text{ ksi}$

$$K = \frac{M_y \times 12,000}{\phi b d^2}$$

$\phi = 0.9$

$b = 12 \text{ in}$

$d = 18.56$

ASSUME 2" COVER \rightarrow #7 BARS

$$K = \frac{26^{\text{K}} \times 12,000}{0.9 \times 12 \times (18.56)^2} = 84 \text{ psi} < K_{\text{min}}$$

$\rho_{\text{min}} = 0.0033 = \frac{200}{f_y}$

$$A_s = \rho b d = 0.0033 \times 12 \times 17.56 = 0.695 \text{ in}^2$$

USE #7 BARS @ 9" O.C $L_s = 0.80 \text{ in}^2/\text{ft}$ vert.

Horizontal: Assume #5 bars use #5 @ 7" O.C.

Burk-Kleinpeter, Inc.

Engineers, Architects, Planners, Environmental Scientists
4176 Canal Street, New Orleans, LA 70119


CSCPS

| | | | | |
|-----------------|-------------------|-----------------|-------------|-----------------------|
| Job No. 9104 | Design By: RAG | Date: Aug/91 | Checked By: | Page 7 of 10 |
|-----------------|-------------------|-----------------|-------------|-----------------------|

Slab Design: Thickness = 2'-0" $d = 24" - 3 - \frac{7}{8} \times \frac{1}{2} = 20.56$

min steel = $A_s = 0.0033 \times 12 \times 20.56 = 0.814 \text{ in}^2 / \text{ft of slab}$

use # 8 @ 9" o.c. $A_s = 1.05 \text{ in}^2 / \text{ft of slab}$ (MIN.)



Refer to pg. 2 (4' strip) NTS

$$W_1 = \frac{98^k}{40} = 2.45^k \quad DL \downarrow \times (1.4) = 3.43^k \times 4 = 13.73^k$$

$$W_2 = \frac{132^k}{40 \times 11} = 0.3^k / \text{ft} \quad DL \downarrow \times (1.4) = 0.42^k = 1.68^k$$

$$W_3 = \frac{116.4}{5 \times 40} = 0.6^k / \text{ft} \quad LL \text{ OVER } 5' \downarrow \times (1.7) = 1.02^k / \text{ft} = 4.08^k / \text{ft}$$

$$W_4 = \frac{166^k}{40 \times 5.875} = 0.71^k / \text{ft} \quad LL \uparrow \text{ OVER } 5.875' \times (1.7) = 1.21^k / \text{ft} = 4.9^k / \text{ft}$$

$$W_5 = \frac{31.2^k}{4} = 7.8^k \times (1.4) = 10.9^k = 43.6^k$$

1 SUP. ST. 1 PIPE

$$W_6 = \frac{352^k}{4} = 8.8^k \times (1.4) = 12.3^k = 49.2^k$$

1 SUP. ST. 1 PIPE

$$M_4 = \frac{160.2^k}{40} \times 3.78' = 15.1^k \times (1.7) \times 26^k = 104^k$$

* ASSUME W7, W8 : P=0


Burk-Kleinpeter, Inc.

Engineers, Architects, Planners, Environmental Scientists
4176 Canal Street, New Orleans, LA 70119

CSCPS

| | | | | |
|-----------------|-------------------|-----------------|-------------|-----------------|
| Job No. 9104 | Design By: PLG | Date: Aug/91 | Checked By: | Page 8 of 10 |
|-----------------|-------------------|-----------------|-------------|-----------------|

CASE I fully loaded



$f_c = 2000 \text{ psi}$

$E = 3160 \text{ Ksi}$

$E = 455,040 \text{ Ksf}$

$I = \frac{1}{12} 1 \times (2)^3 = 0.667 \text{ ft}^4$ very conservative

max. $M_y = -97.917 \text{ k} \cdot \text{ft}$ @ $x = 5.82 \text{ ft}$


$K = \frac{97.917 \text{ k} \cdot \text{ft} \times 12,000}{0.9 \times 48 \times (20.5)^2} \leq K_{crit}$

max. $V_y = 47.751 \text{ k}$

max. $R_y = 87.124 \text{ k}$

$P = 0.0033$

CASE II $W_A = 0$ $W_B = 0$ $W_7 = 0$ $W_8 = 0$ $P_1 = 0$



max. $M_y = -91.122 \text{ k}$
max. $V_y = 47.75 \text{ k}$
max. $R_y = 92.96 \text{ k}$

Burk-Kleinpeter, Inc.

Engineers, Architects, Planners, Environmental Scientists
4176 Canal Street, New Orleans, LA 70119

CSCPS

| Job No. | Design By: | Date: | Checked By: | Page |
|---------|------------|--------|-------------|---------|
| 9104 | PAG | Aug/91 | | 9 of 10 |

$M_{y \max} = 97 \text{ k}$ use 100 k
 $V_{y \max} = 47.5 \text{ k}$ use 50 k
 $R_{y \max} = 92.9 \text{ k}$ use 94 k

Flexure:

$M_y = 100 \text{ k}$ $b = 48 \text{''}$ $\text{COVER} = 3 \text{''}$ Assume #8 BARS


$d = 24 \text{''} - 3 \text{''} - \frac{1}{2} \text{''} = 20.5 \text{''}$

$K = \frac{100 \text{ k} \times 12000}{0.9 \times 48 \times 30.5^2} = 66 \ll K_{min}$

$A_s = \frac{0.0033 \times 48 \times 20.5}{4} = \frac{3.247 \text{ in}^2}{4} = \frac{0.81 \text{ in}^2}{4}$

USE #8 @ 9" O.C $A_s = \frac{1.05 \text{ in}^2}{4}$ T.B. COMP. IN T.B.

USE #6 @ 12" Long Direction



***** BEAM *****

INPUT DATA

CASE I

9A/E

NO. OF SPANS = 3
NO. OF SUPPORTS = 2
NO. OF CONCENTRATED LOADS = 3
NO. OF DISTRIBUTED LOAD AREAS = 3
NO. OF CONCENTRATED COUPLES = 1

MODULUS OF ELASTICITY, E = 455040
MOMENT OF INERTIA, I = .667

LEFT END IS FREE
RIGHT END IS FREE

BEAM LENGTH = 11
LENGTH SPAN 1 = 1.5
LENGTH SPAN 2 = 7
LENGTH SPAN 3 = 2.5

SUPPORT NO. 1 AT X = 1.5
SUPPORT NO. 2 AT X = 8.5

CONCENTRATED LOAD NO. 1 IS 49.200 AT X = 1.5
CONCENTRATED LOAD NO. 2 IS 13.720 AT X = 5.875
CONCENTRATED LOAD NO. 3 IS 43.600 AT X = 10.5

DISTRIBUTED LOAD NO. 1 IS 5.760 AT X = 0
TO 5.760 AT X = 5
DISTRIBUTED LOAD NO. 2 IS 1.680 AT X = 5
TO 1.680 AT X = 11
DISTRIBUTED LOAD NO. 3 IS -4.840 AT X = 0
TO -4.840 AT X = 5.875

CONCENTRATED COUPLE NO. 1 IS 104.000 AT X = 5.875

SUPPORT REACTIONS

R(1) = 29.841 AT X = 1.500
R(2) = 87.124 AT X = 8.500

M(O) = 0
M(L) = 0

CRITICAL VALUES

SHEAR(MAX) = 47.751 AT X = 6.529
SHEAR(MIN) = -39.275 AT X = 8.471
MOMENT(MAX) = 4.731 AT X = 5.682
MOMENT(MIN) = -97.917 AT X = 5.624
SLOPE(MAX) = 4.583E-04 AT X = 0.000
SLOPE(MIN) = -9.247E-04 AT X = 10.941
DEFL(MAX) = 0.001070 AT X = 5.000
DEFL(MIN) = -0.002110 AT X = 11.000

90/F

***** BEAM *****

RESULTS

| X | SHEAR | MOMENT | SLOPE (RAD) | DEFLECTION |
|--------|---------|---------|-------------|------------|
| 0.000 | -0.000 | -0.000 | 4.553E-04 | -0.000687 |
| 1.000 | -0.920 | -0.460 | 4.578E-04 | -0.000227 |
| 2.000 | -21.199 | -11.520 | 4.463E-04 | 0.000226 |
| 3.000 | -22.119 | -33.179 | 3.729E-04 | 0.000647 |
| 4.000 | -23.039 | -55.758 | 2.267E-04 | 0.000948 |
| 5.000 | -23.959 | -79.257 | 4.496E-06 | 0.001070 |
| 6.000 | -35.124 | 0.611 | -2.519E-04 | 0.000934 |
| 7.000 | -36.504 | -35.354 | -3.087E-04 | 0.000663 |
| 8.000 | -38.434 | -72.998 | -4.867E-04 | 0.000375 |
| 9.000 | 42.960 | -65.760 | -7.557E-04 | -0.000346 |
| 10.000 | 45.280 | -22.640 | -9.058E-04 | -0.001190 |
| 11.000 | 0.002 | 0.000 | -9.247E-04 | -0.002110 |

***** BEAM *****

INPUT DATA

CASE 10

90/F

NO. OF SPANS = 3
NO. OF SUPPORTS = 2
NO. OF CONCENTRATED LOADS = 2
NO. OF DISTRIBUTED LOAD AREAS = 2
NO. OF CONCENTRATED COUPLES = 1

MODULUS OF ELASTICITY, E = 455040
MOMENT OF INERTIA, I = .667

LEFT END IS FREE
RIGHT END IS FREE

BEAM LENGTH = 11
LENGTH SPAN 1 = 1.5
LENGTH SPAN 2 = 7
LENGTH SPAN 3 = 2.5

SUPPORT NO. 1 AT X = 1.5
SUPPORT NO. 2 AT X = 8.5

CONCENTRATED LOAD NO. 1 IS 13.720 AT X = 5.875
CONCENTRATED LOAD NO. 2 IS 43.600 AT X = 10.5

DISTRIBUTED LOAD NO. 1 IS 5.760 AT X = 0
TO 5.760 AT X = 5
DISTRIBUTED LOAD NO. 2 IS 1.680 AT X = 5
TO 1.680 AT X = 11

CONCENTRATED COUPLE NO. 1 IS 104.000 AT X = 5.875

SUPPORT REACTIONS

R(1) = 3.236 AT X = 1.500
R(2) = 92.964 AT X = 8.500

M(0) = 0
M(L) = 0

CRITICAL VALUES

SHEAR(MAX) = 47.751 AT X = 5.529
SHEAR(MIN) = -45.114 AT X = 8.471
MOMENT(MAX) = 20.017 AT X = 5.850
MOMENT(MIN) = -91.122 AT X = 8.471
SLOPE(MAX) = 3.403E-04 AT X = 0.000
SLOPE(MIN) = -8.024E-04 AT X = 11.000
DEFL(MAX) = 0.000779 AT X = 8.059
DEFL(MIN) = -0.001604 AT X = 11.000

9F/E

***** BEAM *****

RESULTS

| X | SHEAR | MOMENT | SLOPE (RAD) | DEFLECTION |
|--------|---------|---------|-------------|------------|
| 0.000 | -0.001 | -0.000 | 3.408E-04 | -0.000507 |
| 1.000 | -5.760 | -2.880 | 3.377E-04 | -0.000167 |
| 2.000 | -8.284 | -9.902 | 3.169E-04 | 0.000162 |
| 3.000 | -14.044 | -21.065 | 2.674E-04 | 0.000457 |
| 4.000 | -19.804 | -37.989 | 1.717E-04 | 0.000681 |
| 5.000 | -25.564 | -60.673 | 1.077E-05 | 0.000779 |
| 6.000 | -40.964 | 15.209 | -1.897E-04 | 0.000678 |
| 7.000 | -42.644 | -26.595 | -2.080E-04 | 0.000471 |
| 8.000 | -44.324 | -70.078 | -3.668E-04 | 0.000215 |
| 9.000 | 46.960 | -68.760 | -6.334E-04 | -0.000225 |
| 10.000 | 45.280 | -22.640 | -7.835E-04 | -0.001006 |
| 11.000 | 0.002 | 0.000 | -8.024E-04 | -0.001804 |

Burk-Kleinpeter, Inc.

Engineers, Architects, Planners, Environmental Scientists
4176 Canal Street, New Orleans, LA 70119

CSCPS

Job No.

9104

Design By:

RLG

Date:

Aug/91

Checked By:


Page 10

of 10

$$R_y = 94^k$$

MAX

$$d = 20.5'' - 6'' = 14.5$$



$$b_0 = 4 \times (12 + 14.5) = 106$$

$$V_y \leq \phi \times 4 \sqrt{f_c'} b_0 d$$

$$0.85 \times 4 \sqrt{3000} \times 106 \times 14.5 = 286^k \text{ ok}$$