






## Projected Power Sector CO<sub>2</sub> Emissions



Data source: NETL analysis using the Energy Information Administration's Annual Energy Outlook and Carben model.




## CFPP Average Efficiency and Range for 2007



Data source: Energy Velocity Suite, May 2008



## CFFP Efficiency by Year Online, Steam Cycle Type and Capacity Factor (2007)



Data source: Energy Velocity Suite, May 2008

# Literature review of heat rate improvement projects

Improvement Projects	Efficiency Increase (percentage points)
Air Preheaters (optimize)	0.16 to 1.5
Ash Removal System (replace)	0.1
Boiler (increase airheater surface)	2.1
Combustion System (optimize)	0.15 to 0.84
Condenser (optimize)	0.7 to 2.4
Cooling System Performance (upgrade)	0.2 to 1
Feedwater Heaters (optimize)	0.2 to 2
Flue Gas Moisture Recovery	0.3 to 0.65
Flue Gas Heat Recovery	0.3 to 1.5
Coal Drying (Installation)	0.1 to 1.7
Process Controls (installation/improvement)	0.2 to 2
Reduction of Slag and Furnace Fouling	0.4
Sootblower Optimization	0.1 to 0.65
Steam Leaks (reduce)	1.1
Steam Turbine (refurbish)	0.84 to 2.6



## Unit Efficiencies by Age Band and Steam Cycle Type

Steam cycle type	Age band	No. of Units	Nameplate capacity (MW)	Generation (BkWh)	Avg. eff.	Efficiency Range	Eff. of Top 10%
Sub-critical	1969 and before	410	77,789	447	31.3%	19.1 – 40.9%	36.3%
	1970 to 1989	273	127,675	824	31.4%	20.5 – 38.7%	36.3%
	1990 to present	27	7,477	51	29.9%	21.1 – 37.6%	35.9%
<b>Subcritical subtotal</b>		<b>710</b>	<b>212,942</b>	<b>1,322</b>	<b>31.3%</b>	<b>19.1 – 40.9%</b>	<b>36.4%</b>
Super-critical	1969 and before	34	19,467	114	34.9%	22.5 – 40.1%	38.8%
	1970 to 1989	74	60,169	398	35.1%	29.8 - 41.0%	39.1%
	1990 to present	1	1,426	10	40.2%	N/A	N/A
<b>Supercritical subtotal</b>		<b>109</b>	<b>1,061</b>	<b>522</b>	<b>35.1%</b>	<b>22.5 – 41.0%</b>	<b>39.3%</b>
<b>Grand Total</b>		<b>819</b>	<b>294,003</b>	<b>1,844</b>	<b>31.8%</b>	<b>19.1 – 41.0%</b>	<b>37.4%</b>


NATIONAL ENERGY TECHNOLOGY LABORATORY

Data source: Energy Velocity Suite, May 2008



Improved PC efficiency, constant power scenario


## Carbon dioxide emissions from existing CFPPs



**Improved PC efficiency, constant coal scenario**




## **Electricity generation from existing CFPPs**






## CFPP Efficiency and Temperature (2007)



Data sources: Plant efficiencies – Energy Velocity Suite, Oct 2007; Elevation - ESRI Digital Elevation Model; Temperature – Dept. of Agriculture's National Resources Conservation Service




## CFPP Efficiency and Elevation (2007)



Data sources: Plant efficiencies – Energy Velocity Suite, Oct 2007; Elevation - ESRI Digital Elevation Model; Temperature – Dept. of Agriculture's National Resources Conservation Service




## Average unit efficiency by boiler manufacturer



Data source: Energy Velocity Suite, Oct 2007




## Average unit efficiency by generator manufacturer



Data source: Energy Velocity Suite, Oct 2007




## Average unit efficiency by cooling system type



Data sources: Plant efficiencies and pollution controls – Energy Velocity Suite, Oct 2007; Cooling system configurations – Energy Information Administration's 2005 form 767 data




## Efficiency and emission control equipment



Data sources: Plant efficiencies and pollution controls – Energy Velocity Suite, Oct 2007; Cooling system configurations – Energy Information Administration's 2005 form 767 data

Cheap coal, combined with decisions to sacrifice efficiency for reliability contributed to lack of supercritical plants and lower-than-expected efficiencies in the past 20 years



Data source: Energy Velocity Suite, Oct 2007; Coal prices, Energy Information Administration, Annual Energy Review  
Prices are in chained (2000) dollars, calculated by using gross domestic product implicit price deflators  
<http://www.eia.doe.gov/emeu/aer/coal.html>.