

Carbon Dioxide Capture from Existing Coal-Fired Power Plants

DOE/NETL-401/110907



Final Report (Original Issue Date, December 2006)

Revision Date, November 2007



Disclaimer

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference therein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed therein do not necessarily state or reflect those of the United States Government or any agency thereof.

Carbon Dioxide Capture from Existing Coal-Fired Power Plants

DOE/NETL-401/110907

Final Report (Original Issue Date, December 2006)

Revision Date, November 2007

NETL Contact:

**Jared P. Ciferno
Office of Systems Analysis and Planning Division**

Prepared by:

**Massood Ramezan, Project Manager
Timothy J. Skone, Project Engineer
Research and Development Solutions, LLC**

**Nsakala ya Nsakala, and Gregory N. Liljedahl, Project Co-Leaders
Alstom Power Inc.**

With Support From:

**Loren E. Gearhart, Principal Investigator
ABB Lummus Global, Inc.**

**Rolf Hestermann, Principal Investigator
Alstom Power Generation AG**

**Barry Rederstorff, Host Site Advisor
American Electric Power**

**National Energy Technology Laboratory
www.netl.doe.gov**

This Page Intentionally Left Blank



TABLE OF CONTENTS

TABLE OF CONTENTS	i
LIST OF TABLES	iii
LIST OF FIGURES	vi
ACRONYMS AND ABBREVIATIONS	ix
ACKNOWLEDGMENTS	xi
EXECUTIVE SUMMARY	1
1 INTRODUCTION	1
1.1 Background.....	2
1.2 Current Study	3
1.2.1 CO ₂ Capture Level Sensitivity Study.....	4
1.2.2 Solvent Regeneration Energy Sensitivity Study - A Look To The Future:.....	5
2 STUDY UNIT DESCRIPTION AND BASE CASE PERFORMANCE	9
2.1 Study Unit Description	9
2.2 Base Case Performance Analysis	12
2.2.1 Calibration of the Boiler Computer Model	12
2.2.2 Overall System Description and Material and Energy Balance (Base Case).....	13
2.2.3 Boiler Analysis Results (Base Case).....	16
2.2.4 Steam Cycle Performance (Base Case).....	17
2.2.5 Flue Gas Desulfurization System Analysis (Base Case)	21
3 THE SENSITIVITY OF PLANT PERFORMANCE AND ECONOMICS TO CO₂ CAPTURE LEVEL	23
3.1 Study Unit Modifications and Definition of the Amine-Based CO ₂ Capture Systems.....	23
3.1.1 Design Basis for CO ₂ Capture Systems Retrofit Equipment and Performance Calculations (Cases 1-5)	24
3.1.2 Boiler Island Modifications and Performance (Cases 1-5).....	32
3.1.3 Design and Performance of Advanced Amine CO ₂ Removal Systems (Cases 1-4).....	37
3.1.4 Process Description - CO ₂ Removal, Compression, and Liquefaction System (Cases 1-4)	37
3.1.5 Case 5/Concept A: Design and Performance of Kerr-McGee/ABB Lummus Amine CO ₂ Removal System	75
3.1.6 Steam Cycle Modifications, Performance, and Integration with Amine Process (Cases 1-5).....	96
3.1.7 Project Construction Schedule (Cases 1-5).....	111
3.2 Summary and Comparison of Overall Plant Performance and Carbon Dioxide Emissions (Cases 1-5)	113
3.2.1 Auxiliary Power and Net Plant Output	114
3.2.2 Net Plant Heat Rate and Thermal Efficiency.....	115
3.2.3 CO ₂ Emissions	116
3.2.4 Steam Cycle Performance.....	118
3.2.5 Boiler Performance	119
3.3 Cost Analysis	120
3.3.1 Cost Estimation Basis	120
3.3.2 Carbon Dioxide Separation and Compression System Costs	122



3.3.3	Boiler Modification Costs.....	132
3.3.4	Flue Gas Desulfurization System Modification Costs.....	132
3.3.5	Let Down Steam Turbine/Generator Costs.....	133
3.3.6	Charges for Loss of Power During Construction.....	133
3.3.7	Summary of Total Retrofit Investment Costs.....	133
3.4	Economic Analysis.....	136
3.4.1	Economic Study Scope and Assumptions.....	136
3.4.2	Economic Analysis Results.....	140
4	ADVANCES IN POST COMBUSTION CO₂ CAPTURE TECHNOLOGIES.....	147
5	SENSITIVITY OF PLANT PERFORMANCE AND ECONOMICS TO SOLVENT REGENERATION ENERGY.....	149
5.1	Performance Analysis.....	150
5.1.1	Steam Cycle Modifications and Performance with Reduced Solvent Regeneration Energy.....	154
5.2	Cost Analysis.....	157
5.3	Economic Analysis.....	157
6	REPLACEMENT POWER DISCUSSION.....	159
7	CONCLUSIONS AND RECOMMENDATIONS FOR FUTURE WORK.....	161
8	BIBLIOGRAPHY.....	164
9	APPENDICES.....	A-1
9.1	Appendix I – Plant Drawings (Cases 1-5).....	A-2
9.2	Appendix II - Equipment Lists (Cases 1-5).....	B-1
9.3	Appendix III - Economic Sensitivity Studies (Cases 1-5).....	C-1
9.3.1	Case 1 (90% CO ₂ Capture).....	C-2
9.3.2	Case 2 (70% CO ₂ Capture).....	C-4
9.3.3	Case 3 (50% CO ₂ Capture).....	C-6
9.3.4	Case 4 (30% CO ₂ Capture).....	C-8
9.4	Appendix IV – Let Down Turbine Technical Information (Cases 1 and 4).....	D-1



LIST OF TABLES

Table ES-1: Summary of Technical and Economic Performance for Retrofitting Pulverized Coal-Fired Plant.....	3
Table ES- 2: Plant Performance and Economics vs. Solvent Regeneration Energy.....	9
Table 1-1: Dakota Gasification Project’s CO ₂ Specification for EOR	7
Table 2-1: Gas Side Material and Energy Balance (Base Case).....	14
Table 2-2: Overall Plant Performance Summary (Base Case).....	16
Table 2-3: Boiler/Turbine Steam Flows and Conditions (Base Case)	17
Table 2-4: FGD System Analysis Assumptions	22
Table 2-5: Existing FGD System Performance.....	22
Table 3-1: Coal Analysis	25
Table 3-2: Natural Gas Analysis.....	25
Table 3-3: Flue Gas Analysis Entering Amine System (Cases 1-5)	27
Table 3-4: CO ₂ Product Specification.....	27
Table 3-5: Key Parameters for Process Simulation	28
Table 3-6: Soda Ash (Na ₂ CO ₃) Requirements	29
Table 3-7: Process Steam Conditions (reboilers).....	29
Table 3-8: Process Steam Conditions (reclaimer).....	29
Table 3-9: Cooling Water Conditions.....	30
Table 3-10: Surface Condensate (for amine make-up)	30
Table 3-11: Raw Water (fresh water)	30
Table 3-12: Potable Water	31
Table 3-13: Plant Air	31
Table 3-14: Instrument Air	31
Table 3-15: LP Fuel Gas (natural gas).....	31
Table 3-16: Power Supply Requirements	31
Table 3-17: Modified FGD System Assumptions (Cases 1-5)	33
Table 3-18: Modified FGD System Performance (Cases 1-5).....	33
Table 3-19: Gas Side Boiler Island Material and Material Energy Balance (Cases 1-5).....	36
Table 3-20: Overall Material Balance for Amine Plants (Cases 1-4; 90%-30% CO ₂ Capture).....	48
Table 3-21: Energy and Process Demands (Cases 1-4; 90%-30% CO ₂ Capture).....	49
Table 3-22: Case 1 Material & Energy Balance for CO ₂ Compression, Dehydration, and Liquefaction (90% CO ₂ Recovery)	51
Table 3-23: Case 2 Material and Energy Balance for CO ₂ Compression, Dehydration, and Liquefaction (70% CO ₂ Recovery)	54
Table 3-24: Case 3 Material and Energy Balance for CO ₂ Compression, Dehydration, and Liquefaction (50% CO ₂ Recovery).....	57
Table 3-25: Case 4 Material and Energy Balance for CO ₂ Compression, Dehydration, and Liquefaction (30% CO ₂ Recovery)	60
Table 3-26: CO ₂ Product Specification and Calculated Product Comparison (Cases 1-4).....	62
Table 3-27: Chemical and Desiccants Consumption (lbm/day) for Cases-1-4 (90-30% CO ₂ Recovery)	62
Table 3-28: Equipment Summary - CO ₂ Removal, Compression, and Liquefaction System (Cases 1-4)	63
Table 3-29: Consumption of Utilities for Cases 1-4 (90%-30% CO ₂ Recovery)	64
Table 3-30: Auxiliary Power Usage for Case 1 (90% CO ₂ Recovery).....	64



Table 3-31: Auxiliary Power Usage for Case 2 (70% CO ₂ Recovery)	65
Table 3-32: Auxiliary Power Usage for Case 3 (50% CO ₂ Recovery)	66
Table 3-33: Auxiliary Power Usage for Case 4 (30% CO ₂ Recovery)	67
Table 3-34: Key Process Parameters for Simulation (Cases 1-4)	68
Table 3-35: Reclaimer Bottoms Composition (Cases 1-4).....	70
Table 3-36: Filter Residue Composition (Cases 1-4).....	70
Table 3-37: Material and Energy Balance for Case 5/Concept A Amine System	88
Table 3-38: Material and Energy Balance for Case 5/Concept A CO ₂ Compression, Dehydration and Liquefaction System.....	89
Table 3-39: Equipment Summary CO ₂ Removal, Compression, and Liquefaction System (Cases 1, 5)	90
Table 3-40: Utility Consumption for Case 5/Concept A	91
Table 3-41: Auxiliary Power Usage for Case 5/Concept A	91
Table 3-42: Chemicals and Desiccants Consumption for Case 5/Concept A	92
Table 3-43: Key Process Parameters Comparison for Case 5/Concept A	93
Table 3-44: Reclaimer Bottoms Composition for Case 5/Concept A.....	94
Table 3-45: Filter Residue Composition for Case 5/Concept A	94
Table 3-46: Cooling Tower Blowdown Composition Limitations – Case 5/Concept A	95
Table 3-47: Expected Steam Conditions at Extraction Points for 30% CO ₂ Removal	110
Table 3-48: Plant Performance and CO ₂ Emissions Comparison (Base Case and Cases 1-5)	113
Table 3-49: Prices for Consumables	122
Table 3-50: Project and Process Contingencies	122
Table 3-51: Case 1 (90% Capture) CO ₂ Separation and Compression System Investment Costs	123
Table 3-52: Case 1 (90% Capture) CO ₂ Separation and Compression System Operating & Maintenance Costs	124
Table 3-53: Case 2 (70% Capture) CO ₂ Separation and Compression System Investment Costs	125
Table 3-54: Case 2 (70% Capture) CO ₂ Separation and Compression System Operating & Maintenance Costs	126
Table 3-55: Case 3 (50% Capture) CO ₂ Separation and Compression System Investment Costs	127
Table 3-56: Case 3 (50% Capture) CO ₂ Separation and Compression System Operating & Maintenance Costs	128
Table 3-57: Case 4 (30% Capture) CO ₂ Separation and Compression System Investment Costs	129
Table 3-58: Case 4 (30% Capture) CO ₂ Separation and Compression System Operating & Maintenance Costs	130
Table 3-59: Case 5/Concept A (96% Capture) CO ₂ Separation and Compression System Investment Costs	131
Table 3-60: Case 5/Concept A (96% Capture) CO ₂ Separation and Compression System Operating & Maintenance Costs	132
Table 3-61: Let Down Turbine Generator Costs and Electrical Outputs for Cases 1-5 (D&R Cost Basis).....	133
Table 3-62: Total Retrofit Investment Costs (Cases 1-5)	134
Table 3-63: CO ₂ Removal, Compression, and Liquefaction System Equipment Summary (Cases 1-5).....	135
Table 3-64: Base Economic Assumptions (Base Case and Cases 1-5).....	138
Table 3-65: Economic Evaluation Study Assumptions (Base Case and Cases 1-5).....	139
Table 3-66: Economic Sensitivity Study Parameters.....	140



Table 3-67: Economic Results (Cases 1-4).....	141
Table 3-68: Economic Results for Cases 1 and 5	144
Table 4-1: List of Selected Advanced Post-Combustion CO ₂ Capture Technologies	147
Table 5-1: Solvent Regeneration Energy for Amine Based CO ₂ Capture Systems	149
Table 5-2: Plant Performance and CO ₂ Emissions vs. Solvent Regeneration Energy	152
Table 5-3: Incremental Cost of Electricity Breakdown & Mitigation Costs.....	157
Table 9-1: Case 1 CO ₂ Capture System Equipment List with Data (90% CO ₂ Recovery).....	1
Table 9-2: Case 2 CO ₂ Capture System Equipment List with Data (70% CO ₂ Recovery).....	2
Table 9-3: Case 3 CO ₂ Capture System Equipment List with Data (50% CO ₂ Recovery).....	3
Table 9-4: Case 4 CO ₂ Capture System Equipment List with Data (30% CO ₂ Recovery).....	4
Table 9-5: Case 5/Concept A CO ₂ Capture System Equipment List with Data (96% CO ₂ Recovery).....	5
Table 9-6: Case 1 (90% CO ₂ Capture).....	2
Table 9-7: Case 2 (70% CO ₂ Capture).....	4
Table 9-8: Case 3 (50% CO ₂ Capture).....	6
Table 9-9: Case 4 (30% CO ₂ Capture).....	8
Table 9-10: Case 5 (96% CO ₂ Capture).....	10

LIST OF FIGURES

Figure ES-1: Incremental Levelized Cost of Electricity (LCOE) and CO ₂ Mitigation Cost of Retrofitting a Pulverized Coal-fired Plant at Various Levels of Carbon Capture.....	1
Figure ES-2: Affect of CO ₂ Capture Rate on the Total Investment Cost for Retrofitting a Pulverized Coal-Fired Plant	4
Figure ES-3: Plant Performance Impact of Retrofitting a Pulverized Coal-fired Plant at Various Levels of Carbon Capture.....	5
Figure ES-4: Reduction in Carbon Dioxide Emissions to the Environment.....	7
Figure ES-5: Economic Sensitivity Results (Case 1, 90% CO ₂ Capture).....	8
Figure 1-1: Post-Combustion Amine-Based CO ₂ Capture Retrofit	2
Figure 2-1: Conesville Power Station	9
Figure 2-2: Study Unit Boiler (Existing Conesville Unit #5 Steam Generator)	10
Figure 2-3: Simplified Gas Side Process Flow Diagram (Base Case)	13
Figure 2-4: Selected Conesville #5 Turbine Heat Balance (basis for steam turbine modelin)g	19
Figure 2-5: Steam Cycle Diagram and Performance (Base Case)	20
Figure 2-6: Steam Cycle Mollier Diagram (Base Case)	21
Figure 2-7: Existing Flue Gas Desulfurization System Process Flow Diagram	22
Figure 3-1: AEP Conesville, Ohio, Electric Power Generation Station Site and New Equipment Locations (Cases 1-4)	26
Figure 3-2: Modified FGD System Simplified Process Flow Diagram (Cases 1-5).....	32
Figure 3-3: New Secondary SO ₂ Scrubber Location (Cases 1-4)	34
Figure 3-4: Simplified Boiler Island Gas Side Process Flow Diagram for CO ₂ Separation by Monoethanolamine Absorption (Cases 1-5)	35
Figure 3-5: Advanced MEA Process Flow Diagram (Cases 1-4)	45
Figure 3-6: CO ₂ Compression (Cases 1-4).....	46
Figure 3-7: Flue Gas Bypass System used for 70%, 50%, and 30% CO ₂ Absorption Cases (Cases 2, 3, and 4)	47
Figure 3-8: Case 1 CO ₂ Compression, Dehydration, and Liquefaction Schematic (90% CO ₂ Recovery)	50
Figure 3-9: Case 2 CO ₂ Compression, Dehydration, and Liquefaction Schematic (70% CO ₂ Recovery)	53
Figure 3-10: Case 3 CO ₂ Compression, Dehydration, and Liquefaction Schematic (50% CO ₂ Recovery)	56
Figure 3-11: Case 4 CO ₂ Compression, Dehydration, and Liquefaction Schematic (30% CO ₂ Recovery)	59
Figure 3-12: Equipment Variations – CO ₂ Removal, Compression, and Liquefaction Systems (Cases 1-4).....	63
Figure 3-13: Reboiler Pressure Optimization Study Results (Case 1).....	69
Figure 3-14: Conesville Unit #5 Existing Flue Gas Desulfurization System Scrubbers and Stack.....	72
Figure 3-15: Conesville Unit #5 Existing Turbine Building.....	73
Figure 3-16: Conesville Unit #5 Existing LP Turbine and IP/LP Crossover Pipe.....	74
Figure 3-17: Existing Conesville Cooling Towers & CO ₂ Compression/Liquefaction System Location	75

Figure 3-18: Process Flow Diagram for Case 5/Concept A: Flue Gas Cooling and CO ₂ Absorption.....	84
Figure 3-19: Process Flow Diagram for Case 5/Concept A: Solvent Stripping.....	85
Figure 3-20: Process Flow Diagram for Case 5/Concept A: CO ₂ Compression, Dehydration, and Liquefaction	86
Figure 3-21: Modified Steam/Water Schematic (simplified).....	97
Figure 3-22: Case 1 – Modified Water-Steam Cycle for 90% CO ₂ Removal.....	100
Figure 3-23: Case 2 – Modified Water-Steam Cycle for 70% CO ₂ Removal.....	102
Figure 3-24: Case 3 – Modified Water-Steam Cycle for 50% CO ₂ Removal.....	104
Figure 3-25: Case 4 – Modified Water-Steam Cycle for 30% CO ₂ Removal.....	106
Figure 3-26: Case 5/Concept A – Modified Water-Steam Cycle for 96% CO ₂ Removal	107
Figure 3-27: Case 5/Concept A – Modified Water-Steam Cycle Mollier Diagram for 96% CO ₂ Removal	108
Figure 3-28: Existing LP Turbine at Conesville Unit #5	109
Figure 3-29: Typical Retrofit Solution for the Conesville Unit #5 LP Turbine Type	111
Figure 3-30: Project Construction Scheduled (Cases 1-5).....	112
Figure 3-31: Plant Auxiliary Power & Net Electrical Output (MWe)	114
Figure 3-32: Plant Thermal Efficiency (HHV Basis)	115
Figure 3-33: Plant Thermal Efficiency vs. Capture Level	115
Figure 3-34: Plant Thermal Efficiency Loss Relative to Base Case (HHV Basis)	116
Figure 3-35: Carbon Dioxide Distribution.....	117
Figure 3-36: Specific Carbon Dioxide Emissions.....	117
Figure 3-37: Specific Carbon Dioxide Emissions vs. CO ₂ Capture Level.....	118
Figure 3-38: Total Generator Output (existing + new let down turbine generator).....	119
Figure 3-39: New Equipment Specific Investment Costs	134
Figure 3-40: Economic Results (Cases 1-4)	142
Figure 3-41: Impact of CO ₂ Capture Level on Incremental LCOE and CO ₂ Mitigation Cost (Cases 1-4).....	142
Figure 3-42: Economic Results for Case 1 and Case 5.....	145
Figure 3-43: Economic Sensitivity Results (Case 1 - 90% CO ₂ Capture)	146
Figure 5-1: Plant Gross and Net Output vs. Solvent Regeneration Energy	153
Figure 5-2: Plant Thermal Efficiency and Efficiency Loss vs. Solvent Regeneration Energy	154
Figure 5-3: Plant CO ₂ Emissions vs. Solvent Regeneration Energy	154
Figure 5-4: Case 1a – Modified Water-Steam Cycle (90% Capture: 1,200 Btu/lbm Solvent Regeneration Energy)	156
Figure 5-5: Incremental LCOE Breakdown and CO ₂ Mitigation Cost	158
Figure 5-6: Incremental LCOE and Mitigation Cost vs. Solvent Regeneration Energy	158
Figure 9-1: Existing Overall Site (before CO ₂ Unit Addition)	3
Figure 9-2: Cases 1-4 Flue Gas Cooling & CO ₂ Absorption Equipment Layout	5
Figure 9-3: Cases 1-4 Solvent Stripping and Compression Equipment Layout	6
Figure 9-4: Cases 1-4 Overall Plot Plan for Modified Conesville Unit #5	7
Figure 9-5: Case 5/Concept A – Flue Gas Cooling & CO ₂ Absorption Equipment Layout.....	9
Figure 9-6: Case 5/Concept A – Solvent Stripping Equipment Layout.....	10
Figure 9-7: Case 5/Concept A – CO ₂ Compression & Liquefaction Equipment Layout.....	11
Figure 9-8: Case 5/Concept A – Overall Equipment Layout Conceptual Plan.....	12
Figure 9-9: Case 5/Concept A – Overall Plot Plan for Modified Conesville Unit #5.....	13
Figure 9-10: Case 1 Sensitivity Studies (90% CO ₂ Capture).....	3



Figure 9-11: Case 2 Sensitivity Studies (70% CO₂ Capture)..... 5
Figure 9-12: Case 2 Sensitivity Studies (50% CO₂ Capture)..... 7
Figure 9-13: Case 4 Sensitivity Studies (30% CO₂ Capture)..... 9
Figure 9-14: Case 5 Sensitivity Studies (96% CO₂ Capture)..... 11
Figure 9-15: Typical General Outline Arrangement for LDT Generator for Case 1
(90% Recovery) 7
Figure 9-16: Turbine Generator General Arrangement (Case 1: 90% removal)..... 8
Figure 9-17: Typical General Outline Arrangement for LDT Generator for Case 4
(30% Recovery) 9
Figure 9-18: Turbine Generator General Arrangement for Case 4
(30% removal) 10

ACRONYMS AND ABBREVIATIONS

ABB	ABB Lummus Global Inc.
AEP	American Electric Power
ANSI	American National Standards Institute
APC	Air Pollution Control System
AST	Adiabatic Saturation Temperature
bara	Bar absolute
barg	Bar gauge
BI	Boiler Island
B.L.	Boundary Limit
BOP	Balance of Plant
Btu	British Thermal Unit
cm H ₂ O	Centimeters of water
CO ₂	Carbon Dioxide
COE	Cost of Electricity
DCC	Direct Contact Cooler
DOE/NETL	Department of Energy/National Energy Technology Laboratory
EOR	Enhanced Oil Recovery
EPC	Engineered, Procured, and Constructed
ESP	Electrostatic Precipitator
FD	Forced Draft
FGD	Flue Gas Desulfurization
FOM	Fixed Operation & Maintenance
GHG	Greenhouse Gases
gpm	Gallons per Minute
GPS	Gas Processing System
g	Grams
HHV	Higher Heating Value
HP	High Pressure
hr	Hour
HSS	Heat Stable Salts
ID	Induced Draft
in. H ₂ O	Inches of Water
in. Hga	Inches of Mercury, Absolute
IP	Intermediate Pressure
IRI	Industrial Risk Insurers
ISO	International Standards Organization
J	Joules
kg	Kilograms
kWe	Kilowatts electric
kWh	Kilowatt-hour
LAM	Lean MEA solution



lbm	Pound mass
LDT	Let Down Turbine
LHV	Lower Heating Value
LP	Low Pressure
LT	Low Temperature
MCC	Motor Control Center
MCR	Maximum Continuous Rating
MEA	Monoethanolamine
MJ	Mega joules
MMBtu	Million of British Thermal Units
MWe	Megawatt Electric
MUPC	Make-up Power Cost
NGCC	Natural Gas Combined Cycle
NPSH	Net Positive Suction Head
N ₂	Nitrogen Gas
OCDO	Ohio Coal Development Office
OSBL	Outside Boundary Limits
O&M	Operation & Maintenance
PA	Primary Air
PC	Pulverized Coal
PFD	Process Flow Diagram
PFWH	Parallel Feedwater Heater
PHX	Primary Heat Exchanger
PLC	Programmable Logic Controller
ppm	Parts per million
psia	Pound per square inch, absolute
psig	Pound per square inch, gauge
RDS	Research and Development Solutions
s	Second
SA	Secondary Air
SCPC	Supercritical Pulverized Coal
TIC	Total Investment Cost
TPD	Ton Per Day
VOM	Variable Operation & Maintenance

ACKNOWLEDGMENTS

The authors appreciatively acknowledge the following people for their contributions to the successful performance of the work presented herein: Mark Borman and Tom Ross of AEP Conesville, Ohio, Plant for providing field unit information; Bill Anderson and Paul Milios of ABB Lummus Global for providing cost estimation and technical support respectively; Neil Canvin, Aku Rainio, Ray Chamberland, Glen Jukkola, and Larry Cellilli from Alstom for providing steam turbine modeling and analysis, economic analysis, contract administration, technical guidance, and project accounting respectively.

EXECUTIVE SUMMARY

There is growing concern that emissions of carbon dioxide (CO₂) and other greenhouse gases (GHG) to the atmosphere is resulting in climate change with undefined consequences. This has led to a comprehensive program to develop technologies to reduce CO₂ emissions from coal-fired power plants. New technologies, based upon both advanced combustion and gasification technologies hold promise for economically achieving CO₂ reductions through improved efficiencies. However, if the United States decides to embark on a CO₂ emissions control program employing these new and cleaner technologies in new plants only, it may not be sufficient. It may also be necessary to reduce emissions from the existing fleet of power plants.

This study was performed to evaluate the technical and economic feasibility of various levels of CO₂ capture (e.g., 90%, 70%, 50%, and 30%) for retrofitting an existing pulverized coal-fired power plant (Conesville #5 unit in Ohio) using advanced amine-based capture technology. Impacts on plant output, efficiency, and CO₂ emissions, resulting from addition of the CO₂ capture systems on an existing coal-fired power plant were considered. Cost estimates were developed for the systems required to produce, extract, clean, and compress CO₂, which could then be available for sequestration and/or other uses such as enhanced oil or gas recovery. Results are reported in terms of the incremental cost of electricity, levelized over 20 years, (LCOE) to retrofit and operate an existing pulverized coal-fired power plant at various levels of carbon capture. The cost of CO₂ mitigation is also reported for each level of carbon capture. Summary results are presented in Figure ES-1 and summarized in Table ES-1.





Figure ES-1: Incremental Levelized Cost of Electricity (LCOE) and CO₂ Mitigation Cost of Retrofitting a Pulverized Coal-fired Plant at Various Levels of Carbon Capture

The results demonstrate an almost linear relationship between the percent change in carbon capture and the incremental LCOE and CO₂ mitigation cost across the study range of 90% to 30% capture. A 10% reduction in the level of carbon capture equates to approximately an 11% reduction in the incremental LCOE and a 4% increase in the CO₂ mitigation cost.





**Table ES-1: Summary of Technical and Economic Performance for Retrofitting
a Pulverized Coal-Fired Plant**

Case	Units	Base Case	Case 1 (90% Capture)	Case 2 (70% Capture)	Case 3 (50% Capture)	Case 4 (30% Capture)
Boiler Parameters						
Main Steam Flow	lb/hr	3,131,619	3,131,651	3,131,651	3,131,651	3,131,651
Main Steam Pressure	psia	2,535	2,535	2,535	2,535	2,535
Main Steam Temp	Deg F	1,000	1,000	1,000	1,000	1,000
Reheat Steam Temp	Deg F	1,000	1,000	1,000	1,000	1,000
Boiler Efficiency	Percent	88.1	88.1	88.1	88.1	88.1
Coal Heat Input, HHV	10 ⁶ Btu/hr	4,228.7	4,228.7	4,228.7	4,228.7	4,228.7
CO₂ Removal System Parameters						
Solvent Regeneration Energy	Btu/lbm-CO ₂	n/a	1,550	1,550	1,550	1,550
Steam Pressure	psia	n/a	47	47	47	47
Steam Extraction Flow	lb/hr	n/a	1,210,043	940,825	671,949	403,170
Natural Gas Heat Input, HHV	10 ⁶ Btu/hr	n/a	13.0	9.7	6.7	4.2
Steam Cycle Parameters						
Existing Steam Generator Output	kW	463,478	342,693	370,700	398,493	425,787
CO ₂ Removal System Generator Output	kW	n/a	45,321	35,170	25,031	14,898
Total Turbine Generator Output	kW	463,478	388,014	405,870	423,524	440,685
Auxillary Power: Existing Plant	kW	29,700	29,758	29,928	30,113	30,306
Auxillary Power: CO ₂ Removal System	kW	n/a	54,939	42,697	30,466	18,312
Net Plant Power	kW	433,778	303,317	333,245	362,945	392,067
Plant Performance Parameters						
Net Plant Heat Rate, HHV	Btu/kWh		13,984	12,728	11,686	10,818
Net Plant Efficiency, HHV	Percent	35.01	24.5	26.9	29.3	31.7
Energy Penalty	Percent	0	10.5	8.1	5.7	3.3
Capacity Factor	Percent	85	85	85	85	85
Plant CO₂ Profile						
CO ₂ Produced	lb/hr	866,102	867,595	867,212	866,872	866,585
CO ₂ Captured	lb/hr	0	779,775	607,048	433,606	260,164
CO ₂ Emissions	lb/hr	866,102	87,820	260,164	433,266	606,421
Incremental Capital and O&M Costs						
Total Investment Cost	\$1,000	n/a	400,094	365,070	280,655	211,835
Total Investment Cost	\$/kW	n/a	1,319	1,095	773	540
Fixed O&M Costs	\$1000/yr	n/a	2,494	2,284	2,079	1,869
Variable O&M Costs	\$1000/yr	n/a	17,645	14,711	10,876	7,019
Levelized, Make-up Power Cost	\$1000/yr	n/a	62,194	47,926	33,768	19,885
CO ₂ By-product Revenue	\$1000/yr	n/a	0	0	0	0
Feedstock (natural gas) O&M Costs	\$1000/yr	n/a	653	488	337	211
Incremental LCOE Contributions						
Capital Component	¢/kWh	n/a	3.10	2.57	1.82	1.27
Fixed O&M	¢/kWh	n/a	0.13	0.11	0.09	0.07
Variable O&M	¢/kWh	n/a	3.66	2.62	1.72	0.96
Feedstock O&M	¢/kWh	n/a	0.03	0.02	0.01	0.01
Total	¢/kWh	n/a	6.92	5.32	3.64	2.31
CO ₂ Mitigation Cost	\$/ton	n/a	81	88	91	103
CO ₂ Mitigation Cost	\$/tonne	n/a	89	96	100	113
CO ₂ Capture Cost	\$/ton	n/a	54	58	61	70
CO ₂ Capture Cost	\$/tonne	n/a	59	64	67	77

Percent Change in Retrofit Investment Costs Show a Linear Correlation with CO₂ Capture Rate

The total investment required to retrofit an existing plant is also dependant on the level of carbon capture. Reductions in boiler modification costs and carbon capture equipment size are the primary factors. Figure ES-2 shows an almost linear relationship between percent CO₂ capture and total investment cost (TIC) based on the retrofitted plant net power output. As a result, this study shows a 10% reduction in CO₂ capture causes approximately a 10% reduction in the required retrofit investment across the study range of 90% to 30% capture. Table ES-1 summarizes the TIC on a \$/kW-net and per \$1000 dollar basis for each CO₂ capture rate.




Figure ES-2: Affect of CO₂ Capture Rate on the Total Investment Cost for Retrofitting a Pulverized Coal-Fired Plant

Retrofit Investment and Operating Costs Included in the Study

The project capital cost estimates (July, 2006 cost date) include all required retrofit equipment such as the amine-based CO₂ scrubbing systems, the modified flue gas desulfurization (FGD) system, the CO₂ compression and liquefaction systems, and steam cycle modifications. Boiler island modifications other than for the FGD system are not required.

Operating and maintenance (O&M) costs were calculated for all systems. The O&M costs for the Base Case were provided by AEP. For the retrofit CO₂ capture system evaluations, additional O&M costs were calculated for the new equipment. The variable O&M (VOM) costs for the new equipment included such categories as chemicals and desiccants, waste handling, maintenance material and labor, and contracted services. A make-up power cost (MUPC) for the reduction in net power production is also included in the VOM costs. A levelized MUPC of 6.40 ¢/kWh-net, equivalent to a new subcritical pulverized coal (bituminous) power plant without carbon capture, was determined for each Case included within the study. The fixed O&M (FOM) costs for the new equipment include operating labor only.

Adding CO₂ Capture Technology Impacts Net Plant Output and Thermal Efficiency

Significant reductions in net plant output are incurred (10%-30% for Cases 1-4) as a result of the CO₂ capture system. For example, capturing 90% of the carbon reduces the net plant output from 433.8 MW to 303.3 MW. The capture system design includes a let down steam turbine generator that contributes 45.3 MW to the existing steam turbine generator output. Inclusion of the let down steam turbine improves the technical performance and lowers the incremental LCOE for retrofitting a pulverized coal-fired power plant with carbon capture technology.

Net plant thermal efficiency is also reduced from about 35.0% (HHV basis) for the Base Case to 24.4% - 31.6% for Cases 1-4. The efficiency reductions are due to reductions in the steam turbine output due to steam extraction for solvent regeneration and significant auxiliary power requirement increases as shown in Table ES-1. The auxiliary power increases are primarily due to the CO₂ compression and liquefaction system. The efficiency decrease is essentially a linear function of CO₂ recovery level over the range of CO₂ capture investigated.




Figure ES-3: Plant Performance Impact of Retrofitting a Pulverized Coal-Fired Plant at Various Levels of Carbon Capture

Retrofitting Existing Coal-fired Plants Can Help Reduce U.S. GHG Emissions

Specific carbon dioxide emissions were reduced from about 908 g/kWh (2 lbm/kWh) for the Base Case to between 59-704 g/kWh (0.13-1.55 lbm/kWh) depending on CO₂ recovery level as

shown in




Figure ES-4. This corresponds to between 6.6% and 77.5% of the Base Case carbon dioxide emissions. The mass of carbon dioxide produced in each case is relatively the same¹, however the significant reduction in net power production in each of the retrofit cases (Cases 1-4) results in a higher CO₂ production rate per kilowatt-hour of power produced. Table ES-1 summarizes the mass of CO₂ produced, emitted, and captured for each case on a pound per hour basis. The mass of CO₂ emissions avoided is determined as the difference per kilowatt-hr in CO₂ emissions relative to the Base Case. For example, Case 1 (90% capture) emits 0.29 lbm-CO₂/kWh and the Base Case emits 2.00 lbm-CO₂/kWh. The difference is 1.71 lbm-CO₂/kWh. An 85.5% reduction in CO₂ released to the environment per kilowatt-hour of power produced.

¹ Coal feed rate is unchanged from the Base Case to each of the retrofit cases (Cases 1-4). A small amount of supplemental natural gas is utilized to regenerate the solvent media in the carbon capture system, therefore, adding to the total mass of CO₂ produced.




Figure ES-4: Reduction in Carbon Dioxide Emissions to the Environment

Sensitivity Analysis Results Demonstrate a Range of Scenarios for Evaluating the Benefits of Retrofitting Pulverized Coal-fired Plants with Carbon Capture Technology

Specific results from this study are limited to the retrofit of AEP’s Conesville Unit #5. Therefore, a sensitivity analysis of the key economic variables was conducted to evaluate the applicability of retrofitting other pulverized coal-fired power plants with carbon capture technology. The economic sensitivity analysis was done by varying a number of parameters (Capacity Factor, Total Investment Cost, Make-up Power Cost, and CO₂ By-product Selling Price) that affect the economic results. These sensitivity parameters were chosen since the base values used for these parameters are site specific to this study.

The objective of this analysis was to determine the relative impacts of the sensitivity parameters and CO₂ capture level on incremental cost of electricity and CO₂ mitigation cost. The sensitivity analysis was conducted for each case analyzed within this study. The economic sensitivity results obtained from Case 1 (90% capture) are briefly discussed below.

Results for the Case 1 sensitivity study are shown in Figure ES-5. This figure shows the sensitivity of incremental LCOE to capacity factor, total investment cost, make-up power cost, and CO₂ by-product selling price. The base parameter values represent the point in Figure ES-5 where all the sensitivity curves intersect (point 0.0, 0.0). The incremental LCOE ranges from a low of -0.50 ¢/kWh to a high of 7.96 ¢/kWh for the Case 1 sensitivity analysis. The order of sensitivity (most sensitive to least sensitive) of these parameters to incremental LCOE is: CO₂

by-product selling price (levelized) > capacity factor > total investment cost > make-up power cost (levelized). For Cases 2 thru 5, the total investment cost becomes more significant than the make-up power cost, but they are approximately equivalent in Case 1.




Figure ES-5: Economic Sensitivity Results (Case 1, 90% CO₂ Capture)

Reductions in Solvent Regeneration Energy Prove Key to Future Reductions in the Cost of Amine-Based Carbon Capture

Improvements in technical and economic performance resulting from reduction in solvent regeneration energy at the 90% carbon capture level were also evaluated as part of this study and compared to previous work conducted by NETL and Alstom (Bozzuto et al., 2001). The solvent regeneration energy used in this study is based on present day technology, and is 34% less than

in the prior study (2,350 to 1,550 Btu/lbm-CO₂). The result is an improvement in plant thermal efficiency of 4.2 percentage points (from 20.3% to 24.5%). Additionally, retrofit specific investment costs (\$/kWe) were reduced by 52% and incremental LCOE was reduced by 43%.

Because of this significant improvement in amine system performance (in particular, solvent regeneration energy) in the past several years, technical and economic performance of a near-future solvent regeneration level of 1,200 Btu/lbm-CO₂ was compared in a simplified manner to the current technology level of 1,550 Btu/lbm-CO₂. The results demonstrated a potential future improvement in plant thermal efficiency loss as low as 9.3 percentage points. Correspondingly, the retrofit specific investment costs (\$/kWe) and incremental LCOE were further reduced by 3% and 9% respectively.

Table ES-2 shows the primary impacts of solvent regeneration energy level on plant performance and economics. The results show a significant improvement in plant efficiency relative to the earlier 2001 study (Case 5).

Table ES- 2: Plant Performance and Economics vs. Solvent Regeneration Energy

Case	Base Case	Case 5 (2001)	Case 1 (2006)	Case 1a (Near-future)
Solvent Regeneration Energy (Btu/lbm-CO ₂)	---	2,350	1,550	1,200
Net Plant Efficiency (% HHV)	35.0	20.2	24.4	25.7
Efficiency Loss (% Points)	---	14.8	10.6	9.3
Incremental LCOE (¢/kWh)	---	12.54	6.92	6.32
CO ₂ Mitigation Cost (\$/tonne)	---	134	81	73
CO ₂ Mitigation Cost (\$/tonne)	---	148	89	81
CO ₂ Capture Cost (\$/tonne)	---	76	54	52
CO ₂ Capture Cost (\$/tonne)	---	83	59	57

Conclusions

No major technical barriers exist for retrofitting AEP's Conesville Unit #5 to capture CO₂ with post-combustion amine-based capture systems. Nominally, four acres of new equipment space is needed for the amine-based capture and compression system and can be located in three primary locations on the existing 200-acre power plant site, which accommodates a total of six units (2,080 MWe). Slightly less acreage is needed as the capture level is reduced. However, if all six units on this site were converted to CO₂ capture, it may be difficult to accommodate all the new CO₂ capture equipment on the existing site and some additional land would probably need to be purchased.

Plant technical performance and the incremental cost of adding carbon capture technology was evaluated at 90%, 70%, 50%, and 30% capture levels with a solvent regeneration energy level of 1,550 Btu/lbm-CO₂, which represents the "state of the art" at the time of this study (ca. 2006). Lower levels of CO₂ capture can be achieved by simply bypassing some of the flue gas around the CO₂ capture system and only processing a fraction of the total flue gas in the amine based capture system, which can then be made smaller. Flue gas bypassing was determined to be the best approach, from a cost and economic standpoint, to obtain lower CO₂ recovery levels. Energy requirements and power consumption are high, resulting in significant decreases in overall power plant thermal efficiencies, which range from about 24.5% to 31.6% as the CO₂

capture level decreases from 90% to 30% for Cases 1-4 as compared to 35% for the Base Case (all HHV basis). The efficiency decrease is essentially a linear function of CO₂ recovery level.

Specific carbon dioxide emissions were reduced from about 908 g/kWh (2 lbm/kWh) for the Base Case to 132-704 g/kWh (0.29-1.55 lbm/kWh) as the CO₂ recovery level decreases from 90% to 30%. Case 2 (70% CO₂ capture) was found to yield approximately this same amount of CO₂ emissions, 362 g/kWh (0.781 lbm/kWh) as typical natural gas combined cycle (NGCC) plant without carbon capture.

Specific investment costs are \$540 to \$1,319/kWe-new as CO₂ capture level increases from 30% to 90%. The specific investment cost is a nearly linear function of CO₂ recovery level, although equipment selection and economy of scale effects make this relationship much less linear than efficiency.

All cases studied incur significant increases to the levelized cost of electricity (LCOE) as a result of CO₂ capture. The incremental LCOE, as compared to the Base case (air firing without CO₂ capture) increases from 2.31 to 6.92 ¢/kWh as CO₂ capture level increases from 30% to 90%. Conversely, CO₂ mitigation cost increases slightly from \$89 to \$113/tonne of CO₂ avoided as the CO₂ capture level decreases from 90% to 30%. The near linear decrease in incremental LCOE with reduced CO₂ capture indicates there is no optimum CO₂ recovery level.

For the ranges studied, the incremental LCOE is most impacted by the following parameters (in given order): CO₂ by-product selling price, CO₂ capture level, solvent regeneration energy, capacity factor, investment cost, and make-up power cost.

To examine the impact improvements in amine-based systems, a solvent regeneration energy sensitivity study was completed for the 90% capture level. Reduced solvent regeneration energy was found to have significant impacts on the plant performance and economics. Plant thermal efficiency was calculated to change by about 3.7 percentage points for a change in solvent regeneration energy of 1,000 Btu/lbm-CO₂. Similarly, incremental cost of electricity was determined to be sensitive to changes in solvent regeneration energy. The incremental LCOE was calculated to change by about 0.6 ¢/kWh (or about 10% relative to Case 1 at 6.92 ¢/kWh) for a change in solvent regeneration energy of 1,000 Btu/lbm-CO₂. Incremental LCOE reductions of about 49% were found, as compared to the original 2001 study.

Overall, the results demonstrate the technical and economical feasibility for retrofitting pulverized coal-fired power plants in the U.S. over a range of carbon capture levels. Research efforts continue to improve upon the technical and economic performance of amine-based carbon capture technology to ensure a potential option for existing U.S. power plants to contribute to reducing carbon emissions in the event the United States decides to embark on a CO₂ emissions control program.

1 INTRODUCTION

There is growing concern that emissions of CO₂ and other greenhouse gases (GHG) to the atmosphere is resulting in climate change with undefined consequences. This has led to a comprehensive program to develop technologies to reduce CO₂ emissions from coal-fired power plants. New technologies, such as advanced combustion systems and gasification technologies hold great promise for economically achieving CO₂ reductions. However, if the United States decides to embark on a CO₂ emissions control program employing these new and cleaner technologies in new plants only, it may not be sufficient. It will also be necessary to reduce emissions from the existing fleet of power plants. This study will build on the results of previous work to help determine better approaches to capturing CO₂ from existing coal-fired power plants.

This study significantly increases the information available on the impact of retrofitting CO₂ capture to existing PC-fired power plants. This study also provides input to potential electric utility actions concerning GHG emissions mitigation, should the U.S. decide to reduce CO₂ emissions. Such information is critical for deciding on the best path to follow for reduction of CO₂ emissions, should that become necessary. This study better informs the public as to the issues involved in reducing CO₂ emissions, provides regulators with information to assess the impact of potential regulations, and provides data to plant owners/operators concerning CO₂ capture technologies. If this is to be done in the most economic manner, it will be necessary to know what level of CO₂ recovery is most economical from the point of view of capital cost, cost of electricity (COE), and operability. All this will contribute to achieving necessary controls in the most economically feasible manner.

Although switching to natural gas as a fuel source is an option, a tight supply and rising costs may prevent this from being a universal solution. Also, fuel switching may not provide the desired CO₂ emission reductions; and, therefore, some form of CO₂ capture may be required. Captured CO₂ could be sold for enhanced oil or gas recovery or sequestered. The results of this CO₂ capture study will enhance the public's understanding of post-combustion control options and influence decisions and actions by government regulators and power plant operators relative to reducing GHG CO₂ emissions from power plants.

The objectives for this study are to evaluate the technical and economic impacts of removing CO₂ from a typical existing U.S. coal-fired electric power plant using advanced amine-based post-combustion CO₂ capture systems. By investigating various levels of CO₂ capture, potential exists for identifying an economically optimum CO₂ capture level as well as simply quantifying the effect of CO₂ capture level on typical measures of plant performance and economic merit. As a view of the future for amine-based CO₂ capture systems, a sensitivity analysis showing the effect of anticipated reductions in solvent regeneration energy was also investigated (Please refer to Section 4 for details). This sensitivity study was done at the 90% CO₂ capture level only with solvent regeneration energy values of 1,550 and 1,200 Btu/lbm-CO₂ (Cases 1 and 1a respectively). The 1,550 Btu/lbm-CO₂ level represents the state of the art at the time of this study (ca. 2006) (IEA, 2004), the 1,200 Btu/lbm-CO₂ level represents a near-future value which may be possible with improved solvents, as discussed in the literature. The primary impacts are quantified in terms of plant electrical output reduction, thermal efficiency reduction, CO₂

emissions reduction, retrofit investment costs, and the incremental cost of generating electricity resulting from the addition of the CO₂ capture systems to the selected study unit.

1.1 Background

In a report titled “Engineering Feasibility and Economics of CO₂ Capture on an Existing Coal-Fired Power Plant,” (Bozzuto et al., 2001), Alstom evaluated the impact of adding facilities to capture >90% of the CO₂ from AEP’s Conesville, Ohio, Unit #5. During the 1999-2001 time period of the study, Alstom teamed with American Electric Power (AEP), ABB Lummus Global Inc. (ABB), National Energy Technology Laboratory (NETL), and Ohio Coal Development Office (OCDO) and conducted a comprehensive study evaluating the technical and economic feasibility of three alternate CO₂ capture technologies applied to an existing U.S. coal-fired electric power plant. The power plant analyzed in this study was Conesville #5, a subcritical, pulverized-coal (PC) fired steam plant operated by AEP of Columbus, Ohio. Unit #5 is one of six coal-fired steam plants located on the Conesville site which has a total generating capacity of ~2,080 MWe. The Unit #5 steam generator is a nominal 450 MW, coal-fired, subcritical pressure, controlled circulation unit. The furnace is a single cell design that employs corner firing with tilting tangential burners. The fuel utilized is bituminous coal from the state of Ohio. The flue gas leaving the steam generator system is cleaned of particulate matter in an electrostatic precipitator (ESP) and of SO₂ in a lime-based flue gas desulfurization (FGD) system before being discharged to the atmosphere.

One of the CO₂ capture concepts investigated in this earlier study was a post-combustion system which consisted of an amine-based scrubber using monoethanolamine (MEA) as depicted in Figure 1-1. This system was referred to as **Concept A**. In Concept A, coal is burned conventionally in air as schematically depicted below. The flue gases leaving the modified FGD system (a secondary absorber is added to reduce the SO₂ concentration, as required by the MEA system) are cooled with a direct contact cooler and ducted to the MEA system where more than 96% of the CO₂ is removed, compressed, and liquefied for usage or sequestration. The MEA system uses the Kerr-McGee/ABB Lummus Global’s commercial MEA process. The remaining flue gases leaving the new MEA system (consisting of primarily oxygen, nitrogen, water vapor and a relatively small amount of sulfur dioxide and carbon dioxide) are discharged to the atmosphere. The CO₂ capture results were compared to a Base Case. The Base Case represents the “business as usual” operation scenario for the power plant without CO₂ capture.




Figure 1-1: Post-Combustion Amine-Based CO₂ Capture Retrofit

Although boiler performance is identical to the Base Case in Concept A, there is a major impact to the steam cycle system where low-pressure steam is extracted to provide the energy for solvent regeneration. About 79% of the intermediate pressure (IP) turbine exhaust steam is extracted from the IP/LP crossover pipe. This steam is expanded from 200 psia to 65 psia through a new steam turbine/generator where electricity is produced. The exhaust steam leaving the new turbine provides the heat source for solvent regeneration in the reboilers of the CO₂ recovery system.

Solvent regeneration for this system requires about 5.46 MJ/Tonne CO₂ (2,350 Btu/lbm-CO₂). The condensate leaving the reboilers is pumped to the existing deaerator. The remaining 21% of the IP turbine exhaust steam is expanded in the existing low-pressure turbine before being exhausted to the existing condenser. The total electrical output from both the existing and new generators is 331,422 kW. This represents a gross output reduction of 132,056 kW (about 28%) as compared to the Base Case.

Investment costs required for adding the capture system to this existing unit were found to be very high (~\$1,602/kWe-new: new refers to the new output level of 331,422 kW). The impact on the cost of electricity was found to be an increase of about 6.2¢/kWh (not including Make-up Power Costs, MUPC).²

Based on these results, further study was deemed necessary to find a better approach for capturing CO₂ from existing PC-fired power plants.

1.2 Current Study

In the current study NETL teamed with Alstom Power Inc., AEP, and ABB as well as with Science Applications International Corporation (SAIC)/Research and Development Solutions (RDS) to conduct a follow-up study. The follow up study again investigated post-combustion capture systems with amine scrubbing as applied to the Conesville #5 unit. The post-combustion CO₂ scrubbing system for the current study differs from the previous study in several ways:

- An advanced “state of the art” amine CO₂ scrubbing system is used for CO₂ removal from the flue gas stream. This advanced system requires significantly less energy for solvent regeneration. Solvent regeneration for this system, designed and selected in 2006, requires about 3.6 MJ/Tonne CO₂ (3.1x10⁶ Btu/Ton CO₂) (~34% reduction as compared to the previous study, designed and selected in 2000). Additionally, the reboiler is operated at 3.1 bara (45 psia) as compared to 4.5 bara (65 psia) in the previous study.
- Several CO₂ capture levels are investigated in this study (90%, 70%, 50%, and 30%). These are referred to as **Cases 1, 2, 3, and 4** respectively in this study. In the previous study only one CO₂ recovery level (96%) was investigated. The costs and economic evaluation of this previous case (Case 5 in the current study) were updated.
- Alstom’s steam turbine retrofit group developed a detailed analysis of the modified existing steam turbine. Previously, a more simplified analysis was done for the existing steam turbine.

² Costs and economic evaluation were updated as part of the current study. Both the investment cost and incremental cost of electricity doubled as a result of the updated analysis; see Case 5 results.

- In the current study significant quantities of heat rejected from the CO₂ capture/compression system are integrated with the steam/water cycle. Previously, heat integration was not used because the CO₂ capture/compression system was located too far away from the steam/water system. The reboiler pressure for the current study was also lowered.
- It is recognized that solvent regeneration energy represents a key variable for amine-based post-combustion CO₂ capture systems in terms of the impact it ultimately has on the measures of power plant performance (thermal efficiency) and economic merit (cost of electricity). Knowing that the commercial implementation of these amine-based post-combustion capture systems will be several years in the future, and that research is continually improving the performance of these amines, a sensitivity analysis showing the effect of anticipated reductions in solvent regeneration energy was also investigated in this study. This sensitivity study was done at the 90% capture level only and the solvent regeneration energy levels investigated for this capture level were 1,550 and 1,200 Btu/lbm-CO₂. These cases are referred to as **Cases 1 and 1a** respectively in this study.

1.2.1 CO₂ Capture Level Sensitivity Study

The following list defines the five cases included in the capture level sensitivity study presented in this report. The first four cases (Cases 1-4) use an advanced “state of the art” amine scrubbing system designed and cost estimated in 2006. The fifth case (Case 5) uses the Kerr-McGee/ABB Lummus Global’s MEA scrubbing system, which was originally designed and cost-estimated in 2000.

- **Case 1:** 90% Capture
- **Case 2:** 70% Capture
- **Case 3:** 50% Capture
- **Case 4:** 30% Capture
- **Case 5:** 96% Capture “Concept A of 2001 study” using Kerr-McGee/ABB Lummus Global’s commercial MEA-based process (cost and economic analysis update of previous study only).

To provide a frame of reference, each of the cases is evaluated against a Base Case from the standpoints of performance and impacts on power generation cost. The Base Case represents the “business as usual” operation scenario for the existing plant without CO₂ recovery. The Base Case which is used for the current study is identical to the Base Case used in the previous study from a plant performance standpoint. Fuel costs and other operating and maintenance costs for the Base Case have been updated based on AEP’s current recommendations. All technical performance and cost results associated with these options are being evaluated in comparative manner.

Furthermore, in the current study, investment costs and economics are updated for “Concept A” from the original study in order to be directly comparable with the current study results. This is referred to as Case 5 in the current study. It should be pointed out that for Case 5 the process

design and equipment selections were developed in 2000 and were not updated for the current study.

1.2.2 Solvent Regeneration Energy Sensitivity Study - A Look To The Future:

It is well known that commercial implementation of these amine-based post-combustion capture systems for power plant applications will not occur until several years in the future. This delay is because these systems need to be proven at large scale, CO₂ sequestration technology needs to be proven, and policies need to be implemented to make utilization of these systems economic. During this time period, numerous research and developmental efforts are ongoing to further advance post-combustion CO₂ capture technologies. These efforts seek to develop technologies that are focused on improving performance and reducing cost with post-combustion CO₂ capture.

One of the key parameters with post-combustion CO₂ capture systems that is an indicator of relative system performance is regeneration energy requirement (Btu/lbm-CO₂). When these post-combustion CO₂ capture systems are integrated with power plants, this variable is potentially quite sensitive with respect to the common measures of power plant performance (thermal efficiency) and economic merit (cost of electricity). Hence, as a look to the future, a simple sensitivity analysis for solvent regeneration energy and the impacts on power plant performance (thermal efficiency) and economics (cost of electricity) was carried out. This sensitivity study was done at the 90% capture level only and the solvent regeneration energy levels investigated were 1,550 and 1,200 Btu/lbm-CO₂. These cases are referred to as Cases 1 and 1a respectively.

- **Case 1** – Existing power plant retrofit with an advanced “state of the art” amine system for 90% CO₂ capture (1,550 Btu/lbm-CO₂ solvent regeneration energy)
- **Case 1a** – Existing power plant retrofit with an advanced “near future” amine system for 90% CO₂ capture (1,200 Btu/lbm-CO₂ solvent regeneration energy)

The solvent regeneration energy level of 1,550 Btu/lbm-CO₂ represents the state of the art at the time of this study (ca. 2006) (IEA, 2004), the 1,200 Btu/lbm-CO₂ level represents a future value, which may be possible with improved solvents as discussed in the literature.

Alstom Power Inc. managed and performed the subject study from its U.S. Power Plant Laboratories office in Windsor, Connecticut. Alstom Steam Turbine Retrofit group performed the steam turbine analysis from its offices in Mannheim, Germany. ABB Lummus Global, from its offices in Houston, Texas, participated as a subcontractor. American Electric Power participated by offering their Conesville Unit #5 as the case study, and provided relevant technical and cost data. RDS is the prime contractor reporting to NETL for the project. AEP is one of the largest U.S. utilities and is the largest consumer of Ohio coal, and as such, brings considerable value to the project. Similarly, Alstom Power and ABB Lummus Global are well established as global leaders in the design and manufacture of power generation equipment, petrochemical and CO₂ separation technology. Alstom Environmental Business Unit is a world leader in providing equipment and services for power plant environmental control and provided their expertise to this project. The U.S. Department of Energy, National Energy Technology Laboratory through RDS provided consultation and funding.

The motivation for this study was to provide input to potential U.S. electric utility actions to meet Kyoto protocol targets. If the U.S. decides to reduce CO₂ emissions consistent with the Kyoto protocol, action would need to be taken to address the fleet of existing power plants. Although fuel switching from coal to gas is one likely scenario, it will not be a sufficient measure and some form of CO₂ capture for use or disposal may also be required. The output of this CO₂ capture study will enhance the public's understanding of CO₂ capture and influence decisions and actions by government, regulators, equipment suppliers, and power plant owners to reduce their greenhouse gas CO₂ emissions.

The primary objectives for this study are to evaluate the technical and economic impacts of removing CO₂ from this existing U.S. coal-fired electric power plant. By investigating various levels of capture, potential exists for identifying a "sweet spot," as well as simply quantifying the effect of this variable on typical measures of plant performance and economic merit. The impacts are quantified in terms of plant electrical output, thermal efficiency, CO₂ emissions, retrofit investment costs, and the incremental cost of generating electricity resulting from the addition of the CO₂ capture systems. All technical performance and cost results associated with these options are being evaluated in comparative manner. Technical and economic issues being evaluated include:

- Overall plant thermal efficiency
- Boiler efficiency
- Steam cycle thermal efficiency
- Steam cycle modifications
- Plant CO₂ emissions
- Plant SO₂ emissions
- Flue Gas Desulfurization system modifications and performance
- Plant systems integration and control
- Retrofit investment cost and cost of electricity (COE)
- Operating and Maintenance (O&M) costs
- CO₂ Mitigation Costs

Cost estimates were developed for all the systems required to extract, clean, compress and liquefy the CO₂, to a product quality acceptable for pipeline transport. The Dakota Gasification Company's CO₂ specification (Dakota 2005) for EOR, given in Table 1-1, was used as one of the bases for the design of the CO₂ capture system.

Table 1-1: Dakota Gasification Project's CO₂ Specification for EOR

Component	units	Value
CO ₂	vol %	96
H ₂ S	vol %	1
CH ₄	vol %	0.3
C ₂ + HC's	vol %	2
CO	vol %	---
N ₂	ppm by vol.	6000
H ₂ O	ppm by vol.	2
O ₂	ppm by vol.	100
Mercaptans and other Sulfides	vol %	0.03

The CO₂ product could then be available for use in enhanced oil or gas recovery or for sequestration. Additionally, an economic evaluation, showing the impact of CO₂ capture on the incremental LCOE, was developed. Included in the economic evaluation was a sensitivity study showing the effects of plant capacity factor, CO₂ by-product selling price, investment cost, and make-up power cost, on the incremental LCOE (¢/kWh) and on the mitigation cost for the CO₂ (\$/ton of mitigated CO₂).



This Page Intentionally Left Blank

2 STUDY UNIT DESCRIPTION AND BASE CASE PERFORMANCE

This section provides a brief description of the selected Conesville #5 study unit. The study unit is one of six existing coal-fired steam plants located on the site as shown in Figure 2-1. AEP owns and operates these units except for Unit #4, which is jointly owned by AEP, Cinergy, and Dayton Power and Light. The total electric generating capacity on this site is ~2,080 MWe, although two of the older units (Units 1 and 2, shown on the left) have been retired. The steam generated in Unit #5 is utilized in a subcritical steam cycle for electric power generation. The capacity of Conesville Unit #5 is ~430 MWe-net.



Figure 2-1: Conesville Power Station

The Base Case for this study is defined as the unmodified existing study unit firing coal at full load without capture of CO₂ from the flue gas. This represents the “business as usual” operating scenario and is used as the basis of comparison for the CO₂ removal options investigated in this study. The overall performance of the Base Case is presented in Section 2.2.

2.1 Study Unit Description

The power plant analyzed in this study is AEP’s Conesville Unit #5. This unit is a coal-fired steam plant which generates ~430 MWe-net using a subcritical pressure steam cycle. This plant

has been in commercial operation since 1976. A general arrangement elevation drawing of the study unit steam generator is shown in Figure 2-2.




Figure 2-2: Study Unit Boiler (Existing Conesville Unit #5 Steam Generator)

The steam generator can be described as a tangentially coal-fired, subcritical pressure, controlled circulation, and radiant reheat wall unit. The furnace is a single cell design utilizing five elevations of tilting tangential coal burners. The furnace is about 15.75 m (51.67 ft) wide,

13.51 m (44.33 ft) deep and 52.33 m (171.67 ft) high. The unit fires mid-western bituminous coal. The coal is supplied to the five burner elevations with five RP-903 coal pulverizers. The unit is configured in a “Conventional Arch” type design and is representative in many ways of a large number of coal-fired units in use throughout the U.S. today. The unit is designed to generate about 391 kg/s (3.1×10^6 lbm/hr) of steam at nominal conditions of 175 bara (2,535 psia) and 538°C (1,000°F) with reheat steam also heated to 538°C (1,000°F). These represent the most common steam cycle operating conditions for the existing U.S. fleet of utility scale power generation systems. Outlet steam temperature control is provided with de-superheating spray and burner tilt.

The superheater is divided into four major sections. Saturated steam leaving the steam drum first cools the roof and walls of the rear pass before supplying the low-temperature superheater section. The low-temperature superheater section is located in the rear pass of the unit and is a horizontal section with the outlet tubes in a vertical orientation adjacent to the finishing superheater section. Steam leaving the low-temperature superheater section first flows through the de-superheater spray stations and then to the radiant superheat division panel section. The division panels are located in the upper furnace directly above the combustion zone of the lower furnace. Steam leaving the division panel section flows to the superheater platen section, which is a more closely spaced vertical section located between the panels and the finishing pendant reheater. Steam leaving the platens flows into the finishing superheater section which is also a pendant section located downstream of the pendant reheater, just before the gas turns downward to enter the low-temperature superheater section in the rear pass of the unit. Steam leaving the finishing superheater is piped to the high-pressure turbine where it is expanded to reheat pressure and then returned to the reheat de-superheating spray station.

The reheater is divided into two sections, a low-temperature radiant wall section followed by a spaced finishing pendant section. Steam is supplied to the reheater radiant wall from the de-superheating spray station, which is fed from the high-pressure turbine exhaust. The reheater radiant wall section is located in the upper furnace and covers the entire front wall and most of the two sidewalls of the upper furnace. The pendant finishing reheat section is located above the arch between the superheat platen and superheat finishing sections. Steam leaving the finishing reheater is returned to the intermediate pressure turbine where it continues its expansion through the intermediate and low-pressure turbines before being exhausted to the condenser.

The gases leaving the low-temperature superheater section are then further cooled in an economizer section. The economizer is comprised of four banks of spiral-finned tubes (0.79 fins/cm or 2 fins/inch), which heats high-pressure boiler feedwater before it is supplied to the steam drum. The feedwater supplying the economizer is supplied from the final extraction feedwater heater.

Flue gas leaving the economizer section then enters the Ljungstrom[®] trisector regenerative air heater, which is used to heat both the primary and secondary air streams prior to combustion in the lower furnace. Particulate matter is removed from the cooled flue gas leaving the air heater in an electrostatic precipitator (ESP) and sulfur dioxide is removed in a lime-based flue gas de-sulfurization (FGD) system. The induced draft fans are located in between the ESP and the FGD. The cleaned flue gas leaving the FGD system is then exhausted to the atmosphere through the stack, which also serves Unit #6. The induced draft and forced draft fans are controlled to operate the unit in a balanced draft mode with the furnace maintained at a slightly negative pressure (typically -0.5 in wg).

The high-pressure superheated steam leaving the finishing superheater is expanded through the high-pressure steam turbine, reheated in the two-stage reheater and returned to the intermediate pressure turbine. The steam continues its expansion through the low-pressure turbine sections where it expands to condenser pressure. The generator produces about 463 MW of electric power at Maximum Continuous Rating (MCR). The steam cycle utilizes six feedwater heaters (three low-pressure heaters, a deaerator, and two high-pressure heaters) where the feedwater is preheated to about 256°C (493°F) before entering the economizer of the steam generator unit. The boiler feed pump is steam turbine driven with steam provided from the intermediate pressure turbine exhaust and expanded to condenser pressure.

2.2 Base Case Performance Analysis

The Base Case can be described as the unmodified existing unit firing coal at full load and without capture of CO₂ from the flue gas. This represents the “business as usual” operating scenario and is used as the basis of comparison for the CO₂ removal options investigated in this study. The first step in the development of a Base Case was to set up a computer model of the boiler. Using test data from the existing unit, the computer model was then calibrated. The calibrated boiler model was then used for analysis of the Base Case and the CO₂ removal cases. The development of the Base Case was done as part of the original study (Bozzuto et al., 2001) and was not repeated for the current study. The Base Case of the original study was used as the Base Case for the current study description of the Base Case development (extracted from the original study report) is provided in this section.

2.2.1 Calibration of the Boiler Computer Model

The first step in the calculation of a Base Case was to set up a steady state performance computer model of the Conesville #5 steam generator unit. This involves calculating or obtaining all the geometric information for the unit as required by the proprietary Reheat Boiler Program (RHBP). The RHBP provides an integrated, steady state performance model of the Boiler Island including, in addition to the steam generator unit, pulverizers, air heater, and steam temperature control logic. The RHBP is used to size components and/or predict performance of existing components. In this study, since the boiler island component sizes are known, the RHBP was used exclusively for calculating unit performance.


The next step in the heat transfer analysis of the Base Case was to calibrate the RHBP model of the unit. This involves obtaining test data (with air firing) for the existing unit and “adjusting” the performance model to match the test data. The required test data includes steam temperatures entering and leaving each major heat exchanger section in the unit, steam pressures, coal analysis, flue gas oxygen content, etc. The “adjustments” or “calibration factors” for the model are in the form of “surface effectiveness factors” and “fouling factors” for the various heat exchanger sections throughout the unit. Unfortunately, the test data used for calibration of this model was not totally complete and several assumptions were required in the calibration process. Although all the required data was not available, primarily due to existing instrumentation limitations, a satisfactory calibrated model was obtained.

Using the calibrated boiler model and providing it with new steam side inputs (mass flows, temperatures, and pressures) from the agreed upon MCR steam turbine material and energy

balance, the model was run and performance was calculated for the Base Case. The performance for the overall power plant system is described in Section 2.2.2 with the boiler performance shown in Section 2.2.3 and the steam turbine performance in Section 2.2.4.

2.2.2 Overall System Description and Material and Energy Balance (Base Case)

The simplified gas side process flow diagram for the Base Case is shown in Figure 2-3 and the associated material and energy balance for this case is shown in Table 2-1. Overall plant performance is summarized in Table 2-2. This system is described previously in Section 2.2. Boiler efficiency is calculated to be 88.13%. The net plant heat rate is calculated to be 10,285 kJ/kWh (9,749 Btu/kWh) for this case as shown in Table 2-2. Auxiliary power is 29,700 kW and the net plant output is 433,778 kW. Carbon dioxide emissions are 109 kg/s (88,156 lbm/hr) or about 907 g/kWh (2.00 lbm/kWh).



Material Flow Stream Identification

1	Raw Coal to Pulverizers	9	FGD System Solids to Disposal	17	Mixed Primary Air to Pulverizers
2	Air Infiltration Stream	10	Flue Gas to Stack	18	Pulverized Coal and Air to Furnace
3	Flue Gas from Economizer to Air Heater	11	Air to Primary Air Fan	19	Secondary Air to Forced Draft Fan
4	Flue Gas Leaving Air Heater to ESP	12	Primary Air to Steam Coil Air Heater	20	Secondary Air to Steam Coil Air Heater
5	Flyash Leaving ESP	13	Primary Air to Air Heater	21	Secondary Air to Air Heater
6	Flue Gas Leaving ESP to Induced Draft Fan	14	Air Heater Leakage Air Stream	22	Heated Secondary Air to Furnace
7	Flue Gas to Flue Gas Desulfurization System	15	Tempering Air to Pulverizers	23	Bottom Ash from Furnace
8	Lime Feed to FGD System	16	Hot Primary Air to Pulverizers		

Figure 2-3: Simplified Gas Side Process Flow Diagram (Base Case)



Table 2-1: Gas Side Material and Energy Balance (Base Case)

Constituent	(Units)	1	2	3	4	5	6	7	8	9	10	11	12	13
O ₂	(lbm/hr)	26586	42147	101097	144807		144817	144817	5335		144578	203237	203237	112918
N ₂	"	4868	139626	2797385	2942220		2942220	2942220			2942220	673283	673283	374075
H ₂ O	"	37820	2357	228849	231294		231294	231294	250709	45979	436024	11365	11365	6314
CO ₂	"			867210	867210		867210	867210			866156			
SO ₂	"			20202	20202		20202	20202			1063			
H ₂	"	16102												
Carbon	"	236665												
Sulfur	"	10110												
Ca	"								12452					
Mg	"								584					
MgO	"									484				
MgSO ₃	"									1293				
MgSO ₄	"									94				
CaSO ₃	"									31579				
CaSO ₄	"									2468				
CaCO ₃	"									2398				
Ash/Inerts	"	42313		33851	33851	33851			968	968				
		Raw Coal	Leakage Air	Flue gas to AH	Flue gas to ESP	Flyash	Flue gas to ID Fan	Flue gas to FGD	Lime Slurry	FGD Disposal	Flue gas to CO ₂ Sep	Pri Air to PA Fan	PA from PA Fan	Pri Air to AH
Total Gas	(lbm/hr)		184130	4014743	4205743		4205743	4205743			4390042	887885	887885	493308
Total Solids	"	374455		33851	33851	33851			14003	42884				
Total Flow	"	374455	184130	4048594	4239594	33851	4205743	4205743	270067	88863	4390042	887885	887885	493308
Temperature	(Deg F)	80	80	706	311	311	311	325	80	136	136	80	92	92
Pressure	(Psia)	14.7	14.7	14.6	14.3	14.7	14.2	15	14.7	14.7	14.7	14.7	15.6	15.6
h _{sensible}	(Btu/lbm)	0.000	0.000	161.831	57.924	57.750	57.924	61.384	0.000	14.116	14.116	0.000	2.899	2.899
Chemical	(10 ⁶ Btu/hr)	4228.715												
Sensible	(10 ⁶ Btu/hr)	0.000	0.000	655.007	245.567	1.955	243.612	258.166	0.000	3.314	63.916	0.000	2.574	1.430
Latent	(10 ⁶ Btu/hr)	0.000	2.475	240.291	242.858	0.000	242.858	242.858	0.000	0	464.020	11.933	11.933	6.630
Total Energy ⁽¹⁾	(10 ⁶ Btu/hr)	4228.715	2.475	895.298	488.425	1.955	486.470	501.024	0.000	3.314	527.936	11.933	14.507	8.060

Constituent	(Units)	14	15	16	17	18	19	20	21	22	23			
O ₂	(lbm/hr)	43720	90319	66680	156999	183585	641283	641283	641283	643801				
N ₂	"	144835	299208	299208	520107	524975	2124443	2124443	2124443	3122785				
H ₂ O	"	2445	5051	3729	8779	46599	35860	35860	35860	36001				
CO ₂	"													
SO ₂	"													
H ₂	"					16102								
Carbon	"					236655								
Sulfur	"					10110								
Ca	"													
Mg	"													
MgO	"													
MgSO ₃	"													
MgSO ₄	"													
CaSO ₃	"													
CaSO ₄	"													
CaCO ₃	"													
Ash/Inerts	"					42313					8463			
		Air Htr Lkg Air	Temper ing Air	Hot Pri Air	Mixed Pri Air	Coal-Pri Air Mix	Sec Air to FD	Sec air to SCAH	Sec Air to AH	Hot Sec Air	Bottom Ash			
Total Gas	(lbm/hr)	191000	394577	291308	685885		2801587	2801587	2801587	2812587				
Total Solids	"										8463			
Total Flow	"	191000	394577	291308	685885	1060340	2801587	2801587	2801587	2812587	8463			
Temperature	(Deg F)	92	92	666	339		80	86.4	86.4	616.1	2000			
Pressure	(Psia)	15.6	15.6	15.6	15.6	15.0	14.7	15.2	15.1	14.9	14.7			
h _{sensible}	(Btu/lbm)	2.899	2.899	145.249	63.358		0.000	1.549	1.549	132.582	480.000			
Chemical	(10 ⁶ Btu/hr)					4228.715								



Sensible	(10 ⁶ Btu/hr)	0.554	1.144	42.312	43.456		0.000	4.341	4.341	372.898	4.062			
Latent	(10 ⁶ Btu/hr)	2.567	5.303	3.915	9.218		37.653	37.653	37.653	37.801	0.000			
Total Energy ⁽¹⁾	(10 ⁶ Btu/hr)	3.121	6.447	46.227	52.674	4281.389	37.653	41.994	41.994	410.699	4.062			
Notes: (1) Energy Basis: Chemical Based on Higher Heating Value (HHV); Sensible energy above 80F; Latent based on 1050 Btu/lbm of water vapor														

Table 2-2: Overall Plant Performance Summary (Base Case)

	Units	Base Plant
Fuel Parameters		
Coal Heat Input (HHV)	10 ⁶ Btu/hr	4228.7
Natural Gas Heat Input (HHV)	10 ⁶ Btu/hr	---
Total Fuel Heat Input (HHV)	10 ⁶ Btu/hr	4228.7
Steam Cycle Parameters		
Existing Steam Turbine Generator Output	kW	463478
CO ₂ Removal System Turbine Generator Output	kW	0
Total Turbine Generator Output	kW	463478
Total Auxiliary Power	kW	29700
Net Plant Output	kW	433778
Overall Plant Performance Parameters		
Net Plant Efficiency (HHV)	fraction	0.3501
Net Plant Efficiency (LHV)	fraction	0.3666
Normalized Efficiency (HHV; Relative to Base Case)	fraction	1.0000
Net Plant Heat Rate (HHV)	Btu/kWhr	9749
Net Plant Heat Rate (LHV)	Btu/kWhr	9309
Overall Plant CO₂ Emissions		
Carbon Dioxide Emissions	lbm/hr	866102
Specific Carbon Dioxide Emissions	lbm/kWhr	1.997
Specific Carbon Dioxide Emissions	kg/kWhr	0.906
Normalized Specific CO ₂ Emissions (Relative to Base Case)	fraction	1.000

2.2.3 Boiler Analysis Results (Base Case)

The main steam flow for this case and all other cases in this study is 395 kg/s (3,131,619 lbm/hr). The cold reheat flow leaving the high-pressure turbine for this case and all other cases in this study is 348 kg/s (2,765,058 lbm/hr). The hot reheat flow (including de-superheating spray) returning to the intermediate pressure turbine for this case is 359 kg/s (2,850,885 lbm/hr). The overall steam conditions produced by the existing Conesville #5 steam generator unit are shown in Table 2-3 below. To produce these conditions, the superheat circuit requires about 3.6% spray and the reheat circuit requires about 3.1% spray to maintain required steam outlet temperatures. The burner tilts are -10 degrees (the minimum value the customer uses). The boiler was fired with 15% excess air and the resulting boiler efficiency calculated for this case was 88.13% with an air heater exit gas temperature of 155°C (311°F).

Table 2-3: Boiler/Turbine Steam Flows and Conditions (Base Case)

		SHO	FWI	ECO	RHO	RHI
Mass Flow	(lbm/hr)	3131619	3131619	3017507	2850885	2850885
Pressure	(psia)	2535	3165	3070	590.8	656.5
Temperature	(Deg F)	1005	496.2	630	1005	607.7
Enthalpy	(Btu/lbm)	1459.7	483.2	652.8	1517.1	1290.4
Notes: SHO = Superheater Outlet; FWI = Feedwater Inlet; ECO = Economizer Outlet; RHO = Reheater Outlet; RHI = Reheater Inlet						

2.2.4 Steam Cycle Performance (Base Case)

The selected steam turbine energy and mass flow balance for Conesville #5, which provides the basis for developing the steam turbine performance calculations presented in this study is shown in Figure 2-4.

This turbine heat balance diagram, created by Black & Veatch, is a valves-wide-open, 5% over pressure case utilizing a condenser pressure of 6.35 cm Hga (2.5 in.-Hga) and a steam extraction for air heating of 6.3 kg/s (50,000 lbm/hr). Following general guidelines it is assumed that this diagram reflects the design maximum allowable flow conditions of the existing turbine.

In order to reflect the key performance parameters of the selected unit “as designed,” the Black & Veatch heat balance diagram was accurately re-modeled and the following adaptations to real mode operations were made:

- During normal operation no steam is required to feed the steam coil air heaters (6.3 kg/s or 50,000 lb/hr). Therefore, this extraction flow is set to zero.
- Reheat de-superheater spray water flow rate of 11 kg/s (85,827 lb/hr) is to be used as calculated in associated boiler performance computer simulation runs.

Keeping all other conditions constant, namely live steam (LS) pressure and temperature, reheat (RH) temperature and backpressure, the turbine base model reacts to the increase in RH spray (from zero to 11 kg/s or 85,827 lb/hr) and the switch-off of the extraction flow to the air pre-heaters (from 6.3 kg/s to 0 kg/s or from 50,000 lb/hr to 0 lb/hr) with a slight reduction in live steam flow due to the given swallowing capacity of the HP turbine (-0.26% in LS flow). In order to allow comparison with previous investigations the swallowing capacity was slightly re-adjusted to allow the nominal flow of 395 kg/s (3,131,619 lb/hr) at 5% overpressure.

The calculated power output applying this model showed some deficiency when compared to previous studies. This is partly due to the improved detailed modeling of the LP turbine performance, and to other differences between the previous and current models. Again, in order to allow comparison with previous investigations, the generator efficiency was adjusted in a way to allow easy comparison with previous results. Although the resulting generator efficiency may reach higher than typical values, this method allows easy comparison and simple adjustment between the two analyses, by just modifying the generator efficiency.

The final steam cycle for the Base Case is shown schematically in Figure 2-5. Figure 2-6 shows the associated Mollier diagram, which illustrates the process on enthalpy-entropy coordinates. The high-pressure turbine expands about 391 kg/s (3.1×10^6 lbm/hr) of steam at 175 bara (2,535 psia) and 538°C (1,000°F). Reheat steam is returned to the intermediate pressure turbine at 610 psia and 1,000°F. These conditions (temperature and pressure) represent the most common steam cycle operating conditions for existing utility-scale power generation systems in use today in the U.S. The condenser pressure used for the Base Case and all other cases in this study was 6.35 cm Hga (2.5 in. Hga). The steam turbine performance analysis results show the generator produces an output of 463,478 kWe and the steam turbine heat rate is about 8,200 kJ/kWh (7,773 Btu/kWh).

The key parameters describing the reference case are listed below:

Live steam pressure	2,535 / 175	psia / bara
Live steam temperature	1,000 / 538	°F / °C
Live steam flow	3,131,619 / 395	lbm/hr / kg/s
Steam for air pre-heating	0 / 0	lbm/hr / kg/s
RH de-superheating spray	85,827 / 11	lbm/hr / kg/s
Backpressure	2.5 / 6.35	In. Hg abs / cm Hg abs
Power output	463,478	kW




Figure 2-4: Selected Conesville #5 Turbine Heat Balance (basis for steam turbine modeling)




Figure 2-5: Steam Cycle Diagram and Performance (Base Case)




Figure 2-6: Steam Cycle Mollier Diagram (Base Case)

2.2.5 Flue Gas Desulfurization System Analysis (Base Case)

Figure 2-7 shows the process flow diagram for the existing Flue Gas Desulfurization System. The stream numbers in Figure 2-7 also correspond to stream numbers shown in Figure 2-3. The flue gas leaving the ID fan (Stream 7) is delivered to the absorber, which consists of a tray followed by a two-stage spray system. The incoming gas is saturated as it passes through the scrubbing slurry contained on the tray and through the two spray levels. The active component of the scrubbing slurry is calcium oxide (Stream 8a), which reacts with sulfur dioxide to form calcium bisulfite (Stream 9). The scrubbing slurry is circulated from the reagent feed tank that forms the base of the scrubber to the spray levels. The solids loading in the scrubbing slurry controls the blow down from the reaction tank to by-product disposal. The flue gas passes through chevron-type mist eliminators that remove entrained liquid before exiting the scrubber (Stream 10). The water utilized in spray washing the mist eliminators also serves as make-up (Stream 8b).

Table 2-4 identifies the assumptions that were made in predicting the FGD performance. Table 2-5 shows the gas constituents at the existing absorber inlet and outlet locations. Results show a CO_2/SO_2 mole ratio of 63 and an SO_2 removal efficiency of 94.9%, corresponding to a value of 104 ppmv at the outlet of the absorber.




Figure 2-7: Existing Flue Gas Desulfurization System Process Flow Diagram

Table 2-4: FGD System Analysis Assumptions

Quantity	Unit	Existing Absorber
Ca/SO	Mol Ratio	1.04
Solids	Wt. %	20
CaO	Wt. %	90
MgO	Wt. %	5
Inerts	Wt. %	5
Bypass Leakage	Wt. %	2.5
Liquid/Gas (L/G) Ratio	gpm/1000 acfm	55
SO ₂ Removal Efficiency		
APC	%	94.8
Absorber	%	97.2

Table 2-5: Existing FGD System Performance

Base Case						
Species	Existing Absorber Inlet			Existing Absorber Outlet		
	Mol/hr	Vol. %	Unit	Mol/hr	Vol. %	Unit
O ₂	4,469	3.14	Vol. %	4,461	2.91	Vol. %
N ₂	105,018	73.74	Vol. %	105,018	68.44	Vol. %
H ₂ O	12,863	9.03	Vol. %	24,228	15.79	Vol. %
CO ₂	19,743	13.86	Vol. %	19,720	12.85	Vol. %
SO ₂	315	2,212	ppmv	16	104	ppmv
SO ₂ Removal Efficiency, %					94.9	
CO ₂ /SO ₂ Mole Ratio		63				

3 THE SENSITIVITY OF PLANT PERFORMANCE AND ECONOMICS TO CO₂ CAPTURE LEVEL

This section describes the analysis of the impacts of CO₂ capture level. All CO₂ capture levels were done at the solvent regeneration energy level of 1,550 Btu/lbm-CO₂. As mentioned previously, the solvent regeneration energy level of 1,550 Btu/lbm-CO₂ represents the state of the art at the time of this study (ca. 2006). By investigating various levels of capture, the potential exists for identifying an economic optimum as well as simply quantifying the effect of this important variable on typical measures of plant performance and economic merit. Four CO₂ capture levels (90%, 70%, 50%, and 30%) are investigated in this study. These CO₂ capture levels are referred to as Cases 1, 2, 3, and 4, respectively and these four cases represent the primary case studies for this effort. Additionally, Concept A from the 2001 study was updated (costs and economics only) and is referred to as Case 5. This case used an amine system with ~96% CO₂ capture and solvent regeneration energy requirements of 2,350 Btu/lbm-CO₂.

The primary impacts are quantified in terms of plant electrical output reduction, thermal efficiency, CO₂ emissions, retrofit investment costs, and the incremental cost of generating electricity resulting from the addition of the CO₂ capture systems.

3.1 Study Unit Modifications and Definition of the Amine-Based CO₂ Capture Systems

This section provides most of the technical data for the retrofit cases comprising this study. It also discusses the complete retrofit to the power plant in terms of performance, equipment modifications and new equipment required. Each of the five study cases has equipment designed for the removal and recovery of CO₂ from the boiler flue gas using an amine scrubbing system. Plant material and energy balances are provided for the new and existing major systems and the equipment added or modified to complete the retrofit. The first subsection discusses the design basis used for the study. The second subsection (Section 3.1.2) discusses the boiler island and performance and equipment modifications. The third and fourth subsections discuss the amine-based CO₂ capture and compression systems. The advanced amine systems are discussed first (Section 3.1.3) followed by a review of the amine system from the previous study (Bozzuto et al., 2001) in Section 3.1.5. Finally a discussion of the steam/water cycle modifications and new equipment is presented in Section 3.1.6.

Cases 1-4 (90%, 70%, 50%, and 30% capture, respectively), which use the advanced amine systems, comprise the primary cases of the current study.

A fifth case (**Case 5**) is simply an update of “Concept A” from a previous study (Bozzuto et al., 2001). The update to this case consisted of simply escalating the investment and operating and maintenance costs from 2001 to 2006 \$U.S. and re-calculating the economic analysis such that comparisons between the current study results and the previous results could be done on an equivalent basis. The process design and equipment selections for Case 5/Concept A were not updated.

The current study differs from the previous study in several ways, as listed below:

- First, an advanced amine CO₂ scrubbing system is used for CO₂ removal from the flue gas stream. This advanced system requires significantly less energy for solvent regeneration. Solvent regeneration for this system requires about 3.6 MJ/Tonne CO₂ (3.1x10⁶ Btu/Ton CO₂) (~34% reduction). Additionally, the reboiler was operated at 3.1 bara (45 psia) as opposed to 4.5 bara (65 psia) in the previous study.
- Second, several CO₂ capture levels are investigated in this study (90%, 70%, 50%, and 30%). These are referred to as Cases 1, 2, 3, and 4 respectively in this study. Previously only one CO₂ capture level (96%) was investigated.
- Third, the current study differs from the previous study in that Alstom's steam turbine retrofit group developed a detailed analysis of the modified existing steam turbine. Previously, a more simplified analysis was used for the existing steam turbine.
- Another difference is that in the current study, significant quantities of heat rejected from the CO₂ capture/compression system are integrated with the steam/water cycle. Previously, heat integration was not used because the new CO₂ capture/compression system was located too far away (>1,500 ft) from the existing steam/water system.

3.1.1 Design Basis for CO₂ Capture Systems Retrofit Equipment and Performance Calculations (Cases 1-5)

This section describes many of the assumptions and data used for design of the equipment and in the calculation of process performance.

3.1.1.1 Site Data

Listed below is the summary of the site data used for equipment design:

- Plant is located in Conesville, Ohio, elevation 227 m (744 ft).
- Atmospheric pressure is 76 cm Hga (29.92 in. Hg).
- Dry bulb maximum temperature is 33°C (92°F) and minimum is -1°F.
- Wet bulb temperature for cooling tower design is 24°C (75°F).
- Average cooling tower water temperature is 27°C (80°F).
- Electric power is available from the existing facilities. Auxiliary power is provided through auxiliary transformers at 4,160-volt bus and is reduced down to 480 volts.
- 316L stainless steel is the preferred material of construction where the flue gas cooling systems contain halides and sulfur oxides.
- Pressure of product CO₂ is 139 bara (2,015 psia).
- For all plant performance calculations and material and energy balances the atmospheric conditions to be assumed are the standard conditions of 27°C /80°F, 1.014 bara/14.7 psia, 60% relative humidity).
- Condenser pressure used for all turbine heat balances is 2.5 in. Hga.

3.1.1.2 Fuel Analyses

Table 3-1 shows the coal analysis used for this study and Table 3-2 shows the natural gas analysis. Natural gas was used for desiccant regeneration in the CO₂ drying package.

Table 3-1: Coal Analysis

Proximate Analysis, Wt.%	
Moisture	10.1
Ash	11.3
Volatile Matter	32.7
Fixed Carbon	45.9
Total	100.0
Ultimate Analysis, Wt.%	
Moisture	10.1
Ash	11.3
H	4.3
C	63.2
S	2.7
N	1.3
O	7.1
Total	100.0
Higher Heating Value	
Btu/lbm	11,293
kJ/kg	26,266

Table 3-2: Natural Gas Analysis

Component	Vol.%	
Methane	93.9	
Ethane	3.2	
Propane	0.7	
n-butane	0.4	
Carbon Dioxide	1.0	
Nitrogen	0.8	
Total	100.0	
	LHV	HHV
kJ/kg	47805	53015
kJ/scm	35	39
Btu/lbm	20552	22792
Btu/scf	939	1040

Battery Limit Definition

Figure 3-1 shows a plot plan view of the existing Conesville Unit #5 with the major new equipment locations identified for Cases 1-4.

The new secondary SO₂ absorber for the modified FGD system is located just north and adjacent to the existing lime preparation and SO₂ scrubber equipment building in order to minimize the length of new ductwork and the associated draft losses.

The new amine plant absorbers are located ~30 m (100 feet) west of the Unit #5 stack to minimize the length of ductwork and the associated draft losses. The amine regenerators (Strippers) are located ~61 m (200 feet) south of Unit #5's steam turbine to minimize the length of low pressure steam piping and the associated pressure drops. The CO₂ compression, dehydration, and liquefaction facilities are located ~150 m (500 feet) south of the CO₂ strippers to minimize pressure drop in the connecting duct.

The CO₂ recovery and liquefaction equipment receives cooling water from the existing plant steam/water cycle (the existing plant cooling system). The availability of plant cooling water from the existing plant is the result of diverting steam that would have been used to generate power to the amine regeneration plant. This steam would have been condensed by water from the existing plant cooling tower but is now condensed by the amine regenerators.




Figure 3-1: AEP Conesville, Ohio, Electric Power Generation Station Site and New Equipment Locations (Cases 1-4)

The CO₂ recovery and liquefaction sections have their own control room and MCC. In addition to the flue gas, which serves as the feed to the unit, it must also receive the required utilities and chemicals. Soda ash - if available from existing facilities - can be used to maintain levels in this facility's day tanks. Otherwise it can be off-loaded from trucks into the day tanks. Diatomaceous earth used in the amine filtration equipment will be off-loaded on skids. The spent diatomaceous earth leaves the plant in drums. Amine reclaimer effluent will be collected in a tank truck parked at one end of the unit. Potable water for eye washes and cooling tower make-up water for hose down will be routed along side the CO₂ gas duct. Corrosion inhibitor, to provide oxygen resistance to the amine, will be provided directly from drums into an injection package.

The CO₂ capture and liquefaction sections are based on the following flue gas analysis, which is taken after the modified Flue Gas Desulfurization system (FGD). See Table 3-3.

Table 3-3: Flue Gas Analysis Entering Amine System (Cases 1-5)

Component	Mole %
O ₂	2.94
N ₂	68.31
H ₂ O	15.95
CO ₂	12.80
SO ₂	<10 ppmv
MW	28.59
T (°F)	136
P(psia)	14.7

3.1.1.3 CO₂ Product Specification

The CO₂ product specification is shown in Table 3-4 below. This specification was taken from the Dakota Gasification Company product specification for EOR (Dakota, 2005). A CO₂ product pressure of 139 bara (2,015 psia) is used in all the cases that follow.

Table 3-4: CO₂ Product Specification

Component	Mole %
O ₂	0.0100
N ₂	0.6000
H ₂ O	0.0002
CO ₂	96.000
H ₂ S	0.0001
Mercaptans	0.0300
CH ₄	0.3000
C ₂ + Hydrocarbons	2.0000

3.1.1.4 CO₂ Recovery Process Simulation Parameters

For Cases 1-4, which all use the advanced “state of the art” amine process, a commercial simulator called ProTreat[®] Version 3.3 was used to simulate the MEA process. Hysys[®] Version 2004.2 was used to simulate CO₂ compression and liquefaction systems.

The material balances for Case 5/Concept A were run on two process simulators: Hysim and Amsim. Amsim was used for the Absorption/Stripping systems while Hysim was used for the conventional systems as follows:

- Flue Gas feed Hysim
- Absorber and Stripper Amsim
- Compression liquefaction Hysim

The key process parameters used in the simulations are listed in Table 3-5 as well as data from a built and operating plant.

AES Corporation owns and operates a 200 STPD food grade CO₂ production plant in Oklahoma. This plant was designed and built by ABB Lummus Global as a part of the larger power station complex using coal-fired boilers. This plant was started up in 1990 and has been operating satisfactorily with lower than designed MEA losses. The key process parameters from the present designs for Cases 1-4, which use the advanced amine system, and Case 5/Concept A, which uses the Kerr/McGee ABB Lummus amine system, are compared with those from the built and operating AES plant (Barchas and Davis, 1992) in Table 3-5.

Table 3-5: Key Parameters for Process Simulation

Process Parameter	AEP Design Cases 1-4	AEP Design Case 5	AES Design
Plant Capacity, Ton/Day	9,350-3,120	9,888	200
CO ₂ in Feed, mol %	12.8	13.9	14.7
O ₂ in Feed, mol %	2.9	3.2	3.4
SO ₂ in Feed, ppmv	10 (Max)	10 (Max)	10 (Max)
Solvent	MEA	MEA	MEA
Solvent Conc. Wt%	30	20	15 (Actual 17-18%Wt)
Lean Loading, mol CO ₂ /mol amine	0.19	0.21	0.10
Rich Loading, mol CO ₂ /mol amine	0.49	0.44	0.41
Stripper Feed Temp, °F	205	210	194
Stripper Bottom Temp, °F	247	250	245
Feed Temp To Absorber, °F	115	105	108
CO ₂ Recovery, %	30-90	96	90 (Actual 96-97%)
Absorber Pressure Drop, psi	1	1	1.4
Stripper Pressure Drop, psi	0.7	0.6	4.35
Rich/Lean Exchanger Approach, °F	40	10	50
CO ₂ Compressor 1st /Stage Temp, °F	125	105	115
Liquid CO ₂ Temp, °F	82	82	-13
Steam Use, lbs Steam/ lb CO ₂ captured	1.67	2.6	3.45
Liquid CO ₂ Pressure, psia	2,015	2,015	247

3.1.1.5 Chemicals

This section provides data for the chemicals available on site and used by the CO₂ Recovery Unit. Conditions for liquid chemicals are specified at grade level.

Table 3-6: Soda Ash (Na₂CO₃) Requirements

Property	Pressure at B.L. Psia	Temperature °F
Normal	30	Ambient
Mechanical Design	65	125

- Available for reclaiming MEA
- The import and dilution facilities will be used to keep a day tank in the process area at desirable levels

3.1.1.6 Utilities

De-superheated steam at 3.2 bara (47 psia) is supplied to the amine regeneration system from a new low-pressure (LP) let down turbine that will operate in parallel with the existing LP turbine.

Steam for the new LP let down turbine comes from the existing intermediate pressure (IP) turbine outlet.

Steam:

Reboiler Source: Low-pressure steam from the new LP let down turbine outlet:

The steam leaving the let down turbine is used in the amine regeneration system reboilers for process heating.

Table 3-7: Process Steam Conditions (reboilers)

Property	Pressure at B.L. Psia	Temperature °F
Minimum (for process design)	43	272
Normal	45	274
Maximum	50	281
Mechanical Design	300	500

Reclaimer Source: Low-pressure steam from the existing IP turbine outlet:

The steam leaving the IP turbine is used in the amine system reclaimer for amine reclamation.

Table 3-8: Process Steam Conditions (reclaimer)

Property	Pressure at B.L. Psia	Temperature °F
Minimum (for process design)	85	316
Normal	90	320
Maximum	95	324
Mechanical Design	300	500

Water:

Cooling Water:

Source: Existing Cooling Towers

Table 3-9: Cooling Water Conditions

CW Supply	Pressure at B.L. (Psia)	Temperature °F
Minimum	60	70
Normal	65	80
Maximum	90	95
Mechanical Design	150	150

CW Return	Pressure at B.L. (Psia)	Temperature °F
Minimum		100
Normal	45	110
Maximum		135
Mechanical Design	150	175

Table 3-10: Surface Condensate (for amine make-up)

Property	Pressure at B.L. (Psia)	Temperature °F
Normal	135	110
Mechanical Design	175	200

Raw Water (Fresh Water):

Fresh water is distributed for general use at hose stations. The source of this water is the clarifier, which is used for cooling tower make-up. The capacity of the existing clarifier is sufficient for make up. Its quality is as follows:

Table 3-11: Raw Water (fresh water)

Components	Unit	Specifications
Si	ppm	22
Iron (as Fe)	ppm	0.18
Copper (as Cu)	ppm	0.05
Suspended Solids	ppm	15
Chlorine	ppm	100-180
Alkalinity	ppm	100
Na	ppm	100

Potable Water:

Potable water comes from public network for safety showers and eye washes and requirements are defined below:

Table 3-12: Potable Water

Property	Pressure at B.L. (Psia)	Temperature °F
Normal	115	Ambient
Mechanical Design	150	150

Air:

Plant air and instrument air requirements are defined below:

Table 3-13: Plant Air

Property	Pressure at B.L. Psia	Temperature °F
Normal	130	100
Mechanical Design	190	150

Dew point (at normal supply pressure - 40°C)

Table 3-14: Instrument Air

Property	Pressure at B.L. (Psia)	Temperature °F
Normal	130	100
Mechanical Design	190	150

Dew point (at normal supply pressure - 40°C)
Dust, oil and grease free

Fuel Gas:

Fuel gas (natural gas) requirements are defined below:

Table 3-15: LP Fuel Gas (natural gas)

Property	Pressure at OSBL (Psig)	Temperature °F
Normal	50	Ambient
Mechanical Design	100	150

Power Supply:

All of the required power (100%) for the CO₂ Recovery Unit will be provided by AEP either from the local supply or from the Ohio Grid.

Source: Conesville auxiliary power system at 4,160 volts or stepped down to 480 volts.

Table 3-16: Power Supply Requirements

Service	Voltage	Phase
Auxiliary plant power system	4160	3-phase
Large Motors	4160	3-phase
Small Motors	480	3-phase
Instruments, Lighting, etc.	480 / 230	3/1-phase

3.1.2 Boiler Island Modifications and Performance (Cases 1-5)

This section describes boiler island modifications and performance for the study unit. The modifications to the boiler island and the boiler island performance shown in this section are applicable to all five cases of this study.

3.1.2.1 Boiler Modifications

For this project the boiler scope is defined as everything on the gas side upstream of the FGD System. Therefore, it includes equipment such as the Conesville #5 steam generator, pulverizers, fans, ductwork, electrostatic precipitator (ESP), air heater, coal and ash handling systems, etc. Purposely not included in the boiler scope definition is the FGD system. The FGD system modifications are shown separately in Section 3.1.2.2.

For all the CO₂ capture options investigated in this study (Cases 1-5), Boiler Scope is not modified from the Base Case configuration.

3.1.2.2 Flue Gas Desulfurization System Modifications and Performance

The FGD system for all five cases is modified with the addition of a secondary absorber to reduce the SO₂ content to 10 ppmv or less as required by the amine system downstream.

Modified FGD System Process Description and Process Flow Diagram

The principle of operation of the FGD system is briefly described previously in Section 2.2.5 and is not repeated here. In the five capture cases, however, the entire flue gas stream leaving the existing FGD system absorber is supplied to the new secondary absorber and the flue gas stream leaving the secondary absorber provides the feed stream source for the new amine CO₂ absorption systems. Additional piping and ductwork is required as shown in Figure 3-2, which provides a simplified process flow diagram for the modified FGD system.




Figure 3-2: Modified FGD System Simplified Process Flow Diagram (Cases 1-5)

Modified FGD System Performance

Table 3-17 identifies the assumptions that were made in predicting the modified FGD system performance.

Table 3-17: Modified FGD System Assumptions (Cases 1-5)

Quantity	Unit	Existing Absorber	Secondary Absorber
Ca/S	Mol Ratio	1.04	1.04
Solids	Wt. %	20	20
CaO	Wt. %	90	90
MgO	Wt. %	5	5
Inerts	Wt. %	5	5
By-pass Leakage	Wt. %	2.5	0
Liquid/Gas (L/G) Ratio	gpm/1000 acfm	75	45
SO ₂ Removal Efficiency			
APC	%	94.8	93.0
Absorber	%	97.2	93.0

Table 3-18 indicates the modified FGD system performance by identifying gas constituents at the existing absorber inlet and secondary absorber outlet. Results show a CO₂/SO₂ mole ratio of 63 and an overall SO₂ removal efficiency of 99.7%, corresponding to a value of 6.5 ppmv SO₂ at the outlet of the secondary absorbers.

Table 3-18: Modified FGD System Performance (Cases 1-5)

Constituent	Existing Absorber Inlet			Secondary Absorber Outlet		
	lbm/hr	Mol/hr	Vol %	lbm/hr	Mol/hr	Vol %
O ₂	144817	4526	3.18	144566	4518	2.94
N ₂	2942220	105019	73.75	2942220	105019	68.31
H ₂ O	231294	12838	9.02	441924	24530	15.95
CO ₂	867210	19705	13.84	866102	19680	12.80
SO ₂	20202	315	0.22	87	1	0.00
SO ₂ , ppmv			2215			8.8
Total	4205743	142403	100	4394900	153748	100
SO ₂ Removal Efficiency, %		94.9			99.6	
CO ₂ /SO ₂ , Mole Ratio			62			

Modified FGD System Equipment Layout

Figure 3-3 shows the location of the new secondary SO₂ absorber. The new secondary absorber is a single vessel, which is 12.8 m (42 ft) in diameter, and is located just to the north and adjacent to the existing Conesville Unit #5 lime preparation and scrubber equipment building (i.e. label

#53 shown in green in the lower right part of Figure 3-3). This location minimizes the length of ductwork running from the existing FGD system to the new secondary SO₂ absorber and the ductwork length from the secondary SO₂ absorber to the new CO₂ absorbers. The blue lines indicate alterations, which must be made to the access roads located in this area.




Figure 3-3: New Secondary SO₂ Scrubber Location (Cases 1-4)


Secondary FGD Absorber Effluent:

The existing plant uses lime in its FGD system. In the cost estimate of this plant, it has been assumed that the existing plant disposal facilities can include the relatively small additional load of the secondary regenerator.

3.1.2.3 Boiler Island Material and Energy Balance (Cases 1-5)

A simplified process flow diagram for the modified study unit boiler island is shown in Figure 3-4. This simplified diagram is applicable to each of the five cases included in this study. The operation and performance of the existing boiler and electrostatic precipitator (ESP) systems are identical to the Base Case for all five capture cases investigated and are not affected by the

addition of the MEA-based CO₂ removal systems. The FGD system is modified for each of the five CO₂ removal cases with the addition of a secondary absorber to reduce the SO₂ content to less than 10 ppmv. The FGD system modification is described in Section 3.1.2.2.



Material Flow Stream Identification

1 Raw Coal to Pulverizers	9 FGD System Solids to Disposal	17 Mixed Primary Air to Pulverizers
2 Air Infiltration Stream	10 Flue Gas to Stack	18 Pulverized Coal and Air to Furnace
3 Flue Gas from Economizer to Air Heater	11 Air to Primary Air Fan	19 Secondary Air to Forced Draft Fan
4 Flue Gas Leaving Air Heater to ESP	12 Primary Air to Steam Coil Air Heater	20 Secondary Air to Steam Coil Air Heater
5 Flyash Leaving ESP	13 Primary Air to Air Heater	21 Secondary Air to Air Heater
6 Flue Gas Leaving ESP to Induced Draft Fan	14 Air Heater Leakage Air Stream	22 Heated Secondary Air to Furnace
7 Flue Gas to Flue Gas Desulfurization System	15 Tempering Air to Pulverizers	23 Bottom Ash from Furnace
8 Lime Feed to FGD System	16 Hot Primary Air to Pulverizers	

Figure 3-4: Simplified Boiler Island Gas Side Process Flow Diagram for CO₂ Separation by Monoethanolamine Absorption (Cases 1-5)

The overall material and energy balance for the boiler island system shown above in Figure 3-4 is provided in Table 3-19. The flue gases leaving the modified FGD system are ducted to the new MEA system where various levels (depending on the case in question) of the CO₂ is removed, compressed, and liquefied for usage or sequestration. The remaining flue gases leaving the new MEA system after removal of carbon dioxide (consisting of primarily oxygen, nitrogen, water vapor, and a relatively small amount of sulfur dioxide and carbon dioxide) are discharged to the atmosphere through the existing Unit 5/6 common stack.

Streams 24, 25, and 26 of Table 3-19 are purposely not filled in. These streams are dependent on the CO₂ recovery level and the attributes of these streams are defined in Section 3.1.4.1 for Cases 1-4 and Section 3.1.5.2 for Case 5.



Table 3-19: Gas Side Boiler Island Material and Material Energy Balance (Cases 1-5)

Constituent	(Units)	1	2	3	4	5	6	7	8	9	10	11	12	13
O ₂	(lbm/hr)	26586	42147	101097	144817		144817	144817	5628		144566	203237	203237	112918
N ₂	"	4868	139626	2797385	2942220		2942220	2942220			2942220	673283	673283	374075
H ₂ O	"	37820	2357	228849	231294		231294	231294	258954	48234	441924	11365	11365	6314
CO ₂	"			867210	867210		867210	867210			8661102			
SO ₂	"			20202	20202		20202	20202			87			
H ₂	"	16102												
Carbon	"	236665												
Sulfur	"	10110												
Ca	"								13087					
Mg	"								613					
MgO	"									509				
MgSO ₃	"									1251				
MgSO ₄	"									76				
CaSO ₃	"									34395				
CaSO ₄	"									2051				
CaCO ₃	"									2520				
Ash/Inerts	"	42313		33851	33851	33851			1017	1017				
		Raw Coal	Leakage Air	Flue Gas to AH	Flue Gas to ESP	Flyash	Flue Gas to ID Fan	Flue Gas to FGD	Lime Slurry	FGD Disposal	Flue Gas to CO ₂ Sep	Pri Air to PA Fan	PA from PAA Fan	Pri Air to AH
Total Gas	(lbm/hr)		184130	4014743	4205743		4205743	4205743			4394900	887885	887885	493308
Total Solids	"	374455		33851	33851	33851			20346	41819				
Total Flow	"	374455	184130	4048594	4239594	33851	4205743	4205743	279300	90143	4394900	887885	887885	493308
Temperature	(Deg F)	80	80	706	311	311	311	325	80	136	136	80	92	92
Pressure	(Psia)	14.7	14.7	14.6	14.3	14.7	14.2	15	14.7	14.7	14.7	14.7	15.6	15.6
h_{sensible}	(Btu/lbm)	0.000	0.000	161.831	57.924	57.750	57.924	61.384	0.000	14.116	14.543	0.000	2.899	2.899
Chemical	(10 ⁶ Btu/hr)	4228.715												
Sensible	(10 ⁶ Btu/hr)	0.000	0.000	655.007	245.567	1.955	243.612	258.166	0.000	3.314	63.916	0.000	2.574	1.430
Latent	(10 ⁶ Btu/hr)	0.000	2.475	240.291	242.858	0.000	242.858	242.858	0.000	0.000	464.020	11.933	11.933	6.630
Total Energy⁽¹⁾	(10 ⁶ Btu/hr)	4228.715	2.475	895.298	488.425	1.955	486.470	501.024	0.000	3.314	527.936	11.933	14.507	8.060

Constituent	(Units)	14	15	16	17	18	19	20	21	22	23	24	25	26
O ₂	(lbm/hr)	43720	90319	66680	156999	183585	641283	641283	641283	643801				
N ₂	"	144835	299208	220899	520107	524975	2124443	2124443	2124443	2132785				
H ₂ O	"	2445	5051	3729	8779	46599	35860	35860	35860	36001				
CO ₂	"													
SO ₂	"													
H ₂	"					16102								
Carbon	"					236655								
Sulfur	"					10110								
Ca	"													
Mg	"													
MgO	"													
MgSO ₃	"													
MgSO ₄	"													
CaSO ₃	"													
CaSO ₄	"													
CaCO ₃	"													
Ash/Inerts	"					42313								
		Air Htr Lkg Air	Temperin g Air	Hot Pri Air	Mixed Pri Air	Coal-Pri Air Mix	Sec Air to FD	Sec air to SCAH	Sec Air to AH	Hot Sec Air	Bottom Ash	CO ₂ to Comp	CO ₂ Product	Vent Stream
Total Gas	(lbm/hr)	191000	394577	291308	685885		2801587	280157	280157	281157				
Total Solids	"										8463			
Total Flow	"	191000	394577	291308	685885	1060340	2801587	280157	280157	2812587	8463			
Temperature	(Deg F)	92	92	666	339		80	86.4	86.4	616.1	2000			
Pressure	(Psia)	15.6	15.6	15.6	15.6	15.0	14.7	15.2	15.1	14.9	14.7			
h_{sensible}	(Btu/lbm)	2.899	2.899	145.249	63.358		0.000	1.549	1.549	132.582	480.000			
Chemical	(10 ⁶ Btu/hr)					4228.715								
Sensible	(10 ⁶ Btu/hr)	0.554	1.144	42.312	43.456		0.000	4.341	4.341	372.898	4.062			
Latent	(10 ⁶ Btu/hr)	2.567	5.303	3.915	9.218		37.653	37.653	37.653	37.801	0.000			
Total Energy⁽¹⁾	(10 ⁶ Btu/hr)	3.121	6.447	46.227	52.674	4281.389	37.653	41.994	41.994	410.699	40.062			

(1) Energy Basis: Chemical based on Higher Heating Value (HHV); Sensible energy above 80°F; Latent based on 1050 Btu/lbm of water vapor.

3.1.3 Design and Performance of Advanced Amine CO₂ Removal Systems (Cases 1-4)

This section describes the advanced amine CO₂ Removal Systems used in this study. The amine technology used in this study is similar to existing advanced MEA amine processes. This process tolerates oxygen in the flue gas as well as a limited amount of sulfur dioxide. The process uses an oxygen-activated corrosion inhibitor, which also inhibits amine degradation. Low corrosion rates and minimal loss of the circulating solvent used to absorb CO₂ promotes economical and reliable operation. This study is based on the flue gases coming from the AEP's Conesville Unit #5 flue gas desulfurization system, shown later in this section.

ABB Lummus was responsible for the design, performance, and costs for the amine systems. The designs were based on information contained in the open literature (Bailey and Feron, 2005; Chapel and Mariz, 1999; Choi et al., 2005; Choi et al., 2004; Chinn et al., 2004; IEA, 2004) as well as their own proven experience (Barchas and Davis, 1992). The simulation tools used were ProTreat[®] Version 3.3 and Hysys[®] Version 2004.2. The resulting regeneration energy from this simulation was 1,550 Btu/lbm-CO₂.

There are four CO₂ capture cases using an advanced amine CO₂ removal systems investigated in this study. The four cases are described as follows:

- **Case 1:** 90% Capture
- **Case 2:** 70% Capture
- **Case 3:** 50% Capture
- **Case 4:** 30% Capture

An additional fifth case, also using the advanced amine system was originally planned to be evaluated in this study. This case was defined to be equivalent in CO₂ emissions to a NGCC plant without CO₂ capture, with CO₂ emissions of 362 g/kWh (0.799 lbm/kWh). Because Case 2 (70% CO₂ capture) of the current study was found to yield approximately this same amount of CO₂ emissions 354 g/kWh (0.78 1 lbm/kWh), the team decided not to evaluate this additional case.

The 90% recovery case (Case 1) processes the entire flue gas stream and adjusts the available process variables within the advanced MEA system to achieve 90% recovery in the absorber. The reduced recovery rates for Cases 2, 3, and 4 can be achieved by two methods. The 70%, 50%, and 30% recovery levels for Cases 2, 3, and 4 respectively are achieved by treating only part of the flue gas stream in the absorber and bypassing the remainder of the flue gas stream directly to the stack. The bypassing method allows the absorber and amine regeneration system to be smaller and less costly. The alternate method would involve treating the entire flue gas stream in the absorber and adjusting the available MEA process parameters to achieve a reduced recovery. This method was not chosen because it requires a larger absorber and a larger amine regeneration system, which was found to be significantly more costly than the selected flue gas bypass method.

3.1.4 Process Description - CO₂ Removal, Compression, and Liquefaction System (Cases 1-4)

The following process description applies to all the advanced amine cases in this study (i.e., Cases 1-4). The CO₂ Recovery Plant removes CO₂ from exhaust gas of the existing Conesville

#5 coal-fired steam boiler. The treated flue gas is returned to the existing stack. The captured CO₂ is compressed, dehydrated, and then liquefied in preparation for transport to a consumer.

Since the flue gas conditioning equipment flow scheme includes an existing blower, the pressure profile of the existing power generation equipment does not change from today's operation. To force the flue gas from the secondary flue gas desulfurizer (FGD) through the CO₂ Absorber, the pressure of the flue gas after the FGD is boosted ~0.1 bar (1.5 psi) by a motor driven fan. As the power consumption of the fan is considerable, the location of the absorbers is as close as possible to the new secondary FGD system and the existing stack, to minimize draft loss. The blower will run at constant speed. Each blower, provided as part of the boiler flue gas conditioning equipment, is equipped with its own suction and a discharge damper operated pneumatically. The suction damper controls the suction pressure to adjust for the flow variation resulting from the power plant performance. The suction pressure control will avoid any surges to blower. The discharge damper is an isolation damper.

Direct Contact Cooling

The following description refers to Figure 3-5. The direct contact cooler (DCC) Flue Gas Cooler is a packed column where hot 58°C (136°F) flue gas is brought into intimate contact with a recirculating stream of cool water. Physically the DCC and Absorber have been combined into a single compartmentalized tower. The lower compartment is designed to support the Absorber so that the top head of the DCC is the bottom head of the Absorber. Effectively, this dividing head acts as a chimney tray with a number of upward extending chimneys, which provide passages so the flue gas may flow directly from the DCC into the Absorber.

Theoretically, a direct contact cooler is capable of cooling the gas to a very close approach in a short bed. When the hot gas enters the DCC, it contains water but is highly superheated. At the bottom end of the bed, the gas quickly cools down to a temperature called the "Adiabatic Saturation Temperature" (AST). This is the temperature the gas reaches when some of its own heat content has been used to vaporize just the exact amount of water to saturate the gas.

Up to the point when the AST is reached, the mass flow of the gas stream increases due to evaporation of water. At the AST, water begins to condense as the gas is cooled further. As the gas travels up the column and is cooled further, more water is condensed. This internal refluxing increases the vapor/liquid (V/L) traffic at the bottom end of the bed significantly beyond the external flows and must be considered in the hydraulic design.

The water stream leaving the bottom of the DCC contains the water fed to the top as well as any water, which has condensed out of the flue gas. The condensed water may be somewhat corrosive due to sulfur and nitrogen oxides, which are present in the flue gas. Therefore, instead of using the condensate in the process, it will be blown down from the system. For the DCC to be effective, the temperature of the leaving water must always be lower than the AST.

The DCC Water Pump circulates most of the water leaving the bottom of the DCC back to the top of the direct contact cooler. However, before sending it back to the column, the water stream is first filtered in the DCC Water Filter and then cooled in DCC Water Cooler E-108. The temperature of the cooled water is controlled by a cascade loop, which maintains a constant flue gas exit temperature of 46°C (115°F).

Filtration is necessary to remove any particulate matter, which may enter the DCC in the flue gas. The blow down is taken out after the filter but before the cooler and mixed into the return water of cooler E-108. This way the cooler does not have to handle the extra duty, which would otherwise be imposed by the blow down.

Absorption

The following description refers to Figure 3-5.

CO₂ Absorber:

From the DCC the cooled flue gas enters the bottom of the CO₂ Absorber and flows up the tower counter-current through a stream of 30-wt% MEA solution. The lean MEA solution (LAM) enters the top of the column and heats up gradually as CO₂ is absorbed. By the time the stream leaves the bottom of the tower it has gained approximately 11°C (20°F). The tower has been designed to remove 90% of the CO₂ from the incoming gas. The CO₂ loading in LAM is approximately 0.19 mol CO₂/mol MEA, while the loading of the rich amine leaving the bottom is approximately 0.49 mol CO₂/mol MEA.

To maintain water balance in the process, the temperature of the LAM feed should be close to that of the feed gas stream. Thus, with feed gas temperature fixed at 46°C (115°F), the temperature of the LAM stream must also be close to 46°C (115°F), preferably within 5.5°C (10°F). If the feed gas comes in at a higher temperature than the LAM, it brings in excess moisture, which condenses in the Absorber and becomes excess water. Unless this water is purged from the system, the concentration of MEA will decrease and the performance of the system will suffer. If, on the other hand, the gas feed is colder than the LAM, it heats up in the tower and picks up extra moisture, which is then carried out of the system by the vent gas. The result is a water deficiency situation because more water is removed than comes into the system.

For the reasons explained above, it is essential that both the temperature of the flue gas and that of the LAM be accurately controlled. In fact, it is best to control one temperature and adjust the temperature of the other to maintain a fixed temperature difference.

The rich MEA solvent solution from the bottom of the absorber at 52°C (125°F) is heated to 96°C (205°F) by heat exchange with lean MEA solvent solution from the stripping column and then fed near the top of the stripping column. The lean MEA solvent solution is partially cooled by heat exchange with rich MEA and is further cooled to 4°C (105°F) by exchange with cooling water and fed back to the absorber to complete the circuit.

The CO₂ absorber contains two beds of structured packing and a “Wash Zone” at the very top of the column to reduce water and MEA losses. A liquid distributor is provided at the top of each bed of structured packing. There are several reasons for selecting structured packing for this service:

- Very low pressure drop which minimizes fan horsepower
- High contact efficiency / low packing height
- Good tolerance for mal-distribution in a large tower
- Smallest possible tower diameter
- Light weight

At the bottom of the tower, there is the equivalent of a chimney tray, which serves as the bottom sump for the absorber. Instead of being flat like a typical chimney tray, it is a standard dished head with chimneys. The hold-up volume of the bottom sump is sufficient to accept all the liquid held up in the packing both in the CO₂ absorber and in the Wash Zone. The Rich Solvent Pumps take suction from the chimney tray.

Absorber Wash Zone:

The purpose of the Wash Zone at the top of the tower is to minimize MEA losses both due to mechanical entrainment and also due to evaporation. This is achieved by recirculating wash water in this section to scrub most of the MEA from the lean gas exiting the Absorber. The key to minimizing MEA carryover is a mist separator pad between the wash section and the Absorber. The Wash Water Pump takes water from the bottom of the wash zone and circulates it back to the top of the wash zone.

The key to successful scrubbing is to maintain a low concentration of MEA in the circulating water. As MEA concentration is increased, the vapor pressure of MEA becomes higher and, consequently, the MEA losses are higher. Therefore, relatively clean water must be fed to the wash zone as make-up while an equal amount of MEA laden water is drawn out. A seal accomplishes this and maintains a level on the chimney tray at the bottom of the wash section. Overflow goes to the main absorber. Make-up water comes from the overhead system of the Solvent Stripper.

The lean flue gas leaving the wash zone is released to the existing flue gas stack at atmospheric pressure.

Rich/Lean Solvent Exchanger - E-100:

The Rich/Lean Solvent Exchanger is a plate type exchanger with rich MEA solution on one side and lean MEA solution on the other. The purpose of the exchanger is to recover as much heat as possible from the hot lean solvent at the bottom of the Solvent Stripper by heating the rich solvent feeding the Solvent Stripper. This reduces the duty of the Solvent Stripper Reboiler. This exchanger is the single most important item in the energy economy of the entire CO₂ Recovery Unit.

Lean Amine Cooler – E-104:

A plate frame water-cooled exchanger was added on the lean amine stream leaving the Rich/Lean Solvent Exchanger to reduce the plot space requirement and overall cost of the project. The lean amine cooler further cools the lean amine coming from the rich/lean exchanger E-100 from 66°C to 41°C (150°F to 105°F) with plant cooling water. Cooled amine from E-104 flows to the top of the absorber.

Stripping

Solvent Stripper:

The following description refers to Figure 3-5. The purpose of the Solvent Stripper is to separate CO₂ from the CO₂ rich solvent. The Solvent Stripper contains a top section with trays and a bottom section with structured packing. The top section of the stripper is a water wash zone designed to limit the amount of solvent (MEA) vapors entering the stripper overhead system.

The hot wet vapors from the top of the stripper contain the recovered CO₂, along with water vapor, and a limited amount of solvent vapor. The overhead vapors are cooled by water in the Solvent Stripper Condenser E-105, which is commonly called the reflux condenser, where most of the water and solvent vapors condense. The CO₂ does not condense. The condensed overhead liquid and CO₂ are separated in a reflux drum. CO₂ flows to the CO₂ Compression section on pressure control and the condensed liquid (called reflux) is returned to the top of the stripper. Rich solvent is fed to the stripper at the top of the packed section. As the solvent flows down over the packing to the bottom, hot vapor from the reboiler strips the CO₂ from the solution. The final stripping action occurs in the reboiler E-106.

Solvent Stripper Reboiler E-106:

The steam-heated reboiler consists of several plate frame thermo-siphon type exchangers arranged concentrically around the base of the Stripper. Circulating flow of the solvent through the reboiler is driven by gravity and density differences.

Solvent Reclaimer:

The Solvent Reclaimer is a horizontal heat exchanger. Certain acidic gases present in the flue gas feeding the CO₂ absorber form compounds with the MEA in the solvent solution, which cannot be regenerated by application of heat in the solvent stripper reboiler. These materials are referred to as “Heat Stable Salts” (HSS). A small slipstream of the lean solvent from the discharge of the Solvent Stripper Bottoms Pump is fed to the Solvent Reclaimer. The reclaimer restores the MEA usefulness by removing the high boiling and non-volatile impurities, such as HSS, suspended solids, acids, and iron products from the circulating solvent solution. Soda ash is added into the reclaimer to free MEA from its bond with sulfur oxides by its stronger basic attribute. This allows the MEA to be vaporized into the circulating mixture, minimizing MEA loss. This process is important in reducing corrosion, and fouling in the solvent system. The reclaimer bottoms are cooled intermittently with cooling tower water prior to being loaded on a tank truck.

Solvent Stripper Condenser E-105:

The solvent stripper condenser is a series water-cooled plate frame type heat exchangers. The purpose of the condenser is to completely condense all components contained in the overhead vapor stream leaving the stripper which are condensable under the operating conditions. Boiler feed water at 43°C (110°F) (integrated with the steam/water cycle) and 27°C (80°F) cooling tower water are used as the condensing medium. Components that do not condense include nitrogen, carbon dioxide, oxygen, nitrogen oxides and carbon monoxide. The water vapor and MEA solvent vapor will condense, and the condensed water will dissolve a small amount of carbon dioxide. This exchanger uses some of the cooling water capacity freed up due to the reduced load on the surface condensers of the existing Conesville #5 power plant.

Solvent Stripper Reflux Drum:

The reflux drum provides space and time for the separation of liquid and gases and provides liquid hold-up volume for suction to the reflux pumps.

Solvent Stripper Reflux Pump:

This pump takes suction from the reflux drum and discharges on flow control to the stripper top tray as reflux on flow control.

Semi-Lean Flash Drum:

Rich amine is pumped from the bottom of the absorber and is split into two streams. The first stream is heated in cross exchangers E-102 and E-100 with hot stripper bottoms and the preheated rich amine flowing to the stripper. The other part of the stream is flashed to produce steam, which is used in the stripping column. The Semi-Lean Flash Drum reduces the amount of steam needed in the reboiler. The rich amine prior to being flashed is heated in a pair of exchangers. The first is the semi-lean cooler E-101, where it is cross-exchanged with hot flashed semi-lean amine from the flash drum. The second is the flash preheater E-102, which is heated by hot stripper bottoms on its way to the amine cross exchanger.

Solvent Filtration Package:

The pre-coat filter is no ordinary filter; it is a small system. The main component is a pressure vessel, which has a number of so called “leaves” through which MEA flows. The leaves have a thin (~0.3 cm or 1/8 inch) coating of silica powder, which acts to filter any solids. For the purposes of such application the power is called “filter aid.”

To cover the leaves with the filter aid, the filter must be “pre-coated” before putting it into service. This is accomplished by mixing filter aid in water in a predetermined ratio (typically 10 wt%) to prepare slurry. This takes place in an agitated tank. A pump, which takes its suction from this tank, is then operated to pump the slurry into the filter. Provided the flow rate is high enough, the filter aid is deposited on the leaves while water passes through and can be recycled back to the tank. This is continued until the water in the tank becomes clear, indicating that all the filter aid has been transferred.

The volume of a single batch in the tank is typically 125% of the filter volume because there must be enough to fill the vessel and have some excess left over so the level in the tank is maintained and circulation can continue. In this design, water from the Stripper overhead is used as make-up water to fill the tank. This way the water balance of the plant is not affected.

During normal operation, it is often beneficial to add so called “body” which is the same material as the pre-coat but may be of different particle size. The body is also slurried in water but is continually added to the filter during operation. This keeps the filter coating porous and prevents rapid plugging and loss of capacity. As the description suggests, an agitated tank is needed to prepare the batch. A metering pump is then used to add the body at preset rate to the filter.

When the filter is exhausted (as indicated by pressure drop), it is taken off line so the dirty filter aid can be removed and replaced with fresh material. To accomplish this, the filter must be drained. This is done by pressurizing the filter vessel with nitrogen and pushing the MEA solution out of the filter. After this, the filter is depressurized. Then, a motor is started to rotate the leaves so a set of scrapers will wipe the filter cake off the leaves. The loosened cake then falls off and into a conveyor trough in the bottom of the vessel. This motor-operated conveyor then pushes the used cake out of the vessel and into a disposal container. The rejected cake has the consistency of toothpaste. This design is called “dry cake” filter and minimizes the amount of waste produced.

For this application, about 2% of the circulating MEA will be forced to flow through the filter. A Filter Circulating Pump draws the liquid through the filter. The advantage of placing the pump on the outlet side of the filter is reduced design pressure of the filter vessel and associated piping.

In spite of the restriction on its suction side, ample NPSH is still available for the pump. Flow is controlled downstream of the pump.

The MEA is also passed through a bed of activated carbon to reduce residual hydrocarbons. The presence of hydrocarbons in the amine can cause foaming problems. This study assumes that the bed is changed four times per year.

CO₂ Compression, Dehydration, and Liquefaction

The following description refers to Figure 3-6. CO₂ from the solvent stripper reflux drum, saturated with water, is compressed in a three-stage centrifugal compressor using 43°C (110°F) boiler feed water for interstage and after compression cooling. The heated boiler feedwater is returned to the existing feedwater system of the steam/water cycle, and this heat integration helps improve overall plant efficiency. The interstage coolers for first and second stage are designed to supply 52°C (125°F) CO₂ to the compressor suction.

Most of the water in the wet CO₂ stream is knocked out during compression and is removed from intermediate suction drums. A CO₂ dryer is located after the third stage to meet the water specifications in the CO₂ product. The water-free CO₂ is liquefied after the third stage of compression at about 13 bara (194 psia) by the use of a propane refrigeration system and is further pumped with a CO₂ pump to the required battery limit pressure of 139 bara (2,015 psia).

The propane refrigeration system requires centrifugal compressors, condensers, economizers, and evaporators to produce the required cold. The centrifugal compressor is driven by an electric motor and is used to raise the condensing temperature of the propane refrigerant above the temperature of the available cooling medium, which in this study is 110°F boiler feed water. The condenser is used to cool and condense the discharged propane vapor from the compressor back to its original liquid form. The economizer, which improves the refrigerant cycle efficiency, is designed to lower the temperature of the liquid propane by flashing or heat exchange. The evaporator liquefies the CO₂ vapor by transferring heat from the CO₂ vapor stream to the boiling propane refrigerant.

CO₂ Dryer

The following description refers to Figure 3-6. The purpose of the CO₂ dryer is to reduce the moisture content of the CO₂ product to a value less than pipeline transport specifications. The dryer package includes four dryer vessels loaded with Type 3A molecular sieve, three of which are in service while one is being regenerated or is on standby. The package also includes a natural gas fired regeneration heater and an air-cooled regeneration gas cooler. A water knockout, downstream from the gas cooler, removes the condensed water. The dryers are based on a 12-hour cycle.

The dryer is located on the discharge side of the third stage of the CO₂ Compressor. The temperature of the CO₂ stream entering the dryer is 125°F.

Once a bed is exhausted, it is taken off line and a slipstream of effluent from the on line beds is directed into this dryer after being boosted in pressure by a compressor. Before the slipstream enters the bed, which is to be regenerated, it is heated to a high temperature. Under this high temperature, moisture is released from the bed and carried away in the CO₂ stream. The

regeneration gas is then cooled to the feed gas temperature to condense any excess moisture. After this, the regeneration gas stream is mixed with the feed gas upstream of the third stage knockout drum.

All the regeneration operations are controlled by a programmable logic controller (PLC), which switches the position of several valves to direct the flow to the proper dryer. It also controls the regeneration compressor, heater, and cooler.

Corrosion Inhibitor

Corrosion inhibitor chemical is injected into the process to help control the rate of corrosion throughout the CO₂ recovery plant system. The inhibitor is stored in a tank and is injected into the system via an injection pump (not shown in Figure 3-6). The pump is a diaphragm-metering type pump.

Process Flow Diagrams

The process flow diagram for the CO₂ recovery section is shown in Figure 3-5 and for the CO₂ compression, dehydration and liquefaction process is shown in Figure 3-6.




Figure 3-5: Advanced MEA Process Flow Diagram (Cases 1-4)




Figure 3-6: CO₂ Compression

3.1.4.1 Overall Material and Energy Balance - CO₂ Removal, Compression, and Liquefaction System (Cases 1-4)

This section provides material and energy balances for the CO₂ Removal and Compression Systems for Cases 1-4. Additionally, various other common parameters of comparison are provided for these systems.

Advanced Amine Plant Performance

Table 3-20 and Table 3-21 compare the amine plant material balance and energy demands, respectively, for each recovery case. The material balance shown in Table 3-20 is for the complete amine plant, as is Table 3-21. The CO₂ recovery cases below 90% (Cases 2, 3, and 4) are accomplished by combining the flue gas stream that bypasses the absorber, with the flue gas stream treated by the absorber, as shown in Figure 3-7. Even though the absorber and stripper recovery efficiencies are the same for each case, the net CO₂ recovery is lower due to the bypass.




Figure 3-7: Flue Gas Bypass System used for 70%, 50%, and 30% CO₂ Absorption Cases (Cases 2, 3, and 4)

Table 3-20: Overall Material Balance for Amine Plants (Cases 1-4; 90%-30% CO₂ Capture)

Amine Plant	Case 1 (90% Capture)	Case 2 (70% Capture)	Case 3 (50% Capture)	Case 4 (30% Capture)
Feed to Absorber	moles/hr	moles/hr	moles/hr	moles/hr
CO ₂	19680	15306	10934	6560
H ₂ O	24530	19078	13628	8176
N ₂	105020	81682	58344	35006
O ₂	4518	3514	2510	1506
Total	153746	119582	85416	51248
From Top of Absorber	moles/hr	moles/hr	moles/hr	moles/hr
CO ₂	1962	1552	1102	650
H ₂ O	36460	28354	20252	12150
N ₂	105016	81678	58342	35004
O ₂	4518	3514	2510	1506
Total	147954	115098	82204	49312
Absorber Bypass*	moles/hr	moles/hr	moles/hr	moles/hr
CO ₂	0	4374	8746	13120
H ₂ O	0	5452	10902	16354
N ₂	0	23338	46676	70014
O ₂	0	1004	2008	3012
Total	0	34166	68330	102498
To Stack	moles/hr	moles/hr	moles/hr	moles/hr
CO ₂	1962	5924	9846	13770
H ₂ O	36460	33806	31154	28504
N ₂	105016	105016	105018	105018
O ₂	4518	4518	4518	4518
Total	147954	149264	150536	151810
Acid Gas	moles/hr	moles/hr	moles/hr	moles/hr
CO ₂	17720	13766	9822	5906
H ₂ O	1042	810	578	348
N ₂	0	0	0	0
O ₂	0	0	0	0
Total	18762	14576	10400	6252
	moles/hr	moles/hr	moles/hr	moles/hr
H ₂ O Blow Down	10714	8284	5860	3468

Note: "Bypass" method used to capture <90% CO₂

Table 3-21: Energy and Process Demands (Cases 1-4; 90%-30% CO₂ Capture)

Total Plant	Case 1 (90% Capture)	Case 2 (70% Capture)	Case 3 (50% Capture)	Case 4 (30% Capture)
CO ₂ Captured, Metric TPD	8,481	6,595	4,706	2,829
CO ₂ Captured, Short TPD	9,349	7,270	5,187	3,119
CO ₂ captured, 10 ⁶ -scfd	161.2	125.4	89.5	53.8
H ₂ O Makeup to Amine Plant, gpm	427	331	235	140
H ₂ O Makeup to Cooling Tower, gpm	2,091	1,627	1,161	690
MEA Concentration, wt%	30.0%	30.0%	30.0%	30.0%
CO ₂ Absorbed in the Absorber, %	90.0%	89.9%	89.8%	90.0%
Stripper Energy, Btu/lbm-CO ₂ Absorbed	1,548	1,548	1,551	1,549
Solvent requirement, Gal MEA/lbm CO ₂ Absorbed	2.042	2.044	2.047	2.042
Steam requirement, lbm/lbm CO ₂ Absorbed	1.667	1.669	1.669	1.667
Lean Load, Mole CO ₂ /Mole MEA	0.188	0.190	0.190	0.186
Absorber Diameter, Ft	34.1	30.0	25.4	27.8
Stripper Diameter, Ft	22.0	19.3	16.3	17.9
Steam to Stripper, 10 ³ -lbm/h	1,300	1,010	722	433
Cooling Water (CW), gpm	69,694	54,217	38,693	22,991
Auxiliary power, Total kW Demand	54,939	42,697	30,466	18,247
Auxiliary power, kW w/o CO ₂ Compression	11,802	9,169	6,549	3,866
Auxiliary power, kWh/Short Ton (ST) CO ₂	141	141	141	140
Auxiliary power, kWh/ST CO ₂ w/o CO ₂ Compression	30	30	30	30
Cooling Water, Gallons/ST CO ₂	10,735	10,739	10,742	10,615
Cooling Water, Cubic Meters/Metric Ton CO ₂	46	46	46	45

CO₂ Compression and Liquefaction Plant Performance

This section provides system schematics, material and energy balances, as well as heat duties and power requirements for the Compression and Liquefaction systems for Cases 1-4.

Table 3-22 shows the CO₂ compression and liquefaction system material and energy balance for Case 1 with 90% CO₂ recovery. Figure 3-8 shows the compression and liquefaction system schematic with heat duties and power requirements indicated.

Table 3-23 shows the CO₂ compression and liquefaction system material and energy balance for Case 2 with 70% CO₂ recovery. Figure 3-9 shows the compression and liquefaction system schematic with heat duties and power requirements indicated.

Table 3-24 shows the CO₂ compression and liquefaction system material and energy balance for Case 3 with 50% CO₂ recovery. Figure 3-10 shows the compression and liquefaction system schematic with heat duties and power requirements indicated.

Table 3-25 shows the CO₂ compression and liquefaction system material and energy balance for Case 4 with 30% CO₂ recovery. Figure 3-11 shows the compression and liquefaction system schematic with heat duties and power requirements indicated.




Figure 3-8: Case 1 CO₂ Compression, Dehydration, and Liquefaction Schematic (90% CO₂ Recovery)



Table 3-22: Case 1 Material & Energy Balance for CO₂ Compression, Dehydration, and Liquefaction (90% CO₂ Recovery)

STREAM NAME	Total Acid Stripper	First Stage Discharge	To 2nd Stage	First Stage Water EO	From 2nd Stage	2nd Stage Discharge	To 3rd Stage	2nd Stage Water EO	From 3rd Stage	From 3rd Stage Water EO	3rd Stage Water EO	To Drier	Water From Drier	From Drier Condenser	Condenser CO ₂ Product	From CO ₂ Discharge	From CO ₂ Discharge	Section of Refrig Compressor	Discharge from In Refrig Compr	Rising from Chir Out	
																					frm_stp
PF3 STREAM INFO.																					
VAPOR FRACTION	Molar	1.000	0.993	1.000	0.000	0.974	1.000	0.000	0.988	0.000	0.000	1.000	0.000	1.000	0.000	1.000	1.000	1.000	1.000	1.000	
TEMPERATURE	F	115.0	125	125	125	125	125	125	125	125	125	125	125	125	240	125	264	174	174	56	
PRESSURE	PSIA	19.0	41	41	41	89	89	89	206	200	200	200	195	195	95	199	234	85	85	20	
MOLAR FLOW RATE	lbmol/hr	18.762	18.625	136.50	18.625	18.142	18.142	483	18.142	18.142	218.92	17.923	205.61	17.715	20.119	16,100.00	16,100.00	16,100.00	16,100.00	16,100.00	
MASS FLOW RATE	lb/hr	798,595.3	796,133.6	2,461.7	796,133.6	797,411.1	797,411.1	8,722.4	797,411.1	797,411.1	3,965.2	793,445.9	3,704.0	779,741.9	352,458.5	709,961.7	709,961.7	709,961.7	709,961.7	709,961.7	
ENERGY	Btu/hr	-3.10E+09	-3.09E+09	-1.68E+07	-3.06E+09	-3.10E+09	-3.04E+09	-5.89E+07	-3.01E+09	-3.04E+09	-2.67E+07	-3.02E+09	-2.50E+07	-3.00E+09	-2.41E+09	-7.16E+08	-6.67E+08	-6.94E+08	-6.94E+08	-7.27E+08	
COMPOSITION	Mol %																				
H ₂ O		94.44%	95.14%	0.00%	95.14%	85.14%	97.66%	0.17%	97.66%	0.38%	97.66%	98.85%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	
Nitrogen		5.55%	4.86%	99.52%	4.86%	14.86%	2.34%	99.83%	2.34%	99.62%	1.15%	1.15%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	
Propane		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
Oxygen		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
Ethane		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
n-Butane		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
VAPOR																					
MOLAR FLOW RATE	lbmol/hr	18.762	18.625	0	18.625	18.142	18.142	0	18.142	17.923	17.923	17.923	17.923	17.715	17.715	16,100.00	16,100.00	16,100.00	16,100.00	16,100.00	
MASS FLOW RATE	lb/hr	798,595.3	796,133.6	0	796,133.6	797,411.1	797,411.1	0	797,411.1	793,445.9	793,445.9	793,445.9	793,445.9	779,741.9	779,741.9	709,961.7	709,961.7	709,961.7	709,961.7	709,961.7	
STD VOL FLOW	MMSCFD	170.88	169.84	0	169.84	165.24	165.24	0	165.24	163.24	163.24	163.24	161.37	161.37	146.64	146.64	146.64	146.64	146.64	146.64	
ACTUAL VOL FLOW	ACFM	100.848	46.889	0	25.393	20.739	20.739	0	11.239	9.895	9.895	9.895	8.895	8.895	6.724	6.724	6.724	6.724	6.724	6.724	
MOLECULAR WEIGHT	MW	42.75	42.75	0.28	42.75	43.40	43.40	0.63	43.40	43.71	43.71	43.71	44.01	44.01	44.10	44.10	44.10	44.10	44.10	44.10	
DENSITY	lb/ft ³	0.13	0.28	0.28	0.52	0.63	0.63	0.63	1.17	1.48	1.48	1.48	1.45	1.45	1.76	1.51	0.59	0.59	0.59	0.59	
VISCOSITY	cP	0.0151	0.0155	0.0155	0.0201	0.0160	0.0160	0.0160	0.0207	0.0164	0.0164	0.0164	0.0165	0.0165	0.0097	0.0118	0.0099	0.0099	0.0099	0.0099	
LIGHT LIQUID																					
MOLAR FLOW RATE	lbmol/hr	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
MASS FLOW RATE	lb/hr	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
STD VOL FLOW	BPD	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
ACTUAL VOL FLOW	GPM	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
DENSITY	lb/ft ³	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
MOLECULAR WEIGHT	MW	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
VISCOSITY	cP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
SURFACE TENSION	Dyne/cm	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
HEAVY LIQUID																					
MOLAR FLOW RATE	lbmol/hr	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
MASS FLOW RATE	lb/hr	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
STD VOL FLOW	BPD	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
ACTUAL VOL FLOW	GPM	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
DENSITY	lb/ft ³	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
MOLECULAR WEIGHT	MW	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
VISCOSITY	cP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
SURFACE TENSION	Dyne/cm	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

ABB		Alstom Power	
		AEP Unit 5, Conesville, OH	
		90% CO ₂ Recovery Heat & Material Balance 90% 7T R2CTM80F	
No.	Date	By	REVISION
90	7/17/2006	LEG	
JOB NO: LR12965		REV. A	



Table 3-22: Case 1 Material & Energy Balance for CO₂ Compression, Dehydration, and Liquefaction (90% CO₂ Recovery), continued

STREAM NAME	Vapor from Economizer		Refing to CO ₂ Condenser		Economizer Liquid		Te Economizer		From Subcooler		From Refing		From CO ₂ Pipelines	
	econ_wsp	#/M ³ /H	to_cnh	econ_liq	to_econ	fm_sub_cfh	ref_cnh	prod_pmta	from_pmta	from_pmta	from_pmta	from_pmta	from_pmta	from_pmta
PFED STREAM HO.														
VAPOR FRACTION	Molar	0.148	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
TEMPERATURE	°F	15	-32	15	15	15	100	-10	82					
PRESSURE	PSIA	85	20	85	189	192	2,018	2,015						
MOLAR FLOW/RATE	lbmol/hr	16,100.00	16,100.00	16,100.00	16,100.00	16,100.00	17,717.51	17,717.51						
MASS FLOW/RATE	lb/hr	709,961.7	709,961.7	709,961.7	709,961.7	709,961.7	779,741.9	779,741.9						
ENERGY	Btu/hr	0.00E+00	-8.59E+08	-8.59E+08	-8.59E+08	-8.59E+08	-3.12E+09	-3.08E+09						
COMPOSITION	Mol%													
CO ₂		0.00%	0.00%	0.00%	0.00%	0.00%	100.00%	100.00%						
H ₂ O		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%						
Nitrogen		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%						
Propane		98.00%	98.00%	98.00%	98.00%	98.00%	98.00%	98.00%						
Orygen		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%						
Ethane		41.2%	1.00%	1.00%	1.00%	1.00%	1.00%	1.00%						
n-Butane		0.18%	0.50%	0.50%	0.50%	0.50%	0.50%	0.50%						
i-Butane		0.12%	0.50%	0.50%	0.50%	0.50%	0.50%	0.50%						
VAPOR														
MOLAR FLOW/RATE	lbmol/hr	2,387.2												
MASS FLOW/RATE	lb/hr	104,213.8												
STD VOL FLOW	MMSCF/D	21.74												
ACTUAL VOL FLOW	ACTM	8,754.51												
MOLECULAR WEIGHT	MW	43.56												
DENSITY	lb/ft ³	0.85												
VISCOSITY	cP	0.0075												
LIGHT LIQUID														
MOLAR FLOW/RATE	lbmol/hr	13,712.84	16,100.00	16,100.00	16,100.00	16,100.00	16,100.00	17,717.51	17,717.51					
MASS FLOW/RATE	lb/hr	605,747.9	709,961.7	709,961.7	709,961.7	709,961.7	779,741.9	779,741.9						
STD VOL FLOW	BPD	81,859	96,077	96,077	96,077	96,077	96,077	96,077	64,690	64,690				
ACTUAL VOL FLOW	GPM	2,107.66	2,817.99	2,817.99	2,817.99	2,817.99	2,817.99	2,817.99	1,416.96	1,416.96				
DENSITY	lb/ft ³	35.83	33.81	33.81	33.81	33.81	33.81	33.81	33.81	33.81				
MOLECULAR WEIGHT	MW	44.17	44.10	44.10	44.10	44.10	44.10	44.10	44.10	44.10				
VISCOSITY	cP	0.1841	0.1386	0.1386	0.1386	0.1386	0.1386	0.1386	0.1386	0.1386				
SURFACE TENSION	Dyne/Cm	14.56	11.08	11.08	11.08	11.08	11.08	11.08	11.08	11.08				
HEAVY LIQUID														
MOLAR FLOW/RATE	lbmol/hr													
MASS FLOW/RATE	lb/hr													
STD VOL FLOW	BPD													
ACTUAL VOL FLOW	GPM													
DENSITY	lb/ft ³													
VISCOSITY	cP													
SURFACE TENSION	Dyne/Cm													

ABB

Alstom Power
AEP Unit 5, Conesville, OH
90% CO₂ Recovery
Heat & Material Balance
90% 7T R2C2M80F

JOB NO: LR12965 REV: A




Figure 3-9: Case 2 CO₂ Compression, Dehydration, and Liquefaction Schematic (70% CO₂ Recovery)

Table 3-23: Case 2 Material and Energy Balance for CO₂ Compression, Dehydration, and Liquefaction (70% CO₂ Recovery)

STREAM NAME	First Stage Discharge	To Second Stage	First Stage Water ED	Free Second Stage	2nd Stage Discharge	To 2nd Stage	2nd Stage Water ED	Free 2nd Stage	From 2nd Stage Condenser	3rd Stage Water ED	To 3rd Stage	Water From Distill	From 3rd Stage Condenser	Condensed CO ₂ Product	Eq. CO ₂ Discharge or EUI	Refine from 2nd Refining Compressor	Discharge from 1st Refining Compressor	Refine from CO ₂ Condenser
PROF. STREAM NO.	frm_strp	frm_strp	1st_liq	frm_2nd_strp	2nd_strp	2nd_wap	2nd_liq	frm_3rd_strp	3rd_strp	3rd_wap	3rd_liq	water	frm_3rd	cond_out	to cond	ref_strp	ref_strp	chf_out
VAPOR FRACTION	MoleF	1.000	0.993	1.000	0.974	1.000	0.000	1.000	0.988	1.000	0.000	0.000	1.000	0.000	1.000	1.000	1.000	1.000
TEMPERATURE	F	115.0	125	125	275	125	125	275	125	125	125	125	125	205	125	264	173	56
PRESSURE	PSIA	19.0	41	41	95	89	89	206	200	200	195	195	195	95	199	234	85	20
MOLAR FLOW RATE	lbmol/hr	14,575	14,469	1,060.4	14,469	14,689	375	14,094	14,093.74	170.07	13,923.68	159.73	13,763.95	21,526.53	12,522.00	12,522.00	12,522.00	12,522.00
MASS FLOW RATE	lb/hr	620,393.5	618,481.1	1,912.4	618,481.1	611,705.0	6,776.1	611,705.0	3,080.4	609,624.6	2,877.5	605,747.1	387,802.7	552,182.6	552,182.6	552,182.6	552,182.6	552,182.6
ENERGY	Btu/hr	-2,41E+09	-2,40E+09	-1,25E+07	-2,39E+09	-2,39E+09	-4,57E+07	-2,34E+09	-2,39E+09	-2,07E+07	-2,34E+09	-1,95E+07	-2,33E+09	-5,19E+08	-5,19E+08	-5,40E+08	-5,40E+08	-5,65E+08
COMPOSITION	wt%																	
CO ₂		94.44%	95.14%	0.00%	95.14%	97.66%	0.17%	97.66%	97.66%	0.36%	98.85%	0.00%	100.00%	0.00%	0.00%	0.00%	0.00%	0.00%
H ₂ O		5.56%	4.86%	99.92%	4.86%	2.34%	99.83%	2.34%	2.34%	99.62%	1.15%	100.00%	0.00%	100.00%	0.00%	0.00%	0.00%	0.00%
Nitrogen		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
Propane		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
Oxygen		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
Ethane		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
n-Butane		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
VAPOR		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
MOLAR FLOW RATE	lbmol/hr	14,575	14,469	0	14,469	14,094	0	14,094	13,923.7	13,923.7	0	13,764.0	13,764.0	0	12,522.0	12,522.0	12,522.0	12,522.0
MASS FLOW RATE	lb/hr	620,393.5	618,481.1	0	618,481.1	611,705.0	0	611,705.0	609,624.6	609,624.6	0	605,747.1	605,747.1	0	552,182.6	552,182.6	552,182.6	552,182.6
STD. VOL. FLOW	MMSCFD	132.75	131.78	0	131.78	128.37	0	128.37	128.37	128.37	0	128.92	128.92	0	114.05	114.05	114.05	114.05
ACTUAL VOL. FLOW	ACFM	78,342	36,426	0	19,726	16,112	0	8,731	6,940.79	6,940.79	0	6,956.61	6,956.61	0	5,229.93	6,107.89	15,636.40	15,636.40
MOLECULAR WEIGHT	MW	42.57	42.75	0	42.75	43.40	0	43.40	43.71	43.71	0	44.01	44.01	0	44.10	44.10	44.10	44.10
DENSITY	lb/ft ³	0.13	0.28	0	0.52	0.63	0	1.17	1.48	1.48	0	1.45	1.45	0	1.76	1.51	0.59	0.16
VISCOSITY	cP	0.0151	0.0155	0	0.0201	0.0160	0	0.0207	0.0164	0.0164	0	0.0164	0.0165	0	0.0097	0.0118	0.0099	0.0079
LIGHT LIQUID																		
MOLAR FLOW RATE	lbmol/hr	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MASS FLOW RATE	lb/hr	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
STD. VOL. FLOW	BFD	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
ACTUAL VOL. FLOW	CFM	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
DENSITY	lb/ft ³	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MOLECULAR WEIGHT	MW	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
VISCOSITY	cP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
SURFACE TENSION	Dyne/Cm	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
HEAVY LIQUID																		
MOLAR FLOW RATE	lbmol/hr	106.04	106.04	0	106.04	375.22	375.22	375.22	170.07	170.07	170.07	159.73	159.73	21,526.53	21,526.53	21,526.53	21,526.53	21,526.53
MASS FLOW RATE	lb/hr	1,912.4	1,912.4	0	1,912.4	6,776.1	6,776.1	6,776.1	3,080.4	3,080.4	3,080.4	2,877.5	2,877.5	387,802.7	387,802.7	387,802.7	387,802.7	387,802.7
STD. VOL. FLOW	BFD	131	131	0	131	465	465	465	212	212	212	197	197	26,808	26,808	26,808	26,808	26,808
ACTUAL VOL. FLOW	CFM	387	387	0	387	13,700	13,700	13,700	6,222	6,222	6,222	5,822	5,822	813,800	813,800	813,800	813,800	813,800
DENSITY	lb/ft ³	61.63	61.63	0	61.63	61.66	61.66	61.66	61.72	61.72	61.72	61.63	61.63	59.40	59.40	59.40	59.40	59.40
VISCOSITY	cP	0.5291	0.5291	0	0.5651	0.5651	0.5651	0.5651	0.5621	0.5621	0.5621	0.5282	0.5282	0.2915	0.2915	0.2915	0.2915	0.2915
SURFACE TENSION	Dyne/Cm	67.26	67.26	0	67.33	67.33	67.33	67.33	67.19	67.19	67.19	67.42	67.42	59.38	59.38	59.38	59.38	59.38

Alstom Power
 AEP Unit 5, Connersville, OH
 70% CO₂ Recovery
 Heat & Material Balance
 70%_5T_R2C2WB0

JOB NO: LRT2985 REV: A



Table 3-23: Case 2 Material and Energy Balance for CO₂ Compression, Dehydration, and Liquefaction (70% CO₂ Recovery), continued

STREAM NAME	Vapor from Ecosolizer	Refilling to Ecosolizer	Ecosolizer Liquid	To Ecosolizer	From Subcooler	From Refilling Condenser	From Refilling Pump	CO ₂ To Pipeline
	econ_wap	to_chlr	econ_liq	to_econ	frm_sub_cdrfm	ref_cndfm	prod_pntf	to_pipeline
PFID STREAM NO.	0.149	0.000	0.000	0.000	0.000	0.000	0.000	0.000
VAPOR FRACTION	#DV/FI	0.149	0.000	0.000	0.000	0.000	0.000	0.000
TEMPERATURE	°F	16	-32	16	15	100	-10	82
PRESSURE	PSIA	85	20	85	189	192	2,018	2,015
MOLAR FLOW RATE	lbmol/hr	12,522.00	12,522.00	12,522.00	12,522.00	12,522.00	13,763.95	13,763.95
MASS FLOW RATE	lb/hr	552,182.6	552,182.6	552,182.6	552,182.6	552,182.6	605,747.1	605,747.1
ENERGY	Btu/hr	0.00E+00	-6.68E+08	-6.68E+08	-6.68E+08	-6.38E+08	-2.43E+09	-2.40E+09
COMPOSITION	Mol %							
CO ₂		0.00%	0.00%	0.00%	0.00%	0.00%	100.00%	100.00%
H ₂ O		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
Nitrogen		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
Propane		98.00%	98.00%	98.00%	98.00%	98.00%	0.00%	0.00%
Oxygen		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
Ethane		4.12%	1.00%	1.00%	1.00%	1.00%	0.00%	0.00%
n-Butane		0.18%	0.50%	0.50%	0.50%	0.50%	0.00%	0.00%
n-Butane		0.12%	0.50%	0.50%	0.50%	0.50%	0.00%	0.00%
VAPOR								
MOLAR FLOW RATE	lbmol/hr	1,861.1	-	-	-	-	-	-
MASS FLOW RATE	lb/hr	81,247.7	-	-	-	-	-	-
STD VOL FLOW	MMSCFD	16.95	-	-	-	-	-	-
ACTUAL VOL FLOW	ACTM	6,825.18	-	-	-	-	-	-
MOLECULAR WEIGHT	MM	43.96	-	-	-	-	-	-
DENSITY	lb/ft ³	0.85	-	-	-	-	-	-
VISCOSITY	cP	0.0075	-	-	-	-	-	-
LIGHT LIQUID								
MOLAR FLOW RATE	lbmol/hr	10,660.93	12,522.00	12,522.00	12,522.00	12,522.00	13,763.95	13,763.95
MASS FLOW RATE	lb/hr	470,934.9	552,182.6	552,182.6	552,182.6	552,182.6	605,747.1	605,747.1
STD VOL FLOW	BPD	83,641	74,725	74,725	74,725	74,725	50,255	50,255
ACTUAL VOL FLOW	GPM	1,638.59	2,036.46	2,036.46	2,036.46	2,339.24	1,100.79	1,467.37
DENSITY	lb/ft ³	35.63	33.81	33.81	33.92	29.43	69.61	50.78
MOLECULAR WEIGHT	MM	44.17	44.10	44.10	44.10	44.10	44.01	44.01
VISCOSITY	cP	0.1841	0.1395	0.1395	0.1400	0.0881	0.1593	0.0622
SURFACE TENSION	Dyne/Cm	14.56	11.08	11.08	11.09	5.42	13.90	0.86
HEAVY LIQUID								
MOLAR FLOW RATE	lbmol/hr	-	0.00	-	-	-	-	-
MASS FLOW RATE	lb/hr	-	-	-	-	-	-	-
STD VOL FLOW	BPD	-	-	-	-	-	-	-
ACTUAL VOL FLOW	GPM	-	-	-	-	-	-	-
DENSITY	lb/ft ³	-	-	-	-	-	-	-
VISCOSITY	cP	-	-	-	-	-	-	-
SURFACE TENSION	Dyne/Cm	-	-	-	-	-	-	-

ABB		Aistom Power AEP Unit 5, Conesville, OH
70% CO ₂ Recovery Heat & Material Balance 70% 5T_RZCTW80		REV. A
JOB NO: LR12965		REV.




Figure 3-10: Case 3 CO₂ Compression, Dehydration, and Liquefaction Schematic (50% CO₂ Recovery)

Table 3-24: Case 3 Material and Energy Balance for CO₂ Compression, Dehydration, and Liquefaction (50% CO₂ Recovery)

STREAM NAME	Total Acid Loss from Stripper	First Stage Discharge	To Second Stage	First Stage Water KD	From Second Stage	2nd Stage Discharge	To 2nd Stage	2nd Stage Water KD	From 2nd Stage	From 3rd Stage	3rd Stage Water KD	To 3rd Stage	3rd Stage Water KD	From 3rd Stage	From Drier to Condenser	Water from Drier	From Drier to Condenser	Condensed CO ₂ Product	From CO ₂ Drier to A/EI	From CO ₂ Drier to Discharge	Refining to Feed for CO ₂ Condenser	Discharge to Refining Tower	Refining from Feed for CO ₂ Condenser	
PFD STREAM NO.	frm_atstp	frm_1st_dr	1st_wap	1st_liq	frm_2nd_stlfrm	2nd_dr	2nd_wap	2nd_liq	frm_3rd_stlfrm	frm_3rd_wstwr	3rd_dr	3rd_wap	3rd_liq	frm_3rd_wstwr	frm_drier	water	frm_drier	cond out	to cond	frm_ref_cmprto_ref_cmpr	chh_out	chh_out		
VAPOR FRACTION	Molar	1.000	1.000	1.000	1.000	0.993	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000	0.000	0.000	0.000	0.000	1.000	1.000	1.000		
TEMPERATURE	F	115.0	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	173	173	55	
PRESSURE	PSIA	19.0	41	41	41	95	89	89	200	200	200	200	200	200	185	195	185	205	205	263	263	85	20	
MOLAR FLOWRATE	lbmohr	10.399	10.399	10.323	10.323	10.323	10.323	75.66	10.323	10.055	10.055	10.055	10.055	10.055	9.820	113.96	9.820	15.337	15.337	8.944	8.944	8.944	8.944	
MASS FLOWRATE	lb/hr	442.639.6	442.639.6	441.275.1	441.275.1	441.275.1	441.275.1	4.834.5	4.834.5	4.834.5	4.834.5	4.834.5	4.834.5	4.834.5	432.189.7	2,053.0	432.189.7	276.312.6	276.312.6	394.403.6	394.403.6	394.403.6	394.403.6	
ENERGY	Btu/hr	-1.72E+09	-1.71E+09	-1.71E+09	-1.70E+09	-1.70E+09	-1.70E+09	-3.26E+07	-1.67E+09	-1.65E+09	-1.65E+09	-1.65E+09	-1.65E+09	-1.65E+09	-1.65E+09	-1.39E+07	-1.65E+09	-1.65E+09	-1.65E+09	-3.71E+08	-3.65E+08	-3.65E+08	-4.01E+08	
COMPOSITION	mol %																							
CO ₂		94.44%	94.44%	95.14%	95.14%	95.14%	95.14%	97.86%	97.86%	97.86%	97.86%	97.86%	97.86%	97.86%	100.00%	0.00%	100.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
H ₂ O		5.56%	5.56%	4.86%	4.86%	4.86%	4.86%	2.34%	2.34%	2.34%	2.34%	2.34%	2.34%	2.34%	100.00%	0.00%	100.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
Nitrogen		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
Propane		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
Oxygen		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
Ethane		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
n-Butane		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
WAPOR																								
MOLAR FLOWRATE	lbmohr	10.399	10.323	10.323	10.323	10.323	10.055	0	10.055	9.824.3	9.824.3	9.824.3	9.824.3	9.824.3	9.820.3	113.96	9.820.3	15.337	15.337	8.944.0	8.944.0	8.944.0	8.944.0	
MASS FLOWRATE	lb/hr	442.639.6	441.275.1	441.275.1	441.275.1	441.275.1	4.834.5	4.834.5	4.834.5	4.834.5	4.834.5	4.834.5	4.834.5	4.834.5	432.189.7	2,053.0	432.189.7	276.312.6	276.312.6	394.403.6	394.403.6	394.403.6	394.403.6	
STD VOL FLOW	MMSCFD	94.71	94.03	94.03	94.03	94.03	91.59	91.59	91.59	90.48	90.48	90.48	90.48	90.48	89.44	89.44	89.44	89.44	89.44	81.46	81.46	81.46	81.46	
ACTUAL VOL FLOW	ACFPM	55.986	25.989	25.989	25.989	25.989	11.495	11.495	11.495	4.680.78	4.680.78	4.680.78	4.680.78	4.680.78	4.683.42	4.683.42	4.683.42	4.683.42	4.683.42	3,735.54	3,735.54	3,735.54	3,735.54	
DENSITY	lb/ft ³	0.13	0.28	0.28	0.28	0.28	0.28	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.59	0.59	0.59	0.59	0.59	0.59	0.59	0.16	
VISCOSITY	cP	0.0151	0.0155	0.0155	0.0155	0.0155	0.0160	0.0160	0.0160	0.0207	0.0164	0.0164	0.0164	0.0164	0.0165	1.48	1.48	1.45	1.45	1.76	1.51	1.51	0.079	
LIGHT LIQUID																								
MOLAR FLOWRATE	lbmohr	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
MASS FLOWRATE	lb/hr	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
STD VOL FLOW	BPD	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
ACTUAL VOL FLOW	GPM	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
DENSITY	lb/ft ³	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
MOLECULAR WEIGHT	lbm/lb-mole	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
VISCOSITY	cP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
SURFACE TENSION	Dyne/cm	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
HEAVY LIQUID																								
MOLAR FLOWRATE	lbmohr	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
MASS FLOWRATE	lb/hr	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
STD VOL FLOW	BPD	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
ACTUAL VOL FLOW	GPM	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
DENSITY	lb/ft ³	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
MOLECULAR WEIGHT	lbm/lb-mole	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
VISCOSITY	cP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
SURFACE TENSION	Dyne/cm	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

NOTES

Alstom Power
 AFP Unit 5, Conesville, OH
 50% CO₂ Recovery
 Heat & Material Balance
 50% AT, R2CTW80
 JOB NO: LR12985
 REV: A



Table 3-24: Case 3 Material and Energy Balance for CO₂ Compression, Dehydration, and Liquefaction (50% CO₂ Recovery), continued

STREAM NAME	Vapor from Escalator	Refing to CO ₂ Condenser	Escalator Liquid	To Escalator	From Subcooler	From Refing Condenser	From Product Pump	CO ₂ To Pipeline
PF1 STREAM NO.	escm_wsp	to_chlr	escm_liq	to_escm	frm_sub_cbr	frm_ref_condn	prod_pump	pipeline
VAPOR FRACTION	Mole #/Vol	0.149	0.000	0.000	0.000	0.000	0.000	0.000
TEMPERATURE	°F	-32	16	16	15	100	-10	62
PRESSURE	PSIA	20	85	85	169	152	2,016	2,015
MOLAR FLOW/RATE	lbmol/hr	8,944.00	8,944.00	8,944.00	8,944.00	8,944.00	9,620.33	9,620.33
MASS FLOW/RATE	lb/hr	394,403.6	394,403.6	394,403.6	394,403.6	394,403.6	432,189.7	432,189.7
ENERGY	Btu/hr	0.00E+00	-4.77E+08	-4.77E+08	-4.77E+08	-4.55E+08	-1.73E+09	-1.71E+09
COMPOSITION	Mol %							
CO ₂		0.00%	0.00%	0.00%	0.00%	0.00%	100.00%	100.00%
H ₂ O		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
Nitrogen		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
Propane		86.00%	86.00%	86.00%	86.00%	86.00%	0.00%	0.00%
Oxygen		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
Ethane		4.12%	1.00%	1.00%	1.00%	1.00%	0.00%	0.00%
n-Butane		0.16%	0.50%	0.50%	0.50%	0.50%	0.00%	0.00%
n-Butane		0.12%	0.50%	0.50%	0.50%	0.50%	0.00%	0.00%
VAPOR								
MOLAR FLOW/RATE	lbmol/hr	1,332.2	-	-	-	-	-	-
MASS FLOW/RATE	lb/hr	58,161.8	-	-	-	-	-	-
STD VOL. FLOW	MMSCFD	12.13	-	-	-	-	-	-
ACTUAL VOL. FLOW	ACFM	4,885.62	-	-	-	-	-	-
MOLECULAR WEIGHT	MM	43.56	-	-	-	-	-	-
DENSITY	lb/ft ³	0.85	-	-	-	-	-	-
VISCOSITY	cp	0.0075	0.0065	-	-	-	-	-
LIGHT LIQUID								
MOLAR FLOW/RATE	lbmol/hr	7,611.75	8,944.00	8,944.00	8,944.00	8,944.00	9,620.33	9,620.33
MASS FLOW/RATE	lb/hr	336,241.8	394,403.6	394,403.6	394,403.6	394,403.6	432,189.7	432,189.7
STD VOL. FLOW	BPD	45,439	53,374	53,374	53,374	53,374	58,856	58,856
ACTUAL VOL. FLOW	GPM	1,169.93	1,454.78	1,454.78	1,454.78	1,454.78	1,601.21	1,601.21
DENSITY	lb/ft ³	35.63	33.80	33.80	33.80	33.80	33.80	33.80
MOLECULAR WEIGHT	MM	44.17	44.10	44.10	44.10	44.10	44.01	44.01
VISCOSITY	cp	0.1841	0.1394	0.1394	0.1394	0.0881	0.1593	0.0622
SURFACE TENSION	Dyne/Cm	14.56	11.07	11.07	11.07	5.42	13.90	0.86
HEAVY LIQUID								
MOLAR FLOW/RATE	lbmol/hr	-	-	-	-	-	-	-
MASS FLOW/RATE	lb/hr	-	-	-	-	-	-	-
STD VOL. FLOW	BPD	-	-	-	-	-	-	-
ACTUAL VOL. FLOW	GPM	-	-	-	-	-	-	-
DENSITY	lb/ft ³	-	-	-	-	-	-	-
VISCOSITY	cp	-	-	-	-	-	-	-
SURFACE TENSION	Dyne/Cm	-	-	-	-	-	-	-



Alstom Power
 AEP Unit 5, Conesville, OH
 50% CO₂ Recovery
 Heat & Material Balance
 50% - 4T - R2C1W60
 JOB NO: LR12965 REV: A




Figure 3-11: Case 4 CO₂ Compression, Dehydration, and Liquefaction Schematic (30% CO₂ Recovery)



Table 3-25: Case 4 Material and Energy Balance for CO2 Compression, Dehydration, and Liquefaction (30% CO2 Recovery)

Table with columns: STREAM NAME, PFID FRACTION NO., VAPOR FRACTION, TEMPERATURE, PRESSURE, Molar Flow Rate, Energy, Composition, and various process parameters like flow rates, temperatures, and efficiencies.

ABB logo and revision table with columns for No., Date, By, and Revision. Includes project details like ABB, Alstom Power, and job number LR12965.

Table 3-25: Case 4 Material and Energy Balance for CO₂ Compression, Dehydration, and Liquefaction (30% CO₂ Recovery), continued

STREAM NAME	Units from Separator	Refining to CO ₂ Condenser	Escalator Liquid	To Escalator	From Subcooler	From Reboiler Condenser	From Product Pump	CO ₂ To Pipeline
REF. STREAM NO.	escm, sep	to, cstr	escm, liq	to, escm	from, sub. str	from, reboiler cond. pump	prod. unit to pipeline	
VAPOR FRACTION	Mole #DIV#	0.148	0.000	0.000	0.000	0.000	0.000	
TEMPERATURE	°F	15	15	15	100	-10	82	
PRESSURE	PSIA	85	85	85	189	182	2,018	
MOLAR FLOW RATE	lbmole/hr	5,387.00	5,387.00	5,387.00	5,387.00	5,905.04	5,905.04	
MASS FLOW RATE	lb/hr	236,688.6	236,688.6	236,688.6	236,688.6	259,879.0	259,879.0	
ENERGY	Btu/hr	0.00E+00	-2.88E+08	-2.88E+08	-2.88E+08	-2.73E+08	-1.04E+09	
COMPOSITION	Mol %							
CO ₂		0.00%	0.00%	0.00%	0.00%	0.00%	100.00%	
H ₂ O		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
Nitrogen		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
Propane		99.00%	99.00%	99.00%	99.00%	99.00%	0.00%	
Oxygen		0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	
Ethane		4.12%	1.00%	1.00%	1.00%	1.00%	0.00%	
i-Butane		0.18%	0.50%	0.50%	0.50%	0.50%	0.00%	
n-Butane		0.12%	0.50%	0.50%	0.50%	0.50%	0.00%	
VAPOR								
MOLAR FLOW RATE	lbmole/hr	798.1	-	-	-	-	-	
MASS FLOW RATE	lb/hr	34,754.1	-	-	-	-	-	
STD VOL FLOW	MMSCFD	7.25	-	-	-	-	-	
ACTUAL VOL FLOW	ACFM	2,919.52	-	-	-	-	-	
MOLECULAR WEIGHT	MM	43.56	-	-	-	-	-	
DENSITY	lb/ft ³	0.85	-	-	-	-	-	
VISCOSITY	cp	0.0075	-	-	-	-	-	
LIGHT LIQUID								
MOLAR FLOW RATE	lbmole/hr	4,570.91	5,387.00	5,387.00	5,387.00	5,387.00	5,905.04	
MASS FLOW RATE	lb/hr	201,914.5	236,688.6	236,688.6	236,688.6	236,688.6	259,879.0	
STD VOL FLOW	BPD	27,286	32,028	32,028	32,028	32,028	21,581	
ACTUAL VOL FLOW	GPM	702.85	872.74	872.74	869.81	1,002.81	472.26	
DENSITY	lb/ft ³	35.83	33.81	33.81	33.92	29.43	69.81	
MOLECULAR WEIGHT	MM	44.17	44.10	44.10	44.10	44.10	44.01	
VISCOSITY	cp	0.1841	0.1396	0.1396	0.1400	0.0881	0.1593	
SURFACE TENSION	Dyne/Cm	14.56	11.08	11.08	11.10	5.42	13.90	
HEAVY LIQUID								
MOLAR FLOW RATE	lbmole/hr	0.00	-	-	-	-	-	
MASS FLOW RATE	lb/hr	-	-	-	-	-	-	
STD VOL FLOW	BPD	-	-	-	-	-	-	
ACTUAL VOL FLOW	GPM	-	-	-	-	-	-	
DENSITY	lb/ft ³	-	-	-	-	-	-	
VISCOSITY	cp	-	-	-	-	-	-	
SURFACE TENSION	Dyne/Cm	-	-	-	-	-	-	

Alstom Power
AEP Unit 5, Conesville, OH
30% CO₂ Recovery
Heat & Material Balance
30%_3T_R2C1W80

JOB NO: LR12965 REV: A

CO₂ Product Specification and Actual Composition (Cases 1-4)

The CO₂ product specification and actual composition are shown in Table 3-26. Note that no mercaptans nor methane and heavier hydrocarbons are shown in the flue gas analysis. Therefore, these components are shown as zero in Table 3-26. A CO₂ product pressure of 139 bara (2,015 psia) was used for all the cases.

Table 3-26: CO₂ Product Specification and Calculated Product Comparison (Cases 1-4)

Component	Specification	Calculated Results
	Mole %	Mole %
O ₂	0.0100	<0.0050
N ₂	0.6000	<0.0400
H ₂ O	0.0002	<0.0002
CO ₂	96.000	>99.95
H ₂ S	0.0001	<0.0001
Mercaptans	0.0300	0.00
CH ₄	0.3000	0.00
C ₂ + Hydrocarbons	2.0000	0.00

3.1.4.2 Consumption of Chemicals and Desiccants - CO₂ Removal, Compression, and Liquefaction System (Cases 1-4)

The table below shows the daily chemical consumption for Cases 1-4 with 90%-30% CO₂ recovery respectively. These totals do not include chemicals provided by the cooling tower service people nor disposal of waste, which are handled as a component of operating costs referred to as contracted services and waste handling, respectively.

Table 3-27: Chemical and Desiccants Consumption (lbm/day) for Cases-1-4 (90%-30% CO₂ Recovery)

Chemical	Case 1 (90% Capture)	Case 2 (70% Capture)	Case 3 (50% Capture)	Case 4 (30% Capture)
Soda Ash	2,328	1,811	1,293	776
MEA	28,046	21,813	15,581	9,349
Corrosion inhibitor	1,028	800	571	343
Diatomaceous earth	458	356	254	153
Molecular sieve	257	200	143	86
Activated carbon	1,546	1,202	859	515

3.1.4.3 Equipment - CO₂ Removal, Compression, and Liquefaction System (Cases 1-4)

Complete equipment data summary sheets for Cases 1-4 are provided in Appendix II. These equipment lists have been presented in the so-called “short spec” format, which provides

adequate data for developing a factored cost estimate. Table 3-28 shows a summary of the major equipment for the CO₂ Removal, Compression, and Liquefaction Systems. Three categories are shown in this table (Compressors, Towers/Internals, and Heat Exchangers). These three categories represent, in that order, the three most costly accounts in the cost estimates for these systems (See Section 3.3). These three accounts represent ~90% of the total equipment costs for these systems.

Table 3-28: Equipment Summary - CO₂ Removal, Compression, and Liquefaction System (Cases 1-4)

	Case 1 (90% Capture)		Case 2 (70% Capture)		Case 3 (50% Capture)		Case 4 (30% Capture)	
	No.	HP each	No.	HP each	No.	HP each	No.	HP each
Compressors								
CO ₂ Compressor	2	15,600	2	12,100	1	17,300	1	10,400
Propane Compressor	2	11,700	2	10,200	1	14,600	1	8,800
LP Let Down Turbine	1	60,800	1	47,200	1	33,600	1	20,000
Towers/Internals								
Absorber/Cooler	2	34 / 126	2	30 / 126	2	25 / 126	1	28 / 126
Stripper	2	22 / 50	2	19 / 50	2	16 / 50	1	20 / 50
Heat Exchangers								
Reboilers	10	120.0	8	120.0	6	120.0	4	120.0
Solvent Stripper CW Condenser	12	20.0	10	20.0	7	20.0	4	20.0
Other Heat Exchangers / Avg Duty	36	61.0	35	57.0	25	62.0	16	58.0
Total Heat Exchangers / Avg Duty	58	62.7	53	59.5	38	63.4	24	62.0

A review of this table shows how the number of compression trains is reduced from two trains for the 90% and 70% recovery cases to one train for the 50% and 30% recovery cases. Similarly the number of absorber/stripper trains is reduced from two trains for the 90%, 70% and 50% recovery cases to one train for the 30% recovery case. Additionally, the sizes of the vessels and power requirements for the compressors are also changing. The heat exchanger selections also show variation between the cases. Figure 3-12 is provided to help illustrate how the number of trains (compressor, absorber, and stripper), compressor power requirements, vessel sizes, and the number and heat duty of the heat exchangers in the system change as a function of the CO₂ recovery percentage.




Figure 3-12: Equipment Variations – CO₂ Removal, Compression, and Liquefaction Systems (Cases 1-4)

3.1.4.4 Utilities Usage and Auxiliary Power Requirements - CO₂ Removal, Compression, and Liquefaction System (Cases 1-4)

Table 3-29 shows the CO₂ Removal and Compression System utilities usage for Cases 1-4. Table 3-30, Table 3-31, Table 3-32, and Table 3-33 show auxiliary power requirements for Cases 1-4 respectively (90%-30% CO₂ recovery).

Table 3-29: Consumption of Utilities for Cases 1-4 (90%-30% CO₂ Recovery)

Utility	Units	Case 1 (90% Capture)	Case 2 (70% Recovery)	Case 3 (50% Capture)	Case 4 (30% Capture)
Natural Gas for CO ₂ Dryers	SCF/day	312,000	232,000	161,000	101,000
Saturated Steam at 45 psia	lbm/hr	1,300,000	1,010,000	722,000	433,333
80°F Cooling Tower Water	Gal/minute at 30°F rise	69,694	54,217	38,693	22,991

Table 3-30: Auxiliary Power Usage for Case 1 (90% CO₂ Recovery)

Number of Trains	Tag no.	Description	Number Operating per train	Power ea w/ 0.95 motor eff (kW)	Total all trains (kW)
2	Pump-2	Wash Water Pump	2	52	210
2	Pump-1	Direct Contact Cooler Water Pump	2	90	359
2	P-100	Rich Solvent Pump	2	430	1,719
2	P-102	Lean Solvent Pump	2	291	1,166
2	P-101	Semi-Lean Pump	2	130	519
2		Solvent Stripper Reflux Pump	1	11	22
2		Filter Circ. Pump	2	21	85
7		CO ₂ Pipeline Pump	1	304	2,130
2		LP condensate booster pump	2	108	434
2		Soda ash metering pump	1	0	0
2		Flue Gas FD Fan	1	2,579	5,158
2		CO ₂ Compressor (Motor driven)	1	12,270	24,539
2		Propane Refrigeration Compressors (2)	1	9,153	18,306
1		LP steam turbine/ generator	NA	NA	NA
2		CO ₂ Dryer Package	1	146	292
		Total			54,939



Table 3-31: Auxiliary Power Usage for Case 2 (70% CO₂ Recovery)

Number of Trains	Tag no.	Description	Number Operating per train	Power ea w/ 0.95 motor eff (kW)	Total all trains (kW)
2	Pump-2	Wash Water Pump	2	41	163
2	Pump-1	Direct Contact Cooler Water Pump	2	69	277
2	P-100	Rich Solvent Pump	2	334	1,337
2	P-102	Lean Solvent Pump	2	228	912
2	P-101	Semi-Lean Pump	2	100	398
2		Solvent Stripper Reflux Pump	1	9	17
2		Filter Circ. Pump	2	17	66
5		CO ₂ Pipeline Pump	1	330	1,650
2		LP condensate booster pump	2	84	337
2		Soda ash metering pump	1	0	0
2		Flue Gas FD Fan	1	2,006	4,012
2		CO ₂ Compressor (Motor driven)	1	9,531	19,062
2		Propane Refrigeration Compressors (2)	1	7,113	14,226
1		LP steam turbine/ generator	NA	NA	NA
2		CO ₂ Dryer Package	1	120	240
		Total			42,697

Table 3-32: Auxiliary Power Usage for Case 3 (50% CO₂ Recovery)

Number of Trains	Tag no.	Description	Number Operating per train	Power ea w/ 0.95 motor eff. (kW)	Total all trains (kW)
2	Pump-2	Wash Water Pump	2	29	117
2	Pump-1	Direct Contact Cooler Water Pump	2	49	196
2	P-100	Rich Solvent Pump	2	239	955
2	P-102	Lean Solvent Pump	2	163	651
2	P-101	Semi-Lean Pump	2	71	284
2		Solvent Stripper Reflux Pump	1	6	12
2		Filter Circ. Pump	2	12	47
4		CO ₂ Pipeline Pump	1	295	1,180
2		LP condensate booster pump	2	60	241
2		Soda ash metering pump	1	0	0
2		Flue Gas FD Fan	1	1,433	2,866
1		CO ₂ Compressor (Motor driven)	1	13,602	13,602
1		Propane Refrigeration Compressors (2)	1	10,154	10,154
1		LP steam turbine/ generator	NA	NA	NA
1		CO ₂ Dryer Package	1	161	161
		Total			30,466

Table 3-33: Auxiliary Power Usage for Case 4 (30% CO₂ Recovery)

Number of Trains	Tag no.	Description	Number Operating per train	Power ea w/ 0.95 motor eff (kW)	Total all trains (kW)
1	Pump-2	Wash Water Pump	2	35	70
1	Pump-1	Direct Contact Cooler Water Pump	2	58	116
1	P-100	Rich Solvent Pump	2	287	574
1	P-102	Lean Solvent Pump	2	193	386
1	P-101	Semi-Lean Pump	2	88	176
1		Solvent Stripper Reflux Pump	1	8	8
1		Filter Circ. Pump	2	14	28
3		CO ₂ Pipeline Pump	1	237	711
1		LP condensate booster pump	2	72	145
1		Soda ash metering pump	1	0	0
1		Flue Gas FD Fan	1	1,719	1,719
1		CO ₂ Compressor (Motor driven)	1	8,178	8,178
1		Propane Refrigeration Compressors (2)	1	6,101	6,101
1		LP steam turbine/ generator	NA	NA	NA
1		CO ₂ Dryer Package	1	101	101
		Total			18,312

3.1.4.5 Design Considerations and System Optimization - CO₂ Removal, Compression, and Liquefaction System (Cases 1-4)

A commercial simulator called ProTreat[®] Version 3.3 was used to simulate the advanced MEA process and Hysys[®] Version 2004.2 was used to simulate CO₂ compression and liquefaction system. The key process parameters used are listed in Table 3-34 below.

Table 3-34: Key Process Parameters for Simulation (Cases 1-4)

Process Parameter	Value
CO ₂ in Feed, mol %	12.8
O ₂ in Feed, mol %	2.9
SO ₂ in Feed, ppmv	2
Solvent Type	MEA
Solvent Concentration, Wt%	30
Lean Loading, mol CO ₂ /mol amine	0.19
Rich Loading, mol CO ₂ /mol amine	0.49
Stripper Feed Temp, °F	205
Stripper Bottom Temp, °F	247
Feed Temp To Absorber, °F	115
CO ₂ Recovery, %	30-90
Absorber Pressure Drop, psi	1
Stripper Pressure Drop, psi	0.7
Rich/Lean Exchanger Approach, °F	40
CO ₂ Compressor 1st /Stage Temp, °F	125
Liquid CO ₂ Temp, °F	82
Steam Use, lbs Steam/ lb CO ₂ captured	1.67
Liquid CO ₂ Pressure, psia	2,015

The following parameters were investigated with the objective of reducing the MEA plant energy requirements and ultimately the cost of electricity produced by the power plant.

Number of Absorber and Stripper Trains:

The number of absorbers and strippers is based on using a maximum diameter of 12.2 m (40 ft). The minimum diameter is achieved by bypassing available flue gas while keeping the percentage of CO₂ absorbed in the absorber at 90%.

Absorber Temperature:

Two temperatures were investigated: 58°C (136°F) and 46°C (115°F). A flue gas cooler was added upstream of the absorber to cool the flue gas from 58°C (136°F) to 46°C (115°F). At 58°C (136°F), 90% CO₂ recovery is not achievable due to equilibrium constraints.

Stripper Temperature / Reboiler Pressure:

A preliminary optimization study was done to define the best reboiler pressure for the design of this plant. This was done for the 90% capture case only (Case 1). In this study it was observed that a reduction in reboiler pressure (let down turbine exhaust pressure) would have the following primary impacts:

- Increased Let Down Turbine Output
- Increased Net Plant Output
- Higher Plant Thermal Efficiency
- Increased Let Down Turbine Cost
- Increased Reboiler Cost
- Higher Total Retrofit Costs

The results for the reboiler pressure optimization study are shown in Figure 3-13. The graph on the left shows how the plant thermal efficiency improves linearly and plant retrofit cost increases exponentially as let down turbine outlet pressure is reduced. The graph on the right shows how the combined effect of plant efficiency improvement and retrofit cost increase causes the incremental cost of electricity (COE) to be minimized at a let down turbine outlet pressure of about 2.8-3.4 bara (40-50 psia). A let down turbine outlet pressure of 3.2 bara (47 psia) was selected for this study. Allowing about 0.14 bar (2 psi) for pressure drop between the let down turbine exhaust and the reboiler yields a reboiler operating pressure of 3.1 bara (45 psia). The use of 3.1 bara (45 psia) pressure steam in the stripper reboiler causes no significant sacrifice in the CO₂ loading in the lean amine.




Figure 3-13: Reboiler Pressure Optimization Study Results (Case 1)

Absorber and Stripper Packing Type and Depth:

Eighty-five types of packing were investigated to optimize the absorber and stripper diameter. The packing depth in both the absorber and stripper was optimized until a 90% CO₂ recovery was achieved.

Location and Amount of the Semi-Lean Amine to the Absorber:

The entry location of the semi-lean amine stream to the absorber and the amount of semi-lean amine was varied to minimize energy consumption and maximize CO₂ recovery.

Heat Exchanger Types:

Plate Frame Heat Exchangers, Shell and Tube Exchangers, and Air-Cooled Exchangers were investigated. Plate frame type heat exchangers were used as much as possible to improve energy efficiency and reduce costs.

Number of CO₂ Compression Trains:

Two compression trains are specified to provide for plant turndown capability for the 90% and 70% CO₂ recovery cases. At lower recoveries (50% and 30%) just one train is provided.

3.1.4.6 Outside Boundary Limits (OSBL) Systems - CO₂ Removal, Compression, and Liquefaction System (Cases 1-4)

Reclaimer Bottoms:

The reclaimer bottoms are generated during the process of recovering MEA from heat stable salts (HSS). HSS are produced from the reaction of MEA with SO₂ and NO₂. The HSS accumulate in the reclaimer during the lean amine feed portion of the reclaiming cycle. The volume of reclaimer bottoms generated will depend on the quantity of SO₂ and NO₂ not removed in the Flue Gas Scrubber. A typical composition of the waste is presented below.

Table 3-35: Reclaimer Bottoms Composition (Cases 1-4)

MEA	9.5 wt.%
NH ₃	0.02 wt.%
NaCl	0.6 wt.%
Na ₂ SO ₄	6.6 wt.%
Na ₂ CO ₃	1.7 wt.%
Insolubles	1.3 wt.%
Total Nitrogen	5.6 wt.%
Total Organic Carbon	15.6 wt.%
H ₂ O	59.08 wt.%
pH	10.7
Specific Gravity	1.14

Filter Residues:

A pressure leaf filter filters a slipstream of lean amine. Diatomaceous earth is used as a filter-aid for pre-coating the leaves and as a body feed. Filter cycles depend on the rate of flow through the filter, the amount of filter aid applied, and the quantity of contaminants in the solvent. A typical composition of the filter residue is provided in the table below. These will be disposed of by a contracted service hauling away the drums of spent cake.

Table 3-36: Filter Residue Composition (Cases 1-4)

MEA	2.5 wt.%
Total Organic Carbon	1.5 wt.%
SiO ₂	43 wt.%
Iron Oxides	32 wt.%
Aluminum Oxides	15 wt.%
H ₂ O	6 wt.%
pH	10.0
Specific Gravity	2.6

Excess Solvent Stripper Reflux Water:

The CO₂ Recovery Facility has been designed to operate in a manner to avoid accumulation of water in the Absorber / Stripper system. By controlling the temperature of the scrubbed flue gas entering the absorber the MEA system can be kept in water balance. Excess water can accumulate in the Stripper Reflux Drum and can be reused once the system is corrected to operate in a balanced manner. Should water need to be discarded, contaminants will include small amounts of CO₂ and MEA.

Absorber Flue Gas Scrubber/Cooler:

The existing plant uses lime in its flue gas desulfurizer. In the cost estimate of this plant, it has been assumed that the existing plant disposal facilities can accommodate the additional water blow down load from the flue gas cooler located under the absorber.

Relief Requirements:

The relief valve discharges from the CO₂ Recovery Unit are discharged to atmosphere. No tie-ins to any flare header are necessary.

3.1.4.7 Plant Layout - CO₂ Removal, Compression, and Liquefaction System (Cases 1-4)

Please refer to Appendix I for the plant layout drawings for the modified Conesville #5 Unit. The plant layout for the CO₂ capture equipment has been designed in accordance with a spacing chart called “Oil and Chemical Plant Layout and Spacing” Section IM.2.5.2 issued by Industrial Risk Insurers (IRI).

The open-cup flash point of MEA is 93°C (200°F); and, therefore, it will not easily ignite. In addition to MEA, the corrosion inhibitor is the only other hydrocarbon liquid within the battery limits. The flash point of this material is higher than that of MEA and is handled in small quantities. Thus, no highly flammable materials are handled within the CO₂ Recovery Unit. As the chemicals used in the process present no fire hazard, there is an opportunity to reduce the minimum spacing between equipment from that normally considered acceptable in hydrocarbon handling plants. However, for the drawings that follow, standard spacing requirements, as suggested by IRI have been followed.

The relatively unoccupied plot areas available on the existing site in the immediate vicinity of Unit #5 for the installation of the desired equipment are small. Some equipment items are placed on structures to allow other pieces of equipment to be placed underneath them. This way, pumps and other equipment associated with the absorber can be located under the structure. Locating the pumps under the structure has been considered acceptable because the fluids being pumped are not flammable.

Discussions with vendors suggest that it will be possible to provide insulation on the flue gas fan casing to limit noise to acceptable level. Therefore, it has been assumed that no building needs to be provided for noise reasons.

The CO₂ absorbers are placed adjacent to the flue gas desulfurization (FGD) system scrubbers to minimize the length of the flue gas duct feeding the bottom of the absorbers. Figure 3-14 shows the existing FGD scrubbers (2 -50% units) located just left (west) of the common stack used for Units 5/6, which is shown on the far right side of Figure 3-14. The new CO₂ absorbers

would be placed just to the left (west) of the existing FGD system scrubbers (far left side of Figure 3-14).



Figure 3-14: Conesville Unit #5 Existing Flue Gas Desulfurization System Scrubbers and Stack

The new strippers and the new let down turbine are placed ~30 m (100 ft) south of the existing Unit #5 intermediate pressure turbine just behind the existing turbine building shown in Figure 3-15. This location minimizes the length of the low-pressure steam line feeding the new LP let down turbine and the reboilers. The actual location for the new equipment would be just south of the road in the grassy area shown in the bottom part of Figure 3-15. The top of the Unit #5 boiler can be seen in the upper left side of Figure 3-15 and the duplicate Unit #6 boiler is on the upper right side.



Figure 3-15: Conesville Unit #5 Existing Turbine Building

The new low-pressure steam line runs from the IP/LP crossover pipe (shown in Figure 3-16) to the new let down low-pressure steam turbine, which is located near the strippers just beyond the outside wall shown in the background. The IP/LP crossover pipe will need to be modified with the addition of the steam extraction pipe to feed the let down turbine and the reboiler/reclaimer system. Additionally, a pressure control valve will need to be added downstream of the extraction point as described in Section 3.1.6.




Figure 3-16: Conesville Unit #5 Existing LP Turbine and IP/LP Crossover Pipe

The new CO₂ compression and liquefaction system is located between two existing cooling tower banks as shown in Figure 3-17, ~150 m (500 ft) south of the new strippers. An abandoned warehouse must be removed to make room for the CO₂ Compression Facilities.



Figure 3-17: Existing Conesville Cooling Towers & CO₂ Compression/Liquefaction System Location

The corrosion inhibitor must be protected against freezing during winter. The soda ash solution will not freeze but will become very viscous when it gets cold. Therefore, a heated shed has been provided for housing the Corrosion Inhibitor and the soda ash injection packages.

3.1.5 Case 5/Concept A: Design and Performance of Kerr-McGee/ABB Lummus Amine CO₂ Removal System

Case 5 represents an update (costs and economics only) of a case (Concept A) from an earlier Alstom study (Bozzuto et al., 2001). The process design and equipment selection from the earlier study was not updated in this study. The information provided for Case 5/Concept A in this section and other sections in this report was copied or adapted from the earlier study. It should be noted that the design of Case 5 with ~96% CO₂ recovery (See Bozzuto et al., 2001) is not totally consistent with the design of Case 1 (90% CO₂ recovery) from the current study. Case 1 uses two absorbers, two strippers, and two compression trains. Whereas, Case 5, which was designed in 2000, used five absorbers, nine strippers, and seven compression trains. Additionally, Case 5 equipment, which occupies about twice as much land area, was all located about 1,500 feet from the Unit #5 stack whereas the Case 1 CO₂ Removal System equipment could be located much closer to the existing plant in three primary locations as explained previously.

Case 5/Concept A from this earlier study was a post-combustion system, which used an amine-based (MEA) scrubber for CO₂ recovery. In Concept A, coal is burned conventionally in air.

The flue gases leaving the modified FGD system (a secondary absorber is added to reduce the SO₂ concentration as required by the MEA system) are cooled with a direct contact cooler and ducted to the MEA system where more than 96% of the CO₂ is removed, compressed, and liquefied for usage or sequestration. The remaining flue gases leaving the new MEA system, consisting primarily of oxygen, nitrogen, water vapor and a relatively small amount of sulfur dioxide and carbon dioxide, are discharged to the atmosphere. The Kerr-McGee/ABB Lummus amine technology is used for the Case 5/Concept A CO₂ removal system.

The CO₂ Recovery Unit for Case 5/Concept A is comprised of the following sections:

- Flue Gas Pretreatment
- Absorption
- Stripping
- CO₂ Compression and Liquefaction
- CO₂ Drying

The flue gas pre-treatment section cools and conditions the flue gas, which is then fed to the CO₂ Absorber. In the Absorber, CO₂ is removed from the gas by contacting it, in counter current fashion, with MEA. The recovered CO₂ is then stripped off in the Stripper (or Regenerator) from where the lean solvent is recycled back to the Absorber. Solvent regeneration for Case 5/Concept A requires about 5.46 MJ/Tonne CO₂ (2,350 Btu/lbm-CO₂). The overhead vapor from the Stripper is cooled to condense most of the water vapor. The condensate is used as reflux in the Stripper, and the wet CO₂ stream is fed to the CO₂ Compression and Liquefaction System. Here the CO₂ product is compressed and dried so it can be pumped to its final destination. No specific destination has been chosen for the product pipeline. It has been assumed to end at the battery limit (outlet flange of the CO₂ pump) for costing purposes.

A brief description of the processing scheme for Case 5/Concept A is given in the following paragraphs. Description of the package units is indicative only and may vary for the chosen supplier of the package unit.

3.1.5.1 Case 5/Concept A Process Description - CO₂ Removal, Compression, and Liquefaction System

This section refers to the following process flow diagrams:

- Figure 3-18: Drawing D 09484-01001R-0: Flue Gas Cooling and CO₂ Absorption
- Figure 3-19: Drawing D 09484-01002R-0: Solvent Stripping
- Figure 3-20: Drawing D 09484-01003R-0: CO₂ Compression and Liquefaction

The designs include several process trains. Only one train is shown. The note section of the PFD tells how many trains are included in the complete system. To avoid confusion, suffixes have been used to indicate parallel equipment. These are mainly for spared pumps and drier vessels in parallel. Even if there are several trains, only one drawing (typical) has been prepared to represent all of the trains. On these drawings, flow splits to the other parallel trains have been shown. Similarly, flows coming from other parallel trains and converging to a single common stream have also been shown.

A note about stream numbering convention is also necessary. The stream numbers have not been tagged with “A,” “B,” etc. to indicate which train they belong to. Instead, the flow rate given in the material balance for each stream is the actual flow rate for the stream within the train. The combined flow from all of the trains leaving a process step shows the total flow going to the next process step. As an example, stream 8 (Drawing D 09484-01001R-0) is the rich amine stream leaving one train of the absorber process step, and comprises 1/5 of the total rich amine. Stream 9A is the total rich amine going to the solvent stripping process step. Stream 9A appears on both the absorber and solvent stripper PFDs. After the rich amine flow sheet continuation block, the stream splits nine ways for the nine stripping trains. Then, stream 9 continues for processing on the solvent stripper PFD (Drawing D 09484-01002R-0), with 1/9 of the flow entering the rich-lean solvent exchanger (EA-2205).

Flue Gas Pretreatment:

The pressure profile of the CO₂ capture equipment is contained in the material balance. Since the flue gas pre-treatment equipment flow scheme includes a blower, the pressure profile of the existing Conesville #5 power generation equipment does not change from current operation. To force the flue gas from the secondary FGD through the CO₂ Absorber, the pressure of the flue gas after sulfur removal is boosted to 0.1 barg (1.5 psig) by a motor driven fan. As the power consumption of the fan is considerable, the duct size must be chosen so as not to cause excessive pressure drop over the 460 m (1,500 ft) it takes to get to the absorbers. The blower will run at constant speed. Each blower, provided as part of the boiler flue gas conditioning equipment, is equipped with its own suction and a discharge damper operated pneumatically. The suction damper controls the suction pressure to adjust for the flow variation resulting from the power plant performance. The suction pressure control will avoid any surges to blower. The discharge damper is an isolation damper.

Direct Contact Cooling (Refer to Figure 3-18):

The Direct Contact flue gas Cooler (DCC) is a packed column where the hot flue gas flowing up is brought into intimate contact with cold water, which is fed to the top of the bed and flows down the tower. Physically, DA-2101 and DA-2102 have been combined into a single, albeit compartmentalized tower. DA-2101 is the lower compartment and is designed to support DA-2102 so that the top head of DA-2101 is the bottom head of DA-2102. Effectively, this dividing head acts as a chimney tray with a number of upward extending chimneys, which provide passages for the flue gas to flow directly from the DCC into the Absorber.

Theoretically, a direct contact cooler is capable of cooling the gas to a very close approach in a short bed. When the hot gas enters the DCC, the gas contains water but is highly superheated. At the bottom end of the bed, the gas is quickly cooled to a temperature known as the “Adiabatic Saturation Temperature” (AST). This is the temperature the gas reaches when some of its own heat content has been used to vaporize just the exact amount of water to saturate the gas.

Up to the point when the AST is reached, the mass flow of the gas stream increases due to evaporation of water. At the AST, water vapor contained in the gas begins to condense as the gas is further cooled. And, as the gas travels up the column and is cooled further, more water is condensed. This internal refluxing increases the V/L traffic at the bottom end of the bed significantly beyond the external flows and must be considered in the hydraulic design.

The water stream that leaves the bottom of the DCC contains the water fed to the top as well as any water that has condensed out of the flue gas. The condensed water may be somewhat corrosive due to sulfur and nitrogen oxides that may be present in the flue gas. Therefore, instead of using the condensate in the process, it will be blown down from the system. For the DCC to be effective, the temperature of the leaving water must always be lower than the AST.

DCC Water Pump GA-2102 A/B circulates most of the water leaving the bottom of the DCC back to the top of the direct contact cooler. However, before sending it back to the column the water stream is first filtered in DCC Water Filter FD-2101 and then cooled in DCC Water Cooler EA-2101 against the water from the new cooling tower. Temperature of the cooled water is controlled by a cascade loop, which maintains a constant flue gas exit temperature (Absorber feed temperature). Because of the relatively low cooling water temperature at the plant, the circulating water is cooled down to 35°C (95°F), which, in turn, easily cools the gas down to 46°C (115°F).

Filtration is necessary to remove any particulate matter that may enter the DCC in the flue gas. The blowdown is taken out after the filter but before the cooler and mixed into the return water of cooler EA-2101. This way the cooler does not have to handle the extra duty that would otherwise be imposed by the blowdown stream.

Absorption:

CO₂ Absorber DA-2102 (Refer to Figure 3-18):

From the DCC, the cooled flue gas enters the bottom of the CO₂ Absorber and flows up the tower counter current to a stream of 20 wt% MEA solution. The LAM enters the top of the column and heats up gradually as more and more CO₂ is absorbed. By the time the stream leaves the bottom of the tower, it has gained approximately 16°C (28°F). The tower has been designed to remove 96% of the CO₂ from the incoming gas. The CO₂ loading in LAM is 0.215 mol CO₂/mol MEA, while the loading of the rich amine leaving the bottom is 0.44 mol CO₂/mol MEA. These values are consistent with the values reported by Rochelle (2000).

To maintain water balance in the process, it is imperative that the temperature of the LAM feed be very close to that of the feed gas stream. Thus, with feed gas temperature fixed at 46°C (115°F), the temperature of the LAM stream must also be close to 46°C (115°F), preferably within 5.5°C (10°F). If the feed gas comes in at a higher temperature than the LAM, it brings in excess moisture, which condenses in the Absorber and becomes excess water. Unless this water is purged from the system, the concentration of MEA will decrease and the performance of the system will suffer. If on the other hand, the gas feed is colder than the LAM, it heats up in the tower and picks up extra moisture that is then carried out of the system by the vent gas. The result is a water deficiency situation because more water is removed than what comes into the system.

For the reasons explained above, it is essential that both the temperature of the flue gas and that of the LAM be accurately controlled. In fact, it is best to control one temperature and adjust the temperature of the other to maintain a fixed temperature difference. The design temperature difference is approximately 5.5°C (10°F). The LAM temperature was chosen to be the “master” and the gas temperature to be the “slave.”

The rich MEA solvent solution from the bottom of the absorber at 56°C (133°F) is heated to 95.5°C (204°F) by heat exchange with lean MEA solvent solution returning from the stripping

column. The rich MEA solvent is then fed to the top of the stripping column. The lean MEA solvent solution, thus partially cooled to 62°C (143°F), is further cooled to 41°C (105°F) by exchange with cooling water and fed back to the absorber to complete the circuit.

CO₂ Absorber DA-2102 is a packed tower which contains two beds of structured packing and a third bed, the so-called “Wash Zone,” at the very top of the column. There is also a liquid distributor at the top of each bed. The distributors for the main beds are of high-quality design. There are several reasons for selecting structured packing for this service:

- Very low pressure drop which minimized fan horsepower
- High contact efficiency / low packing height
- Good tolerance for mal-distribution in a large tower
- Smallest possible tower diameter
- Light weight

At the bottom of the tower, there is the equivalent of a chimney tray, which serves as the bottom sump for the absorber. Instead of being flat like a typical chimney tray, it is a standard dished head with chimneys. The hold-up volume of the bottom sump is sufficient to accept all the liquid held up in the packing, both in the CO₂ absorber and in the Wash Zone. Rich Solvent Pump GA-2103 A/D takes suction from the chimney tray.

Absorber Wash Zone (Refer to Figure 3-18):

The purpose of the Wash Zone at the top of the tower is to minimize MEA losses, both due to mechanical entrainment and also due to evaporation. This is achieved by circulating wash water in this section to scrub most of the MEA from the lean gas exiting the Absorber. The key to minimizing MEA carryover is a mist separator pad between the wash section and the absorber. But, the demister cannot stop losses of gaseous MEA carried in the flue gas. This is accomplished by scrubbing the gas with counter current flow of water. Wash Water Pump GA-2101 takes water from the bottom of the wash zone and circulates it back to the top of the bed. The circulation rate has been chosen to irrigate the packing sufficiently for efficient operation.

The key to successful scrubbing is to maintain a low concentration of MEA in the circulating water. As the MEA concentration increases, the vapor pressure of MEA also increases and, consequently, higher MEA losses are incurred. Therefore, relatively clean water must be fed to the wash zone as make-up while an equal amount of MEA laden water is drawn out. A simple gooseneck seal accomplishes this and maintains a level in the chimney tray at the bottom of the wash section. Overflow goes to the main absorber. Make-up water comes from the overhead system of the Solvent Stripper.

The lean flue gas leaving the wash zone is released to atmosphere. The top of the tower has been designed as a stack, which is made high enough to ensure proper dispersion of the existing gas.

Rich/Lean Solvent Exchanger EA-2205 (Refer to Figure 3-19):

The Rich/Lean Solvent Exchange is a plate type exchanger with rich solution on one side and lean solution on the other. The purpose of the exchanger is to recover as much heat as possible from the hot lean solvent from the bottom of the solvent stripper by heating the rich solvent feeding the Solvent Stripper. This reduces the duty of the Solvent Stripper Reboiler. This exchanger is the single most important item in the energy economy of the entire CO₂ Recovery Unit. For this study, 5.5°C (10°F) approach was chosen to maximize the heat recovery. An air

cooler (EC-2201) was added on the lean amine stream leaving the Solvent Stripper. This was to reduce the plot space requirement (compared to placing the air cooler downstream of the rich/lean exchanger) and overall cost of the project. A study was performed which determined that heat transfer via the plate frame lean/rich exchanger is relatively cheap, and thus justifies tight temperature approaches for the exchanger.

Stripping:

Solvent Stripper DA-2201 (Refer to Figure 3-19):

The solvent Stripper is a packed tower which contains two beds of structured packing and a third bed, also called “wash zone,” at the very top of the column. The purpose of the Solvent Stripper is to separate the CO₂ (contained in the rich solvent) from the bottom stream of the CO₂ Absorber that is feeding the stripper. As the solvent flows down, the bottom hot vapor from the reboiler continues to strip the CO₂ from the solution. The final stripping action occurs in the reboiler. The hot wet vapors from the top of the stripper contain the CO₂, along with water vapor and solvent vapor. Solvent Stripper CW Condenser (EA-2206) cools the overhead vapors, where most of the water and solvent vapors condense. The CO₂ does not condense. The condensed overhead liquid and gaseous CO₂ are separated in a reflux drum (FA-2201). CO₂ flows to the CO₂ purification section on pressure control and the liquid (called reflux) is returned via Solvent Stripper Reflux Pump (GA-2202 A/B) to the top bed in the stripper. The top bed of the stripper is a water wash zone designed to limit the amount of solvent (MEA) vapors entering the stripper overhead system.

Solvent Stripper Reboiler EA-2201 (Refer to Figure 3-19):

The steam-heated reboiler is a vertical shell-and-tube thermo-siphon type exchanger using inside coated high flux tubing proprietary of UOP. Circulation of the solvent solution through the reboiler is natural and is driven by gravity and density differences. The reboiler tube side handles the solvent solution and the shell side handles the steam. The energy requirement for the removal of CO₂ is about 2.36 tonnes of steam per tonne of CO₂ (2.6 tons of steam per ton of CO₂) for Case 5/Concept A.

Solvent Reclaimer EA-2203 (Refer to Figure 3-19):

The solvent Stripper Reclaimer is a horizontal heat exchanger. Certain acidic gases, present in the flue gas feeding the CO₂ absorber, form compounds with the MEA in the solvent solution that cannot be regenerated by application of heat in the solvent stripper reboiler. These materials are referred to as “Heat Stable Salts” (HSS). A small slipstream of the lean solvent from the discharge of the Solvent Stripper Bottoms Pump (GA-2201 A/B/C) is fed to the Solvent Reclaimer. The reclaimer restores the MEA usefulness by removing the high boiling and non-volatile impurities, such as HSS, suspended solids, acids, and iron products from the circulating solvent solution. Caustic is added into the reclaimer to free MEA up from its bond with sulfur oxides by its stronger basic attribute. This allows the MEA to be vaporized back into the circulating mixture, minimizing MEA loss. This process is important in reducing corrosion and fouling in the solvent system. The reclaimer bottoms are cooled (EA-2204) and are supplied to a tank truck without any interim storage.

Solvent Stripper Condenser EA-2206 (Refer to Figure 3-19):

EA-2206 is a water-cooled shell and tube exchanger. The purpose of the condenser is to completely condense all components contained in the overhead vapor stream that can condense under the operating conditions, with the use of cooling water as the condensing medium. Components that do not condense include nitrogen, carbon dioxide, oxygen, nitrogen oxides, and carbon monoxide. The water vapor and MEA solvent vapor will condense and the condensed water will dissolve some carbon dioxide. This exchanger uses cooling water capacity freed up due to the reduced load on the existing surface condensers of the power plant. The same is true for the lean solvent cooler (EA-2202).

Solvent Stripper Reflux Drum, FA-2201 (Refer to Figure 3-19):

The purpose of the reflux drum is to provide space and time for the separation of liquid and gases, provide liquid hold-up volume for suction to the reflux pumps, and provide surge for the pre-coat filter. The separation is not perfect, as a small amount of carbon dioxide is left in the liquid being returned to the stripper. The CO₂, saturated with water, is routed to the CO₂ compression and liquefaction system.

Solvent Stripper Reflux Pump, GA-2202 (Refer to Figure 3-19):

This pump takes suction from the reflux drum and discharges on flow control to the stripper top tray as reflux.

Solvent Filtration Package, PA-2251, (Refer to Figure 3-19):

Pre-coat Filter PA-2251 is no ordinary filter; it is a small system. The main component is a pressure vessel that has a number of so called “leaves” through which MEA flows. The leaves have a thin (1/8 inch) coating of silica powder, which acts to filter off any solids. For the purposes of such application the powder is called “filter aid.”

To cover the leaves with the filter aid, the filter must be “pre-coated” before putting it into service. This is accomplished by mixing filter aid in water at a predetermined ratio (typically 10 wt%) to prepare slurry. This takes place in an agitated tank. A pump, which takes it suction from this tank, is then operated to pump the slurry into the filter. Provided the flow rate is high enough, the filter aid is deposited on the leaves while water passes through and can be recycled back to the tank. This is continued until the water in the tank becomes clear, indicating that all the filter aid has been transferred.

The volume of a single batch in the tank is typically 125% of the filter volume because there must be enough to fill the vessel and have some excess left over so the level in the tank is maintained and circulation can continue. In this design, water from the Stripper overhead will be used as make-up water to fill the tank. This way, the water balance of the plant is not affected.

During normal operation, it is often beneficial to add so-called “body” which is the same material as the pre-coat but may be of different particle size. The body is also slurried in water but is continually added to the filter during operation. This keeps the filter coating porous and prevents rapid plugging and loss of capacity. As the description suggests, an agitated tank is needed to prepare the batch. A metering pump is then used to add the body at a prescribed rate to the filter.

When the filter is exhausted (as indicated by pressure drop), it is taken off line so the dirty filter aid can be removed and replaced with fresh material. To accomplish this, the filter must be

drained. Pressurizing the filter vessel with nitrogen and pushing the MEA solution out of the filter accomplishes this. After this step, the filter is depressurized. Then, a motor is started to rotate the leaves so a set of scrapers will wipe the filter cake off the leaves. The loosened cake then falls off into a conveyor trough in the bottom of the vessel. This motor-operated conveyor then pushes the used cake out of the vessel and into a disposal container (oil drum or similar). The rejected cake has the consistency of toothpaste. This design is called “dry cake” filter and minimizes the amount of waste produced.

For this application, some 2% of the circulating MEA will be forced to flow through the filter. In fact, Filter Circulating Pump GA-2203 draws the liquid through the filter as it has been installed downstream of the filter. The advantage of placing the pump on the outlet side of the filter is reduced design pressure of the filter vessel and associated piping. In spite of the restriction on its suction side, ample NPSH is still available for the pump. Flow is controlled on the downstream side of the pump.

Corrosion Inhibitor (Refer to Figure 3-19):

Corrosion inhibitor chemical is injected into the process constantly to help control the rate of corrosion throughout the CO₂ recovery plant system. Since rates of corrosion increase with high MEA concentrations and elevated temperatures, the inhibitor is injected at appropriate points to minimize the corrosion potential. The inhibitor is stored in a tank (Part of the Package, not shown) and is injected into the system via injection pump (Part of the Package, not shown). The pump is a diaphragm-metering pump.

The selection of metallurgy in different parts of the plant is based on the performance feedback obtained from our similar commercial units in operation over a long period of time.

CO₂ Compression, Dehydration, and Liquefaction:

(Refer to Figure 30-20):

CO₂ from the solvent stripper reflux drum, GA-2201, is saturated with water, and is compressed in a three-stage centrifugal compressor using the air and cooling water from the new cooling tower for interstage and after-compression cooling. The interstage coolers for first and second stage are designed to supply 35°C (95°F) CO₂ to the compressor to minimize the compression power requirements.

Most of the water in the wet CO₂ stream is knocked out during compression and is removed from intermediate suction drums. A CO₂ drier is located after the third stage compressor to meet the water specifications for the CO₂ product. The water-free CO₂ is liquefied after the third stage of compression at about 13.4 barg (194 psig) pressure by transferring heat to propane refrigerant. CO₂ is then pumped (GA-2301) to the required battery limit pressure of 138 barg (2000 psig).

The propane refrigeration system requires centrifugal compressors, condensers, economizers, and evaporators to produce the required cold. The centrifugal compressor is driven by an electric motor and is used to raise the condensing temperature of the propane refrigerants above the temperature of the available cooling medium. The condenser is used to cool and condense the discharged propane vapor from the compressor back to liquid form. The economizer, which improves the refrigerant cycle efficiency, is designed to lower the temperature of the liquid propane by flashing or heat exchange. The evaporator liquefies the CO₂ vapor by transferring heat from the CO₂ vapor stream to the boiling propane refrigerant.

Drying:

CO₂ Drier, FF-2351 (Refer to Figure 3-20):

The purpose of the CO₂ drier is to reduce the moisture content of the CO₂ product to less than 20 ppmv to meet pipeline transport specifications. The drier package, FF-2351, includes four drier vessels, three of which are in service while one is being regenerated or is on standby. The package also includes a natural gas fired regeneration heater and a cooled regeneration cooler. The exchanger will have a knock out cooler downstream for separating the condensed water. The drier used as a basis for cost estimation is good for a 10-hour run length based on 3A molecular sieve.

The drier is located on the discharge side of the third stage of the CO₂ Compressor. Considering the cost of the vessel and the performance of the desiccant, this is the location favored by vendors. The temperature of the CO₂ stream entering the drier is 32°C (90°F).

Once a bed is exhausted, it is taken off line, and a slipstream of effluent from the online beds is directed into this drier after being boosted in pressure by a compressor. Before the slipstream enters the bed that is to be regenerated, it is heated to a high temperature. Under this high temperature, moisture is released from the bed and carried away in the CO₂ stream. The regeneration gas is then cooled to the feed gas temperature to condense any excess moisture. After this, the regeneration gas stream is mixed with the feed gas upstream of the third-stage knockout drum.

All the regeneration operations are controlled by a PLC that switches the position of several valves to direct the flow to the proper drier. It also controls the regeneration compressor, heater, and cooler. Because the regeneration gas has the same composition as the feed gas, it also contains some moisture. Thus, it is primarily the heat (“temperature swing”) that regenerates the bed.

Process Flow Diagrams:

The processes described above are illustrated in the following process flow diagrams:

- Figure 3-18: Drawing D 09484-01001R-0: Flue Gas Cooling and CO₂ Absorption
- Figure 3-19: Drawing D 09484-01002R-0: Solvent Stripping
- Figure 3-20: Drawing D 09484-01003R-0: CO₂ Compression and Liquefaction




Figure 3-18: Process Flow Diagram for Case 5/Concept A: Flue Gas Cooling and CO₂ Absorption




Figure 3-19: Process Flow Diagram for Case 5/Concept A: Solvent Stripping




Figure 3-20: Process Flow Diagram for Case 5/Concept A: CO₂ Compression, Dehydration, and Liquefaction

3.1.5.2 Case 5/Concept A Overall Material and Energy Balance - CO₂ Removal, Compression, and Liquefaction System

The material balances (Table 3-37 and Table 3-38) were run on two process simulators: Hysim and Amsim. Amsim was used for the Absorption/Stripping systems while Hysim was used for the conventional systems as follows:

- Flue Gas feed Hysim
- Absorber and Stripper Amsim
- Compression Hysim

The two simulators use a different reference enthalpy. They also use slightly different calculation methods for determining water saturation quantities. There is no simple way to normalize the enthalpies to the same reference. Thus, the enthalpies given in the balance are the values copied directly from the simulation. This creates a discontinuity at the interface between Hysim and Amsim simulations - take for example the wet CO₂ flow to the CO₂ compressor. The stream comes from the Stripper overhead system, which was simulated with Amsim and enters the CO₂ compressor, which was simulated using Hysim. For this particular stream, the enthalpy value given in the balance comes from Hysim. Lastly, convergence algorithms allow the programs to slightly alter input streams. Thus, some leniency and care should be exercised when using such interface streams for heat balance checks. This section contains heat and material balances for Case 5/Concept A.



Table 3-37: Material and Energy Balance for Case 5/Concept A Amine System

TEMPERATURE F	150	115	115	115	115	105	133	106	133	133	133	204
PRESSURE PSIA	16.5	16.5	16.5	16.5	16.5	14.9	16.5	14.9	16.5	16.5	16.5	16.5
COMPONENTS												
CO2 (Carbon Dioxide) LbMol/HR	19,684.00	3,936.80	3,936.80	3,936.23	0.14	3,585.44	7,380.58	141.1	36,902.89	4,100.32	4,100.32	4,100.32
MEA LbMol/HR	0	0	0	0	0	16,765.89	16,763.07	2.82	83,815.36	9,312.82	9,312.82	9,312.82
H2O (Water) LbMol/HR	24,551.00	4,910.20	4,910.20	2,544.80	2,365.50	227,379.00	228,257.60	1,666.30	1,141,288.00	126,809.80	126,809.80	126,809.80
C1 (Methane) LbMol/HR	0	0	0	0	0	0	0	0	0	0	0	0
N2 (Nitrogen) LbMol/HR	105,079.00	21,015.80	21,015.80	21,016.14	0.02	0	1.75	21,014.40	8.76	0.97	0.97	0.97
O2 (Oxygen) LbMol/HR	4,518.00	903.6	903.6	903.61	0	0	0.14	903.47	0.7	0.08	0.08	0.08
Total Molar Flow Rate LbMol/HR	153,832.00	30,766.40	30,766.40	28,400.80	2,365.60	247,730.40	252,403.20	1,262,281.10	1,262,016.00	140,224.00	140,224.00	140,224.00
VAPOR												
MASS FLOW RATE LbMol/HR	446,600.625	3,572.805	3,572.805	3,397.068					2,438.328			
STD. VOL. FLOW RATE MMSCFD	1401.1	280.22	280.22	258.66					216.1			
ACTUAL VOL. FLOW RATE MMACFD	1378	275.6	275.6	254.5					231.72			
MOLECULAR WEIGHT MW	285.821	57.1642	57.1642	58.9234					55.1246			
STD. DENSITY Lb/Ft3	0.765	0.153	0.153	0.1576					0.1354			
GAS COMPRESSIBILITY	0	0	0	0					0			
VISCOSITY cP	0	0	0	0					0			
HEAT CAPACITY Btu/Lb-F	0	0	0	0					0			
THERMAL CONDUCTIVITY Btu/Hr-ft-F	127.958	25.5916	25.5916	27.7192					1.1892			
LIQUID												
MASS FLOW RATE Lb/Hr					85,263	10,557,848	10,923,302		273,082,551	3,371,390	3,371,390	3,371,390
STD. VOL. FLOW RATE GPM					85.26	10252.78	10352.54		51762.7	5751.41	5751.41	5751.41
ACTUAL VOL. FLOW RATE GPM					86.02	10308.54	10467.22		52336.1	5815.12	5815.12	5940.3
MOLECULAR WEIGHT MW					18.02	21.31	21.64		21.64	21.64	21.64	21.64
STD. DENSITY Lb/Ft3					62.34	64.19	65.77		65.77	65.77	65.77	65.77
VISCOSITY cP					0.6383	0.8608	0.6868		0.6868	0.6868	0.6868	0.3544
HEAT CAPACITY Btu/Lb-F					0.9948	0.9357	0.9221		0.9221	0.9221	0.9221	0.9325
THERMAL CONDUCTIVITY Btu/Hr-ft-F					0.3979	0.3557	0.3557		0.3557	0.3557	0.3557	0.3557

STREAM NAME	Rich Amine Feed to Regenerator	Regenerator Overhead Vapor	Regenerator Condenser Outlet	Acid Gas	Regenerator Reflux Liquid	Liquid to Regenerator Reboiler	Regenerator Reboiler Vapor	Lean Amine from Regenerator Reboiler	Lean Amine from Lean/Rich Heat Exchanger	Lean Amine to Cooler	Amine and Water Make-up	Total Acid Gas
STREAM NO.	35	36	37	38	39	41	42	43	21	21	47	24
LIQUID FRACTION	1	0	1	0	1	1	0	1	1	1	1	0
TEMPERATURE F	209	209	105	105	105	248	250	250	173	173	68	105
PRESSURE PSIA	28	26	23	23	23	29.8	30	30	30	30	30	23
COMPONENTS												
CO2 (Carbon Dioxide) LbMol/Hr	4,100.32	2,081.06	2,081.06	2,079.81	1.27	2,701.12	680.61	2,020.51	2,020.51	2,020.51	0	18,718.28
MEA	9,312.82	9.92	9.92	0.01	9.9	9,381.40	68.6	9,312.81	9,312.81	9,314.38	1.58	0.11
H2O (Water) LbMol/Hr	126,809.80	2,128.70	2,128.70	105.7	2,023.00	137,717.90	11,013.80	126,704.00	126,704.00	126,321.80	-382.3	951.3
C1 (Methane) LbMol/Hr	0	0	0	0	0	0	0	0	0	0	0	0
N2 (Nitrogen) LbMol/Hr	0.97	0.97	0.97	0.97	0	0	0	0	0	0	0	8.76
O2 (Oxygen) LbMol/Hr	0.08	0.08	0.08	0.08	0	0	0	0	0	0	0	0.7
Total Molar Flow Rate	140,224.00	4,220.70	4,220.70	2,186.60	2,034.10	149,800.30	11,763.00	138,037.30	138,037.30	137,656.70	-380.7	19,679.20
VAPOR												
MASS FLOW RATE Lb/Hr		221,688		166,131			429,305					121,109,333
STD. VOL. FLOW RATE MMSCFD		38.44		19.91			107.13					179.2
ACTUAL VOL. FLOW RATE MMACFD		27.73		13.72			70.62					123.5
MOLECULAR WEIGHT MW		34.37		47.5			21.97					427.46
STD. DENSITY Lb/Ft3		0.12		0.18			0.09					1.62
GAS COMPRESSIBILITY		0		0			0					0
VISCOSITY cP		0		0			0					0
HEAT CAPACITY Btu/Lb-F		0		0			0					0
THERMAL CONDUCTIVITY Btu/Hr-ft-F		54.78		105.69			6.43					951.17
LIQUID												
MASS FLOW RATE Lb/Hr	3,371,390		145,088		41,234	3,525,978		3,267,542	3,267,542	3,259,998	-7,547	
STD. VOL. FLOW RATE MMSCFD	5751.41		247.18		73.13	6116.13		5709.78	5709.78	5696.53	-13.59	
ACTUAL VOL. FLOW RATE MMACFD	5951.79		248.73		73.61	6434.23		6011.14	5839.38	5825.79	-13.6	
MOLECULAR WEIGHT MW	21.64		30.94		18.24	21.18		21.3	21.3	21.31	-17.84	
STD. DENSITY Lb/Ft3	65.77		65.86		63.27	64.69		64.21	64.21	64.21	62.31	
VISCOSITY cP	0.3401		0.6888		0.6655	0.2592		0.2564	0.4548	0.4549	1.2839	
HEAT CAPACITY Btu/Lb-F	0.9324		0.4962		0.9902	0.9481		0.9491	0.9513	0.9513	0.9454	
THERMAL CONDUCTIVITY Btu/Hr-ft-F	0.3557		0.3945		0.3944	0.3583		0.3557	0.3557	0.3557	0.3664	



Table 3-38: Material and Energy Balance for Case 5/Concept A CO₂ Compression, Dehydration and Liquefaction System

STREAM NAME	Total Acid gas from strippers	To train A liquefaction	First stage discharge	To second stage	First stage water KO	2nd stage discharge	To 3rd stage	2nd stage water KO	From 3rd stage	To drier	3rd stage water KO
STREAM NO.	300	300	301	302	310	303	304	309	306	305	314
VAPOR FRACTION Molar	1.000	1.000	1.000	1.000	0.000	1.000	1.000	0.000	1.000	1.000	0.000
TEMPERATURE F	105	105	230	95	95	236	95	95	282	90	90
PRESSURE PSIG	4	4	25	19	19	62	56	56	191	185	185
MOLAR FLOW RATE LbMol/Hr	19,679.08	2,811.30	2,811.30	2,743.70	67.60	2,743.70	2,708.50	35.19	2,708.50	2,686.56	21.94
MASS FLOW RATE Lb/Hr	841,192	120,170	120,170	118,951	1,219	118,951	118,315	636	118,315	117,917	398
ENERGY Btu/Hr	8.79E+07	1.26E+07	1.58E+07	1.58E+07	-9.79E+05	1.56E+07	1.17E+07	-5.09E+05	1.64E+07	1.10E+07	-3.18E+05
COMPOSITON Mol %											
CO ₂	95.12%	95.12%	95.12%	97.46%	0.09%	97.46%	98.72%	0.18%	98.72%	99.52%	0.54%
H ₂ O	4.83%	4.83%	4.83%	2.49%	99.91%	2.49%	1.23%	99.82%	1.23%	0.42%	99.46%
Nitrogen	0.04%	0.04%	0.04%	0.05%	0.00%	0.05%	0.05%	0.00%	0.05%	0.05%	0.00%
Ammonia	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
Propane	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
Oxygen	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
VAPOR											
MOLAR FLOW RATE LbMol/Hr	19,679.10	2,811.30	2,811.30	2,743.70	--	2,743.70	2,708.50	--	2,708.50	2,686.60	--
MASS FLOW RATE Lb/Hr	841,192	120,170	120,170	118,951	--	118,951	118,315	--	118,315	117,917	--
STD VOL. FLOW MMSCFD	179.23	25.6	25.6	24.99	-	24.99	24.67	-	24.67	24.47	-
ACTUAL VOL. FLOW ACFM	103,907.68	14,843.95	8,749.53	8,063.83	-	4,417.63	3,728.32	-	1,698.44	1,224.03	-
MOLECULAR WEIGHT MW	42.75	42.75	42.75	43.35	-	43.35	43.68	-	43.68	43.89	-
DENSITY Lb/Ft ³	0.13	0.13	0.23	0.25	--	0.45	0.53	--	1.16	1.61	--
VISCOSITY cP	0.0149	0.0149	0.0187	0.0149	--	0.0193	0.0152	--	0.0212	0.0154	--
HYDROCARBON LIQUID											
MOLAR FLOW RATE LbMol/Hr	--	--	--	--	--	--	--	--	--	--	--
MASS FLOW RATE Lb/Hr	--	--	--	--	--	--	--	--	--	--	--
STD VOL. FLOW MMSCFD	-	-	-	-	-	-	-	-	-	-	-
ACTUAL VOL. FLOW ACFM	-	-	-	-	-	-	-	-	-	-	-
MOLECULAR WEIGHT MW	-	-	-	-	-	-	-	-	-	-	-
DENSITY Lb/Ft ³	-	-	-	-	-	-	-	-	-	-	-
VISCOSITY cP	-	-	-	-	-	-	-	-	-	-	-
SURFACE TENSION Dyne/Cm	-	-	-	-	-	-	-	-	-	-	-

STREAM NAME	From drier / To condenser	Water from drier	From condenser	From product pump	From Train A liquefaction	To pipeline	Refrig compressor discharge	From refriger condenser	From subcooler	Refrig to CO ₂ condenser	Refrig from CO ₂ condenser
STREAM NO.	307	311	312	308	309	313	400	401	402	403	404
VAPOR FRACTION Molar	1.000	0.726	0.000	0.000	0.000	0.000	1.000	0.000	0.000	0.173	0.996
TEMPERATURE F	90	380	-26	-12	82	82	149	95	24	-31	-31
PRESSURE PSIG	180	180	2,003	2,000	2,000	2,000	169	162	159	5	5
MOLAR FLOW RATE LbMol/Hr	2,675.15	11.41	2,675.15	2,675.15	2,675.15	18,726.05	2,928.57	2,928.57	2,928.57	2,928.57	2,928.57
MASS FLOW RATE Lb/Hr	117,711	206	117,711	117,711	117,711	823,979	129,141	129,141	129,141	129,141	129,141
ENERGY Btu/Hr	1.10E+07	2.51E+04	-8.07E+06	-7.29E+06	-1.36E+06	-9.50E+06	1.81E+07	7.63E+05	-5.17E+06	-5.17E+06	1.39E+07
COMPOSITON Mol %											
CO ₂	99.95%	0.00%	99.95%	99.95%	99.95%	99.95%	0.00%	0.00%	0.00%	0.00%	0.00%
H ₂ O	0.00%	100.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
Nitrogen	0.05%	0.00%	0.05%	0.05%	0.05%	0.05%	0.00%	0.00%	0.00%	0.00%	0.00%
Ammonia	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
Propane	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	100.00%	100.00%	100.00%	100.00%	100.00%
Oxygen	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
VAPOR											
MOLAR FLOW RATE LbMol/Hr	2,675.2	8.3	--	--	--	--	2,928.6	--	--	506.5	2,915.8
MASS FLOW RATE Lb/Hr	117,711	149	--	--	--	--	129,141	--	--	22,334	128,577
STD VOL. FLOW MMSCFD	2.436	0.08	--	--	--	--	2.667	--	--	4.61	2.656
ACTUAL VOL. FLOW ACFM	1,253.44	5.96	--	--	--	--	3,573.03	--	--	1,860.34	10,709.92
MOLECULAR WEIGHT MW	44.00	18.02	--	--	--	--	44.10	--	--	44.10	44.10
DENSITY Lb/Ft ³	1.57	0.42	--	--	--	--	0.6	--	--	0.20	0.2
VISCOSITY cP	0.0155	0.0154	--	--	--	--	0.0082	--	--	0.0065	0.0065
HYDROCARBON LIQUID											
MOLAR FLOW RATE LbMol/Hr	--	--	2,675.15	2,675.15	2,675.15	18,726.05	--	2,928.57	2,928.57	2,422.10	12.79
MASS FLOW RATE Lb/Hr	--	--	117,711.33	117,711.33	117,711.33	823,979.29	--	129,141.22	129,141.22	106,807.22	563.95
STD VOL. FLOW MMSCFD	-	-	9.766	9.766	9.766	68,360	--	17,452	17,452	14,434	76
ACTUAL VOL. FLOW ACFM	-	-	217.05	213.53	289.79	2,028.56	--	541.52	480.49	372.27	1.97
MOLECULAR WEIGHT MW	-	-	67.61	68.73	50.64	50.64	--	29.73	33.51	35.77	35.77
DENSITY Lb/Ft ³	-	-	44	44	44	44	--	44.1	44.1	44.1	44.1
VISCOSITY cP	-	-	0.1752	0.1607	0.062	0.062	--	0.0906	0.1332	0.1823	0.1823
SURFACE TENSION Dyne/Cm	-	-	16.07	14.07	0.86	0.86	--	5.74	10.51	14.49	14.49

3.1.5.3 Case 5/Concept A Equipment List – CO₂ Removal, Compression, and Liquefaction

Complete equipment data summary sheets for Case 5/Concept A are provided in Appendix II. These equipment lists have been presented in the so-called “short spec” format, which provides adequate data for developing a factored cost estimate.

It should be noted that although Cases 1 and 5 both capture about the same amount of CO₂ (90% and 96% respectively), the design of Case 5 (See Bozzuto et al., 2001), which was developed in 2000, is not totally consistent with the design of Case 1 done in the current study. Table 3-39, which summarizes the major equipment categories for Case 1 and 5, shows that Case 1 uses two absorber trains, two stripper trains, and two compression trains. Case 5, which was designed in 2000, uses five absorber trains, nine stripper trains, and seven compression trains. Additionally, the total number of heat exchangers in the system for Case 1 is 58 whereas for Case 5 is 131. Because of these differences, Case 1 is able to take advantage of significant economy of scale effects for equipment cost with the larger equipment sizes in each train as compared to Case 5. Additionally, Case 5 equipment was all located about 457 m (1,500 ft) from the Unit #5 stack, which also increased the costs of Case 5 relative to Case 1.

Table 3-39: Equipment Summary CO₂ Removal, Compression, and Liquefaction System (Cases 1, 5)

	Case 1 (90% recovery)		Case 5 (96% recovery)	
	No.	HP each	No.	HP each
Compressors				
CO ₂ Compressor	2	15,600	7	4,500
Propane Compressor	2	11,700	7	3,100
LP Let Down Turbine	1	60,800	1	82,300
Towers/Internals	No.	ID/Height (ft)	No.	ID/Height (ft)
Absorber/Cooler	2	34 / 126	5	27 / 126
Strippers	2	22 / 50	9	16 / 50
Heat Exchangers	No.	10 ⁶ -Btu/Hr ea.	No.	10 ⁶ -Btu/Hr ea.
Reboilers	10	120.0	9	217.0
Solvent Stripper CW Condenser	12	20.0	9	42.0
Other Heat Exchangers / Avg Duty	36	61.0	113	36.0
Total Heat Exchangers / Avg Duty	58	101.0	131	56.6

3.1.5.4 Case 5/Concept A Consumption of Utilities - CO₂ Removal, Compression, and Liquefaction System

The following utilities from OSBL are required in the CO₂ Recovery Unit.

- Steam
- High Pressure (HP) Steam
- Low Pressure (LP) Steam
- Water
- Demineralized Water
- Raw Water (Fresh Water, Cooling tower make-up)

- Potable Water (hoses, etc.)
- Air
- Plant Air (maintenance, etc.)
- Instrument Air
- Electric Power
- Natural Gas

Note: The CO₂ Recovery Plant includes cooling water pumps that supply all the cooling water required by this unit. Case 5/Concept A utility consumption is presented in Table 3-40 and the auxiliary power consumption is shown in Table 3-41.

Table 3-40: Utility Consumption for Case 5/Concept A

Utility	Amount Consumed	Units
Natural Gas	0.42	10 ⁶ SCFD
Steam (180 psig)	1,950,000	Lb/hr
Cooling water	22,000	Gpm

Table 3-41: Auxiliary Power Usage for Case 5/Concept A

Number of Trains	Tag no.	Description	Number Operating per train	Power (ea) w/ 0.95 motor eff (kW)	Total all trains (kW)
5	GA-2101 A/B	Wash Water Pump	1	19	95
5	GA-2102 A/B	Direct Contact Cooler Water Pump	1	32	162
5	GA-2103 A/B/C/D	Rich Solvent Pump	3	146	729
9	GA-2201 A/B/C	Lean Solvent Pump	2	117	1,053
9	GA-2202 A/B	Solvent Stripper Reflux Pump	1	3	28
9	GA-2203 A/B	Filter Circ. Pump	1	12	107
7	GA-2301 A/B	CO ₂ Pipeline Pump	1	184	1,288
9	GA-2204 A/B	LP condensate booster pump	1	74	667
3	GA-2501	Caustic metering pump	1	0	0
7	GB-2301	CO ₂ Compressor (Motor driven)	1	3,557	24,901
7	GB-2401	Propane Refrigeration Compressor	1	2,395	16,765
1	GB-2500	LP steam turbine/ generator	NA	NA	NA
7	EC-2301	CO ₂ Compressor 1st stage Air Cooler	1	9	66
7	EC-2302	CO ₂ Compressor 2nd stage Air Cooler	1	10	69
7	EC-2303	CO ₂ Compressor 3rd stage Air Cooler	1	15	103
9	EC-2201	Solvent Stripper Bottoms Cooler	1	256	2,305
7	PA-2351	CO ₂ Drier Package	1	151	1054
1	PA-2551	Cooling Tower	1	962	962
		Total Power			50,355

3.1.5.5 Case 5/Concept A Consumption of Chemicals and Desiccants - CO₂ Removal, Compression, and Liquefaction System

The consumption of chemicals and desiccants for Case 5/Concept A are identified in Table 3-42.

Table 3-42: Chemicals and Desiccants Consumption for Case 5/Concept A

Chemical	Consumption per day (lbm)
Caustic (100%)	3600
MEA	14000
Corrosion inhibitor	1140
Diatomaceous earth	916
Molecular sieve	257
Sodium hypochlorite	3590
Sodium bisulfite	13.8

This total does not include chemicals provided by the cooling tower service people nor disposal of waste. These are handled as a component of operating costs referred to as contracted services and waste handling, respectively.

3.1.5.6 Case 5/Concept A Design Considerations - CO₂ Removal, Compression, and Liquefaction System

The following parameters were optimized for Case 5/Concept A with the objective of reducing the overall unit cost and energy requirements.

- Solvent Concentration
- Lean Amine Loading
- Rich Amine Loading
- Absorber Temperature
- Rich /Lean Exchanger approach
- CO₂ Compressor interstage temperatures
- CO₂ Refrigeration Pressure and Temperature

A minimum of 90% CO₂ recovery was targeted. The above parameters were adjusted to increase the recovery until a significant increase in equipment size and/or energy consumption was observed. AES Corporation owns and operates a 200 STPD food grade CO₂ production plant in Oklahoma. This plant was designed and built by ABB Lummus Global as a part of the larger power station complex using coal-fired boilers. This plant started up in 1990 and has been operating satisfactorily with lower than designed MEA losses. The key process parameters from the present design for Case 5/Concept A are compared with those from the AES plant (Barchas and Davis, 1992) in Table 3-43.

Table 3-43: Key Process Parameters Comparison for Case 5/Concept A

PROCESS PARAMETER	AEP DESIGN (Case 5/Concept A)	AES DESIGN
Plant Capacity (TPD)	9,888	200
CO ₂ in Feed, (% mol)	13.9	14.7
O ₂ in Feed, (% mol)	3.2	3.4
SO ₂ in Feed, (ppmv)	10 (Max)	10 (Max)
Solvent	MEA	MEA
Solvent Conc. (wt%)	20	15 (Actual 17-18 wt%)
Lean Loading (mol CO ₂ / mol MEA)	0.21	0.10
Rich Loading (mol CO ₂ / mol MEA)	0.44	0.41
Stripper Feed Temperature, °F	210	194
Stripper Bottom Temperature, °F	250	245
Feed Temperature to Absorber, °F	105	108
CO ₂ Recovery, %	96	90 (Actual 96%-97%)
Absorber Pressure Drop, psi	1	1.4
Stripper Pressure Drop, psi	0.6	4.35
R/L Exchanger Approach, °F	10	50
CO ₂ Compressor I/STG Temperature, °F	105	115
Liquid CO ₂ Temperature, °F	82	-13
Steam Consumption, lbm steam/ lbm CO ₂	2.6	3.45
Liquid CO ₂ Pressure (psia)	2,015	247

3.1.5.7 Case 5/Concept A OSBL Systems - CO₂ Removal, Compression, and Liquefaction System

Reclaimer Bottoms (Case 5/Concept A):

The reclaimer bottoms are generated during the process of recovering MEA from heat stable salts (HSS), which are produced from the reaction of MEA with SO₂ and NO₂. The HSS accumulate in the reclaimer during the lean amine feed portion of the reclaiming cycle. The volume of reclaimer bottoms generated will depend on the quantity of SO₂ and NO₂ that is not removed in the Flue Gas Scrubber. A typical composition of the waste is presented in Table 3-44.

Table 3-44: Reclaimer Bottoms Composition for Case 5/Concept A

MEA	9.5 wt%
NH ₃	0.02 wt%
NaCl	0.6 wt%
Na ₂ SO ₄	6.6 wt%
Na ₂ CO ₃	1.7 wt%
Insolubles	1.3 wt%
Total Nitrogen	5.6 wt%
Total Organic Carbon	15.6 wt%
H ₂ O	59.08 wt%
pH	10.7
Specific Gravity	1.14

Filter Residues:

A pressure leaf filter filters a slipstream of lean amine. Diatomaceous earth is used as a filter-aid for pre-coating the leaves and as a body feed. Filter cycles depend on the rate of flow through the filter, the amount of filter aid applied, and the quantity of contaminants in the solvent. A typical composition of the filter residue is provided in Table 3-45. These will be disposed of by a contracted service which hauls away the drums of spent cake.

Table 3-45: Filter Residue Composition for Case 5/Concept A

MEA	2.5 wt%
Total Organic Carbon	1.5 wt%
SiO ₂	43 wt%
Iron Oxides	32 wt%
Aluminum Oxides	15 wt%
H ₂ O	6 wt%
pH	10.0
Specific Gravity	1.0

Excess Solvent Stripper Reflux Water:

The CO₂ Recovery Facility has been designed to operate in a manner to avoid accumulation of water in the Absorber/Stripper system. Conversely, no continuous make-up stream of water is required, either. By controlling the temperature of the scrubbed flue gas to the absorber, the MEA system can be kept in water balance. Excess water can accumulate in the Stripper Reflux Drum and can be reused once the system is corrected to operate in a balanced manner. Should water need to be discarded, contaminants will include CO₂ and MEA.

Cooling Tower Blowdown:

The composition limits on cooling tower blowdown are shown in Table 3-46.

Table 3-46: Cooling Tower Blowdown Composition Limitations – Case 5/Concept A

Component	Specification
Suspended Solids	30 ppm average monthly, 100 ppm maximum daily
pH	6.9 to 9
Oil and Grease	15 ppm maximum monthly, 20 ppm maximum daily
Free Chlorine	0.035 ppm

There is a thermal limit specification for the entire river. However, the blowdown volume is too small to affect it significantly.

Relief Requirements:

The relief valve discharges from the CO₂ Recovery Unit to atmosphere. No tie-ins to any flare header are necessary.

3.1.5.8 Case 5/Concept A Plant Layout - CO₂ Removal, Compression, and Liquefaction System

The new equipment required for Case 5/Concept A covers ~7.8 acres of plot area. Plant layout drawings prepared for the Case 5/Concept A CO₂ Recovery System are as follows:

These drawings are shown in Appendix I.

- Plot Plan – Overall Site before CO₂ Unit Addition
- U01-D-0208 Plot Plan – Case 5/Concept A: Flue Gas Cooling & CO₂ Absorption
- U01-D-0214 Plot Plan – Case 5/Concept A: Solvent Stripping
- U01-D-0204 Plot Plan – Case 5/Concept A: CO₂ Compression & Liquefaction
- U01-D-0211 Plot Plan – Case 5/Concept A: Overall Layout Conceptual Plan
- U01-D-0200R Plot Plan – Case 5/Concept A: Modified Overall Site Plan

Plant layout has been designed in accordance with a spacing chart called “Oil and Chemical Plant Layout and Spacing” Section IM.2.5.2 issued by Industrial Risk Insurers (IRI).

When reviewing the layout, the first thing to observe is that no highly flammable materials are handled within the CO₂ Recovery Unit. The open cup flash point of MEA is 93°C (200°F) and, therefore, will not easily ignite. In addition to MEA, the corrosion inhibitor is the only other hydrocarbon liquid within the battery limits. The flash point of this material is higher than that of MEA and is handled in small quantities.

As the chemicals used in the process present no fire hazard, there is an opportunity to reduce the minimum spacing between equipment from that normally considered acceptable in hydrocarbon handling plants. Regardless, for the drawings that follow, standard spacing requirements - as imposed by IRI - have been followed.

The plot areas in the immediate vicinity of Unit #5 available for the installation of the desired equipment are small. Some equipment items are placed on structures to allow other pieces of equipment to be placed underneath them. This way pumps and other equipment associated with the Absorber can be located under the structure. Locating the pumps under the structure has been considered acceptable because the fluids being pumped are not flammable.

Noise is an issue with the flue gas fan as much as it is with compressors. Discussions with vendors suggest that it will be possible to provide insulation on the fan casing to limit noise to acceptable levels. Therefore, it has been assumed that no building needs to be provided for noise reasons.

Having economized on the required plot space as noted above, it was judged not to be practical to divide up the absorbers and strippers that are required into the relatively small plot areas initially offered for this purpose. Eventually, it was agreed that the units would be placed in an area about 460 m (1,500 ft) northeast of the Unit #5/6 common stack. By locating the units in a single location, the MEA piping between the absorber and stripper could be minimized, however, the flue gas duct length and steam piping with this location are quite long.

The corrosion inhibitor must be protected against freezing during winter. The caustic solution will not freeze but will become very viscous when it gets cold. Therefore, a heated shed has been provided for housing the Corrosion Inhibitor and the Caustic injection packages.

The plot plan shows a substation in the Stripper area, but none for the Absorber area. The assumption is that because the electrical consumption of the Absorber equipment is small (0.23 MW) compared to the Stripper equipment, the equipment can be run directly from the auxiliary power 480-volt power system.

For the Rich/Lean Solvent Exchanger, which is a plate and frame type exchanger, area estimates received from vendors based on similar conditions suggest that five units/train would be sufficient for the specified service.

3.1.6 Steam Cycle Modifications, Performance, and Integration with Amine Process (Cases 1-5)

This section presents the performance and modification requirements for the steam/water cycles for all five cases of this study.

3.1.6.1 Amine Process Integration

Figure 3-21 shows a simplified steam cycle schematic that highlights the basic modifications required to integrate the CO₂ capture process into the existing water-steam cycle. These modifications include:

- Addition of a new let down steam turbine generator (LSTG),
- Modification of the existing crossover piping (from existing IP turbine outlet to existing LP turbine inlet). Extracted steam will feed the new let down steam turbine generator and reclaim system of the amine CO₂ recovery system. The exhaust of the let down steam turbine generator (LSTG) ultimately provides the feed steam for the reboilers. This includes a new pressure control valve to maintain a required pressure level even at high extraction flow rates.




Figure 3-21: Modified Steam/Water Schematic (simplified)

Further modifications to the feedwater system, although not shown in Figure 3-21, are recommended in order to ensure optimum integration of the heat rejected within the CO₂ capture and compression system with the existing steam/water cycle.

For the efficient integration of the amine process into the existing water-steam cycle the locations where the steam needs to be extracted to feed the reboiler and the reclaimers need to be carefully matched. A thorough analysis of the overall process revealed that the amine system reboiler operation would be most economical at a steam pressure of 3.2 bara (47 psia) at the let down turbine exit (See Section 3.1.6.7). This pressure level also ensures that the amine will be protected from being destroyed by high temperatures. The amine system reclaimers need steam at 6.2 bara (90 psia). When defining the locations of the extraction piping, it needs to be taken into account that these pressure levels need to be maintained also at loads differing from the MCR design load.

Another important assumption was made and is of crucial importance in determination of the potential modifications and, hence, performance of the unit with the MEA plant being in operation. It was assumed that the existing steam turbine/generator is required to continue operation at maximum load in case of a trip of the MEA plant. Additionally, all pressures should still be within a level that no steam will be blown off. This is of specific relevance for any turbine modifications, since changes in steam swallowing capacity of any turbine cylinder requires taking into account this requirement.

Four different scenarios were considered in the current study to assess the impact of various levels of CO₂ removal on the cost/benefit ratio. In the following paragraphs a description of the impact of the CO₂ removal system on water-steam cycle performance will be given. Five cases are discussed as defined below:

- Case 1 - 90% CO₂ removal with advanced amine system
- Case 2 - 70% CO₂ removal with advanced amine system
- Case 3 - 50% CO₂ removal with advanced amine system

- Case 4 - 30% CO₂ removal with advanced amine system
- Case 5 - 96% CO₂ removal with Kerr/McGee ABB Lummus amine system

For ease of performance comparison, the backpressure for each of the four cases was kept constant at 6.35 cm Hga (2.5 in. Hga).

The following subsections discuss the performance and modification requirements for the steam/water cycles for all five cases of this study.

3.1.6.2 Case 1: Steam Cycle for 90% CO₂ Recovery

In order to remove 90% of the CO₂ contained in the flue gas, the amine plant requires approximately 152.5 kg/s of steam (1.21 x 10⁶ lbm/hr). This is approximately 50% of the steam that would enter the LP turbine cylinder in the absence of the amine plant. Out of this steam flow, roughly 4.5% supplies the reclaimer at a pressure of 6.2 bara (90 psia); whereas, the remaining larger portion is required for operation of the reboiler. Before entering the reboilers, steam is expanded through a new turbine, the so-called Let Down Turbine (LDT), to make the best use of the steam's energy. Refer to Appendix IV for technical details regarding the Let Down Turbine.

Without any additional measures, the decrease in steam flow entering the existing LP turbine would result in a corresponding lower pressure at the LP turbine inlet (about 50% of the pressure level without extraction). Consequently, the pressure at the exhaust of the existing IP turbine would also be reduced to about this same value. Keeping the live steam conditions constant would then result in increased mechanical loading of the IP blades in excess of the permissible stress levels. For this reason, a pressure control valve needs to be added in the IP-LP crossover pipe to protect the IP turbine blading.

Due to the high amount of flow extracted from the IP-LP crossover and, consequently, the remaining low flow passing through the LP turbine, there is a potential risk for the LP blades being damaged. By comparing the load for the 90% CO₂ removal case with data given in the Conesville #5 instruction manual for "lower load limit," it can be shown that the operation as shown in Figure 3-22 is well within the operational range of the existing LP turbine.

Care was taken to integrate the heat rejected within the amine process into the existing water-steam cycle in an efficient manner. The main sources of integrated heat are provided from three sources as listed below:

- CO₂ compressor intercoolers
- Stripper overhead cooler
- Refrigeration compressor cooler (de-superheating section)

Additionally, warm condensate is returned from the amine reboiler/reclaimer system to the existing deaerator. For the 90% CO₂ removal case, the most beneficial arrangement for heat integration is also shown in the lower part of Figure 3-22. It should be noted that with this arrangement the deaerator flow increases by approximately 26%. This may impact deaerator performance or require either modification of the deaerator or a change in the heat integration arrangement in order to reduce the duty of the deaerator. Although the cost for modification of the deaerator was not included in this study, given the relatively large costs required for the other plant modifications (new amine plant and CO₂ compression equipment), this omission should not impact the results of the study significantly.



In summary, the power output of the Conesville #5 Unit after modification to remove 90% of the CO₂ contained in the flue gas will decrease by approximately 16.3% (from 463.5 MWe to 388.0 MWe) when compared to the Base Case as shown in Section 2.2.4.




Figure 3-22: Case 1 – Modified Water-Steam Cycle for 90% CO₂ Removal

3.1.6.3 Case 2: Steam Cycle for 70% CO₂ Recovery

In the case of removal of 70% of the CO₂ contained in the flue gas, the steam required to operate the boiler/reclaimer of the amine process is approximately 118.5 kg/s (940.8 x 10³ lbm/hr), equivalent to approximately 39% of the steam that would enter the LP turbine cylinder in the absence of the amine plant.

Similar to the 90% removal case, the lower steam flow entering the LP turbine would result in a correspondingly lower pressure at the LP turbine inlet (about 59% of the pressure without extraction). Consequently, the pressure at the exhaust of the IP turbine would also come down; therefore, a pressure control valve is required to protect the IP blading.

For this scenario of 70% CO₂ removal, a low load limitation within the LP is not expected to be an issue because even more steam remains within the LP turbine cylinder compared to the 90% removal case.

Heat integration is done in the same manner as for the 90% removal case and is shown in the lower part of Figure 3-23. The deaerator flow is somewhat less than in the 90% removal case, but still significantly higher than the flow as indicated for the reference case (approximately 24.5% larger). Again, this may impact performance of the deaerator or require either modification of the deaerator or a change in the heat integration arrangement in order to reduce the duty of the deaerator.

In summary, as illustrated in Figure 3-23, the power output of the Conesville #5 Unit after modification to remove 70% of the CO₂ contained in the flue gas will decrease by approximately 12.4% (from 463.5 MW to 405.9 MW) when compared to the Base Case (please refer Section 2.2.4).




Figure 3-23: Case 2 – Modified Water-Steam Cycle for 70% CO₂ Removal

3.1.6.4 Case 3: Steam Cycle for 50% CO₂ Recovery

In the case of removal of 50% of the CO₂ contained in the flue gas, the steam required to operate the boiler/reclaimer of the amine process is approximately 84.7 kg/s (671.9 x 10³ lbm/hr), equivalent to approximately 27.6% of the steam that would enter the LP turbine cylinder in the absence of the amine plant.

Again, the lower steam flow entering the LP turbine would result in a corresponding lower pressure at the LP turbine inlet (about 70% of the pressure without extraction) and, consequently, a lower pressure at IP exhaust. Therefore, a pressure control valve is required to protect the IP blading.

Operation close to low load limitation within the LP is not expected to be an issue.

Heat integration is done in the same manner as for the 90% removal case and is shown in Figure 3-24. The deaerator flow is somewhat less than in the 90% removal case, but still significantly higher than the flow as indicated for the reference case (approximately 20% higher). Again, this may impact performance of the deaerator or require either modification of the deaerator or a change in the heat integration arrangement in order to reduce the duty of the deaerator. Moving the location where the condensate from the amine plant is fed back into the turbine cycle up one feedwater heater, i.e., upstream of HTR #53 instead of downstream reduces the duty on the deaerator, but the power generated will be less by approximately 200 kW.

The modified water-steam cycle is shown in Figure 3-24. In summary, the power output of the Conesville #5 Unit after modification to remove 50% of the CO₂ will decrease by approximately 8.6% (from 463.5 MW to 423.5 MW) when compared to the Base Case (please refer to Section 2.2.4).




Figure 3-24: Case 3 - Modified Water-Steam Cycle for 50% CO₂ Removal

3.1.6.5 Case 4: Steam Cycle for 30% CO₂ Recovery

In the case of removal of 30% of the CO₂ contained in the flue gas, the steam required to operate the boiler/reclaimer of the amine process is approximately 50.8 kg/s (403.2 x 10³ lbm/hr), equivalent to approximately 16.4% of the steam that would enter the LP turbine cylinder in the absence of the amine plant.

The lower steam flow entering the LP turbine results in a corresponding lower pressure at the LP turbine inlet (about 80.9% of the pressure without extraction). Consequently, the pressure at the exhaust of the IP turbine would also come down; therefore, a pressure control valve is required to protect the IP blading.

With the heat integration arrangement being the same as with the other cases, the deaerator flow still is approximately 13.4% greater than for the reference case. Again, this may impact performance of the deaerator, or require either modification of the deaerator, or a change in the heat integration arrangement in order to reduce the duty of the deaerator.

The modified water-steam cycle is shown in Figure 3-25. In summary, the power output of the Conesville #5 Unit after modification to remove 30% of the CO₂ will decrease by approximately 5% (from 463.5 MW to 440.7 MW) when compared to the reference case (please refer to Section 2.2.4).




Figure 3-25: Case 4 – Modified Water-Steam Cycle for 30% CO₂ Removal

3.1.6.6 Case 5/Concept A: Steam Cycle for 96% CO₂ Recovery (from previous study)

The steam cycle system for Case 5/Concept A is modified as shown in Figure 3-26, while Figure 3-27 shows the associated Mollier diagram. It should be pointed out that the performance shown for the steam turbine in this case was developed in 2000 using a less detailed analysis than was used for Cases 1-4. About 79% of the IP turbine exhaust is extracted from the IP/LP crossover pipe. This steam is expanded to about 4.5 bara (65 psia) through a new let down steam turbine generating 62,081 kWe. The exhaust from the new turbine, at about 248°C (478°F), is de-superheated and then provides the energy requirement for the solvent regeneration done in the reboilers/stripper system of the MEA CO₂ removal process. The condensate from the reboilers is pumped to the existing deaerator. The remaining 21% of the IP turbine exhaust is expanded in the existing LP turbine. The current study confirmed that the existing LP turbine would be able to operate at this low flow condition. The modified existing steam cycle system produces 269,341 kWe. The total output from both generators is 331,422 kWe. This represents a gross output reduction of 132,056 kWe (about 28.5%) as compared to the Base Case.




Figure 3-26: Case 5/Concept A – Modified Water-Steam Cycle for 96% CO₂ Removal




Figure 3-27: Case 5/Concept A - Modified Water-Steam Cycle Mollier Diagram for 96% CO₂ Removal

3.1.6.7 Discussion of Alternate Solutions for Steam Extraction

While this study focuses on the addition of a new LDT to the existing water-steam cycle to effectively use the energy contained in the steam while matching the requirements of the amine plant, the following paragraphs will give a brief overview of other available retrofit solutions as potential alternatives to the let down turbine approach. The common advantage of all the alternate retrofit scenarios under consideration is that there is no need for an additional turbine-generator with all the equipment and modifications that are linked to this (e.g., new foundations/foundation enforcements, additional transformer, piping, grid connection, etc).

As with all arrangements under consideration, retrofit scenarios have to take into account that the unit has to be able to run at maximum load both with and without the amine plant being in operation. It is this requirement that tremendously increases the mechanical design load acting on the turbine blades, since the pressure upstream of the location where the steam will be extracted drops approximately proportional to the relative amount of steam that will be extracted. This of course means that a scenario for 90% removal of CO₂, where approximately 50% of the steam entering the existing LP turbine cylinder (See Figure 3-28) will be extracted, puts the greatest load on the blading.




Figure 3-28: Existing LP Turbine at Conesville Unit #5

In Table 3-47 pressure data are given for a scenario with 30% CO₂ removal. The data in Row 2 of the table (“Reference Conditions”) are for the 5% overpressure load condition without any modification. In Row 3 (“30% CO₂ removal”), the impact of steam extraction on the pressure distribution within the remaining LP turbine can be seen. Due to the given swallowing capacity of the existing LP turbine the pressure at the LP turbine, inlet drops down from ~14.1 bara (205 psia) with no steam extraction to ~11.7 bara (169 psia) with the amine plant being in operation [requiring ~51 kg/s (403,000 lbm/hr) of steam to remove 30% of the CO₂]. Without taking additional measures, about the same pressure would also act on the exhaust section of the IP turbine and the existing blading would not be able to withstand this increased mechanical loading.

Table 3-47: Expected Steam Conditions at Extraction Points for 30% CO₂ Removal

		A1	A2	A3	LP inlet	
Reference Conditions		9.5 psia 169.8 klb/hr	25.2 psia 119.5 klb/hr	63.7 psia 140.9 klb/hr	205.1 psia 2,486.4 klb/hr	No steam extraction
30% CO₂ removal	Existing turbine, pls. refer to Section "30% removal" above	9.0 psia 0 klb/hr	21.9 psia 75.4 klb/hr	54.1 psia 92.8 klb/hr	169.4 psia 2,048.6 klb/hr	Steam extraction in operation
Scenario "LP retrofit"	30% CO ₂ removal, no LDT, retrofitted LP turbine	~9.0 psia; determined by turbine swallowing capacity & backpressure	47 psia to feed reboiler	90 psia to feed reclaimer	205.1 psia	Steam extraction in operation
Scenario "LP & HP/IP retrofit"	30% CO ₂ removal, requirements for LP turbine retrofit	~9.0 psia; determined by turbine swallowing capacity & backpressure	~22 psia	~47 psia	~105 psia	Steam extraction in operation

A retrofit solution offers the potential to specifically address these issues. This can be done by designing the new blade path in such a way that the pressure levels required to feed the amine plant can be closely matched at the extraction points inside the LP turbine, thus minimizing the impact on the IP turbine. A preliminary engineering assessment revealed that a steam path could be designed to achieve a 6.2 bara (90 psia) pressure level at the first extraction point ("A3") to feed the reclaimer as well as a 3.2 bara (47 psia) pressure level at the second extraction point ("A2") to feed the reboilers. Since the steam flow to feed the reboiler with the 3.2 bara (47 psia) steam is significantly more than the flow that was originally extracted to feed the connected feedwater heater (48.7 kg/s vs. 15.1 kg/s or 386.5×10^3 lbm/hr vs. 119.5×10^3 lbm/hr) it is very likely that the piping requires modification, which in turn may mean that the LP turbine outer casing also needs to be modified in order to allow bigger pipe diameters to be connected. It also needs to be considered that the existing piping and the connected feedwater heater most likely will not be designed to allow operation at the higher pressure (3.2 bara vs. 1.7 bara or 47 psia vs. 25.2 psia). This could be overcome by either replacement of the existing piping and feedwater heater, or it needs to be checked whether the blade path and turbine casing could be modified to allow for an additional extraction point at approximately 1.7 bara (25 psia).

In principle, the comments above apply similarly to the 50%, 70%, and 90% CO₂ removal scenarios with the requirements for a proper steam path design getting more and more challenging as more steam is required for the amine plant, i.e., with increasing rate of CO₂ removal. At higher removal rates, in order to allow operation, both with and without the amine plant being in operation, it is likely that an HP/IP retrofit needs to be considered as well. This would allow not only reducing the mechanical load on the LP blading by reducing the pressure

level at LP inlet, but also better matching of the extraction pressures to the new requirements while optimizing cycle efficiency.

In summary, alternative technically proven retrofit solutions are available that may offer attractive solutions that does not necessitate the addition of a new Let Down Turbine. For a typical LP turbine retrofit solution, please refer to Figure 3-29. It should be noted that all of the retrofit options (HP, IP, LP), in addition to the advantages indicated above, offer the potential advantage of improved heat rate and power output due to the application of state of the art blading technology, and therefore can mitigate, to some extent, the performance deterioration due to the addition of the post-combustion carbon capture equipment. To have a sound basis for comparison and evaluation, a detailed engineering assessment is required, taking into account unit specifics that go well beyond the intent and scope of this study.




Figure 3-29: Typical Retrofit Solution for the Conesville Unit #5 LP Turbine Type

3.1.7 Project Construction Schedule (Cases 1-5)

Figure 3-30 shows the project construction schedule for the retrofit of Conesville Unit #5 to CO₂ capture, which is 36 months in duration. This schedule is assumed to apply to each of the five cases in this study (Cases 1-5). Engineering is completed in the first 15 months. Procurement occurs in months 9-23 and Construction takes place in months 14-34. Commissioning and startup are done in months 35 and 36.




Figure 3-30: Project Construction Schedule (Cases 1-5)



3.2 Summary and Comparison of Overall Plant Performance and Carbon Dioxide Emissions (Cases 1-5)

This section summarizes overall performance and CO₂ emissions from the existing and modified power plants. Table 3-48 shows a comparison of the Conesville #5 plant performance and emissions for the CO₂ recovery cases and the Base Case that has no CO₂ recovery system. The first column shows the performance results for the Base Case. The performance shown for the Base Case is identical to what was reported in the previous study (Bozzuto et al., 2001) for this unit.

Table 3-48: Plant Performance and CO₂ Emissions Comparison (Base Case and Cases 1-5)

		Base-Case	Case 5	Case 1	Case 2	Case 3	Case 4	
		Original	Concept A	Advanced	Advanced	Advanced	Advanced	
	(units)	Plant	MEA - 96% Capture	MEA - 90% Capture	MEA - 70% Capture	MEA - 50% Capture	MEA - 30% Capture	
<u>Boiler Parameters</u>								
Main Steam Flow	(lbm/hr)	3131619	3131651	3131651	3131651	3131651	3131651	
Reheat Steam Flow (to IP turbine)	(lbm/hr)	2853607	2853607	2848739	2848715	2848655	2848567	
Main Steam Pressure	(psia)	2535	2535	2535	2535	2535	2535	
Main Steam Temp	(Deg F)	1000	1000	1000	1000	1000	1000	
Reheat Steam Temp	(Deg F)	1000	1000	1000	1000	1000	1000	
Boiler Efficiency	(percent)	88.13	88.13	88.13	88.13	88.13	88.13	
Flue Gas Flow leaving Economizer	(lbm/hr)	4014743	4014743	4014743	4014743	4014743	4014743	
Flue Gas Temperature leaving Air Heater	(Deg F)	311	311	311	311	311	311	
Coal Heat Input (HHV)	(HHV) (10 ⁶ Btu/hr)	4228.7	4228.7	4228.7	4228.7	4228.7	4228.7	
	(LHV) (10 ⁶ Btu/hr)	4037.9	4037.9	4037.9	4037.9	4037.9	4037.9	
<u>CO₂ Removal Steam System Parameters</u>								
CO ₂ Removal System Steam Pressure	(psia)	---	65	47	47	47	47	
CO ₂ Removal System Steam Temp	(Deg F)	---	478	424	424	424	424	
CO ₂ Removal System Steam Extraction Flow	(lbm/hr)	---	1935690	1210043	940825	671949	403170	
CO ₂ Removal System Condensate Pressure (from reboilers)	(psia)	---	64.7	40	40	40	40	
CO ₂ Removal System Condensate Temperature	(Deg F)	---	292.7	267.3	267.3	267.3	267.3	
CO ₂ Removal System Heat to Cooling Tower	(10 ⁶ Btu/hr)	---	1441.1	890.2	692.5	494.2	293.1	
Natural Gas Heat Input	(HHV) ² (10 ⁶ Btu/hr)	0	17.7	13.0	9.7	6.7	4.2	
	(LHV) (10 ⁶ Btu/hr)	---	16.0	11.7	8.7	6.0	3.8	
	(10 ⁶ SCF/Day)	---	0.417	0.312	0.232	0.161	0.101	
<u>Steam Cycle Parameters</u>								
Total Heat Input to Steam Cycle	(10 ⁶ Btu/hr)	3707.4	3707.4	3707.4	3707.4	3707.4	3707.4	
Heat Output to CO ₂ Removal System Reboilers & Reclaimer	(10 ⁶ Btu/hr)	---	1953.0	1218.1	947.1	676.5	405.9	
Existing Condenser Pressure	(psia)	1.23	1.23	1.23	1.23	1.23	1.23	
Existing Condenser Heat Loss	(10 ⁶ Btu/hr)	2102.8	603.3	1257.0	1514.7	1778.6	2047.6	
Existing Steam Turbine Generator Output	(kW)	463478	269,341	342693	370700	398493	425787	
CO ₂ Removal System Turbine Generator Output	(kW)	0	62,081	45,321	35,170	25,831	14,898	
Total Turbine Generator Output	(kW)	463478	331422	388014	405870	423524	440685	
<u>Auxiliary Power Requirements</u>								
Condensate Pump Power	(kW)	563	450	504	515	527	540	
Condenser Cooling Water Pump Power	(kW)	5562	5407	5679	5838	6011	6191	
Boiler Island Auxiliary Power (Fans & Pulverizers)	(kW)	7753	7753	7753	7753	7753	7753	
Coal & Ash Handling System	(kW)	1020	1020	1020	1020	1020	1020	
FGD & ESP System Auxiliary Power	(kW)	8157	8157	8157	8157	8157	8157	
Misc. Auxiliary Power (Lighting, HVAC, Trans., etc)	(kW)	6645	6645	6645	6645	6645	6645	
CO ₂ Removal System Auxiliary Power	(kW)	0	50355	54939	42697	30466	18312	
Total Auxiliary Power	(kW)	29700	79788	84697	72625	60579	48618	
	fraction of gross output	(fraction)	0.064	0.241	0.218	0.179	0.143	0.110
<u>Plant Performance Parameters</u>								
Net Plant Output	(kW)	433778	251634	303317	333245	362945	392067	
Normalized Net Plant Output (Relative to Base Case)	(fraction)	1.00	0.58	0.70	0.77	0.84	0.90	
Net Plant Efficiency (HHV)	(fraction)	0.3501	0.2022	0.2441	0.2683	0.2925	0.3161	
Net Plant Efficiency (LHV)	(fraction)	0.3666	0.2119	0.2556	0.2811	0.3063	0.3311	
Normalized Efficiency (HHV; Relative to Base Case)	(fraction)	1.00	0.58	0.70	0.77	0.84	0.90	
Net Plant Heat Rate (HHV)	(Btu/kWh)	9749	16875	13984	12719	11670	10796	
Net Plant Heat Rate (LHV)	(Btu/kWh)	9309	16110	13351	12143	11142	10309	
<u>Plant CO₂ Emissions</u>								
Carbon Dioxide Produced	(lbm/hr)	866102	868137	867595	867212	866872	866585	
Carbon Dioxide Recovered	(lbm/hr)	0	835053	779775	607048	433606	260164	
Carbon Dioxide Emissions	(lbm/hr)	866102	33084	87820	260164	433266	606422	
Fraction of Carbon Dioxide Recovered	(fraction)	0	0.962	0.90	0.70	0.50	0.30	
Specific Carbon Dioxide Emissions	(lbm/kWh)	1.997	0.131	0.290	0.781	1.194	1.547	
Normalized Specific CO ₂ Emissions (Relative to Base Case)	(fraction)	1.00	0.066	0.145	0.391	0.598	0.775	
Avoided Carbon Dioxide Emissions (as compared to Base)	(lbm/kWh)	---	1.865	1.707	1.216	0.803	0.450	

The second column shows results for Case 5/Concept A, also from the previous study (Bozzuto, et al., 2001), which captured ~96% of the CO₂ using the Kerr-McGee/ABB Lummus Global oxygen inhibited MEA technology. Columns 3, 4, 5, and 6 show results for Cases 1-4 of the current study, which capture 90%, 70%, 50%, and 30% of the CO₂, respectively, using an advanced MEA system.

Several comparisons have been made in these tables and throughout the report. Some of the more important comparisons are categorized and summarized in the following subsections.

3.2.1 Auxiliary Power and Net Plant Output

The auxiliary power required for the Base Case is 29,700 kW or about 6.4% of the gross electrical output. Net plant output is 433,778 kW. All the CO₂ capture options require large amounts of additional auxiliary power to the CO₂ compression systems and CO₂ capture systems, which deliver the CO₂ as a liquid at 138 barg (2,000 psig). These CO₂ capture and compression systems consume in the range of about 18-55 MWe. The total amount of auxiliary power for these plants represents a range of about 11-24% of the gross output, depending on CO₂ recovery level, as shown in Figure 3-31.

Additionally, extraction of steam from the existing steam turbine to provide energy necessary for solvent regeneration also significantly reduces steam turbine output (refer to Section 3.2.4) and, therefore, reduces net plant output. Net plant output is reduced to between 252-392 MWe for these cases or between about 58%-90% of the Base Case output as shown in Figure 3-31.

Comparison of net plant outputs for Case 5/Concept A from the original study (Bozzuto et al., 2001) and the advanced MEA 90% Capture case of the current study indicates the impact of the advanced MEA solvent. An improvement of about 51 MWe in net output (~20% greater output) is realized with the advanced MEA solvent. This represents an improvement of about 28% on output reduction. Correcting to a common CO₂ capture percentage of 96% would reduce this improvement to about 26%.




Figure 3-31: Plant Auxiliary Power & Net Electrical Output (MWe)

3.2.2 Net Plant Heat Rate and Thermal Efficiency

Because of the large energy requirements for solvent regeneration and large auxiliary power demands for the new equipment required for the CO₂ capture systems, net plant heat rate and thermal efficiency are degraded substantially relative to the Base Case as shown in Figure 3-32. Figure 3-33 shows the same results plotted as a function of the capture level. As shown in Figure 3-33, the thermal efficiency decreases linearly for the advanced amine cases as CO₂ capture level increases (Cases 1-4) and then drops sharply for Case 5 with the Kerr/McGee ABB Lummus amine.




Figure 3-32: Plant Thermal Efficiency (HHV Basis)

The Base Case plant thermal efficiency (HHV Basis) is about 35%. For the CO₂ capture cases, with large amounts of steam extracted for solvent regeneration and increased auxiliary power for CO₂ compression and liquefaction systems, plant thermal efficiencies are reduced to between 31.6%-20.2% (HHV basis) depending on capture level.




Figure 3-33: Plant Thermal Efficiency vs. Capture Level

Figure 3-34 shows the efficiency losses relative to the Base Case. Thermal efficiency losses range from about 3.4 to 14.8 percentage points.




Figure 3-34: Plant Thermal Efficiency Loss Relative to Base Case (HHV Basis)

Comparison of thermal efficiency losses for Case 5/Concept A from the original study (Bozzuto et al., 2001), and the advanced MEA 90% capture case of the current study indicates the impact of using the advanced MEA solvent. A reduction of about 4.2 percentage points in thermal efficiency loss is realized with the advanced MEA solvent. This represents an improvement of about 28% with the advanced MEA solvent. Correcting to a common CO₂ capture percentage of ~96% would reduce this improvement to about 3.5 percentage points in thermal efficiency loss or about 24%.

3.2.3 CO₂ Emissions

CO₂ emissions are summarized in Table 3-48. Specific carbon dioxide emissions were reduced from 906 g/kWh (1.997 lbm/kWh) for the Base Case to between 59-702 g/kWh (0.131-1.547 lbm/kWh) depending on CO₂ capture level for these cases. This corresponds to between 6.6% and 77.5% of the Base Case carbon dioxide emissions. Figure 3-35 and Table 3-48 indicate the quantity of CO₂ captured and the avoided CO₂ emissions.




Figure 3-35: Carbon Dioxide Distribution

Figure 3-36 compares specific CO₂ emissions (lbm/kWh). Recovery of CO₂ ranged from 30% to 96% for the capture cases.




Figure 3-36: Specific Carbon Dioxide Emissions

Figure 3-37 shows these same CO₂ emission results plotted as a function of capture level.




Figure 3-37: Specific Carbon Dioxide Emissions vs. CO₂ Capture Level

3.2.4 Steam Cycle Performance

The Base Case steam cycle is considered fairly typical of the U.S. fleet with subcritical steam conditions of 175 bara / 538°C / 538°C (2,535 psia / 1,000°F / 1,000°F). These represent the most common steam conditions for the existing fleet of U.S. electric utility power plant units in operation today. Six extraction feedwater heaters are used. The generator in this case produces 463,478 kWe.

The steam cycles for the five capture cases were all modified in a similar fashion. The steam cycles for the CO₂ capture cases differ from the Base Case steam cycle in that they each extract significant quantities of steam from the IP/LP crossover pipe. The extracted steam, at about 13.8 bara (200 psia) is expanded through a new “let down” steam turbine generating electric power before the steam is exhausted into the reboilers of the CO₂ recovery plant. The exhaust pressure of 4.5 bara (65 psia) was used for all the CO₂ capture cases (90%, 70%, 50%, and 30% capture) using the advanced amine of the current study (i.e., Cases 1-4).

Additionally, for Cases 1-4 of the current study, low-level heat was recovered from various areas of the CO₂ capture and compression system, and this heat was integrated with the steam cycle for overall plant efficiency improvement. This heat integration was possible in the current study because the CO₂ capture and compression equipment was able to be located relatively close to the existing unit. The absorbers were located near the existing Unit #5/6 common stack, and the strippers were located near the existing steam turbine. The CO₂ compressors were located as close as possible to the new strippers. In the previous study, all the CO₂ capture and compression equipment (absorbers, strippers, compressors, etc.) was located approximately 457 m (1,500 ft) northeast of the existing Conesville Unit #5/6 stack. Because of this relatively long distance, heat integration was determined to be impractical in the previous study.

The modified existing steam turbine generator of Case 5/Concept A, analyzed in the previous study, produces ~269 MWe and the new let down turbine produces ~62 MWe for a total generator output of ~331 MWe. The gross output for this case is reduced by ~132 MWe or about 30% as compared to the Base Case.

For Cases 1-4 of the current study using the advanced MEA solvent, the CO₂ capture levels are 90%, 70%, 50%, and 30% respectively, the modified existing steam turbine generator produces 343-426 MWe and the new letdown turbine produces 45-15 MWe for a total generator output of 388-441 MWe. The gross output is reduced by 23-75 MWe or 5%-17% for these cases. The total output is nearly a linear function of CO₂ recovery level. Figure 3-38 shows the total generator output for all the cases included in the study. The crosshatched bar shows the output of Case 5/Concept A of the previous study.

Comparison of total generator output for Case 5/Concept A from the original study (Bozzuto et al., 2001), and the advanced MEA 90% capture case of the current study indicates the impact of three primary differences between the designs as listed below:

- Reduced steam extraction required for the advanced MEA solvent regeneration
- Heat integration between the CO₂ capture/compression/liquefaction equipment and the existing steam/water cycle
- Reduced reboiler operating pressure

An improvement of about 57 MWe in total generator output is realized with the advanced MEA solvent case, which represents an improvement of about 17% on total generator output reduction. Correcting to a common CO₂ recovery percentage of ~96% would be expected to reduce this improvement to about 16%.




Figure 3-38: Total Generator Output (existing + new let down turbine generator)

3.2.5 Boiler Performance

The Base Case, updated Case 5/Concept A, and the four new CO₂ capture cases (Cases 1-4) were all analyzed based on the existing boiler producing a main steam flow of 395 kg/s (3,131,619 lbm/hr) at conditions of 538°C and 175 bara (1,000°F and 2,535 psia) at the steam turbine. This main steam flow represents the maximum continuous rating (MCR) for the existing unit. All six

cases also provided reheat steam to the steam turbine at 538°C (1,000° F). The boiler performance for the Base Case, updated Case 5/Concept A, and the four new CO₂ capture cases (Cases 1-4) was identical. Boiler efficiency for each of these six cases is 88.13%.

3.3 Cost Analysis

The project capital cost estimates (Total Investment Cost [TIC]) for all five cases, including engineering, procurement, and construction (EPC basis) and process and project contingencies, are presented in this section. All costs were estimated in July 2006 U.S. dollars. These costs include all required equipment to complete the retrofit such as the new advanced amine-based CO₂ scrubbing system, the new CO₂ compression, dehydration, and liquefaction system, the modified FGD system, the new let down steam turbine generator, and the existing steam cycle modifications.

Operating and maintenance (O&M) costs were calculated for all systems. The O&M costs for the Base Case (Conesville #5 Unit) were provided by American Electric Power (AEP). For the retrofit CO₂ capture system evaluations, additional O&M costs were calculated for the new equipment. The variable operating and maintenance (VOM) costs for the new equipment included such categories as chemicals and desiccants, waste handling, maintenance material and labor, contracted services, and make-up power cost (MUPC) from the reduction in net electricity production. The fixed operating and maintenance (FOM) costs for the new equipment includes operating labor only.

3.3.1 Cost Estimation Basis

The following assumptions were made in developing these cost estimates for each concept evaluated:

- July 2006 U.S. dollars
- Outdoor installation
- Investment in new utility systems is outside the scope
- CO₂ product pipeline is outside the scope
- No special limitations for transportation of large equipment
- No protection against unusual airborne contaminants (dust, salt, etc.)
- No unusual wind storms
- No earthquakes
- No piling required
- All releases can go to atmosphere – no flare provided
- CO₂ Product Pump designed to API standards, all other pumps conform to ANSI
- All heat exchangers designed to TEMA “C”
- All vessels are designed to ASME Section VIII, Div 1.

- Annual operating time is 7,446 hr/yr (85% capacity factor)
- The investment cost estimate was developed as a factored estimate based on in-house data for the major equipment. Such an estimate can be expected to have accuracy of +/- 30%.
- Process and project contingency were added to the EPC to derive the TIC.
- Make-up power cost was assessed at a 20-year levelized rate of 6.40 ¢/kWh (equivalent to a new Subcritical Pulverized Coal (Greenfield) Plant without carbon capture)
- No purchases of utilities or charges for shutdown time have been charged against the project

Other exclusions from the cost estimate are as follows:

- Soil investigation
- Environmental permits
- Disposal of hazardous or toxic waste
- Disposal of existing materials
- Custom's and Import duties
- Sales/use tax
- Forward escalation
- Capital spare parts
- Chemical loading facilities
- Buildings except for compressor building and electrical substation
- Financing cost
- Owners cost
- Guards during construction
- Site medical and ambulance service
- Cost & fees of authorities
- Overhead high voltage feed lines
- Cost to run a natural gas pipeline to the plant
- Excessive piling
- Contingency and risk

The costs used for consumption of fuel and chemicals in this project are shown in Table 3-49.

Table 3-49: Prices for Consumables

Consumables	(\$/lbm)	(\$/kg)
MEA	0.95	2.09
Soda Ash	0.26	0.56
Corrosion Inhibitor	3.00	6.61
Activated Carbon	1.00	2.20
Molecular Sieve	2.00	4.41
Diatomaceous Earth	1.25	2.75
	(\$/10⁶ Btu)	(\$/GJ)
Coal	1.80	1.90
Natural Gas	6.75	7.12

The project and process contingencies applied to the capital expenditures are shown in Table 3-50. The capital cost estimate provided for the CO₂ separation and compression system includes the let down steam turbine; therefore, the project and process contingency for carbon capture was applied to the let down steam turbine by default.

Table 3-50: Project and Process Contingencies

Capital Equipment	Project Contingency*	Process Contingency*
CO ₂ Separation and Compression System	25%	18%
Flue Gas Desulfurization (FGD) System	11%	0%
Let Down Steam Turbine	25%	18%

*Percent of bare erected cost (i.e., sub-total direct cost in the investment tables for each case).

3.3.2 Carbon Dioxide Separation and Compression System Costs

This section shows both investment and operating and maintenance cost estimates for the Carbon Dioxide Separation and Compression Systems developed in this study. Five separate cost estimates for both the investment and O&M costs are provided in this section. There are four estimates provided for the 90%, 70%, 50%, and 30% CO₂ capture levels of the current study (Cases 1-4 respectively), which used an advanced amine. There is one additional cost estimate (Case 5) which is simply an update of Concept A (96% CO₂ capture) of the previous study (Bozzuto et al., 2001) to July 2006 U.S. dollars for comparison purposes. Case 5 used the Kerr McGee/ABB Lummus amine system.

3.3.2.1 Case 1 - 90% CO₂ Capture with Advanced Amine System

Investment Cost:

Table 3-51 shows investment costs for the CO₂ Separation and Compression System designed to capture 90% of the CO₂ contained in the Conesville #5 flue gas stream. Included in this table (Acc't. Code - 14200) are the steam cycle modification costs as well as the costs for the new let down turbine and associated electric generator. The steam cycle modifications were described



previously in Section 3.1.3. The Total Investment Cost (TIC) of this equipment is \$377,829,000. The expected level of accuracy for this cost estimate is +/-30%.

Table 3-51: Case 1 (90% Capture) CO₂ Separation and Compression System Investment Costs

Acc't Code	Description	Pieces	Direct Manhours	Labor (\$1,000)	Material (\$1,000)	Total (\$1,000)	%
11000	Heaters						0.00%
11200	Exchangers & Aircoolers		25,200	466	19,049	19,515	5.17%
12000	Vessel / Filters		6,638	123	5,018	5,141	1.36%
12100	Towers / Internals		29,859	552	22,571	23,123	6.12%
12200	Reactors						0.00%
13000	Tanks						0.00%
14100	Pumps		4,431	82	3,350	3,432	0.91%
14200	Compressors		60,663	1,122	45,856	46,978	12.43%
18000	Special Equipment		5,070	94	3,833	3,926	1.04%
	Sub-Total Equipment	140	131,862	2,439	99,676	102,115	27.03%
21000	Civil		175,815	3,253	6,977	10,230	2.71%
21100	Site Preparation						0.00%
22000	Structures		46,152	854	4,087	4,941	1.31%
23000	Buildings		24,175	447	1,196	1,643	0.43%
30000	Piping		362,619	6,708	17,942	24,650	6.52%
40000	Electrical		186,804	3,456	7,974	11,430	3.03%
50000	Instruments		153,839	2,846	12,460	15,306	4.05%
61100	Insulation		131,862	2,439	5,183	7,623	2.02%
61200	Fireproofing		65,931	1,220	1,495	2,715	0.72%
61300	Painting		32,965	610	698	1,308	0.35%
	Sub-Total Commodities		1,180,161	21,833	58,011	79,844	21.13%
70000	Construction Indirects					35,228	9.32%
	Sub-Total Direct Cost (Bare Erected Cost)		1,312,023	24,272	157,687	217,188	57.48%
71000	Construction Management					2,000	0.53%
80000	Home Office Engineering					29,400	7.78%
80000	Basic Engineering					5,000	1.32%
95000	License Fee	Excluded					0.00%
19400	Vendor Reps					1,750	0.46%
19300	Spare parts					2,900	0.77%
80000	Training cost	Excluded					0.00%
80000	Commissioning	Excluded					0.00%
19200	Catalyst & Chemicals	Excluded					0.00%
97000	Freight					4,700	1.24%
96000	CGL / BAR Insurance						0.00%
91400	Escalation to July 2006 Dollars					7,200	1.91%
	Total Base Cost					270,138	71.50%
	Contractors Fee					14,300	3.78%
	Total (EPC):					284,438	75.28%
93000	Project Contingency					54,297	14.37%
93000	Process Contingency					39,094	10.35%
	Total Investment Cost (TIC):					377,829	100.00%

Exclusions: bonds, taxes, import duties, hazardous material handling & disposal, capital spare parts, catalyst & chemicals, commissioning and initial operations, buildings other than control room & MCC.

Operating and Maintenance Cost:

Table 3-52 shows O&M costs for the CO₂ Separation and Compression System for the 90% CO₂ Capture Case. The variable, feedstock, and make-up power costs are reported at the 85% capacity factor. The make-up power cost represents the levelized cost over a 20-year period. All other costs represent first year operating costs.

Table 3-52: Case 1 (90% Capture) CO₂ Separation and Compression System Operating & Maintenance Costs

Operating & Maintenance Costs	Subtotal (\$1000/yr)	Total (\$1000/yr)
Fixed O&M Costs		2,494
Operating Labor	2,494	
Variable O&M Costs		17,645
Chemicals	10,161	
Waste Handling & Contracted Services	767	
Maintenance (Materials and Labor)	6,716	
Feedstock O&M Costs		653
Natural Gas	653	
Levelized, Make-up Power Cost		62,194
Levelized, Make-up Power Cost (@ \$6.40 ¢/kWh)	62,194	

3.3.2.2 Case 2 - 70% CO₂ Capture with Advanced Amine System

Investment Cost:

Table 3-53 shows investment costs for the CO₂ Separation and Compression System designed to capture 70% of the CO₂ contained in the Conesville #5 flue gas stream. Included in the table (Acc't. Code - 14200) are the steam cycle modification costs and the costs for the new let down turbine and associated electric generator. The steam cycle modifications were described previously in Section 3.1.3. The Total Investment Cost (TIC) of this equipment is \$342,805,000. The expected level of accuracy for this cost estimate is +/-30%.



Table 3-53: Case 2 (70% Capture) CO₂ Separation and Compression System Investment Costs

Acc't Code	Description	Pieces	Direct Manhours	Labor (\$1,000)	Material (\$1,000)	Total (\$1,000)	%
11000	Heaters						0.00%
11200	Exchangers & Aircoolers		20,664	382	15,620	16,002	4.67%
12000	Vessel / Filters		5,605	104	4,237	4,340	1.27%
12100	Towers / Internals		26,482	490	20,018	20,508	5.98%
12200	Reactors						0.00%
13000	Tanks						0.00%
14100	Pumps		3,402	63	2,572	2,635	0.77%
14200	Compressors		57,726	1,068	43,636	44,704	13.04%
18000	Special Equipment		4,841	90	3,659	3,749	1.09%
	Sub-Total Equipment	133	118,720	2,197	89,742	91,938	23.37%
21000	Civil		158,293	2,928	6,282	9,210	2.69%
21100	Site Preparation						0.00%
22000	Structures		41,552	769	3,679	4,448	1.30%
23000	Buildings		21,765	403	1,077	1,480	0.43%
30000	Piping		326,480	6,040	16,154	22,193	6.47%
40000	Electrical		168,187	3,111	7,179	10,291	3.00%
50000	Instruments		138,507	2,562	11,218	13,780	4.02%
61100	Insulation		118,720	2,196	4,667	6,863	2.00%
61200	Fireproofing		59,360	1,098	1,346	2,444	0.71%
61300	Painting		29,680	549	628	1,177	0.34%
	Sub-Total Commodities		1,062,544	19,656	52,230	71,886	20.97%
70000	Construction Indirects					31,717	9.25%
	Sub-Total Direct Cost (Bare Erected Cost)		181,263	21,853	141,972	195,542	57.04%
71000	Construction Management					2,000	0.58%
80000	Home Office Engineering					27,930	8.15%
80000	Basic Engineering					5,000	1.46%
95000	License Fee	Excluded					0.00%
19400	Vendor Reps					1,750	0.51%
19300	Spare parts					2,600	0.76%
80000	Training cost	Excluded					0.00%
80000	Commissioning	Excluded					0.00%
19200	Catalyst & Chemicals	Excluded					0.00%
97000	Freight					4,300	1.25%
96000	CGL / BAR Insurance						0.00%
91400	Escalation to July 2006 Dollars					6,600	1.93%
	Total Base Cost					245,722	71.68%
	Contractors Fee					13,000	3.79%
	Total (EPC):					258,722	75.47%
93000	Project Contingency					48,886	14.26%
93000	Process Contingency					35,198	10.27%
	Total Investment Cost (TIC):					342,805	100.00%

Exclusions: bonds, taxes, import duties, hazardous material handling & disposal, capital spare parts, catalyst & chemicals, commissioning and initial operations, buildings other than control room & MCC.

Operating and Maintenance Cost:

Table 3-54 shows O&M costs for the CO₂ Separation and Compression System for the 70% CO₂ Capture Case. The variable, feedstock, and make-up power costs are reported at the 85% capacity factor. The make-up power cost represents the levelized cost over a 20-year period. All other costs represent first year operating costs.

**Table 3-54: Case 2 (70% Capture) CO₂ Separation and Compression System
Operating & Maintenance Costs**

Operating & Maintenance Costs	Subtotal (\$1000/yr)	Total (\$1000/yr)
Fixed O&M Costs		2,284
Operating Labor	2,284	
Variable O&M Costs		14,711
Chemicals	8,005	
Waste Handling & Contracted Services	597	
Maintenance (Materials and Labor)	6,109	
Feedstock O&M Costs		488
Natural Gas	488	
Levelized, Make-up Power Cost		47,926
Levelized, Make-up Power Cost (@ \$6.40 ¢/kWh)	47,926	

3.3.2.3 Case 3 – 50% CO₂ capture with Advanced Amine Systems

Investment Cost:

Table 3-55 shows investment costs for the CO₂ Separation and Compression System designed to capture 50% of the CO₂ contained in the Conesville #5 flue gas stream. Included in this table (Acc't. Code - 14200) are the steam cycle modification costs as well as the costs for the new let down turbine and associated electric generator. The steam cycle modifications were described previously in Section 3.1.3. The Total Investment Cost (TIC) of this equipment is \$258,390,000. The expected level of accuracy for this cost estimate is +/-30%.



Table 3-55: Case 3 (50% Capture) CO₂ Separation and Compression System Investment Costs

Acc't Code	Description	Pieces	Direct Manhours	Labor (\$1,000)	Material (\$1,000)	Total (\$1,000)	%
11000	Heaters						0.00%
11200	Exchangers & Aircoolers		15,864	293	11,992	12,285	4.75%
12000	Vessel / Filters		4,051	75	3,063	3,137	1.21%
12100	Towers / Internals		23,202	429	17,538	17,968	6.95%
12200	Reactors						0.00%
13000	Tanks						0.00%
14100	Pumps		2,776	51	2,098	2,150	0.83%
14200	Compressors		38,200	707	28,876	29,583	11.45%
18000	Special Equipment		3,864	71	2,921	2,992	1.16%
	Sub-Total Equipment	107	87,957	1,626	66,488	68,115	17.32%
21000	Civil		117,276	2,170	4,654	6,824	2.64%
21100	Site Preparation						0.00%
22000	Structures		30,785	570	2,726	3,296	1.28%
23000	Buildings		16,126	298	798	1,096	0.42%
30000	Piping		241,883	4,475	11,968	16,443	6.36%
40000	Electrical		124,606	2,305	5,319	7,624	2.95%
50000	Instruments		102,617	1,898	8,311	10,209	3.95%
61100	Insulation		87,957	1,627	3,457	5,085	1.97%
61200	Fireproofing		43,979	814	997	1,811	0.70%
61300	Painting		21,989	407	465	872	0.34%
	Sub-Total Commodities		787,218	14,564	38,695	53,260	20.61%
70000	Construction Indirects					23,498	9.09%
	Sub-Total Direct Cost (Bare Erected Cost)					144,874	56.07%
71000	Construction Management					2,000	0.77%
80000	Home Office Engineering					22,470	8.70%
80000	Basic Engineering					5,000	1.94%
95000	License Fee	Excluded					0.00%
19400	Vendor Reps					1,750	0.68%
19300	Spare parts					1,900	0.74%
80000	Training cost	Excluded					0.00%
80000	Commissioning	Excluded					0.00%
19200	Catalyst & Chemicals	Excluded					0.00%
97000	Freight					3,200	1.24%
96000	CGL / BAR Insurance						0.00%
91400	Escalation to July 2006 Dollars					5,000	1.94%
	Total Base Cost					186,194	72.06%
	Contractors Fee					9,900	3.83%
	Total (EPC):					196,094	75.89%
93000	Project Contingency					36,219	14.02%
93000	Process Contingency					26,077	10.09%
	Total Investment Cost (TIC):					258,390	100.00%

Exclusions: bonds, taxes, import duties, hazardous material handling & disposal, capital spare parts, catalyst & chemicals, commissioning and initial operations, buildings other than control room & MCC.

Operating and Maintenance Cost:

Table 3-56 shows O&M costs for the CO₂ Separation and Compression System for the 50% CO₂ Capture Case. The variable, feedstock, and make-up power costs are reported at the 85% capacity factor. The make-up power cost represents the levelized cost over a 20-year period. All other costs represent first year operating costs.

**Table 3-56: Case 3 (50% Capture) CO₂ Separation and Compression System
Operating & Maintenance Costs**

Operating & Maintenance Costs	Subtotal (\$1000/yr)	Total (\$1000/yr)
Fixed O&M Costs		2,079
Operating Labor	2,079	
Variable O&M Costs		10,876
Chemicals	5,820	
Waste Handling & Contracted Services	426	
Maintenance (Materials and Labor)	4,630	
Feedstock O&M Costs		337
Natural Gas	337	
Levelized, Make-up Power Cost		33,768
Levelized, Make-up Power Cost (@ \$6.40 ¢/kWh)	33,738	

3.3.2.4 Case 4 - 30% CO₂ Capture with Advanced Amine System

Investment Cost:

Table 3-57 shows investment costs for the CO₂ Separation and Compression System designed to capture 30% of the CO₂ contained in the Conesville #5 flue gas stream. Included in this table (Acc't. Code - 14200) are the steam cycle modification costs as well as the costs for the new let down turbine and associated electric generator. The steam cycle modifications were described previously in Section 3.1.3. The Total Investment Cost (TIC) of this equipment is \$189,570,000. The expected level of accuracy for this cost estimate is +/-30%.

**Table 3-57: Case 4 (30% Capture) CO₂ Separation and Compression
 System Investment Costs**

Acc't Code	Description	Pieces	Direct Manhours	Labor (\$1,000)	Material (\$1,000)	Total (\$1,000)	%
11000	Heaters						0.00%
11200	Exchangers & Aircoolers		10,123	187	7,652	7,839	4.14%
12000	Vessel / Filters		2,413	45	1,824	1,869	0.99%
12100	Towers / Internals		12,745	236	9,634	9,870	5.21%
12200	Reactors						0.00%
13000	Tanks						0.00%
14100	Pumps		1,728	32	1,306	1,338	0.71%
14200	Compressors		34,761	643	26,276	26,919	14.20%
18000	Special Equipment		2,137	40	1,615	1,655	0.87%
	Sub-Total Equipment	65	63,907	1,183	48,307	49,490	12.58%
21000	Civil		85,208	1,576	3,382	4,958	2.62%
21100	Site Preparation						0.00%
22000	Structures		22,367	414	1,981	2,394	1.26%
23000	Buildings		11,716	217	580	796	0.42%
30000	Piping		175,742	3,251	8,695	11,947	6.30%
40000	Electrical		90,534	1,675	3,865	5,539	2.92%
50000	Instruments		74,557	1,379	6,038	7,418	3.91%
61100	Insulation		63,906	1,182	2,512	3,694	1.95%
61200	Fireproofing		31,953	591	725	1,316	0.69%
61300	Painting		15,977	296	338	634	0.33%
	Sub-Total Commodities		101,185	10,581	28,116	38,696	20.41%
70000	Construction Indirects					17,073	9.01%
	Sub-Total Direct Cost (Bare Erected Cost)		635,868	11,764	76,423	105,259	55.53%
71000	Construction Management					2,000	1.06%
80000	Home Office Engineering					15,600	8.23%
80000	Basic Engineering					5,000	2.64%
95000	License Fee	Excluded					0.00%
19400	Vendor Reps					1,750	0.92%
19300	Spare parts					1,400	0.74%
80000	Training cost	Excluded					0.00%
80000	Commissioning	Excluded					0.00%
19200	Catalyst & Chemicals	Excluded					0.00%
97000	Freight					2,300	1.21%
96000	CGL / BAR Insurance						0.00%
91400	Escalation to July 2006 Dollars					3,700	1.95%
	Total Base Cost					137,009	72.27%
	Contractors Fee					7,300	3.85%
	Total (EPC):					144,309	76.12%
93000	Project Contingency					26,315	13.88%
93000	Process Contingency					18,947	9.99%
	Total Investment Cost (TIC):					189,570	100.00%

Exclusions: bonds, taxes, import duties, hazardous material handling & disposal, capital spare parts, catalyst & chemicals, commissioning and initial operations, buildings other than control room & MCC.

Operating and Maintenance Cost:

Table 3-58 shows O&M costs for the CO₂ Separation and Compression System for the 30% CO₂ Capture Case. The variable, feedstock, and make-up power costs are reported at the 85% capacity factor. The make-up power cost represents the levelized cost over a 20-year period. All other costs represent first year operating costs.

**Table 3-58: Case 4 (30% Capture) CO₂ Separation and Compression System
Operating & Maintenance Costs**

Operating & Maintenance Costs	Subtotal (\$1000/yr)	Total (\$1000/yr)
Fixed O&M Costs		1,869
Operating Labor	1,869	
Variable O&M Costs		7,019
Chemicals	3,408	
Waste Handling & Contracted Services	256	
Maintenance (Materials and Labor)	3,355	
Feedstock O&M Costs		211
Natural Gas	211	
Levelized, Make-up Power Cost		19,885
Levelized, Make-up Power Cost (@ \$6.40 ¢/kWh)	19,885	

3.3.2.5 Case 5/Concept A – 96% Capture with Kerr McGee/ABB Lummus amine system (costs updated from previous study)

Investment Cost:

Table 3-59 shows investment costs for the Case 5/Concept A CO₂ Separation and Compression System, which uses the Kerr McGee/ABB Lummus amine system. The costs shown in this table are the costs from the 2000 study (Bozzuto et al., 2001) escalated to 2006 dollars (1.3017 escalation factor). Included in this table (Acc't. Code - 14200) are the steam cycle modification costs as well as the new let down turbine and associated electric generator. The steam cycle modifications were described in Section 3.1.3. The Total Investment Cost (TIC) of this equipment is \$678,792,517. The expected level of accuracy for this cost estimate is +/- 30%.



**Table 3-59: Case 5/Concept A (96% Capture) CO₂ Separation and
Compression System Investment Costs**

Acc't Code	Description	Pieces	Direct Manhours	Labor (\$1,000)	Material (\$1,000)	Total (\$1,000)	%
11000	Heaters						0.00%
11200	Exchangers & Aircoolers		44,970	907	37,074	37,981	5.60%
12000	Vessel / Filters		5,776	117	4,762	4,879	0.72%
12100	Towers / Internals		43,200	872	35,615	36,487	5.38%
12200	Reactors						0.00%
13000	Tanks						0.00%
14100	Pumps		10,078	203	8,309	8,512	1.25%
14200	Compressors		100,925	2,036	83,203	85,239	12.56%
18000	Special Equipment		10,991	221	9,061	9,282	1.37%
	Sub-Total Equipment	436	215,940	4,357	178,023	182,380	26.87%
21000	Civil		287,919	5,809	12,461	18,271	2.69%
21100	Site Preparation						0.00%
22000	Structures		75,579	1,524	7,299	8,823	1.30%
23000	Buildings		39,589	799	2,136	2,935	0.43%
30000	Piping		593,833	11,981	32,044	44,025	6.49%
40000	Electrical		305,914	6,173	14,242	20,415	3.01%
50000	Instruments		251,929	5,083	22,253	27,336	4.03%
61100	Insulation		215,939	4,357	9,258	13,614	2.01%
61200	Fireproofing		107,970	2,179	2,670	4,849	0.71%
61300	Painting		53,985	1,090	1,246	2,335	0.34%
	Sub-Total Commodities		1,932,657	38,995	103,608	142,603	21.01%
70000	Construction Indirects					62,928	9.27%
	Sub-Total Direct Cost (Bare Erected Cost)					387,911	57.15%
71000	Construction Management					2,603	0.38%
80000	Home Office Engineering					57,889	8.53%
80000	Basic Engineering					6,509	0.96%
95000	License Fee	Excluded					0.00%
19400	Vendor Reps					3,254	0.48%
19300	Spare parts					5,207	0.77%
80000	Training cost	Excluded					0.00%
80000	Commission	Excluded					0.00%
19200	Catalyst & Chemicals	Excluded					0.00%
97000	Freight					1,432	0.21%
96000	CGL / BAR Insurance					8,461	1.25%
91400	Escalation to July 2001 Dollars					13,017	1.92%
	Total Base Cost					486,283	71.64%
	Contractors Fee					25,709	3.79%
	Total (EPC):					511,991	75.43%
93000	Project Contingency					96,978	14.29%
93000	Process Contingency					69,824	10.29%
	Total Investment Cost (TIC):					678,793	100.00%

Exclusions: bonds, taxes, import duties, hazardous material handling & disposal, capital spare parts, catalyst & chemicals, commissioning and initial operations, buildings other than control room & MCC.

Operating and Maintenance Cost:

Table 3-60 shows O&M costs for the Case 5/Concept A CO₂ Separation and Compression System, which captures 96% of the carbon dioxide from the Conesville #5 flue gas stream. They amount to \$132,809,000/yr.

Table 3-60: Case 5/Concept A (96% Capture) CO₂ Separation and Compression System Operating & Maintenance Costs

Operating & Maintenance Costs	Subtotal (\$1000/yr)	Total (\$1000/yr)
Fixed O&M Costs		2,488
Operating Labor	2,488	
Variable O&M Costs		18,640
Chemicals	4,870	
Waste Handling & Contracted Services	843	
Maintenance (Materials and Labor)	\$12,927	
Feedstock O&M Costs		890
Natural Gas	890	
Levelized, Make-up Power Cost		86,832
Levelized, Make-up Power Cost (@ \$6.40 ¢/kWh)	86,832	

3.3.3 Boiler Modification Costs

For this project the Boiler Scope is defined as everything on the gas side upstream of the FGD System. Therefore, it includes equipment such as the steam generator, pulverizers, fans, ductwork, electrostatic precipitator (ESP), air heater, coal and ash handling systems, etc. Purposely not included in the boiler scope definition is the FGD system. The FGD system modification costs are shown separately in Section 3.3.4. For all the capture options investigated in this study (Cases 1-5), Boiler Scope is not modified from the Base Case configuration and, as such, there are no costs in this category.

3.3.4 Flue Gas Desulfurization System Modification Costs

Flue Gas Desulfurization System modification costs for these CO₂ capture options are relatively minor as compared to the other new equipment required. The Flue Gas Desulfurization System modifications, which include the addition of a secondary absorber island, building, booster fan, and ductwork, are described in Section 3.1.3. The total cost required for the Flue Gas Desulfurization (FGD) System scope modifications is \$15,800,000 in January 2000 dollars. At an escalation rate of 4.12% per year for this type of equipment (Oil & Gas Journal, 2006), in July 2006 dollars EPC cost, is \$20,540,000 ($[15,800,000 * 1.0412]^{6.5}$). The bare erected cost of the FGD System was estimated to be \$15,680,000 in July 2006 dollars. An 11% project contingency was added to the the FGD System cost, therefore, the TIC contribution is \$22,264,800. This cost is applied to all the capture options investigated in this study (i.e., Cases 1-5). This estimate

includes material, engineering and construction. The expected level of accuracy for this cost estimate is +/- 10%.

3.3.5 Let Down Steam Turbine/Generator Costs

The MEA systems require significant quantities of heat for regeneration of the MEA solvent. Low-pressure steam is extracted from the existing turbine to provide the energy for solvent regeneration. The steam extraction location is the existing turbine IP/LP crossover pipe. This steam is expanded from ~200 psia to 65 psia for Case 5 or 47 psia for Cases 1-4 through a new “Let down” steam turbine/generator where electricity is produced. The exhaust steam leaving the new let down turbine provides the heat source for solvent regeneration in the reboilers of the MEA CO₂ recovery system. Table 3-61 shows the investment costs for the let down steam turbine generator (D&R cost basis). Although the costs shown for these turbines are on a D&R (Delivered and Representative) basis, construction costs and other balance of plant costs associated with these turbines are included for each case as a part of the CO₂ Separation and Compression System Investment Costs shown in Section 3.3.2.

Table 3-61: Let Down Turbine Generator Costs and Electrical Outputs for Cases 1-5 (D&R Cost Basis)

Let Down Steam Turbine Costs (D&R Basis)	OCDO-A updated	Current Study				
		96% (Case-5)	90% (Case-1)	70% (Case-2)	50% (Case-3)	30% (Case-4)
CO ₂ Capture Percentage						
Generator Cost (10 ³ \$)	10,516	9,800	9,400	8,900	8,500	
Generator Output (kWe)	62,081	45,321	35,170	25,031	14,898	

3.3.6 Charges for Loss of Power During Construction

During the construction period for the new equipment, it is assumed the existing Conesville Unit #5 power plant will be operated in its normal way. The new CO₂ capture equipment is being located in three separate locations (see Appendix I for plant layout drawings), and it is assumed that the erection of this equipment will not impede the operation of Conesville Unit #5 or any of the other units on site. Once construction is completed, it has been assumed that the final connections between the CO₂ capture systems and the existing power plant can be completed during the annual outage for the unit. Final shakedown testing will be completed after the outage. Therefore, there are no charges for loss of power during construction.

3.3.7 Summary of Total Retrofit Investment Costs

Table 3-62 summarizes the total retrofit investment costs (TIC Basis) required for each of the five cases. The first column shows the costs for updated Case 5/Concept A from the previous study (Bozzuto et al., 2001), which captures ~96% of the CO₂. The last four columns show the costs for the current study (Cases 1-4) using the advanced MEA system. The costs include specific costs (\$/kWe) on both a new and original kWe basis.


Table 3-62: Total Retrofit Investment Costs (Cases 1-5)

Retrofit Cost Summary (\$1000)	2001 Study Updated	Current Study			
	96% (Case-5)	90% (Case-1)	70% (Case-2)	50% (Case-3)	30% (Case-4)
CO ₂ Separation and Compression System	668,277	368,029	333,406	249,490	181,070
Flue Gas Desulfurization System	22,265	22,265	22,265	22,265	22,265
Let Down Steam Turbine Generator*	10,516	9,800	9,400	8,900	8,500
Boiler Modifications					
Total Retrofit/Investment Cost (i.e., TIC):	701,057	400,094	365,070	280,655	211,835
\$/kW-new:	2,786	1,319	1,095	773	540
\$/kW-original:	1,616	922	842	647	488

*Engineering, construction management, overhead, fees, and contingency are Included in the CO₂ separation and compression system cost.

Figure 3-39 shows the specific investment costs (\$/kWe) for each case. Two costs are plotted for each of the cases in this figure. The upper curve specific costs are relative to the new plant output, which is lower than the original (Base Case) due to added auxiliary power and reduced steam turbine output. The lower curve specific costs are relative to the original plant output of the Base Case.

By comparing the cost for the 96% capture case from the previous study with the cost for the 90% capture case from the current study, as shown in Figure 3-39s a significant cost reduction is indicated for the current study. The current study specific costs (\$/kWe-new) are about half of what the updated previous study (96% capture case) results indicate. It should be pointed out that if Case 5 (~96% recovery) was designed as a part of the current study, it would likely have equipment selections similar to Case 1 (90% recovery) and therefore significant cost reductions and improved economics would result.


Figure 3-39: New Equipment Specific Investment Costs

The specific costs for the current study cases (Cases 1-4) are nearly a linear function of CO₂ recovery percentage. However, some economy of scale effects and other non-linearities are evident. To help understand this non-linearity, a brief review of equipment selection is necessary.

Table 3-63 shows a summary of the major equipment selected for the CO₂ Removal, Compression, and Liquefaction Systems for all five cases. Three categories are shown in this table (Compressors, Towers/Internals, and Heat Exchangers). These three categories represent the three most costly accounts in the cost estimates for these systems. These accounts represent ~90% of the total equipment costs for these systems. A review of this table shows how the number of compression trains is reduced from two trains, for the 90% and 70% recovery cases, to one train for the 50% and 30% recovery cases. Similarly, the number of absorber/stripper trains is reduced from two trains for the 90%, 70%, and 50% recovery cases to one train for the 30% recovery. The heat selections show even more variation between the cases. Equipment sizes are also indicated in this table.

Table 3-63: CO₂ Removal, Compression, and Liquefaction System Equipment Summary (Cases 1-5)

	90% (Case-1)		70% (Case-2)		50% (Case-3)		30% (Case-4)		96% (Case-5)	
	No.	HP ea	No.	HP ea	No.	HP ea	No.	HP ea	No.	HPea
Compressors										
CO ₂ Compressor	2	15,600	2	12,100	1	17,300	1	10,400	7	4,500
Propane Compressor	2	11,700	2	10,200	1	14,600	1	8,800	7	3,100
LP Let Down Turbine	1	60,800	1	47,200	1	33,600	1	20,000	1	82,300
Towers/Internals										
Absorber/Cooler	2	34/126	2	30/126	2	25/126	1	28/126	5	27/126
Stripper	2	22/50	2	19/50	2	16/50	1	20/50	9	16/50
Heat Exchangers										
Reboilers	10	120.0	8	120.0	6	120.0	4	120.0	9	217.0
Solvent Stripper CW Condenser	12	20.0	10	20.0	7	20.0	4	20.0	9	42.0
Other Heat Exchangers / Average Duty	36	61.0	35	57.0	25	62.0	16	58.0	113	36.0
Total Heat Exchangers / Average Duty	58	62.7	53	59.5	38	63.4	24	62.0	131	48.8

It should also be noted, as shown in Table 3-63, that the design of Case 5 (See Bozzuto et al., 2001) is not totally consistent with the design of Case 1 done in the current study, although the CO₂ recovery in each case is similar. Case 1 uses two (2) absorber trains, two stripper trains, and two compression trains. Conversely, Case 5, which was designed in 2000, used five absorber trains, nine stripper trains, and seven compression trains. Because of these differences, Case 1 is able to take advantage of economy of scale effects for equipment cost with the larger equipment sizes used in each train as compared to Case 5. Additionally, Case 5 equipment was all located about 457 m (1,500 ft) from the Unit #5/6 common stack, which also contributed to the increased cost of Case 5 relative to Case 1.

All the costs shown above were used in the economic evaluation (Section 3.4) to develop incremental Cost of Electricity (COE) values and CO₂ mitigation cost comparisons.

3.4 Economic Analysis

A comprehensive economic evaluation comparing the Base Case study unit and various retrofit CO₂ capture scenarios using an advanced amine was performed. The purpose of the evaluation was to quantify the impact of CO₂ capture on the Cost of Electricity (COE) for this existing coal-fired unit. CO₂ mitigation costs were also determined in this analysis. The economic evaluation results are presented as incremental Costs of Electricity (levelized basis). The reported costs of electricity are incremental relative to the Base Case (air fired without CO₂ capture, i.e., business as usual).

Additionally, economic sensitivity studies were developed for each of the CO₂ capture options to highlight which parameters affected the incremental COE and CO₂ mitigation cost to the greatest extents. The sensitivity parameters chosen (Investment Cost, Capacity Factor, Make-up Power Cost, and CO₂ Selling Price) were judged to be the most important parameters to vary for this project. These parameters are either site-specific or there is uncertainty in their values in looking to the future. Therefore, proper use of the sensitivity results could potentially allow extrapolation of results for application to units other than the selected study unit (Conesville Unit #5).

The economic analysis was performed by Research and Development Solutions, Inc. (RDS) using the levelized revenue requirement method (a form of discounted cash flow analysis). The model has the capability to analyze the economic effects of different technologies based on differing capital costs, operating and maintenance costs, fuel costs, and cost of capital assumptions. The primary metrics are levelized cost of electricity (LCOE) and CO₂ mitigation cost. Both are reported on an incremental cost of CO₂ capture basis within this study. All cost data were provided by Alstom (see Section 3.3).

3.4.1 Economic Study Scope and Assumptions

A total of five CO₂ capture cases were evaluated in this economic analysis in addition to the Base Case without CO₂ capture:

- Case 1: 90% CO₂ capture with advanced “State of the Art” amine
- Case 2: 70% CO₂ capture with advanced “State of the Art” amine
- Case 3: 50% CO₂ capture with advanced “State of the Art” amine
- Case 4: 30% CO₂ capture with advanced “State of the Art” amine
- Case 5: 96% CO₂ capture with Kerr-McGee/ABB Lummus amine technology (ca. 2000)

Case 5 is simply an update of Concept A of the previous study (Bozzuto et al., 2001). As shown in Section 3.3.2.5, the investment and O&M costs of Concept A of the previous study were updated to July 2006 U.S. dollars. This information was used to update the economic analysis of Case 5 to a common basis with Cases 1-4.

The primary outputs from this economic analysis are the incremental Levelized Cost of Electricity (LCOE) and CO₂ mitigation costs relative to the Base Case. These two measures of economic merit were determined for all cases evaluated.

Incremental LCOE was calculated using a simplified model derived from the NETL Power Systems Financial Model for calculating levelized cost of electricity.³ Total Plant Cost (TPC) was replaced with Total Investment Cost (TIC) to reflect the retrofit analyzed within this study. The term “Incremental COE” and “LCOE” are used synonymously within this report. The following equation was used to calculate the LCOE over a 20-year period.

$LCOE_p = \text{levelized annual capital charge} + \text{levelized annual operating costs}$

$$LCOE_p = \frac{(CCF_p)(TPC) + [(LF_{F1})(OC_{F1}) + (LF_{F2})(OC_{F2}) + \dots] + (CF)[(LF_{V1})(OC_{V1}) + (LF_{V2})(OC_{V2}) + \dots]}{(CF)(KWH)}$$

Where:

- LCOE = levelized cost of electricity over P years
- P = levelization period (e.g., 10, 20, or 30 years)
- CCF = capital charge factor for a levelization period of P years
- TIC = total investment cost [the sum of bare erected costs (includes costs of process equipment, supporting facilities, direct and indirect labor), detailed design costs, construction/project management costs, project contingency, process contingency and technology fees]
- LF_{F_n} = levelization factor for category n fixed operating cost
- OC_{F_n} = category n fixed operating cost for the initial year of operation (but expressed in “first-year-of-construction” year dollars)
- CF = plant capacity factor
- LF_{V_n} = levelization factor for category n variable operating cost
- OC_{V_n} = category n variable operating cost at 100% capacity factor for the initial year of operation (but expressed in “first-year-of-construction” year dollars)
- KWH = annual net kilowatt-hours of power generated at 100% capacity factor

All costs are expressed in “first-year-of-construction” year dollars, and the resulting LCOE is also expressed in “first-year-of-construction” year dollars (January 2007). CO₂ mitigation and capture costs were calculated according to the following equations.

$$\text{CO}_2 \text{ Mitigation Cost} = (LCOE_{Cp} - LCOE_{Ref}) / (CO_{2Ref \text{ emitted}} - CO_{2Cp \text{ emitted}})$$

$$\text{CO}_2 \text{ Captured Cost} = (LCOE_{Cp} - LCOE_{Ref}) / (CO_{2Cp \text{ produced}} - CO_{2Cp \text{ emitted}})$$

Where:

- CO₂ Mitigation Cost = \$/ton of CO₂ avoided
- CO₂ Captured Cost = \$/ton of CO₂ removed
- CO₂ = Carbon dioxide (tons/kWh at plant capacity factor)
- LCOE = Levelized cost of electricity (\$/kWh)
- c_p = Capture plant
- Ref = Reference plant

³ Power Systems Financial Model Version 5.0, September 2006.

Economic Study Assumptions:

The base assumptions used to evaluate the Base Case (i.e., without CO₂ capture) and all other CO₂ capture cases (Cases 1-5) are given in Table 3-64. This approach enabled the evaluation of the impacts of CO₂ capture in terms of incremental costs of electricity and CO₂ mitigations costs.

Table 3-64: Base Economic Assumptions (Base Case and Cases 1-5)

Parameter	Unit	Value
Investment Cost	\$/kW	as estimated
Capacity Factor	%	85
Income Tax Rate	%	38
Repayment Term of Debt	Years	15
Grace Period on Debt Repayment	Years	0
Debt Reserve Fund		None
Depreciation (150% declining balance)	Years	20
Working Capital (all parameters)	\$	0
Investment Tax Credit	%	0
Tax Holiday	Years	0
Start-up Costs (% of EPC)	%	2
EPC Escalation	%	0
Duration of Construction	Years	3
Debt	%	45
Equity	%	55
After-tax Weighted Cost of Capital	%	9.67
Capital Charge Factor	-	0.175
Fixed O&M Levelization Factor	-	1.1568
Variable O&M Levelization Factor	-	1.1568
Natural Gas Levelization Factor	-	1.1651

Table 3-65 compares the economic analysis results for Cases 1-5 to the Base Case (0% Capture). American Electric Power (AEP) provided the assumptions pertaining to the Base Case unit (i.e., Conesville #5 Unit) operating at a 72% capacity factor. The Base Case values were adjusted to an 85% capacity factor for comparison to Cases 1-5.



Table 3-65: Economic Evaluation Study Assumptions (Base Case and Cases 1-5)

Percent CO ₂ Capture (Case)	0% (Base Case)	90% (Case-1)	70% (Case-2)	50% (Case-3)	30% (Case-4)	96% (Case-5)
Power Generation						
Net Output (MW)	433.8	303.3	333.2	362.9	392.1	251.6
Capacity Factor (%)	85%	85%	85%	85%	85%	85%
Operating Hours (hrs/yr)	7,446	7,446	7,446	7,446	7,446	7,446
Net Efficiency, HHV (%)	35.0%	24.5%	26.9%	29.3%	31.7%	20.3%
Net Plant Heat Rate, HHV (Btu/kWh)	9,778	13,984	12,728	11,686	10,818	16,856
Total Fuel Heat Input at MCR (MMBtu/hr)	4,242	4,242	4,242	4,242	4,242	4,242
Coal HHV Input (MMBtu/hr)	4,229	4,229	4,229	4,229	4,229	4,229
Net Generation (MWh/yr)	3,230,075	2,258,498	2,481,342	2,702,488	2,919,331	1,873,667
Costs						
Total Investment Cost (\$1000s)	NA	400,094	365,070	280,655	211,835	701,057
Total Investment Cost (\$/kW)	NA	1,319	1,095	773	540	2,786
Fixed O&M Costs (\$1000/yr)	0	2,494	2,284	2,079	1,869	2,488
Variable O&M Costs (\$1000/yr)	0	17,645	14,711	10,876	7,019	18,640
Levelized, Make-up Power Cost						
Make-up Power Cost (¢/kWh)	NA	6.40	6.40	6.40	6.40	6.40
Make-up Power Cost (\$1000/yr)	0	62,194	47,926	33,768	19,885	86,832
CO ₂ By-product Revenue						
CO ₂ By-product Selling Price (\$/ton)	0	0	0	0	0	0
CO ₂ By-product (lb/hr)	866,102	779,775	607,048	433,606	260,163	835,053
CO ₂ By-product Revenue (\$1000/yr)	0	0	0	0	0	0
Feedstock O&M Costs						
Coal Price (\$/MMBtu)	1.80	1.80	1.80	1.80	1.80	1.80
Coal for CO ₂ System (MMBtu/hr)	0	0	0	0	0	0
Coal Cost (\$1000/yr)	0	0	0	0	0	0
Natural Gas Price (\$/MMBtu)	6.75	6.75	6.75	6.75	6.75	6.75
Natural Gas for CO ₂ System (MMBtu/hr)	0	13.00	9.70	6.70	4.20	17.70
Natural Gas Cost (\$1000/yr)	0	653	488	337	211	890
LCOE Assumptions						
Levelization Term (years)	NA	20	20	20	20	20
Capital Charge Factor	NA	0.175	0.175	0.175	0.175	0.175
Fixed O&M Levelization Factor	NA	1.1568	1.1568	1.1568	1.1568	1.1568
Variable O&M Levelization Factor	NA	1.1568	1.1568	1.1568	1.1568	1.1568
Feedstock O&M Levelization Factor	NA	1.1651	1.1651	1.1651	1.1651	1.1651
LCOE Contributions						
Capital Component (¢/kWh)	NA	3.10	2.57	1.82	1.27	6.55
Fixed O&M (¢/kWh)	NA	0.13	0.11	0.09	0.07	0.15
Variable O&M (¢/kWh)	NA	3.66	2.62	1.72	0.96	5.79
Feedstock O&M (¢/kWh)	NA	0.03	0.02	0.01	0.01	0.06
Total (¢/kWh)	NA	6.92	5.32	3.64	2.31	12.54
CO ₂ Mitigation Cost (\$/ton)	NA	81	88	91	103	134
CO ₂ Mitigation Cost (\$/tonne)	NA	89	96	100	113	148
CO ₂ Capture Cost (\$/ton)	NA	54	58	61	70	76
CO ₂ Capture Cost (\$/tonne)	NA	59	64	67	77	83

Note: Make-up Power Cost (MUPC) applied to this study is already levelized over 20 years. Therefore, the annual cost represents the "levelized cost" not the "first-year cost". The reported annual MUPC is not multiplied by the variable O&M levelization factor when calculating the LCOE. The CO₂ By-product revenue represents the "first-year cost" and is multiplied by the variable O&M levelization factor when calculating the LCOE.

Economic Sensitivity Study:

Additionally, economic sensitivity studies were developed for the five primary cases (each of the CO₂ capture options) to highlight which parameters affected the incremental LCOE and CO₂ mitigation cost to the greatest extents. A total of 40 economic evaluation cases are reported in Appendix III. The sensitivity analysis was designed to show the effects on incremental LCOE and CO₂ mitigation cost of variations in the four parameters of interest. The four parameters varied in this sensitivity study were capacity factor, total investment cost, make-up power cost (levelized), and CO₂ by-product selling price (levelized). Three points were calculated for each parameter as shown in Table 3-66. These sensitivity parameters were chosen since the base values used for these parameters are site specific to this project. Therefore proper use of these sensitivity results could potentially allow extrapolation to apply results to units other than just Conesville #5.

Table 3-66: Economic Sensitivity Study Parameters

Parameter	Units	Base	Sensitivity Analysis	
			Base – 25%	Base +25%
Total Investment Cost (TIC)	\$	As Estimated	Base – 25%	Base +25%
Capacity Factor	%	85	72	90
CO ₂ Selling Price, Levelized	\$/ton	0	25	50
Make-up Power Cost, Levelized	¢/kWh	6.40	4.80	8.00

3.4.2 Economic Analysis Results

This section summarizes all the economic analysis results obtained from this study. Results discussed in subsections 3.4.2.1 and 3.4.2.2 were obtained while using a combination of economic assumptions given in Table 3-64 and Table 3-65. The results discussed in subsection 3.4.2.3 were obtained while using a combination of economic assumptions given in Table 3-64, Table 3-65, and Table 3-66. All these results are briefly discussed in the following subsections.

3.4.2.1 Economic Results for Cases 1-4 (90%-30% CO₂ capture)

Economic results for Cases 1-4 are shown in Table 3-67 and plotted in Figure 3-40 and Figure 3-41. The incremental LCOE is comprised of capital, fixed O&M, variable O&M, and fuel components. For the 90% CO₂ capture, for example, the respective LCOE values for these components are 3.10, 0.13, 3.66, and 0.03 ¢/kWh for a combined total of 6.92 ¢/kWh. The total incremental LCOE decreases almost linearly from 6.92 to 2.31 ¢/kWh as the CO₂ capture level decreases from 90% to 30%. The CO₂ mitigation cost, on the other hand, increases slightly from \$89 to \$113/tonne of CO₂ avoided, as the CO₂ capture level decreases from 90% to 30%, due to economy of scale effects.

Table 3-67: Economic Results (Cases 1-4)

Case	Case 1	Case 2	Case 3	Case 4
Power Generation				
Net Output (MW)	303.3	333.2	362.9	392.1
Capacity Factor (%)	85%	85%	85%	85%
Net Plant Heat Rate, HHV (Btu/kWh)	13,984	12,728	11,686	10,818
Net Efficiency, HHV (%)	24.5%	26.9%	29.3%	31.7%
Energy Penalty	10.5%	8.1%	5.7%	3.3%
CO₂ Profile				
CO ₂ Captured (lb/hr)	779,775	607,048	433,606	260,163
CO ₂ Captured (%)	90%	70%	50%	30%
Costs				
Total Investment Cost (\$1000s)	400,094	365,070	280,655	211,835
Total Investment Cost (\$/kW)	1,319	1,095	773	540
Fixed O&M Costs (\$1000/yr)	2,494	2,284	2,079	1,869
Variable O&M Costs (\$1000/yr)	17,645	14,711	10,876	7,019
Levelized, MUPC (\$1000/yr)	62,194	47,926	33,768	19,885
CO ₂ By-product Revenue (\$1000/yr)	0	0	0	0
Feedstock O&M Costs (\$1000/yr)	653	488	337	211
Coal Cost (\$1000/yr)	0	0	0	0
Natural Gas Cost (\$1000/yr)	653	488	337	211
LCOE Contributions				
Capital Component (¢/kWh)	3.10	2.57	1.82	1.27
Fixed O&M (¢/kWh)	0.13	0.11	0.09	0.07
Variable O&M (¢/kWh)	3.66	2.62	1.72	0.96
Feedstock O&M (¢/kWh)	0.03	0.02	0.01	0.01
Total (¢/kWh)	6.92	5.32	3.64	2.31
CO ₂ Mitigation Cost (\$/ton)	81	88	91	103
CO ₂ Mitigation Cost (\$/tonne)	89	96	100	113
CO ₂ Capture Cost (\$/ton)	54	58	61	70
CO ₂ Capture Cost (\$/tonne)	59	64	67	77

Note: Make-up Power Cost (MUPC) applied to this study is already levelized over 20 years. Therefore, the annual cost represents the "levelized cost" not the "first-year cost". The reported annual MUPC was not multiplied by the variable O&M levelization factor when calculating the LCOE. The CO₂ By-product revenue represents the "first-year cost" and was multiplied by the variable O&M levelization factor when calculating the LCOE.




Figure 3-40: Economic Results (Cases 1-4)




Figure 3-41: Impact of CO₂ Capture Level on Incremental LCOE and CO₂ Mitigation Cost (Cases 1-4)

3.4.2.2 Economic Results for Case 1 and Case 5 (90% and 96% CO₂ capture)

As stated in Section 3.3.2.5, the investment costs and O&M costs of Concept A (96% CO₂ Capture with MEA) from the previous study (Bozzuto et al., 2001) were updated to July 2006 dollars. The economic analysis of this case, referred to in the present study as Case 5, was then done in the same manner as Cases 1-4. Results obtained from Case 5 are compared below to those obtained from Case 1 (90% CO₂ capture). The rationale for this comparison is that the CO₂

capture percentages of both cases are close to one another, and this comparison shows the impact of using the advanced amine on economic performance parameters of merit. An equitable comparison of specific costs (\$/kWe) and economics (LCOE, mitigation costs) between the advanced amine and the Kerr-McGee/ABB Lummus amine was not possible since the amine system design for the previous study was not consistent with the current designs for the advanced amine, as explained in more detail below.

Economic results for Case 1 and Case 5 are shown in Table 3-68 and Figure 3-42. The capital, fixed O&M, variable O&M, and fuel components of the incremental LCOE for Case 5 are 6.55, 0.15, 5.79, and 0.06 ¢/kWh for a total incremental LCOE value of 12.54 ¢/kWh. The corresponding values for Case 1 are 3.10, 0.13, 3.66, and 0.03 ¢/kWh for a combined total of 6.92 ¢/kWh. Extrapolating the Case 1 LCOE to 96% capture would yield an incremental COE of about 7.37 ¢/kWh. This shows an improvement of 5.17 ¢/kWh at the 96% capture level (i.e., the advanced amine vs. the Kerr-McGee/ABB Lummus amine).

The cost of electricity for Case 5 is 81% higher than that of Case 1, primarily due to its higher total investment cost (\$2,786 vs. \$1,319/kWe), reduced efficiency (20.3% vs. 24.5% HHV), and, to a lesser extent, higher CO₂ capture (96% vs. 90%). Consistent with incremental LCOE results, the CO₂ mitigation cost of Case 5 is more than 66% higher than that of Case 1 (\$148 vs. \$89/tonne).

It should be noted that the design of Case 5 (See Bozzuto et al., 2001) is not totally consistent with the design of Case 1 done in this study. Case 1 uses 2 absorbers, 2 strippers, and 2 compression trains. Case 5, which was designed in 2000, used 5 absorbers, 9 strippers, and 7 compression trains. Because of these differences, Case 1 is able to take advantage of economy of scale effects for equipment cost due to the larger equipment sizes. Additionally, Case 5 equipment was all located about 457 m (1,500 ft) from the Unit #5 stack, which also increased the costs of Case 5 relative to Case 1. It should be pointed out that if Case 5 (~96% recovery) was designed as a part of the current study, it would likely have equipment selections similar to Case 1 (i.e., a two-train system) and therefore significant cost reductions and improved economics would result.

Because of these significant design differences, an equitable comparison of specific costs (\$/kWe) and economics (LCOE, mitigation costs) between the advanced amine and the Kerr-McGee/ABB Lummus amine was not possible. The results presented in Table 3-68 and Figure 3-42 must be viewed with the above context.

Table 3-68: Economic Results for Cases 1 and 5

Case	Case 1	Case 5
Power Generation		
Net Output (MW)	303.3	251.6
Capacity Factor (%)	85%	85%
Net Plant Heat Rate, HHV (Btu/kWh)	13,984	16,856
Net Efficiency, HHV (%)	24.5%	20.3%
Energy Penalty	10.5%	14.7%
CO₂ Profile		
CO ₂ Captured (lb/hr)	779,775	835,053
CO ₂ Captured (%)	90.0%	96.0%
Costs		
Total Investment Cost (\$1000s)	400,094	701,057
Total Investment Cost (\$/kW)	1,319	2,786
Fixed O&M Costs (\$1000/yr)	2,494	2,488
Variable O&M Costs (\$1000/yr)	17,645	18,640
Levelized Make-up Power Cost (\$1000/yr)	62,194	86,832
CO ₂ By-product Revenue (\$1000/yr)	0	0
Feedstock O&M Costs (\$1000/yr)	653	890
Coal Cost (\$1000/yr)	0	0
Natural Gas Cost (\$1000/yr)	653	890
LCOE Contributions		
Capital Component (¢/kWh)	3.10	6.55
Fixed O&M (¢/kWh)	0.13	0.15
Variable O&M (¢/kWh)	3.66	5.79
Feedstock O&M (¢/kWh)	0.03	0.06
Total (¢/kWh)	6.92	12.54
CO ₂ Mitigation Cost (\$/ton)	81	134
CO ₂ Mitigation Cost (\$/tonne)	89	148
CO ₂ Capture Cost (\$/ton)	54	76
CO ₂ Capture Cost (\$/tonne)	59	83

Note: Make-up Power Cost (MUPC) applied to this study is already levelized over 20 years. Therefore, the annual cost represents the "levelized cost" not the "first-year cost". The reported annual MUPC was not multiplied by the variable O&M levelization factor when calculating the LCOE. The CO₂ by-product revenue represents the "first-year cost" and was multiplied by the variable O&M levelization factor when calculating the LCOE.




Figure 3-42: Economic Results for Case 1 and Case 5

3.4.2.3 Economic Sensitivity Analysis Results

The economic sensitivity analysis was done by varying a number of parameters (Capacity Factor, Total Investment Cost, Make-up Power Cost, and CO₂ By-product Selling Price) that affect the economic results. These sensitivity parameters were chosen since the base values used for these parameters are site specific to this project. Therefore, proper use of these sensitivity results could potentially allow extrapolation to apply results to units other than just Conesville #5. The objective of this analysis was to determine the relative impacts of the sensitivity parameters and CO₂ capture level on incremental cost of electricity and CO₂ mitigation cost.

Results obtained from Cases 1, 2, 3, 4, and 5 (with 90%, 70%, 50%, 30%, and 96% CO₂ capture, respectively) are presented in tabular and graphical forms in **Appendix III**. The economic sensitivity results obtained from Case 1 (90% CO₂ capture) are briefly discussed below. Detailed economic results for Case 1 and the other cases are in Appendix III.

Economic Sensitivity Analysis Results for Case 1 (90% CO₂ Capture)

Results for the Case 1 sensitivity study are shown in Figure 3-43. This figure shows the sensitivity of incremental LCOE to capacity factor, total investment cost, make-up power cost, and CO₂ by-product selling price. The base parameter values represent the point in Figure 3-43 where all the sensitivity curves intersect (point 0.0, 0.0). The incremental LCOE ranges from a low of -0.50 ¢/kWh to a high of 7.96 ¢/kWh for the Case 1 sensitivity analysis. The order of sensitivity (most sensitive to least sensitive) of these parameters to incremental LCOE is: CO₂ by-product selling price (levelized) > capacity factor > total investment cost > make-up power cost (levelized). For Cases 2 thru 5, the total investment cost becomes more significant than the make-up power cost, but, they are approximately equivalent in Case 1.





Figure 3-43: Economic Sensitivity Results (Case 1 - 90% CO₂ Capture)

4 ADVANCES IN POST COMBUSTION CO₂ CAPTURE TECHNOLOGIES

Numerous major research and developmental efforts are continually ongoing inside and outside the U.S. to further advance post-combustion CO₂ capture technologies. Such efforts seek to develop advanced/breakthrough technologies aimed at improving performance and cost, with the ultimate goal of developing cost-competitive post-combustion CO₂ capture technologies. A selected number of these technologies are listed in Table 4-1.

As can be seen, these technologies are at various stages of development, ranging from laboratory-scale to commercial-scale. More detailed information can be found on these technologies through the websites/references given in the table.

Table 4-1: List of Selected Advanced Post-Combustion CO₂ Capture Technologies

Technology	R & D by	Status	Information Source
Aqueous Ammonia	Powerspan, In-house NETL	Pilot-plant	DOE NETL Carbon Sequestration Technology Roadmap and Program Plan 2006 (www.netl.gov)
Amine-Enhanced Sorbents	In-house NETL	Laboratory scale	CO ₂ Capture Systems Using Amine Enhanced Sorbents, Coal-Gen 2006, Cincinnati, OH; (www.netl.gov)
Ionic Liquids	University of Notre Dame; SACHEM; Merck	Laboratory scale	DOE NETL Carbon Sequestration Technology Roadmap and Program Plan 2006 (www.netl.gov)
Enzymatic CO ₂ Sorbents	Carbozyme CO ₂	Laboratory scale	DOE NETL Carbon Sequestration Technology Roadmap and Program Plan 2006 (www.netl.gov)
Dry Regenerable Sorbents	Research Triangle Institute	Laboratory scale, Pilot scale	DOE Website: www.netl.gov
Chilled Ammonia	Alstom	Pilot scale (5-MWth)	http://www.power.alstom.com
KS [®] Solvents (KS 1, KS2, KS3)	Kansai Electric Power Co./ Mitsubishi Heavy Industry, Ltd.	Commercial scale on gas fired flue gas, Pilot scale on coal-fired flue gas	Japanese R&D on Large-Scale CO ₂ Capture http://services.bepress.com/cgi/viewcontent.cgi?article=1006&context=eci/separations_technology_vi

Selected technologies are briefly described below.

Aqueous Ammonia: This joint NETL-Powerspan development entails reacting ammonia with CO₂ in the flue gas to form ammonium carbonate, and subsequently heating the ammonium carbonate to release a pure CO₂ stream. Advantages include: (1) low theoretical heat of regeneration (286 Btu/lbm CO₂ vs. 825 Btu/lbm CO₂ for MEA); and (2) multi-pollutant control with saleable by-products (ammonium sulfate and ammonium nitrate fertilizers). One technical challenge is degradation of carbonate in the CO₂ absorber leading potentially to ammonia slip in the flue gas.

Amine-Enhanced Sorbents: This technology is being developed by NETL. The principle of operation of the process entails exposing a CO₂-rich stream to a carbon material (substrate) with

amine compounds attached unto it. The CO₂ absorbed on the amine sites is subsequently released upon increasing the temperature. This process has some advantages over the MEA process, e.g., higher CO₂ carrying capacity; lower heat capacity, as there is no water to heat. One technical challenge is that small particle diameters can cause high-pressure drops across the absorber. The sorbent regeneration energy has been estimated at 620 Btu/lbm CO₂, which would be a breakthrough improvement over the current state-of-the-art of about 1,600 Btu/lbm CO₂.

Chilled Ammonia: This process, being developed by Alstom, entails chilling the flue gas, recovering large quantities of water for recycle, and then utilizing a CO₂ absorber similar in design to the absorbers used in systems to reduce flue gas sulfur dioxide emissions. CO₂ is stripped at high pressure and compressed to a pressure suitable for use in EOR or sequestration. In laboratory tests co-sponsored by Alstom, EPRI, and others, the process has demonstrated a potential for capturing more than 90% CO₂ at an efficiency penalty that is much lower than other CO₂ capture technologies. This process is undergoing validation testing in a 5-MW_{th} slipstream from a plant in Wisconsin.

KS[®] Solvents (KS1, KS2, and KS3): Kansai Electric Power Company (KEPCO) and Mitsubishi Heavy Industry (MHI) in Japan jointly developed these sterically hindered amines. The KS1 process has been capturing 160 tonnes/day CO₂ from a steam reforming flue gas at Kedah Danul Aman in Malaysia since 1999. Hokuriku Electric Power Company has operated a test plant with KS[®] solvents treating 50 m³N/hr of flue gas from a coal-fired plant at the Toyama-Shinko power station. KEPCO and MHI report that the regeneration energy for KS[®] solvents is much less than that of MEA (700 vs. 900 kcal/kg-CO₂ or 1,260 vs. 1,620 Btu/lbm-CO₂).

5 SENSITIVITY OF PLANT PERFORMANCE AND ECONOMICS TO SOLVENT REGENERATION ENERGY

With respect to solvent regeneration energy, process simulation results showed that the advanced amine used in this study (Cases 1-4), based on present day technology, required 1,550 Btu/lbm-CO₂. This solvent regeneration energy was 34% less than in the prior study (2,350 Btu/lbm-CO₂), which was completed six years ago. Comparatively, recent values for solvent regeneration energy in the open literature are as shown in Table 5-1:

Table 5-1: Solvent Regeneration Energy for Amine-Based CO₂ Capture Systems

Source	Kerr-McGee Lummus MEA, Bozzuto et al. 2001	Econamine FG ⁺ , DOE/NETL, Parsons, WorleyParsons 2006	Econamine FG ^{+SM} , IEA Report PH4/33 2004	KS1-IEA Report PH4/33 2004
Btu/lbm-CO ₂	2,350	1,530	1,395	1,375

Numerous research and developmental efforts are ongoing to further advance post-combustion CO₂ capture technologies. These efforts seek to develop technologies that are focused on improving performance, and reducing cost with post-combustion CO₂ capture. One of the key parameters with post-combustion CO₂ capture systems that is an indicator of relative system performance is solvent regeneration energy requirement (Btu/lbm-CO₂). Hence, as a look to the future, a simplified sensitivity analysis for solvent regeneration energy and the resulting impacts on power plant performance (thermal efficiency) and economics (cost of electricity) was carried out.

It is understood that solvent regeneration energy represents a key variable for amine-based post-combustion CO₂ capture systems in terms of the impact this variable ultimately has on the most common measures of power plant performance (thermal efficiency) and economic merit (cost of electricity). Research and development in this area continues to progress and as a result, amine solvents and post-combustion capture systems are improving in performance. Future systems incorporating the improvements will have significant positive impacts on power plant performance and economics. Therefore, a sensitivity analysis showing the effect of anticipated reductions in solvent regeneration energy was performed in this study.

This sensitivity study was done at the 90% capture level only and the solvent regeneration energy levels investigated were 1,550 and 1,200 Btu/lbm-CO₂. These cases are referred to as **Cases 1 and 1a** respectively. The value of 1,550 Btu/lbm-CO₂ used in this study (Case 1) was taken as a base value and represents current technology (ca. 2006). The value of solvent regeneration energy for the sensitivity case (Case 1a) was selected, keeping in mind future technological developments/advancements. It is well known that commercial implementation of these amine-based post-combustion capture systems for power plant applications will not occur until several years in the future. This delay is due to a variety of reasons such as: these systems need to be proven at large scale, CO₂ sequestration technology needs to be proven, and policies need to be implemented to make utilization of these systems economical. It is also understood that solvent regeneration energy represents a key variable for amine-based post-combustion CO₂ capture systems in terms of the impact this variable ultimately has on the common measures of power plant performance (thermal efficiency) and economic merit (cost of electricity). Furthermore, research in this area continues, and as a result, amine solvents and post-combustion

capture systems in general are improving in performance and, therefore, power plants will incur reduced impacts on power plant performance and economics. The solvent regeneration energy level selected for Case 1a was 1,200 Btu/lbm-CO₂, which represents a near future goal. This solvent regeneration energy value was agreed on by NETL, RDS, and Alstom. This more advanced amine would represent an amine that would be commercially available in the near future.

This sensitivity study was completed in a very simplified manner. Process simulations, equipment design, and cost estimates for this future amine-based capture system were not developed since physical properties and other information, which are necessary for use in process design, equipment sizing, and material selection, are unknown for this future case (Case 1a). Costs for Case 1a were assumed to be the same as for Case 1. A detailed steam turbine material and energy balance was developed for Case 1a and therefore the calculated plant performance should be quite accurate for this case.

The following basic work steps were applied for this evaluation:

- Regeneration energy requirements and heat integration requirements between the Gas Processing System and the steam cycle are defined for the new case
- Alstom Steam Turbine Group (STG) calculates new steam turbine heat balance for the reduced solvent regeneration energy case
- An estimate of amine system auxiliary power changes for the reduced solvent regeneration energy case are developed
- Overall power plant performance (thermal efficiency) is calculated for the reduced solvent regeneration energy case
- Investment costs are assumed not to change for the reduced solvent regeneration energy case as compared to Case 1 (90% CO₂ capture case with 1,550 Btu/lbm-CO₂ solvent regeneration energy requirement)
- Economics (incremental COEs and CO₂ mitigation costs) are calculated for the reduced solvent regeneration energy case
- New tables, graphs, and a new report section are developed to discuss the results from the reduced solvent regeneration energy case

This sensitivity study therefore represents a view of the potential future capabilities for amine-based post-combustion CO₂ capture systems. In summary, the results obtained from this sensitivity study enabled the quantification of the performance and economic impacts on the power plant, for the 90% CO₂ capture level, with solvent regeneration energies of 1,550 and 1,200 Btu/lbm-CO₂ (**Cases 1 and 1a** respectively). Results are discussed in the following subsections.

5.1 Performance Analysis

Plant performance and CO₂ emissions are summarized for the existing and modified power plants in Table 5-2. Several graphs also illustrate selected results from the table plotted as a function of solvent regeneration energy. Four cases are shown in this section. The Base Case is

the “business as usual” case without CO₂ capture. Cases 1 and 1a are with 90% CO₂ capture, low level heat integration between the gas processing system and the steam cycle, and various levels of solvent regeneration energy. Comparisons between cases 1 and 1a isolate the impacts of solvent regeneration energy level. Case 5, from the earlier study (Bozzuto et al., 2001) is also shown. This case differs in that it has 96% CO₂ capture, a solvent regeneration energy requirement of 2,350 Btu/lbm-CO₂, and no heat integration between the gas processing system and the steam cycle. These four cases are listed below.

- **Base Case** - Existing power plant without CO₂ capture - refer to Section 2 for details.
- **Case 1** – Existing power plant retrofit with an advanced “state of the art” amine system for 90% CO₂ capture (1,550 Btu/lbm-CO₂ solvent regeneration energy) - refer to Section 3 for details.
- **Case 1a** – Existing power plant retrofit with an advanced “near future” amine system for 90% CO₂ capture (1,200 Btu/lbm-CO₂ solvent regeneration energy).
- **Case 5** – Existing power plant retrofit with a Lummus/Kerr-McGee MEA system (ca. 2000 design) for 90% CO₂ capture (2,350 Btu/lbm-CO₂ solvent regeneration energy) - refer to Section 3 for details.

Table 5-2: Plant Performance and CO₂ Emissions vs. Solvent Regeneration Energy

	(units)	Base-Case Original Plant	Case 5 Concept A MEA	Case 1 Advanced MEA	Case 1a Advanced MEA
Solvent Regeneration Energy	(Btu/lbm-CO ₂)	0	2350	1550	1200
CO ₂ Capture	(percent)	0	96	90	90
<u>Boiler Parameters</u>					
Main Steam Flow	(lbm/hr)	3131619	3131651	3131651	3131651
Reheat Steam Flow (to IP turbine)	(lbm/hr)	2853607	2853607	2848739	2848725
Main Steam Pressure	(psia)	2535	2535	2535	2535
Main Steam Temp	(Deg F)	1000	1000	1000	1000
Reheat Steam Temp	(Deg F)	1000	1000	1000	1000
Boiler Efficiency	(percent)	88.13	88.13	88.13	88.13
Flue Gas Flow leaving Economizer	(lbm/hr)	4014743	4014743	4014743	4014743
Flue Gas Temperature leaving Air Heater	(Deg F)	311	311	311	311
Coal Heat Input (HHV)	(10 ⁶ Btu/hr)	4228.7	4228.7	4228.7	4228.7
	(LHV) (10 ⁶ Btu/hr)	4037.9	4037.9	4037.9	4037.9
<u>CO₂ Removal Steam System Parameters</u>					
CO ₂ Removal System Steam Pressure	(psia)	---	65	47	47
CO ₂ Removal System Steam Temp	(Deg F)	---	478	424	424
CO ₂ Removal System Steam Extraction Flow	(lbm/hr)	---	1935690	1210043	975152
CO ₂ Removal System Condensate Pressure (from reboilers)	(psia)	---	64.7	40	40
CO ₂ Removal System Condensate Temperature	(Deg F)	---	292.7	267.3	267.3
CO ₂ Removal System Heat to Cooling Tower	(10 ⁶ Btu/hr)	---	1441.1	890.2	698.2
Natural Gas Heat Input	(HHV) ² (10 ⁶ Btu/hr)	0	17.7	13.0	13.0
² (For Dessiccant Regeneration)	(LHV) (10 ⁶ Btu/hr)	---	16.0	11.7	11.7
	(10 ⁸ SCF/Day)	---	0.417	0.312	0.312
CO ₂ produced from Natural Gas usage	(lbm/hr)	---	---	1492	1492
<u>Steam Cycle Parameters</u>					
Total Heat Input to Steam Cycle	(10 ⁶ Btu/hr)	3707.4	3707.4	3707.4	3707.4
Heat Output to CO ₂ Removal System Reboilers & Reclaimer	(10 ⁶ Btu/hr)	---	1953.0	1218.1	980.6
Existing Condenser Pressure	(psia)	1.23	1.23	1.23	1.23
Existing Condenser Heat Loss	(10 ⁶ Btu/hr)	2102.8	603.3	1260	1468
Existing Steam Turbine Generator Output	(kW)	463478	269,341	342693	367859
CO ₂ Removal System Turbine Generator Output	(kW)	0	62,081	45321	36083
Total Turbine Generator Output	(kW)	463478	331422	388014	403942
<u>Auxiliary Power Requirements</u>					
Condensate Pump Power	(kW)	563	450	503	512
Condenser Cooling Water Pump Power	(kW)	5562	5407	5687	5730
Boiler Island Auxiliary Power (Fans & Pulverizers)	(kW)	7753	7753	7753	7753
Coal & Ash Handling System	(kW)	1020	1020	1020	1020
FGD & ESP System Auxiliary Power	(kW)	8157	8157	8157	8157
Misc. Auxiliary Power (Lighting, HVAC, Trans, etc)	(kW)	6645	6645	6645	6645
Air Separation Unit Power Requirement (Case B)	(kW)	0	50355	54939	54845
CO ₂ Removal System Auxiliary Power	(kW)	---	---	---	---
Total Auxiliary Power	(kW)	29700	79788	84704	84662
fraction of gross output	(fraction)	0.064	0.241	0.218	0.210
		433.8	251.6	303.3	319.3
<u>Plant Performance Parameters</u>					
Net Plant Output	(kW)	433778	251634	303310	319280
Normalized Net Plant Output (Relative to Base Case)	(fraction)	1.00	0.58	0.70	0.74
Net Plant Efficiency (HHV)	(fraction)	0.3501	0.2022	0.2441	0.2569
Net Plant Efficiency (LHV)	(fraction)	0.3666	0.2119	0.2556	0.2691
Normalized Efficiency (HHV; Relative to Base Case)	(fraction)	1.00	0.58	0.70	0.73
Net Plant Heat Rate (HHV)	(Btu/kWh)	9749	16875	13985	13285
Net Plant Heat Rate (LHV)	(Btu/kWh)	9309	16110	13351	12684
<u>Plant CO₂ Emissions</u>					
Carbon Dioxide Produced	(lbm/hr)	866102	868137	867595	867595
Carbon Dioxide Recovered	(lbm/hr)	0	835053	779775	779775
Carbon Dioxide Emissions	(lbm/hr)	866102	33084	87820	87820
Fraction of Carbon Dioxide Recovered	(fraction)	0	0.962	0.90	0.90
Specific Carbon Dioxide Emissions	(lbm/kWh)	1.997	0.131	0.290	0.275
Normalized Specific CO ₂ Emissions (Relative to Base Case)	(fraction)	1.00	0.066	0.145	0.138
Avoided Carbon Dioxide Emissions (as compared to Base)	(lbm/kWh)	---	1.865	1.707	1.722




Figure 5-1: Plant Gross and Net Output versus Solvent Regeneration Energy

Plant output (both Gross and Net) is shown in Figure 5-1 as a function of solvent regeneration energy for the 90% capture level. Plant output is quite sensitive to changes in solvent regeneration energy. Plant net output was calculated to change by about 47 MWe (or about 1.5% relative to Case 1 - 1,550 Btu/lbm-CO₂) for a change in solvent regeneration energy of 1,000 Btu/lbm-CO₂.

Plant thermal efficiency and efficiency loss are shown in Figure 5-2. This figure shows, for the 90% capture level, the impacts on plant thermal efficiency of both solvent regeneration energy and low-level heat integration between the gas processing system and steam cycle.

Plant thermal efficiency is very sensitive to changes in solvent regeneration energy. Plant thermal efficiency was calculated to change by about 3.7 percentage points for a change in solvent regeneration energy of 1,000 Btu/lbm-CO₂. To help put this in perspective, Case 5 from our previous study (Bozzuto et al., 2001), which used the Kerr/McGee – ABB Lummus system, had a solvent regeneration energy of about 2,350 Btu/lbm-CO₂. This energy requirement was considered “state of the art” at the time of that study. In the current study, the advanced “state of the art” amine used for Cases 1-4 used a solvent regeneration energy requirement of 1,550 Btu/lbm-CO₂. This represents a reduction of ~800 Btu/lbm-CO₂ in 6 years.

Similarly, proper integration of the low level heat which is rejected in the gas processing system (compressor intercoolers, solvent stripper condenser, etc.) with the steam cycle condensate stream was calculated to add about 0.7 percentage points to plant thermal efficiency at the 1,550 Btu/lbm solvent regeneration energy level. This efficiency change would be lower for solvents with higher regeneration energy requirements (since less cool condensate leaving the main condenser of the steam cycle is available to recover the rejected heat from the gas processing system) and higher for solvents with lower regeneration energy requirements.




Figure 5-2: Plant Thermal Efficiency and Efficiency Loss vs. Solvent Regeneration Energy

Plant CO₂ emissions for this sensitivity study are summarized in Table 5-2 and Figure 5-3. Specific carbon dioxide emissions were reduced from 906 g/kWh (2.00 lbm/kWh) for the Base Case to between 59-132 g/kWh (0.13-0.29 lbm/kWh) depending on CO₂ capture level and solvent regeneration energy requirement for these cases. This corresponds to values between 6.6% and 14.5% of the Base Case specific carbon dioxide emissions.




Figure 5-3: Plant CO₂ Emissions vs. Solvent Regeneration Energy

5.1.1 Steam Cycle Modifications and Performance with Reduced Solvent Regeneration Energy

Both Case 1 (1,550 Btu/lbm-CO₂ solvent regeneration energy) and Case 1a (1,200 Btu/lbm-CO₂ solvent regeneration energy) remove 90% of the CO₂ contained in the flue gas. For a discussion of the steam cycle modifications required for Case 1a to integrate the steam cycle with the amine system please refer to Section 3.1.6 where the modifications for Cases 1-5 are discussed. Figure 5-4 shows the modified steam turbine energy and material balance for Case 1a. The steam flow required to operate the reboiler/reclaimer in the amine process for Case 1a is approximately

123.0 kg/s (975.2×10^3 lbm/hr), equivalent to approximately 40% of the steam that would enter the LP turbine cylinder in the absence of the amine plant. By comparison, Case 1 uses 152.6 kg/s ($1,210 \times 10^3$ lbm/hr), equivalent to approximately 50% of the steam that would enter the LP turbine cylinder in the absence of the amine plant; Case 5 uses 244.1 kg/s ($1,935.7 \times 10^3$ lbm/hr), equivalent to approximately 79% of the steam that would enter the LP turbine cylinder in the absence of the amine plant.

The higher steam flow entering the LP turbine for Case 1a would result in a correspondingly higher pressure at the LP turbine inlet. Consequently, the pressure drop across the pressure control valve would be reduced (less throttling) for this case, as compared to Case 1.

Heat integration for Case 1a is done in the same manner as for Case 1 (90% removal, 1,550 Btu/lbm-CO₂ solvent regeneration energy). Waste heat from the gas processing system (CO₂ compressor intercoolers, propane refrigeration unit compressor de-superheater, and solvent stripper overhead condenser) is recovered by preheating condensate from the steam cycle as is shown in the lower parts of Figure 5-4. The deaerator flow for this case is somewhat less than in Case 1, but still significantly higher than the flow indicated for the reference case (Base Case). This may impact the performance of the deaerator or require either modification of the deaerator or a change in the heat integration arrangement in order to reduce the duty of the deaerator.

In summary, for Case 1a as illustrated in Figure 5-4, the gross power output of the Conesville #5 Unit will decrease by approximately 12.8% (from 463.5 MW to 403.9 MW), when compared to the Base Case (please refer Section 2.2.4) after modification to remove 90% of the CO₂ contained in the flue gas with a solvent that requires 1,200 Btu/lbm solvent regeneration energy. By comparison, for Case 1, the gross power output of the Conesville #5 Unit will decrease by approximately 16.3% (from 463.5 MW to 388.0 MW), and, for Case 5, the gross power output of the Conesville #5 Unit will decrease by approximately 28.5% (from 463.5 MW to 331.4 MW), when compared to the Base Case.




Figure 5-4: Case 1a – Modified Water-Steam Cycle (90% Capture: 1,200 Btu/lbm Solvent Regeneration Energy)

5.2 Cost Analysis

For the purposes of this sensitivity study, the investment cost for the new equipment associated with the reduced solvent regeneration energy case (Case 1a) is assumed to be the same as for Case 1 (i.e., 90% capture with 1,550 Btu/lbm solvent regeneration energy). This was done because the physical properties and other information, which is necessary for use in equipment sizing and material selection, are unknown for this future case (Case 1a). Referring to Table 3-65, shown previously, the total retrofit investment costs used for Case 1 was \$400,094,000. This same value was also used for Case 1a of this sensitivity study. Specific investment costs are calculated to be 1,319 and 1,253 \$/kWe-new for solvent regeneration energy values of 1,550 and 1,200 Btu/lbm-CO₂ respectively (Case 1 and Case 1a). The operating and maintenance costs for Case 1a are slightly lower than Case 1 due to the increase in net power.

5.3 Economic Analysis

Incremental LCOE breakdown and CO₂ mitigation costs are shown in Table 5-3 and Figure 5-5 for the two cases. Case 5 from the previous study (Bozzuto et al., 2001) is not shown in these LCOE tables or graphs because, as was discussed in Section 3.4 previously, the design and associated investment costs for Case 5 were not developed on a comparable basis to Case 1. The various components that make up the incremental LCOE (capital, fixed O&M, variable O&M, and fuel) are broken out in Table 5-3 and Figure 5-5.

Table 5-3: Incremental Cost of Electricity Breakdown & Mitigation Costs

Economic Property	Case 1 (90% Capture)	Case 1a (90% Capture)
Capital Component (¢/kWh)	3.10	2.95
Fixed O&M (¢/kWh)	0.13	0.14
Variable O&M (¢/kWh)	3.66	3.21
Feedstock O&M (¢/kWh)	0.03	0.03
Total:	6.92	6.32
Mitigated CO ₂ (\$/ton)	81	73
Mitigated CO ₂ (\$/tonne)	89	81
Captured CO ₂ (\$/ton)	81	73
Captured CO ₂ (\$/tonne)	89	81

CO₂ mitigation cost impacts are also shown in Figure 5-5 for the two solvent regeneration energy levels all with 90% CO₂ capture. The mitigation costs range from about 81-89 \$/tonne for these cases.




Figure 5-5: Incremental LCOE Breakdown and CO₂ Mitigation Cost

The incremental LCOE and mitigation cost results are also plotted as a function of solvent regeneration energy for these 90% capture level cases in Figure 5-6. Case 5 with 96% capture from the previous study is also shown for comparison. As shown in Figure 5-6, incremental cost of electricity is quite sensitive to changes in solvent regeneration energy. The incremental LCOE was calculated to change by about 5.41 ¢/kWh for a change in solvent regeneration energy of 1,000 Btu/lbm-CO₂. A similar impact (58.52 \$/tonne) was calculated for mitigation cost.




Figure 5-6: Incremental LCOE and Mitigation Cost vs. Solvent Regeneration Energy

6 REPLACEMENT POWER DISCUSSION

When CO₂ capture equipment is retrofit to a power generation plant, the net electrical output of the plant is reduced as a result of the parasitic power and/or heat requirements of the capture plant. To meet customer demand, it is necessary to replace this lost power. Therefore, sufficient replacement power should be provided to bring net plant electrical output back to the original level. Furthermore, in calculating avoided carbon amounts and costs, the cost and carbon emissions of the facilities providing the replacement power must be included in the calculations.

In considering replacement power options for the existing fleet, there is not one answer that fits every case. Each situation will be different. Factors that will vary from site to site include location, availability of unused land, surrounding land uses, climate, state and federal regulations, labor availability, etc. Some of the possible considerations for replacement (make-up) power are discussed below.

1. Purchase of replacement power from the grid from plants that have spare capacity. This is clearly the simplest option, but it is feasible only in the short range for a few plants. If a large number of plants tried to purchase replacement power from the grid, there would not be enough spare capacity without reducing the redundancy in the system to an unacceptable level. Another drawback is that most of this replacement power would come from coal-fired plants without carbon capture, and factoring this into the calculation would reduce the benefit of the CO₂ capture technology in the retrofit plant.
2. Build a new supercritical pulverized coal (SCPC) plant to provide replacement power for several CO₂ retrofit plants. SCPC plants have the highest efficiency (~40% based on HHV) of any PC plant. Thus, the replacement power would be generated at a higher efficiency than the retrofit unit. If the supercritical unit were not fitted with CO₂ capture technology, then the avoided carbon emissions of the retrofit plant would be reduced.
3. Build a natural gas combined cycle (NGCC) plant to provide replacement power. Like SCPC, NGCC has high efficiency and would replace power at a higher efficiency than the original plant being retrofit. Also, if CO₂ were not captured, the carbon-avoided penalty would be less, because natural gas combustion does not produce as much CO₂ as coal combustion. However, rising natural gas prices may hinder this option.
4. Build a nuclear plant to supply replacement power for several CO₂ retrofit plants. The advantage of nuclear is that the replacement power would be supplied by a plant that does not emit CO₂. However, under current circumstances in the U.S., it would be very difficult to get a nuclear plant built. Permitting and construction could require as long as ten years or more with attendant high costs.
5. Use some form of renewable energy as replacement power. Like nuclear, renewable energy sources do not produce any net CO₂ emissions. Of the various renewable options (wind, solar, tidal, geothermal, biomass, hydroelectric), wind appears to have the best prospects for providing replacement power. Solar and biomass (another form of solar) are dilute resources; tidal would require a large amount of engineering and most hydroelectric sites have either already been exploited or would engender so much opposition as to be infeasible. Wind power has the advantage that it can be implemented in small increments, so that economies of scale are not as important as with some of the

other options. Clearly, some sites would be more amenable to a nearby wind farm than other sites.

6. Use an integrated gasification combined cycle (IGCC) plant to produce replacement power. IGCC, with its combined cycle, has a thermal efficiency on par with SCPC (~40% based on HHV). However, because IGCC costs are significantly higher (20%-30%) than SCPC, the COE is also correspondingly higher. As with other fossil fuel fired technologies discussed above, if CO₂ is not captured, the avoided carbon emissions for the retrofit plant would be reduced.
7. Use an emerging technology to provide replacement power. Two emerging technologies that are under development are oxy-fuel combustion and chemical looping. Both these technologies are designed to produce flue gases with high CO₂ concentrations that can be easily purified to sequestration specifications. Neither technology is currently being used commercially, but both show promise. Since CO₂ capture is inherent in these technologies, they would not penalize the avoided carbon emissions of the retrofit plant.

As indicated above, which of these options is best for a particular power plant will depend on factors unique to that specific situation. In some cases, particularly with smaller or older units, it might be preferable to re-power the entire plant with SCPC, NGCC, IGCC, or some other technology rather than just retrofitting to a CO₂ capture plant. In this way, a higher efficiency option could be chosen, and CO₂ capture technology could be integrated into the design from the beginning, which is always more efficient and economic. Other factors, such as dispatching issues, could affect the entire replacement power picture.

In this study, a replacement/make-up power cost of 6.40 ¢/kWh was applied to each Case. The value reflects the levelized cost of electricity from a new subcritical pulverized bituminous coal (Greenfield) plant without carbon capture. The resulting make-up power cost was allocated to the variable O&M cost category within this study because of its dependency on the net power production and capacity factor. The MUPC of 6.40 ¢/kWh represents the lower cost perspective for a range of bituminous coal Greenfield Plant designs with and without carbon capture (i.e., ~6.33 to 11.42 ¢/kWh).

7 CONCLUSIONS AND RECOMMENDATIONS FOR FUTURE WORK

Conclusions

No major technical barriers exist for retrofitting AEP's Conesville Unit #5 to capture CO₂ with post-combustion amine-based capture systems. Lower levels of CO₂ capture can be achieved by simply bypassing some of the flue gas around the CO₂ capture system and only processing a fraction of the total flue gas in the amine-based capture systems. Flue gas bypassing was determined to be the most cost-effective approach to obtain lower CO₂ recovery levels. Nominally, 4 acres of new equipment space is needed for the amine-based capture and compression system (Case 1, 90% capture level) and this equipment is located in three primary locations on the existing 200-acre power plant site, which accommodates a total of 6 power generation units. The CO₂ absorber equipment, which occupies about 1 acre, is located just west, adjacent to the Unit #5 FGD system. The CO₂ stripper equipment, which occupies about 1 acre, is located just south of the Unit #5 turbine building with the CO₂ compression and liquefaction system, which occupies about 2 acres, is located just south of the strippers between two banks of existing cooling towers. Slightly less acreage is needed as the capture level is reduced. If all 6 units on this site were converted to CO₂ capture, it may be difficult to accommodate all the new CO₂ capture equipment on the existing site and additional land might need to be purchased.

This report is an update of a previous study (Bozzuto et al., 2001) and it demonstrates the advancement of post-combustion amine-based capture technologies. Solvent regeneration energy was reduced by ~34%, which provided an improvement in plant thermal efficiency of 4.2 percentage points (from 20.2% to 24.4%). Additionally retrofit specific investment costs (\$/kWe) were reduced by 52% and incremental COE was reduced by 45%. Demonstration of advanced low cost technologies is critical to carbon capture and sequestration (CCS) for both existing and new plants.

Energy requirements and power consumption are high, resulting in significant decreases in overall power plant efficiencies, which range from about 24.4% to 31.6% as the CO₂ capture level decreases from 90% to 30% for Cases 1-4, as compared to 35% for the Base Case (all HHV basis). The efficiency decrease is essentially a linear function of CO₂ recovery level. Specific carbon dioxide emissions were reduced from about 908 g/kWh (2 lbm/kWh) for the Base Case to 132-704 g/kWh (0.29-1.55 lbm/kWh) as the CO₂ recovery level decreases from 90% to 30%. Recovery of CO₂ ranged from 30% to 90% for the new cases (Cases 1-4) and 96% for the updated case (Case 5) of the previous study.

Specific incremental investment costs are also high, ranging from about \$540 to \$1,319/kWe-new, depending on CO₂ capture level for the current study. The specific investment cost is also nearly a linear function of CO₂ recovery level, although equipment selections and economy of scale effects make this relationship much less linear than efficiency is.

All cases studied indicate significant increases to the LCOE as a result of CO₂ capture. The incremental COE, as compared to the Base Case (air firing without CO₂ capture), ranges from 2.31 to 6.92 ¢/kWh (depending on CO₂ capture level). Similarly CO₂ mitigation cost increases slightly from \$89 to \$113/tonne of CO₂ avoided as the CO₂ capture level decreases from 90% to 30%. The roughly linear decrease in LCOE with reduced CO₂ capture indicates that there is no optimum CO₂ recovery level. Economic sensitivity studies indicate the incremental LCOE is

most impacted by the following parameters (in given order): CO₂ selling price, capacity factor, total investment cost, and make-up power cost.

The updated specific investment cost for Case 5/Concept A of the previous study (Bozzuto et al., 2001) was ~\$2,786/kWe-new. The update of Case 5 did not include the process design or equipment selections.

The advanced amine is expected to provide significant improvement to the plant performance and economics. Use of the advanced amine in comparison to the Kerr-NMcGee/ABB Lummus amine for 90% CO₂ capture showed an improvement in thermal efficiency of about 3.5 percentage points, although, as pointed out above, the process design for Case 5 was not updated in this study. An equitable comparison of specific costs (\$/kWe) and economics (LCOE, mitigation costs) was not possible since the amine system design for the previous study was not consistent with the current designs using the advanced amine, as explained in more detail in Section 3.4.

The commercial implementation of these amine-based post-combustion capture systems will be several years in the future and research is continually improving the performance of amine solvents and systems. A sensitivity analysis was completed that showed the effect of anticipated reductions in solvent regeneration energy (for the 90% capture level). The solvent regeneration energy cases investigated were 1,550 and 1,200 Btu/lbm-CO₂. Plant thermal efficiency is shown to be very sensitive to changes in solvent regeneration energy. Plant thermal efficiency was calculated to change by about 3.7 percentage points (or about 15% relative to Case 1 @ 24.5% thermal efficiency) for a change in solvent regeneration energy of 1,000 Btu/lbm-CO₂. Similarly, incremental LCOE is also quite sensitive to changes in solvent regeneration energy. The incremental LCOE was calculated to change by about 0.8 ¢/kWh (about 10% relative to Case 1 @ 6.92 ¢/kWh) for a change in solvent regeneration energy of 1,000 Btu/lbm-CO₂.

Recommendations for Future Work

Recommendations for future work for CO₂ capture from existing coal-fired utility-scale electric power plants are listed below:

- Re-do case study using best-in class-solvents. Within this context, include the use of modified steam turbine and updated process design, equipment selection, and cost to fully quantify improvements with advanced solvents
- Update the process design, equipment selections, costs, and economic analysis of the Case 5/Concept A CO₂ capture/compression/liquefaction system in order to fully quantify the improvements available with use of the advanced amine system
- Apply the results from best-in-class study to the existing U.S. coal fleet to determine the overall economic impacts and CO₂ emissions reductions, keeping in mind certain criteria:
 - Units of certain size range (large units)
 - Units of certain age group (newer units)
 - Units located near sequestration sites
 - High capacity factor units (Base Loaded)

- Because high CO₂ loadings in the rich amine accelerate corrosion, future studies should include methods or additives to reduce the corrosion to acceptable levels
- Demonstrate best-in-class solvents on a commercial scale
- Because high CO₂ loadings in the rich amine accelerate corrosion, future studies should include methods or additives to reduce the corrosion to acceptable levels

8 BIBLIOGRAPHY

- Baily, D.W., and Feron, P., "Post-Combustion Decarbonization Process," *Oil and Gas Science and Technology – Rev.*, IFP, Vol. 60 (2005), No. 3, pp. 461-474.
- Barchas, R. and Davis, R., "The Kerr-McGee/Lummus Crest Technology for the Recovery of CO₂ from Stack Gases," Presented at the First International Conference on Carbon Dioxide Removal, Amsterdam, The Netherlands, March 4-6, 1992.
- Bozzuto, C.R., Nsakala, N., Liljedahl, G., Palkes, M., Marion, J., Vogel, D., Fugate, M., Guha, M., "Engineering Feasibility and Economics of CO₂ Sequestration/Use on an Existing Coal-Fired Power Plant. Volume I: AEP's Conesville Power Plant Unit No. 5 Retrofit Study," Prepared for the Ohio Department of Development, Ohio Coal Development Office and US Department of Energy, National Energy Technology Laboratory (June 30, 2001).
- Chapel, D. G., and Mariz, C. L., "Recovery of CO₂ from Flue Gases: Commercial Trends," Presented at the Canadian Society of Chemical Engineers Meeting, October 4-6, 1999, Saskatoon, Saskatchewan, Canada.
- Chinn, D., Eimer, D., and Hurst, P., "CO₂ Capture Project: Post-Combustion Integrated Technology (BIT) Overview." Presented at the Third National Conference on Carbon Sequestration, National Energy Technology Laboratory, Alexandria, VA, May 3-7, 2004.
- Choi, G. N., Chu, R., Degen, B., Wen, H., Richen, P. L., and Chinn, D., "Cost Effective amine Plant Design for Post Combustion CO₂ Capture from Power Plant Flue Gas," Presented at the Third National Conference on Carbon Sequestration, National Energy Technology Laboratory, Alexandria, VA, May 3-6, 2004.
- Choi, G. N., Chu, R., Degen, B., Wen, H., Richen, P. L., and Chinn, D., "CO₂ Removal from Power Plant Flue Gas – Cost Efficient Design and Integration Study," *Carbon Dioxide Capture for Storage in Deep Geologic Formations*, Volume 1, D.C. Thomas and S. M. Benson (Eds.), ©2005 Elsevier Ltd.
- Dakota Gasification Company, "Carbon Dioxide Specifications," April 2005, <http://www.dakotagas.com/specs/co2spec.pdf>
- DOE/NETL, "2006 Cost and Performance Comparison of Fossil Energy Power Plants," Volume 1: Bituminous Coal and Natural Gas to Electricity, Draft Final, DOE/NETL – 401/053106, May 2006.
- "Improvement in Power Generation with Post-Combustion Capture of CO₂," IEA Report Number PH4/33, November 2004.
- Liljedahl, G., Marion, J., Nsakala, N., Bozzuto, C., Palkes, Vogel, D., Gupta, J.C., Guha, M., Johnson, H., and Plasynski, S., "Technical and Economic Feasibility of CO₂ Capture on an Existing Coal-Fired Power Plant," for Presentation at the 2001 International Joint Power Generation Conference, New Orleans, LA, June 4-7, 2001.
- Marion, Jr., Nsakala, N., Bozzuto, C., Liljedahl, G., Palkes, Vogel, D., Gupta, J.C., Guha, M., Johnson, H., and Plasynski, S., "Engineering Feasibility of CO₂ Capture on an Existing Coal-Fired Power Plant," Presented at the 26th International Conference on Coal Utilization & Fuel Systems, Clearwater, FL, March 5-8, 2001.
- "Nelson-Farrar Refinery Construction Cost Index," *Oil & Gas Journal*, May 1, 2006.

Palkes, M., Liljedahl, G., Nsakala, N., McDonald, M., and Gupta, J.C., "Preliminary Design of a CO₂/O₂ Combustion Retrofit to an Existing Coal-Fired Boiler for CO₂ Extraction," Presented at Electric Power Gen '99 Conference, Baltimore, MD, April 20-22, 1999.

Resnik, K.P., Yeh, J.T., Pennline, H.W., "Aqua Ammonia process for Simultaneous Removal of CO₂, SO₂, and NO_x," International Journal of Environmental Technology and Management, Vol. 4, Nos. 1/2, 2004.

Rochelle, G., "Research Needs for CO₂ Capture from Flue Gas by Aqueous Absorption/Stripping," Draft of Final Report for DOE P.O. NO. DE-AF26-FT01029, University of Texas at Austin, Texas, September 2000.

Rubin, E.S., Rao, A.B., "A Technical, Economic and Environmental Assessment of Amine-based CO₂ Capture Technology for Power Plant Greenhouse Gas Control," Annual Technical Progress Report, Contract No.: DE-FC26-00NT40935, October, 2002.

9 APPENDICES

Four appendices are included in this section, as listed below:

- Appendix I - Plant Layout Drawings
- Appendix II - Equipment Lists for the CO₂ recovery systems
- Appendix III - Economic Sensitivity Studies
- Appendix IV - Let Down Turbine Technical Information



9.1 Appendix I – Plant Drawings (Cases 1-5)

This appendix contains all layout drawings developed for this project for Cases 1-4 and Case 5/Concept A. Also included is a plot plan of the existing site without modifications for reference. The drawings provided are listed below:

Existing Plant:

66-530.00 Plot Plan – Existing Overall Conesville Site (before CO₂ unit addition)

Cases 1-4

15154-003 Plot Plan – Cases 1-4: Flue Gas Cooling & CO₂ Absorption Equipment Layout

15154-002 Plot Plan – Cases 1-4: Solvent Stripping and Compression Equipment Layout

15154-001 Plot Plan – Cases 1-4: Overall Plot Plan for Modified Conesville Unit #5

Case 5/Concept A:

U01-D-0208 Plot Plan – Case 5/Concept A: Flue Gas Cooling & CO₂ Absorption Equipment Layout

U01-D-0214 Plot Plan – Case 5/Concept A: Solvent Stripping Equipment Layout

U01-D-0204 Plot Plan – Case 5/Concept A: CO₂ Compression & Liquefaction Equipment Layout

U01-D-0211 Plot Plan – Case 5/Concept A: Overall Equipment Layout Conceptual Plan

U01-D-0200R Plot Plan – Case 5/Concept A: Modified Overall Site Plan




Figure 9-1: Existing Overall Site (before CO₂ Unit Addition)



Cases 1-4

The plant layout drawings prepared for the Cases 1-4 CO₂ Recovery Systems are as follows:

15154-003 Plot Plan – Cases 1: Flue Gas Cooling & CO₂ Absorption Equipment Layout

15154-002 Plot Plan – Cases 1: Solvent Stripping and Compression Equipment Layout

15154-001 Plot Plan – Cases 1: Overall Plot Plan for Modified Conesville Unit #5




Figure 9-2: Cases 1-4 Flue Gas Cooling & CO₂ Absorption Equipment Layout




Figure 9-3: Cases 1-4 Solvent Stripping and Compression Equipment Layout




Figure 9-4: Cases 1-4 Overall Plot Plan for Modified Conesville Unit #5



Case 5/Concept A:

The plant layout drawings prepared for the Case 5/Concept A CO₂ Recovery System are as follows

- U01-D-0208 Plot Plan – Case 5/Concept A: Flue Gas Cooling & CO₂ Absorption Equipment Layout
- U01-D-0214 Plot Plan – Case 5/Concept A: Solvent Stripping Equipment Layout
- U01-D-0204 Plot Plan – Case 5/Concept A: CO₂ Compression & Liquefaction Equipment Layout
- U01-D-0211 Plot Plan – Case 5/Concept A: Overall Equipment Layout Conceptual Plan
- U01-D-0200 Plot Plan – Case 5/Concept A: Modified Overall Site Plan




Figure 9-5: Case 5/Concept A – Flue Gas Cooling & CO₂ Absorption Equipment Layout




Figure 9-6: Case 5/Concept A – Solvent Stripping Equipment Layout




Figure 9-7: Case 5/Concept A – CO₂ Compression & Liquefaction Equipment Layout




Figure 9-8: Case 5/Concept A Overall Equipment Layout Conceptual Plan




Figure 9-9: Case 5/Concept A – Overall Plot Plan for Modified Conesville Unit #5



9.2 Appendix II - Equipment Lists (Cases 1-5)

This appendix contains equipment lists for the CO₂ Capture Systems of all five cases (Cases 1-4 and Case 5/Concept A). Equipment data has been presented in the so-called “short spec” format, which provides adequate data for a factored cost estimate

Table 9-1: Case 1 CO₂ Capture System Equipment List with Data (90% CO₂ Recovery)

No. Required	Tag no.	Description	Size Parameters	Material
incl w/abs		Direct Contact Flue Gas Cooler	34' ID x 34' S/S, DP 2.5 psig/ 0.7 psi vac	CS/SS
2		CO ₂ Absorber	34' ID x 92' S/S, DP 2.5 psig/ 0.7 psi vac	CS/SS
2		Solvent Stripper	22' ID x 50' S/S, DP 35 psig/ FV	CS/SS
10	E-106	Solvent Stripper Reboiler	120 MMBTU/HR PHE, 90 psig/ 90 psig	CS/SS
2	E-109	Solvent Stripper Reclaimer	21 MMBTU/HR, DP S/T, 120 psig/ 190 psig	CS/TI
2		Solvent Reclaimer Effluent Cooler	20 MMBTU/HR, DP S/T, 150 psig/ 150 psig	CS/TI
12	E-105	Solvent Stripper CW Condenser	20 MMBTU/HR, DP PHE, 150 psig/ 300 psig	SS/SS
4	E-100	Rich / Lean Solvent Exchanger	158 MMBTU/HR, PHE , 150 psig/ 150 psig	SS316
2	E-101	Rich / Semi-Lean Exchanger	119 MMBTU/HR, PHE, 150 psig/ 150 psig	SS
4	E-102	Lean / Semi-Lean Exchanger	61 MMBTU/HR, PHE, 150 psig/ 150 psig	SS
2	E-108	Absorber Feed Exchanger	117 MMBTU/HR, PHE, 150 psig/ 150 psig	SS
6	E-104	Lean Solvent Exchanger	59 MMBTU/HR, PHE 150 psig/ 150 psig	SS316
2	E-111	Propane Refrigeration De-superheater	25 MMBTU/HR, DP S/T, 300 psig/ 100 psig	CS/CS
2		Propane Refrigeration Condenser	52 MMBTU/HR, DP S/T, 300 psig/ 100 psig	CS/CS
2		Propane Refrigeration Sub-cooler	20 MMBTU/HR, DP S/T, 300 psig/ 2500 psig	CS/LTCS
2		CO ₂ Compressor 1 st stage Cooler	15 MMBTU/HR, DP 75 psig	SS
2		CO ₂ Compressor 2 nd stage Cooler	18 MMBTU/HR, DP 125 psig	SS
2		CO ₂ Compressor 3 rd stage Cooler	16 MMBTU/HR, DP 235 psig	SS
2		CO ₂ Condenser	66 MMBTU/HR, DP S/T, 235 psig/ 300 psig	CS/TI
2		Solvent Stripper Reflux Drum	8'-6" ID x 26' S/S, DP 35 psig/ FV	304L
2		CO ₂ Compressor 2 nd Stage Suction Drum	11'- 6" ID x 15' S/S, DP 75 psig	CS/SS
2		CO ₂ Compressor 3 rd Stage Suction Drum	9' ID x 15' S/S, DP 125 psig	CS/SS
2		Liquid CO ₂ Surge Drum	7' ID x 21' S/S, DP 235 psig	KCS
2		CO ₂ Compressor 3 rd Stage Discharge KO Drum	7' ID x 15' S/S, DP 235 psig	CS/SS
2		Propane Refrigeration Surge Drum	15' ID x 45'-6" S/S, DP 300 psig	CS
2		Propane Refrigeration Suction Scrubber	13' ID x 18' S/S, DP 300 psig	LTCS
2		Soda Ash Day Tank	2' ID x 4' S/S, DP atm	CS
4		DCC Water Filter	3532 gpm ea, DP 35 psig	SS
4	Pump-2	Wash Water Pump	2569 gpm ea, DP 29 psi	DI/SS
4	Pump-1	Direct Contact Cooler Water Pump	3532 gpm ea, DP 36 psi	SS/SS
4	P-100	Rich Solvent Pump	6634 gpm ea, DP 92 psi	SS/SS
4	P-102	Lean Solvent Pump	4870 gpm ea, DP 85 psi	SS/SS
4	P-101	Semi-Lean Pump	2168 gpm ea, DP 85 psi	SS/SS
2		Solvent Stripper Reflux Pump	212 gpm ea, DP 75 psi	DI/SS
4		Filter Circ. Pump	332 gpm ea, DP 91 psi	SS/SS
4		LP Condensate Booster Pump	650 gpm ea, DP 237 psi	CI/ SS
7		CO ₂ Pipeline Pump	270 gpm ea, DP 1815 psi	CS/CS
2		Soda Ash Metering Pump	.45 gpm ea, DP 50 psi	SS
2		CO ₂ Compressor (Motor driven)	15,631 hp ea	SS wheels
2		Propane Refrigeration Compressor	11,661 hp ea	LTCS
2		Corrosion Inhibitor Package	Metering, 22 lb/ hr	
4		Solvent Filter Package	184 gpm ea	
2		CO ₂ Dryer Package	161 hp ea compressor, cooler, gas fired heater	
2		Crane for Compressor Bldg		
2		Flue Gas Fans and Ducting	3286 hp ea, SS blades	



Table 9-2: Case 2 CO₂ Capture System Equipment List with Data (70% CO₂ Recovery)

No. Required	Tag no.	Description	Size Parameters	Material
incl w/abs		Direct Contact Flue Gas Cooler	30' ID x 34' S/S, DP 2.5 psig/ 0.7 psi vac	CS/SS
2		CO ₂ Absorber	30' ID x 92' S/S, DP 2.5 psig/ 0.7 psi vac	CS/SS
2		Solvent Stripper	19' ID x 50' S/S, DP 35 psig/ FV	CS/SS
8	E-106	Solvent Stripper Reboiler	120 MMBTU/HR PHE, 90 psig/ 90 psig	CS/SS
2	E-109	Solvent Stripper Reclaimer	17 MMBTU/HR, DP S/T, 120 psig/ 190 psig	CS/TI
2		Solvent Reclaimer Effluent Cooler	16 MMBTU/HR, DP S/T, 150 psig, 150 psig	CS/TI
10	E-105	Solvent Stripper CW Condenser	20 MMBTU/HR, DP PHE, 150 psig/ 300 psig	SS/SS
4	E-100	Rich / Lean Solvent Exchanger	158 MMBTU/HR, PHE , 150 psig/ 150 psig	SS316
2	E-101	Rich / Semi-Lean Exchanger	119 MMBTU/HR, PHE, 150 psig/ 150 psig	SS
4	E-102	Lean / Semi-Lean Exchanger	61 MMBTU/HR, PHE, 150 psig/ 150 psig	SS
2	E-108	Absorber Feed Exchanger	91 MMBTU/HR, PHE, 150 psig/ 150 psig	SS
5	E-104	Lean Solvent Exchanger	59 MMBTU/HR, PHE, 150 psig/ 150 psig	SS316
2	E-111	Propane Refrigeration De-superheater	19 MMBTU/HR, DP S/T, 300 psig/ 100 psig	CS/CS
2		Propane Refrigeration Condenser	40 MMBTU/HR, DP S/T, 300 psig/ 100 psig	CS/CS
2		Propane Refrigeration Sub-cooler	15 MMBTU/HR, DP S/T, 300 psig/ 2500 psig	CS/LTCS
2		CO ₂ Compressor 1 st stage Cooler	12 MMBTU/HR, DP 75 psig	SS
2		CO ₂ Compressor 2 nd stage Cooler	14 MMBTU/HR, DP 125 psig	SS
2		CO ₂ Compressor 3 rd stage Cooler	12 MMBTU/HR, DP 235 psig	SS
2		CO ₂ Condenser	52 MMBTU/HR, DP S/T, 235 psig/ 300 psig	CS/TI
2		Solvent Stripper Reflux Drum	8' ID x 24' S/S, DP 35 psig/ FV	304L
2		CO ₂ Compressor 2 nd Stage Suction Drum	10'- 6" ID x 14' S/S, DP 75 psig	CS/SS
2		CO ₂ Compressor 3 rd Stage Suction Drum	8'-6" ID x 14' S/S, DP 125 psig	CS/SS
2		Liquid CO ₂ Surge Drum	6'- 6" ID x 20' S/S, DP 235 psig	KCS
2		CO ₂ Compressor 3 rd Stage Discharge KO Drum	6'- 6" ID x 14' S/S, DP 235 psig	CS/SS
2		Propane Refrigeration Surge Drum	14' ID x 42' S/S, DP 300 psig	CS
2		Propane Refrigeration Suction Scrubber	12' ID x 17' S/S, DP 300 psig	LTCS
2		Soda Ash Day Tank	2' ID x 4' S/S, DP atm	CS
4		DCC Water Filter	2730 gpm ea, DP 35 psig	SS
4	Pump-2	Wash Water Pump	1998 gpm ea, DP 29 psi	DI/SS
4	Pump-1	Direct Contact Cooler Water Pump	2730 gpm ea, DP 36 psi	SS/SS
4	P-100	Rich Solvent Pump	5160 gpm ea, DP 92 psi	SS/SS
4	P-102	Lean Solvent Pump	3809 gpm ea, DP 85 psi	SS/SS
4	P-101	Semi-Lean Pump	1663 gpm ea, DP 85 psi	SS/SS
2		Solvent Stripper Reflux Pump	163 gpm ea, DP 75 psi	DI/SS
4		Filter Circ. Pump	258 gpm ea, DP 91 psi	SS/SS
4		LP Condensate Booster Pump	505 gpm ea, DP 237 psi	CI/SS
5		CO ₂ Pipeline Pump	293 gpm ea, DP 1815 psi	CS/CS
2		Soda Ash Metering Pump	.45 gpm ea, DP 50 psi	SS
2		CO ₂ Compressor (Motor driven)	12,143 hp ea	SS wheels
2		Propane Refrigeration Compressor	10,243 hp ea	LTCS
2		Corrosion Inhibitor Package	Metering, 17 lb/ hr	
4		Solvent Filter Package	258 gpm ea	
2		CO ₂ Dryer Package	123 hp ea compressor, cooler, gas fired heater	
2		Crane for Compressor Bldg		
2		Flue Gas Fans and Ducting	2300 hp ea, SS blades	



Table 9-3: Case 3 CO₂ Capture System Equipment List with Data (50% CO₂ Recovery)

No. Required	Tag no.	Description	Size Parameters	Material
incl w/abs		Direct Contact Flue Gas Cooler	25' ID x 34' S/S, DP 2.5 psig/ 0.7 psi vac	CS/SS
2		CO ₂ Absorber	25' ID x 92' S/S, DP 2.5 psig/ 0.7 psi vac	CS/SS
2		Solvent Stripper	16' ID x 50' S/S, DP 35 psig/ FV	CS/SS
6	E-106	Solvent Stripper Reboiler	120 MMBTU/HR PHE, 90 psig/ 90 psig	CS/SS
2	E-109	Solvent Stripper Reclaimer	12 MMBTU/HR, DP S/T, 120 psig/ 190 psig	CS/TI
2		Solvent Reclaimer Effluent Cooler	11 MMBTU/HR, DP S/T, 150 psig/ 150 psig	CS/TI
7	E-105	Solvent Stripper CW Condenser	20 MMBTU/HR, DP PHE, 150 psig/ 300 psig	SS/SS
3	E-100	Rich / Lean Solvent Exchanger	158 MMBTU/HR, PHE , 150 psig/ 150 psig	SS316
2	E-101	Rich / Semi-Lean Exchanger	119 MMBTU/HR, PHE, 150 psig/ 150 psig	SS
3	E-102	Lean / Semi-Lean Exchanger	61 MMBTU/HR, PHE, 150 psig/ 150 psig	SS
2	E-108	Absorber Feed Exchanger	66 MMBTU/HR, PHE, 150 psig/ 150 psig	SS
4	E-104	Lean Solvent Exchanger	59 MMBTU/HR, PHE 150 psig/ 150 psig	SS316
1	E-111	Propane Refrigeration De-superheater	27 MMBTU/HR, DP S/T, 300 psig/ 100 psig	CS/CS
1		Propane Refrigeration Condenser	58 MMBTU/HR, DP S/T, 300 psig/ 100 psig	CS/CS
1		Propane Refrigeration Sub-cooler	22 MMBTU/HR, DP S/T, 300 psig/ 2500 psig	CS/LTCS
1		CO ₂ Compressor 1 st stage Cooler	16 MMBTU/HR, DP 75 psig	SS
1		CO ₂ Compressor 2 nd stage Cooler	20 MMBTU/HR, DP 125 psig	SS
1		CO ₂ Compressor 3 rd stage Cooler	17 MMBTU/HR, DP 235 psig	SS
1		CO ₂ Condenser	73 MMBTU/HR DP S/T, 235 psig/ 300 psig	CS/TI
2		Solvent Stripper Reflux Drum	7' ID x 22' S/S, DP 35 psig/ FV	304L
1		CO ₂ Compressor 2 nd Stage Suction Drum	12' ID x 16' S/S, DP 75 psig	CS/SS
1		CO ₂ Compressor 3 rd Stage Suction Drum	9' ID x 16' S/S, DP 125 psig	CS/SS
1		Liquid CO ₂ Surge Drum	7' ID x 22' S/S, DP 235 psig	KCS
1		CO ₂ Compressor 3 rd Stage Discharge KO Drum	7' ID x 16' S/S, DP 235 psig	CS/SS
1		Propane Refrigeration Surge Drum	16' ID x 47' S/S, DP 300 psig	CS
1		Propane Refrigeration Suction Scrubber	13' ID x 19' S/S, DP 300 psig	LTCS
2		Soda Ash Day Tank	2' ID x 4' S/S, DP atm	CS
4		DCC Water Filter	1931 gpm ea, DP 35 psig	SS
4	Pump-2	Wash Water Pump	1427 gpm ea, DP 29 psi	DI/SS
4	Pump-1	Direct Contact Cooler Water Pump	1931 gpm ea, DP 36 psi	SS/SS
4	P-100	Rich Solvent Pump	3686 gpm ea, DP 92 psi	SS/SS
4	P-102	Lean Solvent Pump	2721 gpm ea, DP 85 psi	SS/SS
4	P-101	Semi-Lean Pump	1189 gpm ea, DP 85 psi	SS/SS
2		Solvent Stripper Reflux Pump	116 gpm ea, DP 75 psi	DI/SS
4		Filter Circ. Pump	184 gpm ea, DP 91 psi	SS/SS
4		LP Condensate Booster Pump	361 gpm ea, DP 237 psi	CI/SS
4		CO ₂ Pipeline Pump	262 gpm ea, DP 1815 psi	CS/CS
2		Soda Ash Metering Pump	.45 gpm ea, DP 50 psi	SS
1		CO ₂ Compressor (Motor driven)	17,328 hp	SS wheels
1		Propane Refrigeration Compressor	14,618 hp	LTCS
2		Corrosion Inhibitor Package	Metering, 12 lb/ hr	
4		Solvent Filter Package	184 gpm ea	
1		CO ₂ Dryer Package	178 hp compressor, cooler, gas fired heater	
1		Crane for Compressor Bldg		
2		Flue Gas Fans and Ducting	1825 hp ea, SS blades	



Table 9-4: Case 4 CO₂ Capture System Equipment List with Data (30% CO₂ Recovery)

No. Required	Tag no.	Description	Size Parameters	Material
Incl w/abs		Direct Contact Flue Gas Cooler	28' ID x 34' S/S, DP 2.5 psig/ 0.7 psi vac	CS/SS
1		CO ₂ Absorber	28' ID x 92' S/S, DP 2.5 psig/ 0.7 psi vac	CS/SS
1		Solvent Stripper	20' ID x 50' S/S, DP 35 psig/ FV	CS/SS
4	E-106	Solvent Stripper Reboiler	120 MMBTU/HR PHE, 90 psig/ 90 psig	CS/SS
1	E-109	Solvent Stripper Reclaimer	14 MMBTU/HR, DP S/T, 120 psig/ 190 psig	CS/TI
1		Solvent Reclaimer Effluent Cooler	13 MMBTU/HR, DP S/T, 150 psig/ 150 psig	CS/TI
4	E-105	Solvent Stripper CW Condenser	20 MMBTU/HR, DP PHE, 150 psig/ 300 psig	SS/SS
2	E-100	Rich / Lean Solvent Exchanger	158 MMBTU/HR, PHE , 150 psig/ 150 psig	SS316
1	E-101	Rich / Semi-Lean Exchanger	119 MMBTU/HR, PHE, 150 psig/ 150 psig	SS
1	E-102	Lean / Semi-Lean Exchanger	122 MMBTU/HR, PHE, 150 psig/ 150 psig	SS
1	E-108	Absorber Feed Exchanger	78 MMBTU/HR, PHE, 150 psig/ 150 psig	SS
2	E-104	Lean Solvent Exchanger	59 MMBTU/HR, PHE 150 psig/ 150 psig	SS316
1	E-111	Propane Refrigeration De-superheater	17 MMBTU/HR, DP S/T, 300 psig/ 100 psig	CS/CS
1		Propane Refrigeration Condenser	35 MMBTU/HR, DP S/T, 300 psig/ 100 psig	CS/CS
1		Propane Refrigeration Sub-cooler	13 MMBTU/HR, DP S/T, 300 psig/ 2500 psig	CS/LTCS
1		CO ₂ Compressor 1 st stage Cooler	10 MMBTU/HR, DP 75 psig	SS
1		CO ₂ Compressor 2 nd stage Cooler	12 MMBTU/HR, DP 125 psig	SS
1		CO ₂ Compressor 3 rd stage Cooler	11 MMBTU/HR, DP 235 psig	SS
1		CO ₂ Condenser	44 MMBTU/HR DP S/T, 235 psig/ 300 psig	CS/TI
1		Solvent Stripper Reflux Drum	7' ID x 23' S/S, DP 35 psig/ FV	304L
1		CO ₂ Compressor 2 nd Stage Suction Drum	10' ID x 13' S/S, DP 75 psig	CS/SS
1		CO ₂ Compressor 3 rd Stage Suction Drum	8' ID x 13' S/S, DP 125 psig	CS/SS
1		Liquid CO ₂ Surge Drum	6' ID x 19' S/S, DP 235 psig	KCS
1		CO ₂ Compressor 3 rd Stage Discharge KO Drum	6' ID x 13' S/S, DP 235 psig	CS/SS
1		Propane Refrigeration Surge Drum	13' ID x 40' S/S, DP 300 psig	CS
1		Propane Refrigeration Suction Scrubber	11' ID x 16' S/S, DP 300 psig	LTCS
1		Soda Ash Day Tank	3' ID x 4' S/S, DP atm	CS
2		DCC Water Filter	2286 gpm ea, DP 35 psig	SS
2	Pump-2	Wash Water Pump	1728 gpm ea, DP 29 psi	DI/SS
2	Pump-1	Direct Contact Cooler Water Pump	2286 gpm ea, DP 36 psi	SS/SS
2	P-100	Rich Solvent Pump	4420 gpm ea, DP 92 psi	SS/SS
2	P-102	Lean Solvent Pump	3220 gpm ea, DP 85 psi	SS/SS
2	P-101	Semi-Lean Pump	1480 gpm ea, DP 85 psi	SS/SS
1		Solvent Stripper Reflux Pump	140 gpm, DP 75 psi	DI/SS
2		Filter Circ. Pump	220 gpm ea, DP 91 psi	SS/SS
2		LP Condensate Booster Pump	434 gpm ea, DP 237 psi	CI/SS
3		CO ₂ Pipeline Pump	210 gpm ea, DP 1815 psi	CS/CS
1		Soda Ash Metering Pump	.45 gpm, DP 50 psi	SS
1		CO ₂ Compressor (Motor driven)	10,419 hp	SS wheels
1		Propane Refrigeration Compressor	8,788 hp	LTCS
1		Corrosion Inhibitor Package	Metering, 14 lb/ hr	
1		Solvent Filter Package	1870 gpm	
1		CO ₂ Dryer Package	108 hp compressor, cooler, gas fired heater	
1		Crane for Compressor Bldg		
1		Flue Gas Fan and Ducting	2190 hp, SS blades	



Table 9-5: Case 5/Concept A CO₂ Capture System Equipment List with Data (96% CO₂ Recovery)

No. Required	Tag no.	Description	Size Parameters	Material
5	DA-2101	Direct Contact Flue Gas Cooler	27' ID x 34' S/S, DP 2.5 psig/ 0.7 psi vac	CS/SS
5	DA-2102	CO ₂ Absorber	27' ID x 92' S/S, DP 2.5 psig/ 0.7 psi vac	CS/SS
9	DA-2201	Solvent Stripper	16' ID x 100' S/S, DP 35 psig/ FV	CS/SS
9	EA-2201	Solvent Stripper Reboiler	217 MMBTU/HR, DP S/T, 50 psig/ 60 psig	CS/SS
9	EA-2203	Solvent Stripper Reclaimer	5.6 MMBTU/HR, DP S/T, 120 psig/ 190 psig	CS/TI
9	EA-2204	Solvent Reclaimer Effluent Cooler	5 MMBTU/HR, DP S/T, 125 psig/ 100 psig	CS/TI
9	EA-2206	Solvent Stripper CW Condenser	41.6 MMBTU/HR, DP S/T, 35 psig/ 100 psig	SS/TI
7	EA-2301	CO ₂ Compressor 1 st Stage Aftercooler	1.9 MMBTU/HR, DP S/T, 75 psig/ 100 psig	SS/TI
7	EA-2302	CO ₂ Compressor 2 nd Stage Aftercooler	1.3 MMBTU/HR, DP S/T, 125 psig/ 100 psig	SS/TI
7	EA-2303	CO ₂ Compressor 3 rd Stage Aftercooler	1 MMBTU/HR, DP S/T, 235 psig/ 100 psig	CS/TI
7	EA-2304	CO ₂ Condenser	19 MMBTU/HR, DP S/T, 235 psig/ 300 psig	CS/TI
5	EA-2101	Direct Contact Flue Gas Water Cooler	4.8 MMBTU/HR, DP P/U, 50 psig/ 100 psig	TI
9	EA-2205	Rich / Lean Solvent Exchanger	210 MMBTU/HR, DP P/P, 135 psig/ 155 psig	SS316
9	EA-2202	Lean Solvent Cooler	101.8 MMBTU/HR, DP P/U, 135 psig/ 100 psig	TI
7	EA-2401	Propane Refrigeration Condenser	20.45 MMBTU/HR, DP S/T, 300 psig/ 100 psig	CS/CS
7	EA-2402	Propane Refrigeration Sub-cooler	5.9 MMBTU/HR, DP S/T, 300 psig/ 2500 psig	CS/LTCS
7	EC-2301	CO ₂ Compressor 1 st Stage Air Cooler	2.94 MMBTU/HR, DP 75 psig	SS
7	EC-2302	CO ₂ Compressor 2 nd Stage Air Cooler	3.1 MMBTU/HR, DP 125 psig	SS
7	EC-2303	CO ₂ Compressor 3 rd Stage Air Cooler	4.6 MMBTU/HR DP 235 psig	SS
9	EC-2201	Solvent Stripper Bottoms Cooler	80.3 MMBTU/HR DP 135 psig	SS
9	FA-2201	Solvent Stripper Reflux Drum	5' ID x 16' S/S, DP 35 psig/ FV	304L
7	FA-2301	CO ₂ Compressor 2 nd Stage Suction Drum	7' - 6" ID x 10' S/S, DP 75 psig	CS/SS
7	FA-2303	Liquid CO ₂ Surge Drum	4' - 6" ID x 14' S/S, DP 235 psig	KCS
7	FA-2304	CO ₂ Compr. 3 rd Stage Discharge KO Drum	4' - 6" ID x 10' S/S, DP 235 psig	CS/SS
7	FA-2401	Propane Refrigeration Surge Drum	10' ID x 30' S/S, DP 300 psig	CS
7	FA-2402	Propane Refrigeration Suction Scrubber	8' - 6" ID x 12' S/S, DP 300 psig	LTCS
3	FB-2503	Caustic Day Tank	2' ID x 4' S/S, DP atm	CS
5	FD-2101	DCC Water Filter	205 gpm ea, DP 35 psig	SS
5	GA-2101 A/B	Wash Water Pump	1425 gpm ea, DP 29 psi	DI/SS
5	GA-2102 A/B	Direct Contact Cooler Water Pump	205 gpm ea, DP 35 psi	SS/SS
5	GA-2103 A/B/C/D	Rich Solvent Pump	3450 gpm ea, DP 92 psi	SS/SS
9	GA-2201 A/B/C	Lean Solvent Pump	3000 gpm ea, DP 85 psi	SS/SS
9	GA-2202 A/B	Solvent Stripper Reflux Pump	210 gpm ea, DP 75 psi	DI/SS
9	GA-2203 A/B	Filter Circ. Pump	290 gpm ea, DP 91 psi	SS/SS
9	GA-2204 A/B	LP Condensate Booster Pump	512 gpm ea, DP 237 psi	CI/SS
7	GA-2301 A/B	CO ₂ Pipeline Pump	217 gpm Ea, DP 1815 psi	CS/CS
3	GA-2501	Caustic Metering Pump	.45 gpm, DP 50 psi	SS
7	GB-2301	CO ₂ Compressor (Motor driven)	4480 hp	SS wheels
7	GB-2401	Propane Refrigeration Compressor	3075 hp	LTCS
1	GB-2500	LP Steam Turbine/Generator	83,365 hp	
9	PA-2551	Corrosion Inhibitor Package	Metering 25 lb/ hr	
9	PA-2251	Solvent Filter Package	140 gpm	
7	PA-2351	CO ₂ Dryer Package	4 driers, 200 hp compressor, electric heater, cooler	
1		Crane for Compr. Bldg. Flue Gas Ducting		
1	PA-2551	Cooling Tower	22,000 gpm, includes basin, pumps, chlorine injection	
1	PA-2552	Cooling Tower Blowdown Treatment Package	100 gpm sand filters and de-chlorinator, hypochlorite Storage Tank	

9.3 Appendix III - Economic Sensitivity Studies (Cases 1-5)

This appendix shows the results of a comprehensive economic sensitivity analysis. This analysis was done by varying a number of parameters that effect economic results for each case studied (Total Investment Cost, Capacity Factor, Make-up Power Cost [Levelized], and CO₂ by-product Selling Price [Levelized]). A total of 40 economic evaluation cases are reported in this appendix.

The sensitivity parameters listed above were chosen since the base values used for these parameters are site specific to this project or there may be some uncertainty in the value chosen when looking forward in time. Therefore proper use of these sensitivity results could potentially allow extrapolation to apply results to units other than just Conesville #5. The objective of this sensitivity analysis was to determine the relative impacts of the sensitivity parameters and CO₂ capture level on incremental cost of electricity and CO₂ mitigation cost.

The economic sensitivity results are shown in the tables and graphs, which follow in this appendix. These tables and graphs are grouped according to Case # as indicated in the following list.

- Case 1 – 90% CO₂ Capture
- Case 2 – 70% CO₂ Capture
- Case 3 – 50% CO₂ Capture
- Case 4 – 30% CO₂ Capture
- Case 5 – 96% CO₂ Capture, Updated Concept A of Previous Study

Each group includes one table and two associated graphs, which follow the table. As such, the results from this sensitivity study are summarized in Table 9-6 to Table 9-10 and plotted in Figure 9-10 to Figure 9-14.

9.3.1 Case 1 (90% CO₂ Capture)

Table 9-6: Case 1 (90% CO₂ Capture)

Power Generation										
Net Output (MW)	303.3	303.3	303.3	303.3	303.3	303.3	303.3	303.3	303.3	303.3
Capacity Factor (%)	85%	72%	90%	85%	85%	85%	85%	85%	85%	85%
Operating Hours (hrs/yr)	7,446	6,307	7,884	7,446	7,446	7,446	7,446	7,446	7,446	7,446
Net Efficiency, HHV (%)	24.5%	24.5%	24.5%	24.5%	24.5%	24.5%	24.5%	24.5%	24.5%	24.5%
Net Plant Heat Rate, HHV (Btu/kWh)	13,984	13,984	13,984	13,984	13,984	13,984	13,984	13,984	13,984	13,984
Coal HHV Input (MMBtu/hr)	4,229	4,229	4,229	4,229	4,229	4,229	4,229	4,229	4,229	4,229
Net Generation (MMWh/yr)	2,258,498	1,913,081	2,391,351	2,258,498	2,258,498	2,258,498	2,258,498	2,258,498	2,258,498	2,258,498
Costs										
Total Investment Cost (\$1000s)	400,094	400,094	400,094	300,070	500,117	400,094	400,094	400,094	400,094	400,094
Total Investment Cost (\$/kW)	1,319	1,319	1,319	989	1,649	1,319	1,319	1,319	1,319	1,319
Fixed O&M Costs (\$1000/yr)	2,494	2,494	2,494	2,494	2,494	2,494	2,494	2,494	2,494	2,494
Variable O&M Costs (\$1000/yr)	17,645	14,947	18,683	17,645	17,645	17,645	17,645	17,645	17,645	17,645
Levelized Make-up Power Cost										
Make-up Power Cost (¢/kWh)	6.40	6.40	6.40	6.40	6.40	6.40	6.40	6.40	6.40	6.40
Make-up Power Cost (\$1000/yr)	62,194	52,682	65,852	62,194	62,194	62,194	62,194	62,194	62,194	62,194
CO ₂ By-product Revenue										
CO ₂ By-product Selling Price (\$/ton)	0	0	0	0	0	0	0	0	25.00	50.00
CO ₂ By-product (lb/hr)	779,775	779,775	779,775	779,775	779,775	779,775	779,775	779,775	779,775	779,775
CO ₂ By-product Revenue (\$1000/yr)	0	0	0	0	0	0	0	0	0	(145,155)
Feedstock O&M Costs (\$1000/yr)	653	553	692	653	653	653	653	653	653	653
Coal Price (\$/MMBtu)	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80
Coal for CO ₂ System (MMBtu/hr)	0	0	0	0	0	0	0	0	0	0
Coal Cost (\$1000/yr)	0	0	0	0	0	0	0	0	0	0
Natural Gas Price (\$/MMBtu)	6.75	6.75	6.75	6.75	6.75	6.75	6.75	6.75	6.75	6.75
Natural Gas for CO ₂ System (MMBtu/hr)	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.00
Natural Gas Cost (\$1000/yr)	653	553	692	653	653	653	653	653	653	653
LCOE Contributions										
Capital Component (¢/kWh)	3.10	3.66	2.93	2.33	3.88	3.10	3.10	3.10	3.10	3.10
Fixed O&M (¢/kWh)	0.13	0.15	0.12	0.13	0.13	0.13	0.13	0.13	0.13	0.13
Variable O&M (¢/kWh)	3.66	3.66	3.66	3.66	3.66	3.66	3.66	3.66	3.66	3.66
Feedstock O&M (¢/kWh)	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03
Total Incremental COE (¢/kWh)	6.92	7.50	6.74	6.14	7.69	6.23	6.23	6.23	6.23	6.23
CO ₂ Mitigation Cost (\$/ton)	81	88	79	72	90	73	89	89	43	6
CO ₂ Mitigation Cost (\$/tonne)	89	97	87	79	99	80	98	98	48	6
CO ₂ Capture Cost (\$/ton)	54	58	52	48	60	48	59	59	29	4
CO ₂ Capture Cost (\$/tonne)	59	64	58	53	66	53	65	65	32	4





Figure 9-10: Case 1 Sensitivity Studies (90% CO₂ Capture)



9.3.2 Case 2 (70% CO₂ Capture)

Table 9-7: Case 2 (70% CO₂ Capture)

Power Generation										
Net Output (MW)	333.2	333.2	333.2	333.2	333.2	333.2	333.2	333.2	333.2	333.2
Capacity Factor (%)	85%	90%	85%	85%	85%	85%	85%	85%	85%	85%
Operating Hours (hrs/yr)	7,446	7,884	7,446	7,446	7,446	7,446	7,446	7,446	7,446	7,446
Net Efficiency, HHV (%)	26.9%	26.9%	26.9%	26.9%	26.9%	26.9%	26.9%	26.9%	26.9%	26.9%
Net Plant Heat Rate, HHV (Btu/kWh)	12,728	12,728	12,728	12,728	12,728	12,728	12,728	12,728	12,728	12,728
Coal HHV Input (MMBtu/hr)	4,229	4,229	4,229	4,229	4,229	4,229	4,229	4,229	4,229	4,229
Net Generation (MW/yr)	2,481,342	2,627,304	2,481,342	2,481,342	2,481,342	2,481,342	2,481,342	2,481,342	2,481,342	2,481,342
Costs										
Total Investment Cost (\$1000s)	365,070	365,070	273,802	456,337	365,070	365,070	365,070	365,070	365,070	365,070
Total Investment Cost (\$/kW)	1,095	1,095	822	1,369	1,095	1,095	1,095	1,095	1,095	1,095
Fixed O&M Costs (\$1000/yr)	2,284	2,284	2,284	2,284	2,284	2,284	2,284	2,284	2,284	2,284
Variable O&M Costs (\$1000/yr)	14,711	15,576	14,711	14,711	14,711	14,711	14,711	14,711	14,711	14,711
Levelized Make-up Power Cost										
Make-up Power Cost (¢/kWh)	6.40	6.40	6.40	6.40	6.40	6.40	6.40	6.40	6.40	6.40
Make-up Power Cost (\$1000/yr)	47,926	50,746	47,926	47,926	47,926	47,926	47,926	47,926	47,926	47,926
CO ₂ By-product Revenue										
CO ₂ By-product Selling Price (\$/ton)	0	0	0	0	0	0	0	0	0	0
CO ₂ By-product (lb/hr)	607,048	607,048	607,048	607,048	607,048	607,048	607,048	607,048	607,048	607,048
CO ₂ By-product Revenue (\$1000/yr)	0	0	0	0	0	0	0	0	0	0
Feedstock O&M Costs (\$1000/yr)	488	413	488	488	488	488	488	488	488	488
Coal Price (\$/MMBtu)	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80
Coal for CO ₂ System (MMBtu/hr)	0	0	0	0	0	0	0	0	0	0
Coal Cost (\$1000/yr)	0	0	0	0	0	0	0	0	0	0
Natural Gas Price (\$/MMBtu)	6.75	6.75	6.75	6.75	6.75	6.75	6.75	6.75	6.75	6.75
Natural Gas for CO ₂ System (MMBtu/hr)	9.70	9.70	9.70	9.70	9.70	9.70	9.70	9.70	9.70	9.70
Natural Gas Cost (\$1000/yr)	488	413	488	488	488	488	488	488	488	488
LCOE Contributions										
Capital Component (¢/kWh)	2.57	3.04	1.93	3.22	2.57	2.57	2.57	2.57	2.57	2.57
Fixed O&M (¢/kWh)	0.11	0.13	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11
Variable O&M (¢/kWh)	2.62	2.62	2.62	2.62	2.62	2.62	2.62	2.62	2.62	2.62
Feedstock O&M (¢/kWh)	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
Total, Incremental COE (¢/kWh)	5.32	5.81	4.68	5.97	4.68	4.68	4.68	4.68	4.68	4.68
CO ₂ Mitigation Cost (\$/ton)	88	95	77	98	77	77	77	77	77	77
CO ₂ Mitigation Cost (\$/tonne)	96	105	85	108	85	85	85	85	85	85
CO ₂ Capture Cost (\$/ton)	58	64	51	65	51	51	51	51	51	51
CO ₂ Capture Cost (\$/tonne)	64	70	57	72	57	57	57	57	57	57





Figure 9-11: Case 2 Sensitivity Studies (70% CO₂ Capture)

9.3.3 Case 3 (50% CO₂ Capture)

Table 9-8: Case 3 (50% CO₂ Capture)

Power Generation										
Net Output (MW)	362.9	362.9	362.9	362.9	362.9	362.9	362.9	362.9	362.9	362.9
Capacity Factor (%)	85%	90%	85%	85%	85%	85%	85%	85%	85%	85%
Operating Hours (hrs/yr)	7,446	7,884	7,446	7,446	7,446	7,446	7,446	7,446	7,446	7,446
Net Efficiency, HHV (%)	29.3%	29.3%	29.3%	29.3%	29.3%	29.3%	29.3%	29.3%	29.3%	29.3%
Net Plant Heat Rate, HHV (Btu/kWh)	11,686	11,686	11,686	11,686	11,686	11,686	11,686	11,686	11,686	11,686
Coal HHV Input (MMBtu/hr)	4,229	4,229	4,229	4,229	4,229	4,229	4,229	4,229	4,229	4,229
Net Generation (MMWh/yr)	2,702,488	2,861,458	2,702,488	2,702,488	2,702,488	2,702,488	2,702,488	2,702,488	2,702,488	2,702,488
Costs										
Total Investment Cost (\$1000s)	280,655	280,655	280,655	280,655	280,655	280,655	280,655	280,655	280,655	280,655
Total Investment Cost (\$/kW)	773	773	773	773	773	773	773	773	773	773
Fixed O&M Costs (\$1000/yr)	2,079	2,079	2,079	2,079	2,079	2,079	2,079	2,079	2,079	2,079
Variable O&M Costs (\$1000/yr)	10,876	11,516	10,876	10,876	10,876	10,876	10,876	10,876	10,876	10,876
Levelized Make-up Power Cost										
Make-up Power Cost (¢/kWh)	6.40	6.40	6.40	6.40	6.40	6.40	6.40	6.40	6.40	6.40
Make-up Power Cost (\$1000/yr)	33,768	35,754	33,768	33,768	33,768	33,768	33,768	33,768	33,768	33,768
CO ₂ By-product Revenue										
CO ₂ By-product Selling Price (\$/ton)	0	0	0	0	0	0	0	0	0	0
CO ₂ By-product (lb/hr)	433,606	433,606	433,606	433,606	433,606	433,606	433,606	433,606	433,606	433,606
CO ₂ By-product Revenue (\$1000/yr)	0	0	0	0	0	0	0	0	0	0
Feedstock O&M Costs (\$1000/yr)	337	357	337	337	337	337	337	337	337	337
Coal Price (\$/MMBtu)	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80
Coal for CO ₂ System (MMBtu/hr)	0	0	0	0	0	0	0	0	0	0
Coal Cost (\$1000/yr)	0	0	0	0	0	0	0	0	0	0
Natural Gas Price (\$/MMBtu)	6.75	6.75	6.75	6.75	6.75	6.75	6.75	6.75	6.75	6.75
Natural Gas for CO ₂ System (MMBtu/hr)	6.70	6.70	6.70	6.70	6.70	6.70	6.70	6.70	6.70	6.70
Natural Gas Cost (\$1000/yr)	337	357	337	337	337	337	337	337	337	337
LCOE Contributions										
Capital Component (¢/kWh)	1.82	1.72	1.36	1.82	1.82	1.82	1.82	1.82	1.82	1.82
Fixed O&M (¢/kWh)	0.09	0.08	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09
Variable O&M (¢/kWh)	1.72	1.72	1.72	1.72	1.72	1.72	1.72	1.72	1.72	1.72
Feedstock O&M (¢/kWh)	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
Total Incremental COE (¢/kWh)	3.64	3.53	3.18	3.64	3.64	3.64	3.64	3.64	3.64	3.64
CO ₂ Mitigation Cost (\$/ton)	91	88	79	91	91	91	91	91	91	91
CO ₂ Mitigation Cost (\$/tonne)	100	97	87	100	100	100	100	100	100	100
CO ₂ Capture Cost (\$/ton)	61	59	53	61	61	61	61	61	61	61
CO ₂ Capture Cost (\$/tonne)	67	65	59	67	67	67	67	67	67	67





Figure 9-12: Case 2 Sensitivity Studies (50% CO₂ Capture)

9.3.4 Case 4 (30% CO₂ Capture)

 Table 9-9: Case 4 (30% CO₂ Capture)

Power Generation										
Net Output (MW)	392.1	392.1	392.1	392.1	392.1	392.1	392.1	392.1	392.1	392.1
Capacity Factor (%)	85%	90%	85%	85%	85%	85%	85%	85%	85%	85%
Operating Hours (hrs/yr)	7,446	7,884	7,446	7,446	7,446	7,446	7,446	7,446	7,446	7,446
Net Efficiency, HHV (%)	31.7%	31.7%	31.7%	31.7%	31.7%	31.7%	31.7%	31.7%	31.7%	31.7%
Net Plant Heat Rate, HHV (Btu/kWh)	10,818	10,818	10,818	10,818	10,818	10,818	10,818	10,818	10,818	10,818
Coal HHV Input (MMBtu/hr)	4,229	4,229	4,229	4,229	4,229	4,229	4,229	4,229	4,229	4,229
Net Generation (MMWh/yr)	2,919,331	3,091,056	2,919,331	2,919,331	2,919,331	2,919,331	2,919,331	2,919,331	2,919,331	2,919,331
Costs										
Total Investment Cost (\$1000s)	211,835	211,835	158,876	264,794	211,835	211,835	211,835	211,835	211,835	211,835
Total Investment Cost (\$/kW)	540	540	405	675	540	540	540	540	540	540
Fixed O&M Costs (\$1000/yr)	1,869	1,869	1,869	1,869	1,869	1,869	1,869	1,869	1,869	1,869
Variable O&M Costs (\$1000/yr)	7,019	7,432	7,019	7,019	7,019	7,019	7,019	7,019	7,019	7,019
Levelized Make-up Power Cost										
Make-up Power Cost (¢/kWh)	6.40	6.40	6.40	6.40	6.40	6.40	6.40	6.40	6.40	6.40
Make-up Power Cost (\$1000/yr)	19,885	21,054	19,885	19,885	19,885	19,885	19,885	19,885	19,885	19,885
CO ₂ By-product Revenue										
CO ₂ By-product Selling Price (\$/ton)	0	0	0	0	0	0	0	0	0	50.00
CO ₂ By-product (lb/hr)	260,163	260,163	260,163	260,163	260,163	260,163	260,163	260,163	260,163	260,163
CO ₂ By-product Revenue (\$1000/yr)	0	0	0	0	0	0	0	0	0	(48,429)
Feedstock O&M Costs (\$1000/yr)	211	224	211	211	211	211	211	211	211	211
Coal Price (\$/MMBtu)	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80
Coal for CO ₂ System (MMBtu/hr)	0	0	0	0	0	0	0	0	0	0
Coal Cost (\$1000/yr)	0	0	0	0	0	0	0	0	0	0
Natural Gas Price (\$/MMBtu)	6.75	6.75	6.75	6.75	6.75	6.75	6.75	6.75	6.75	6.75
Natural Gas for CO ₂ System (MMBtu/hr)	4.20	4.20	4.20	4.20	4.20	4.20	4.20	4.20	4.20	4.20
Natural Gas Cost (\$1000/yr)	211	224	211	211	211	211	211	211	211	211
LCOE Contributions										
Capital Component (¢/kWh)	1.27	1.50	0.95	1.59	1.27	1.27	1.27	1.27	1.27	1.27
Fixed O&M (¢/kWh)	0.07	0.09	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07
Variable O&M (¢/kWh)	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96
Feedstock O&M (¢/kWh)	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
Total Incremental COE (¢/kWh)	2.31	2.55	1.99	2.63	2.14	2.14	2.14	2.14	2.14	2.14
CO ₂ Mitigation Cost (\$/ton)	103	114	89	117	95	95	95	95	95	95
CO ₂ Mitigation Cost (\$/tonne)	113	125	98	129	105	105	105	105	105	105
CO ₂ Capture Cost (\$/ton)	70	77	60	79	65	65	65	65	65	65
CO ₂ Capture Cost (\$/tonne)	77	85	66	87	71	71	71	71	71	71





Figure 9-13: Case 4 Sensitivity Studies (30% CO₂ Capture)

9.3.5 Case 5 (96% CO₂ Capture)

 Table 9-10: Case 5 (96% CO₂ Capture)

Power Generation										
Net Output (MW)	251.6	251.6	251.6	251.6	251.6	251.6	251.6	251.6	251.6	251.6
Capacity Factor (%)	85%	85%	85%	85%	85%	85%	85%	85%	85%	85%
Operating Hours (hrs/yr)	7,446	7,446	7,446	7,446	7,446	7,446	7,446	7,446	7,446	7,446
Net Efficiency, HHV (%)	20.3%	20.3%	20.3%	20.3%	20.3%	20.3%	20.3%	20.3%	20.3%	20.3%
Net Plant Heat Rate, HHV (Btu/kWh)	16,856	16,856	16,856	16,856	16,856	16,856	16,856	16,856	16,856	16,856
Total Fuel Heat Input at MCR (MMBtu/hr)	4,242	4,242	4,242	4,242	4,242	4,242	4,242	4,242	4,242	4,242
Coal HHV Input (MMBtu/hr)	4,229	4,229	4,229	4,229	4,229	4,229	4,229	4,229	4,229	4,229
Net Generation (MWh/yr)	1,873,667	1,587,106	1,983,882	1,873,667	1,873,667	1,873,667	1,873,667	1,873,667	1,873,667	1,873,667
Costs										
Total Investment Cost (\$1000s)	701,057	701,057	701,057	876,322	701,057	701,057	701,057	701,057	701,057	701,057
Total Investment Cost (\$/kW)	2,786	2,786	2,786	3,483	2,786	2,786	2,786	2,786	2,786	2,786
Fixed O&M Costs (\$1000/yr)	2,488	2,488	2,488	2,488	2,488	2,488	2,488	2,488	2,488	2,488
Variable O&M Costs (\$1000/yr)	18,640	15,789	19,737	18,640	18,640	18,640	18,640	18,640	18,640	18,640
Levelized Make-up Power Cost										
Make-up Power Cost (¢/kWh)	6.40	6.40	6.40	6.40	6.40	6.40	6.40	6.40	6.40	6.40
Make-up Power Cost (\$1000/yr)	86,832	73,552	91,940	86,832	86,832	86,832	86,832	86,832	86,832	86,832
CO ₂ By-product Revenue										
CO ₂ By-product Selling Price (\$/ton)	0	0	0	0	0	0	0	0	0	0
CO ₂ By-product (lb/hr)	835,053	835,053	835,053	835,053	835,053	835,053	835,053	835,053	835,053	835,053
CO ₂ By-product Revenue (\$1000/yr)	0	0	0	0	0	0	0	0	0	0
Feedstock O&M Costs (\$1000/yr)	890	754	942	890	890	890	890	890	890	890
Coal Price (\$/MMBtu)	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.80
Coal for CO ₂ System (MMBtu/hr)	0	0	0	0	0	0	0	0	0	0
Coal Cost (\$1000/yr)	0	0	0	0	0	0	0	0	0	0
Natural Gas Price (\$/MMBtu)	6.75	6.75	6.75	6.75	6.75	6.75	6.75	6.75	6.75	6.75
Natural Gas for CO ₂ System (MMBtu/hr)	17.70	17.70	17.70	17.70	17.70	17.70	17.70	17.70	17.70	17.70
Natural Gas Cost (\$1000/yr)	890	754	942	890	890	890	890	890	890	890
LCOE Contributions										
Capital Component (¢/kWh)	6.55	7.73	6.18	4.91	6.55	6.55	6.55	6.55	6.55	6.55
Fixed O&M (¢/kWh)	0.15	0.18	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
Variable O&M (¢/kWh)	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79
Feedstock O&M (¢/kWh)	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06
Total, Incremental COE (¢/kWh)	12.54	13.75	12.17	10.91	14.18	11.38	13.70	8.39	13.70	4.25
CO ₂ Mitigation Cost (\$/ton)	134	147	130	117	152	122	147	90	147	46
CO ₂ Mitigation Cost (\$/tonne)	148	163	144	129	168	135	162	99	162	50
CO ₂ Capture Cost (\$/ton)	76	83	73	66	85	69	83	51	83	26
CO ₂ Capture Cost (\$/tonne)	83	91	81	72	94	76	91	56	91	28





Figure 9-14: Case 5 Sensitivity Studies (96% CO₂ Capture)

9.4 Appendix IV – Let Down Turbine Technical Information (Cases 1 and 4)

This appendix provides technical information regarding the let down turbines used for Case 1 (90% CO₂ capture) and Case 4 (30% CO₂ capture). Three attachments are provided as listed below:

- Attachment A: Steam Turbine and Auxiliaries General Technical Information (applicable to both the 90% and 30% CO₂ recovery let down turbines)
- Attachment B: Information specific to the Case 1 let down turbine (90% CO₂ capture)
- Attachment C: Information specific to the Case 4 let down turbine (30% CO₂ capture turbine)

Attachment A:**Steam Turbine and Auxiliaries General Technical Information (applicable to both the 90% and 30% CO₂ recovery let down turbines)****1. GENERAL DESIGN INFORMATION****1.1 TURBINE**

The turbine is a multistage straight backpressure single line type with the shaft aligned horizontally. Its casing consists of a fabricated steel structure made from welded steel plates. Steam is admitted through two inlet openings located on the top and the bottom of the inlet box, respectively. The upper part of this casing is welded to the duct (out of scope of supply).

The turbine rotor is fabricated of high chromium steel with the coupling disc at the generator side being an integral part of it.

1.2 TURBINE CHOKE VALVES

IP steam is admitted through one quick-closing choke valve and two control choke valves, located at the side of the turbine.

The quick-closing choke valves are arranged in front of the control choke valve.

1.3 BEARINGS

Turbine rotor is supported with two hydrodynamic bearings. The bearings are supplied with high pressure jacking oil at start up and in case of low speed rotor rotations.

1.4 TURNING GEAR

The turbine front pedestal will be equipped with a motor driven turning gear with automatic operation control system.

The turning gear is capable of starting the unit from standstill and rotating the turbine-generator shaft line continuously at recommended turning speed with normal lube oil pressure.

1.5 TECHNICAL DATA OF THE TURBINE

Please refer to the specific turbine under consideration (see separate attachment).

2. GENERATOR

The generator is an air-cooled generator running at 3,600 rpm.

For more specific information on the generator under consideration, please refer to the generator description in the separate attachment.

AUXILIARY SYSTEMS

3.1 TURBINE SUPERVISORY SYSTEM

The turbine supervisory system ensures supervision of turbine/generator unit shaft-line critical operating parameters (e.g.:turbine and generator journal bearings temperatures and vibration levels and turbine thrust bearing temperature and wearing).

The supervisory system is connected with the turbine safety system and may generate alarm and tripping signals through adjustable monitoring consoles.

3.2 TURBINE SAFETY AND PROTECTION SYSTEM

The safety and protection system is able to stop the steam turbine by a quick, automatic closing of choke valves.

A turbine trip may be initiated either automatically or by action of an operator under instruction. In faulty conditions of a monitored parameter, a threshold detector emits an alarm and, in the worst case, may even promote an automatic trip.

3.3 STEAM TURBINE GOVERNING SYSTEM

The Steam Turbine Governing System governs the position of the control choke valve. This control system ensures the following functions:

- Control of the turbine generator speed (frequency in island operation) when the generator is not coupled to the grid
- Control of the turbo-generator load when the generator is coupled to the grid

In normal operation the system operates with a sliding pressure at inlet at the maximum opening of the turbine with a load limitation.

3.4 GLAND STEAM SYSTEM

Correct operation of the turbine requires clearances between fixed and moving parts, through which steam tends to leak. The gland steam system ensures that no steam escapes from valves and shaft glands into the turbine room.

3.5 DRAIN SYSTEM

The drains have the following purposes:

- To eliminate the condensates in order to avoid damages to the machine,
- To ensure the thermal conditioning of the turbine by steam circulation from glands when the control valves are closed or just opened.

3.6 OIL SYSTEM

One complete combined lube and control oil system is feeding two separate circuits.

The function of this system is to ensure, on one side, the lubrication and cooling of journal bearings, and the thrust bearing, for the whole set (turbine, generator), and on the other side, the control oil of the turbine. It consists mainly of a packaged oil tank. Electrically driven positive displacement (main and auxiliary) and centrifugal (emergency) pumps are vertically submerged in this oil tank.

Two full duty oil coolers are arranged in parallel on oil and cooling water circuits with a changeover oil valve to change the cooler on duty without interruption of the oil flow to the bearings. An emergency standby pump delivers lube oil without passing through the coolers and filters.

The control and safety and protection systems use the common lube and control oil for actuation of valves.

4. SCOPE OF SUPPLY AND LIMITS OF DELIVERY

4.1 SCOPE OF DELIVERY

Table 9-11: Let Down Turbine Scope of Delivery

Item No.	Description	Quantity per one unit	Remarks
1.	Complete turbine: A) turbine casing B) bladed rotor C) blade carrier with fixed blades D) end gland seals	1 set	Including insulation
2.	Turbine steam admission system consists of quick closing and control choke valves	1 set	Including insulation
3.	Complete turbine pedestals with bearings and elements necessary for the shaft line adjustment and pedestal survey	1 set	
4.	Turbine-Generator coupling	1 set	
5.	Complete electrical turning gear with clutch and hand turning facility	1 set	
6.	Handling devices for steam turbine components	1 set	
7.	Complete gland steam system including: A) pressure reducing valve, B) piping and valves, C) gland steam condenser	1 set	
8.	Complete oil systems including: A) pumps (main, auxiliary, emergency), B) oil tank, C) coolers (2 x 100%), D) oil filter (duplex) E) piping and valves, F) oil mist and separator, G) oil tank drain piping (ending with isolating valves)	1 set	
9.	Complete air cooled generator with excitation system and AVR	1 set	

10.	Handling devices for generator components	1 set	
11.	T/G control and protection system: A) system cubicle, B) hardware, C) software, D) speed probes	1 set	
12.	T/G supervisory equipment (TSE): A) instrument rack incl. power supply B) probes and sensors with connection to local junction boxes, transmitters, etc., C) proximity sensors and monitors, D) software	1 set	
13.	Instrumentation and cables for the T/G and auxiliaries	1 set	Cabling up to local junction boxes
14.	Special tools	1 set	
15.	Spare parts for start-up	1 set	
16.	Mandatory spare parts	1 set	
17.	Documentation: A) quality, B) assembly, C) manuals	1 set	English versions only

4.2 LIMITS OF DELIVERY

The scope of supply as mentioned in Table 9-11 above is limited to the following boundaries:

Steam:	Inlet weld connection on IP steam admission valve Outlet weld connection on LP casing (upper exhaust)
Cooling water	Inlet/outlet of cooling water flange connections at lube oil coolers.
Condensate/Feedwater:	Inlet weld connection at LP turbine hood spray water stop valve. Inlet connection at gland steam supply control valve.
Gland system:	Outlet flange at gland steam condenser exhaust ventilator fan. Feedwater inlet/outlet flange connections at gland steam condenser. Condensate outlet flange at gland steam condenser.
Lube oil system:	Outlet flange at vapour ventilator fan of oil tank Supply and drain connections on lube oil tank.
Elec. equipment:	Terminals at motor terminal boxes. Terminals at plant mounted local junction boxes.
I&C:	Terminals at control cubicles Terminals at local junction boxes
Generator:	Output terminals of the generator and brush gear, Output terminals of the generator and brush gear measuring boxes, Output terminals of the noise hood measuring boxes, Output and input terminals in the excitation system cubicle, Output and input flanges on the coolers



Attachment B:


Steam Turbine and Auxiliaries for Case 1 Let Down Turbine (90% CO₂ removal)

1. TECHNICAL DATA OF THE TURBINE

Parameter	Unit	Value
Number of casings	-	1
Nominal speed	rpm	3,600
Plant cycle	-	single flash
Inlet pressure psia	200	
Temperature	°F	711
Exhaust pressure	psia	47
Gross Electric Power Output (at generator terminals)	kW	48,030

2. GENERATOR

The generator is an air-cooled generator running at 3600 rpm. It is designed for a nominal active power of 50.00 MW at a power factor of 0.9. A general arrangement drawing is shown in Figure 9-15.



MAIN FEATURES	APPROXIMATE DIMENSIONS		APPROXIMATE WEIGHTS			
		mm.	in.	tons	lbs.	
Water / air cooled	A :	7 252	285.5	Stator :	53.0	116 800
	B :	3 150	124.0	Rotor + Exciter armature :	18.0	39 700
Brushless exciter	B1 :	3 330	131.1	Bearings :	1.6	3 500
	C :	4 200	165.4	Base frame :	12.1	26 700
Soundproofed housing	H :	1 500	59.1	Exciter field :	0.7	1 500
	L :	7 352	289.5	Housing :	12.0	26 400
Protection degree IP 54	L1 :	510	20.1	Miscellaneous :	5.0	11 000
	L2 :	2 530	99.6			
	L3 :	2 530	99.6	TOTAL :	102.4	225 600
	L4 :	1 782	70.2			
MV equipment located inside the generator	R :	11 300	444.9			

APPROXIMATE INERTIA		
MR ²	Kg.m ²	Lb.ft ²
Generator	: 1 640	38 900

Figure 9-15: Typical General Outline Arrangement for LDT Generator for Case 1 (90% Recovery)

3. TURBINE GENERATOR ARRANGEMENT




Figure 9-16: Turbine Generator General Arrangement (Case 1: 90% removal)

Attachment C:

Steam Turbine and Auxiliaries for Case 4 Let Down Turbine (30% CO₂ removal)

1. TECHNICAL DATA OF THE TURBINE

Parameter	Unit	Value
Number of casings	-	1
Nominal speed	rpm	3600
Plant cycle -	single flash	
Inlet pressure psia	195	
Temperature °F	711	
Exhaust pressure	psia	47
Gross Electric Power Output (at generator terminals)	kW	15054

2. GENERATOR

The generator is an air-cooled generator running at 3,600 rpm. It is designed for a nominal active power of 15.00 MW at a power factor of 0.9. A general arrangement drawing is shown in Figure 9-17.




Figure 9- 17: Typical General Outline Arrangement for LDT Generator for Case 4 (30% Recovery)

Main Features	Approximate Weights		
		Tons	Lbm
Water /air cooled	Stator	: 26.4	58 202
	Support base	9.4	20 723
Brushless exciter	Rotor + Exciter Rotor	: 11.5	25 353
	Exciter	0.4	882
Soundproof housing	Bearings	: 1.3	2 866
	Housing	6.0	15 212
Protection degree IP 55	Coolers	: 1.6	3 527
	Miscellaneous	2.6	5 732
MV equipment located inside the generator	TOTAL	: 60.1	132 498

3. TURBINE GENERATOR ARRANGEMENT




Figure 9-18: Turbine Generator General Arrangement for Case 4 (30% removal)