

For the Nuclear Regulatory Commission.

**Jon Hopkins,**

*Senior Project Manager, Section 2, Project Directorate III, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.*

[FR Doc. 03-1749 Filed 1-24-03; 8:45 am]

BILLING CODE 7590-01-P

**NUCLEAR REGULATORY COMMISSION**

[Docket No. 50-346]

**FirstEnergy Nuclear Operating Company; Notice of Withdrawal of Application for Amendment to Facility Operating License**

The U.S. Nuclear Regulatory Commission (the Commission) has granted the request of FirstEnergy Nuclear Operating Company (the licensee) to withdraw its October 9, 2001, application for proposed amendment to Facility Operating License No. NPF-3 for the Davis-Besse Nuclear Power Station, Unit No. 1, located in Ottawa County, Ohio.

The proposed amendment would have revised the Technical Specifications regarding surveillance testing of the Steam and Feedwater Rupture Control System instrumentation to decrease the frequency of functional testing and to revise setpoint allowable values accordingly.

The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the **Federal Register** on December 26, 2001 (66 FR 66466). However, by letter dated December 20, 2002, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendment dated October 9, 2001, and the licensee's letter dated December 20, 2002, which withdrew the application for license amendment. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the Internet at the NRC Web site, <http://www.nrc.gov/reading-rm/adams/html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS, should contact the NRC PDR Reference staff by telephone at 1-800-397-4209, or 301-415-4737 or by e-mail to [pdr@nrc.gov](mailto:pdr@nrc.gov).

Dated at Rockville, Maryland, this 21st day of January 2003.

For the Nuclear Regulatory Commission.

**Jon Hopkins,**

*Senior Project Manager, Section 2, Project Directorate III, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.*

[FR Doc. 03-1750 Filed 1-24-03; 8:45 am]

BILLING CODE 7590-01-P

**NUCLEAR REGULATORY COMMISSION**

[Docket No. 50-263]

**Nuclear Management Company, LLC; Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for a Hearing**

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. DPR-22, issued to the Nuclear Management Company, LLC, for operation of the Monticello Nuclear Generating Plant, located in Wright County, Minnesota.

The proposed amendment would revise the operating license to authorize changing the design bases and the Updated Safety Analysis Report (USAR) based upon revised analyses of (1) the long-term containment response to a design-basis loss-of-coolant accident (LOCA) and (2) containment pressure required for adequate net positive suction head (NPSH) for the residual heat removal (RHR) pumps and core spray pumps following a LOCA. The revised analyses incorporate revised inputs, assumptions, alternative scenarios, and different analytical methods and results from those currently described in the USAR and previously approved by the Nuclear Regulatory Commission in Monticello License Amendment Nos. 98 (dated July 25, 1997) and 102 (dated September 16, 1998). These changes include additional contributions to, and allowance for error in, (1) the reactor decay heat input; (2) longer delays in initiating long-term containment cooling for reactor isolation and small-break events; (3) improved credit (K-value of 147 Btu/sec-°F rather than 143.1 Btu/sec-°F) for RHR heat exchanger performance; and (4) a slightly higher design temperature limit (196.7 °F rather than 195 °F) for piping attached to the wetwell based on revised calculations of wetwell pressure and a corresponding increase in allowable service water temperature. The revised results reduce (from 18.26 psia to 17.51 psia) the overpressure credit needed for adequate NPSH (*i.e.*, the revised analysis of long-term

wetwell pressure response to a design-basis LOCA with containment spray cooling results in a wetwell pressure below the previous NRC-approved limit curve during the period from 2000 to 4000 seconds).

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations.

By February 26, 2003, the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license, and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. Interested persons should consult a current copy of 10 CFR 2.714,<sup>1</sup> which is available at the Commission's Public Document Room (PDR), located at One White Flint North, Public File Area O1 F21, 11555 Rockville Pike (first floor), Rockville, Maryland, or electronically on the Internet at the NRC Web site <http://www.nrc.gov/reading-rm/doc-collections/cfr>. If there are problems in accessing the document, contact the PDR Reference staff at 1-800-397-4209, 301-415-4737, or by e-mail to [pdr@nrc.gov](mailto:pdr@nrc.gov). If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel will rule on the request and/or petition; and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR 2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition must specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) The nature of the petitioner's right under the Act to be

<sup>1</sup> "The most recent version of Title 10 of the Code of Federal Regulations, published January 1, 2002, inadvertently omitted the last sentence of 10 CFR 2.714(d) and subparagraphs (d)(1) and (2), regarding petitions to intervene and contentions. For the complete, corrected text of 10 CFR 2.714(d), please see 67 FR 20884; April 29, 2002."