

**RELEASE
FIRE PROTECTION AND LIFE SAFETY
EVALUATION FOR A LOW-RISE OFFICE BUILDING**

The Offeror or the Offeror's representative shall complete this form based on a walk-through of the building or their knowledge of the building's fire protection and life safety systems. This form consists of a series of short answer and yes/no/not applicable questions related to the building's fire protection and life safety systems.

1. Fundamental Code Requirements.

- a. The offered building shall be evaluated for compliance with the most recent edition of the building and fire code adopted by the jurisdiction in which the building is located; with the exception that the technical egress requirements of the building shall be evaluated based on the egress requirements of the National Fire Protection Association (NFPA) 101, *Life Safety Code*. All areas that do not meet the above stated criteria shall be identified as to the extent that they do comply.

2. Definitions.

- a. Low-Rise Building: A building less than 75 feet in height where the building height is measured from the lowest level of fire department vehicle access to the floor of the highest occupied floor. A building that is 5 stories or less in height is typically considered a low-rise building.
- b. Hazardous Areas: Any space or compartment within a building in which storage or other activity exists that is not part of normal office space arrangements and that possesses the potential for producing a fully involved fire. Such areas used for: the storage or use of combustibles or flammables; toxic, noxious, or corrosive materials; or heat producing appliances, etc. (as defined in the latest edition of NFPA 101, *Life Safety Code*).

The Offeror states, as part of this offer, that the proposed space/building is as described below and that the information provided is accurate. In addition, the Offeror agrees all features and devices described below are in operating order and properly maintained. **THIS SFO PRELEASE FORM WILL BE COMPLETED BY THE OFFEROR OR THE OFFEROR'S REPRESENTATIVE.** Please provide additional pages should this form not provide sufficient space to respond adequately to any question.

BUILDING ADDRESS			
Building Name:			
Building Address:			
City:			
State:			
9-Digit Zip Code:			
BUILDING CODE AND FIRE CODE ADOPTED BY LOCAL JURISDICTION			
Building Code:		YEAR:	
Fire Code:		YEAR:	
SIZE AND LAYOUT			
The following information applies to (check one):			
<input type="checkbox"/> an existing building			
<input type="checkbox"/> a building planned for lease construction			
<input type="checkbox"/> a building planned for lease construction with Government option to purchase			
Identify each floor in which space is offered to Government:			
Identify gross square footage of space offered to Government on each floor:			
Identify height (in feet) of the building above the lowest level of fire department vehicle access:			
Identify the number of floors above the lowest level of fire department vehicle access:			
Identify the number of floors below the lowest level of fire department vehicle access:			
OTHER OCCUPANCIES IN BUILDING (Check All That Apply)			
<input type="checkbox"/> Restaurants	<input type="checkbox"/> Laboratories	<input type="checkbox"/> Storage	<input type="checkbox"/> Retail
<input type="checkbox"/> Other (list)			

**RELEASE
FIRE PROTECTION AND LIFE SAFETY
EVALUATION FOR A LOW-RISE OFFICE BUILDING**

BUILDING CONSTRUCTION TYPE (Check One)					
<input type="checkbox"/> Fire resistive	<input type="checkbox"/> Heavy Timber	<input type="checkbox"/> Ordinary	<input type="checkbox"/> Wood Frame	<input type="checkbox"/> Unprotective non-combustible	
VERTICAL OPENINGS (CHECK ONE)					
Between Two or More Floors					
Exit Stairways	<input type="checkbox"/> open	<input type="checkbox"/> enclosed with doors, provide description			
Shafts	<input type="checkbox"/> open	<input type="checkbox"/> enclosed, provide description			
Atrium	<input type="checkbox"/> open	<input type="checkbox"/> enclosed, provide description			
Other	<input type="checkbox"/> open	<input type="checkbox"/> enclosed, provide description			
None	<input type="checkbox"/>				
ELECTRICAL SYSTEM					
Please Check YES, NO, or NA to the following question:			YES	NO	NA
The building electrical system appears to comply with the NFPA 70, <i>National Electrical Code</i> in that there are no obvious deficiencies (e.g., temporary wiring, use of extension cords, deteriorated equipment, missing equipment, etc.). If potential problems are noted, describe on an attached sheet.					
BUILDING EGRESS AND EXITING SYSTEM					
Please Check YES, NO, or NA to the following questions:			YES	NO	NA
Unrestrictive access is provided to a minimum of two exits on each floor.					
Scissor stairs count as only one approved exit.					
Fire escapes are not counted as an approved exit.					
Corridors have a 1-hour fire-resistive rating.					
Exit access is at least 44 inches wide.					
All exit stairways terminate directly at a public way or at an exterior exit discharge.					
All exit doors swing in the direction of exit travel.					
BUILDINGS PROTECTED THROUGHOUT BY AUTOMATIC FIRE SPRINKLERS					
Please Check YES, NO, or NA to the following questions:			YES	NO	NA
The minimum separation distance between two exits or exit access doors measured in a straight line between the exits or exit access doors shall not be less than one-third the length of the maximum overall diagonal dimension of the building or area served.					
The travel distance to the exits is not more than 300 feet.					
The maximum length of a dead-end corridor is 50 feet.					
The common path of travel is not more than 100 feet in length.					
BUILDINGS NOT PROTECTED THROUGHOUT BY AUTOMATIC FIRE SPRINKLERS					
Please Check YES, NO, or NA to the following questions:			YES	NO	NA
The minimum separation distance between two exits or exit-access doors measured in a straight line between the exits or exit-access doors shall not be less than one-half the length of the maximum overall diagonal dimension of the building or area served.					
The travel distance to the exits is not more than 200 feet.					
The maximum length of a dead-end corridor is 50 feet.					
The common path of travel is not more than 75 feet in length.					

**RELEASE
FIRE PROTECTION AND LIFE SAFETY
EVALUATION FOR A LOW-RISE OFFICE BUILDING**

STANDPIPES AND PORTABLE FIRE EXTINGUISHERS			
Please Check YES, NO, or NA to the following questions:	YES	NO	NA
Standpipes are installed in building.			
Portable fire extinguishers are installed in building.			
BUILDING EXIT HARDWARE AND EGRESS DOORS			
Please Check YES, NO, or NA to the following questions:	YES	NO	NA
All exit stairway doors are in proper working order.			
All exit stairway doors are self-closing or automatic-closing; and self-latching.			
In an emergency, all exit stairway doors permit re-entry from the exit stairway enclosure to the interior of the building.			
Exit doors require one action to open (e.g., no locks, locked during unoccupied periods only). NOTE: Special locking arrangements may be permitted if allowed by local jurisdiction.			
AUTOMATIC FIRE SPRINKLERS			
Please Check YES, NO, or NA to the following questions:	YES	NO	NA
Automatic fire sprinklers are installed throughout the building.			
Automatic fire sprinklers are installed in all below-grade space.			
Automatic fire sprinklers are installed only in corridors.			
Automatic fire sprinklers are installed in all hazardous areas (as defined by NFPA 101, <i>Life Safety Code</i>).			
Automatic fire sprinklers are installed in other locations in the building (describe locations on additional sheet).			
Central Sprinkler Company's Omega line of fire sprinklers are installed in the building (describe location(s), model(s), number of sprinklers, date installed, etc. on additional sheet).			
Automatic fire sprinklers having an "O-Ring" are installed in the building (describe location(s), model(s), number of sprinklers, date installed, etc. on additional sheet).			
The automatic fire sprinkler system is electronically supervised in accordance with NFPA 13, <i>Standard for Installation of Sprinkler Systems</i> .			
The automatic fire sprinkler system is maintained in accordance with the applicable local codes or NFPA 25, <i>Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems</i> .			
SMOKE DETECTORS			
Please Check YES, NO, or NA to the following questions:	YES	NO	NA
Smoke detectors are installed throughout the building.			
Smoke detectors are installed only in corridors.			
Smoke detectors are installed only in elevator lobbies.			
Smoke detectors are installed in all hazardous areas (as defined by NFPA 101, <i>Life Safety Code</i>).			
Smoke detectors are installed in other locations in the building (describe other locations on additional sheet).			
Duct smoke detectors are installed in the building.			
HEAT DETECTORS			
Please Check YES, NO, or NA to the following questions:	YES	NO	NA
Heat detectors are installed throughout the building.			
Heat detectors are installed only in corridors.			
Heat detectors are installed in all hazardous areas (as defined by NFPA 101, <i>Life Safety Code</i>).			
Heat detectors are installed in other locations in the building (describe other locations on additional sheet).			

**RELEASE
FIRE PROTECTION AND LIFE SAFETY
EVALUATION FOR A LOW-RISE OFFICE BUILDING**

FIRE ALARM SYSTEM			
Please Check YES, NO, or NA to the following questions:	YES	NO	NA
A fire alarm system is installed in the building.			
Audible alarm notification appliances are installed and located throughout the building to be effectively heard above normal conditions of occupancy.			
Visible alarm notification appliances are installed and located throughout the building.			
Operation of the fire alarm system automatically notifies building occupants to evacuate or relocate within the building.			
Operation of the fire alarm system automatically notifies the local fire department or UL central station service.			
Emergency power is provided for the fire alarm system.			
The fire alarm system has emergency voice communication capabilities.			
The fire alarm system is maintained in accordance with the applicable local codes or NFPA 72, <i>National Fire Alarm Code</i> .			
HAZARDOUS AREAS Hazardous Areas as defined by NFPA 101, <i>Life Safety Code</i>			
Please Check YES, NO, or NA to the following questions:	YES	NO	NA
Hazardous areas are located in the building.			
List locations of all hazardous areas in the building (describe locations on additional sheet).			
EXIT SIGNS, EMERGENCY LIGHTING, & EMERGENCY POWER			
Please Check YES, NO, or NA to the following questions:	YES	NO	NA
Illuminated exit signs are installed along exit paths.			
Emergency lighting is installed along exit paths.			
Emergency power is provided for building's life safety systems (e.g., exit signs, emergency lighting, fire alarm, etc.).			
An emergency generator is installed in the building to provide emergency power to the building's life safety systems.			
An UPS system is installed in the building to provide emergency power to the building's life safety systems.			
INTERIOR FINISH			
Please Check YES, NO, or NA to the following questions:	YES	NO	NA
Offered space has corkboard installed on walls.			
Offered space has carpet installed on walls.			
Offered space has wood paneling installed on walls.			
ELEVATORS			
Please Check YES, NO, or NA to the following questions:	YES	NO	NA
Elevators have a current certificate of elevator inspection from the local jurisdiction.			
Elevators are equipped with telephones or other two-way emergency signaling systems connected to an emergency communication location manned during normal working hours when the elevators are in service.			
Elevators are automatically recalled by smoke detectors located in elevator lobbies and machine rooms.			
Elevators recall to an alternate level when activated by primary level smoke detector.			
Elevators are equipped with firemen's manual capture feature.			
PUBLIC ADDRESS SYSTEMS			
Please Check YES, NO, or NA to the following question:	YES	NO	NA
An independent public address system is provided throughout the building.			