

## TIPS FOR FIRE HOSE INSTALLATIONS

- Equip fire taps with gated wye valves so that two hoses can be brought into service on a fire simultaneously.
- A clamped or pinned type coupling provided in the water hose joint nearest to a continuous miner could allow rapid switchover for firefighting use.
- Provide regulators for high water pressure situations.
- Maintain a laminated list of equipment at each storage

location to enhance routine inspections.

## It Happened...

On July 24, 1989, a roof fall in the trolley haulage entry caused an energized trolley wire to come in contact with combustible material from the roof fall. The mine was evacuated. Water from fire hoses was eventually used to extinguish the fire.

On January 2, 1992, the metal cables in a slope belt were caught in a return roller causing it to stick and create heat. The belt caught fire and was extinguished with fire hoses.

On September 26, 1996, smoke was detected coming from a battery compartment of a personnel carrier parked in a charging station. A battery fault occurred causing a fire. It was extinguished using a fire hose.



Example of manifolds, fire hoses and nozzles commonly used.

## Best Practices Fire Protection

Card No. BFP-10



*HOSES AND NOZZLES should be stored properly, in sufficient quantities, and at easily accessible locations. Additional water hose for equipment operation can also be stored at or near fire hose storage locations to provide additional resources for fire fighting.*

### LOCATIONS

Portable Water Cars (300 feet of hose)  
Section Loading Point (Capable of reaching the face)  
Strategic Locations Along Belt Conveyors (500 feet of hose)

- **ALWAYS** standardize hose and pipe connections.
- **ALWAYS** install manifolds with multiple hose connections so that more than one hose can be used to attack a mine fire.
- **ALWAYS** install manifolds in the upright position upwind of the belt drive so a suppression system and a fire hose can be operated simultaneously.
- **ALWAYS** store short coiled lengths of fire hose for easy handling and transportation.
- **ALWAYS** use fire hose nozzles rated for the mine's water pressure.
- **ALWAYS** check for missing gaskets when connecting fire hose.
- **NEVER** travel over fire hose with a mine vehicle.
- **NEVER** drag fire hose over sharp objects.
- **NEVER** allow hose to become pinched between equipment and the mine floor.

U.S. Department of Labor  
Mine Safety and Health Administration