

> > Date: Thu, 19 Jan 2006 13:19:58 -0700
> > To: Debbie Finfrock <dfinfrock63@yahoo.com>
> > From: Steve Hanson <hanson@lanl.gov>
> > Subject: Re: Fwd: Sanitary Effluent Recycling Facility status
> > CC: bbeers@lanl.gov, vpw@lanl.gov, craig Douglass <craigd@lanl.gov>

> > Debbie -

> > The answers are given in the spaces you provided.

> > Steve

> > The SERF has not been operational (treating SWWS Plant effluent) since mid-June, 2005.

> > > > The DOE FY06 budget did not provide funding to operate the SERF. Only initially, funding was secured in November, 2005.

> > > > We expect hope to resume SERF operations: beginning of May, 2006 if there is an answer to that).

> > > > Therefore, the Metropolis Center has not been using recycled treated effluent for its cooling tower use since mid-June 2005.

> > > > The SWWS sends treated effluent to a 500Kgal tank at TA-3. The water flows from the tank to the outfall in Sandia Canyon. None of the effluent is sent to the Metropolis Center at this time.

> > > > IF I am mistaken in any of this, please straighten me out. Thanks very much and good luck during this transitional time!

> > > > Debbie

> > > > *****

> > > > Debbie J. Finfrock, P.E.
> > > > Finfrock Engineering
> > > > 24 Doc Holiday Rd.
> > > > Edgewood, NM 87015-8259
> > > > Phone and FAX (505) 286-6458
> > > > dfinfrock63@yahoo.com
> > > > www.finfro.com