

CO₂ Capture From *Existing* Coal-Fired Power Plants



Final Results

***Revised:
December 2007***

***Original Publication Date:
December 2006***

**Jared Ciferno
National Energy Technology Laboratory**



Disclaimer

This presentation was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference therein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed therein do not necessarily state or reflect those of the United States Government or any agency thereof.



Background—Scoping Study

Scoping Study Objectives:

1. Literature search on large-scale CO₂ capture from existing PC plants
2. Investigate all potential cost saving strategies
3. Explore definition of ‘optimal’ level of CO₂ recovery
4. Is there enough information available to calculate the optimal level of CO₂ recovery? If not, develop a plan for a more detailed study



Background—Fall 2005 Scoping Study

Question : Is there enough information in the literature to answer these questions?

Scoping Study Objectives:

1. Literature search on large-scale CO₂ capture from existing PC plants
2. Identify barriers to CO₂ capture retrofits
3. Investigate all potential cost saving strategies
4. Define 'optimal' level of CO₂ recovery
5. Is there enough information available to calculate the optimal level of CO₂ recovery? If not, develop a plan for a more detailed study



Background: Study 1

1991: EPRI/IEA/Fluor Daniel¹

- New 500 MW PC Plant
- Sensitivity Studies: 50% and 20% CO₂ capture on new plant
- Retrofit 500 MW PC plant using MEA with 90% CO₂ capture

	NEW				Retrofit*
CO ₂ Capture, %	0	90	50	20	90
Gross Power, MW	554	447	488	529	447
Auxiliary Power, MW	41	109	79	53	111
Heat Rate, Btu/kWh	9,800	14,900	12,300	10,600	15,000
Efficiency, %	35	23	28	32	23
COE, cents/kWh	4.2	9.3	7.2	5.7	10
Increase in COE, %	-	>100	71	36	>100



Source: *Engineering and Economic Evaluation of CO₂ Removal from Fossil-Fuel-Fired Power Plants*, IE-7365, Fluor Daniel, Irvine, CA., IEA, France, EPRI, Palo Alto, CA. (1991)

Background: Source 2

2001: DOE-NETL/Alstom Power

- Retrofit of AEP's Conesville Unit #5 (463 MW) plant via
1.) MEA scrubbing, 2.) Oxy-fuel combustion, 3.) MEA/MDEA scrubbing
- Minimum 90% flue gas CO₂ captured

Conclusions

- "...oxy-fuel most promising for 90% capture, but MEA and MEA/DEA scrubbing 'appears' to be cheaper at <90% capture levels..."
- "...specific investment costs are high, ranging from about **800 to 1800 \$/kW...**"
- "...all cases indicate significant increases to the COE as a result of CO₂ capture—about **6.2 cents/kWh** (2001\$)"



Source: Engineering Feasibility and Economics of CO₂ Capture on and Existing Coal-Fired Power Plant, DOE/NETL, Pittsburgh, PA., Alstom Power, Windsor, CT. (2000)

Background: Source 3

2004: Canadian Clean Coal Power Coalition/IEA GHG

- Objective: “To demonstrate that coal-fired electricity generation can effectively address all environmental issues projected in the future, including CO₂.”
- Evaluated amine scrubbing and oxy-fuel combustion for existing PC power plants and new power plants

Conclusions

- Identified significant opportunities to optimize amine scrubbing efficiency via heat integration---ONLY with a New Plant!
- “...during the course of Fluor’s studies it became apparent that retrofits would be less attractive than expected. Therefore, the later stages of the studies concentrated on greenfield applications for all technologies...”



Source: Canadian Clean Coal Power Coalition Studies on CO₂ Capture and Storage
IEA GHG, PH 4/27 (March 2004)

Background: Source 4

2004: Nexant for the CO₂ Capture Project (CCP)

- Cost reduction opportunities for an NGCC post-combustion retrofit system using advanced amines
- Identified 8 significant cost cutting ideas for NGCC retrofits

	1	2	BIT
CO₂ Capture, %	0	90	90
Net Power, MW	392	322	357
Efficiency, %	57.6	47.3	52.5
\$/tonne CO₂ Avoided	-	60 →	28.2

- Cost reduction is too impressive to be ignored
- Question is: Could some of Nexant's recommendations be applied to a retrofit PC power plant?



Source: CO₂ Capture Project: Post-Combustion “Best Integrated Technology” (BIT) Overview
Chinn, D. (Chevron Texaco), Eimer, D. (Norsk Hydro), Hurst, P. (BP), 2004 Carbon Sequestration Conference

Potential Cost Saving Strategies

Technology improvements in past 5-10 years

Potential Retrofit Options	Outcome/Notes
1. Heat Integration	↓ Steam Consumption
2. Minimize equipment needed	↓ Capital cost (ex. No flue gas cooler)
3. Lower cost of materials	↓ Capital cost (stainless vs. carbon steel)
4. Structured column packing	↓ Capital cost, ↓ Sorbent rate (ex. KS1)
5. Plate-and-frame HX	↓ Capital cost
6. ANSI Pumps vs. API Pumps	↓ Capital cost
7. Vapor-recovery system	↓ Steam Consumption
8. Large diameter absorbers	↓ # of Absorbers, ↓ Capital cost
9. Advanced solvents*	↓ Capital cost, ↓ Sorbent circ. rate (ex. KS1)
10. Lower re-boiler duty	↓ Steam Consumption

Example:

Current amines (MEA) require at least 1,600 Btu/lb CO₂ captured
 Fluor Econamine FG+ requires 1,300-1,400 Btu/lb CO₂ captured
 Mitsubishi's KS-1 solvent requires 1,200 Btu/lb CO₂ captured



Optimal versus Required CO₂ Removal

1. The capture rate that results in minimum \$/tonne CO₂ avoided or \$/ton CO₂ captured
2. Fraction CO₂ removed at specified COE or \$/tonne avoided
3. $\Delta\text{COE}_{\text{retrofit}} (x\% \text{ capture}) = \Delta\text{COE}_{\text{greenfield}} (90\% \text{ capture})$
4. Carbon tax—sufficient removal rate such that incremental COE equals the carbon tax




Scoping Study Conclusions

1. Minimal economic and performance data exists for CO₂ capture from *existing* pulverized coal power plants
2. Majority analyses focused on 90% CO₂ capture from **new** plants
3. Significant improvements in CO₂ scrubbing technologies in past 5-10 years
4. *Detailed Systems Analysis Recommended*



Carbon Sequestration From Existing Power Plants Feasibility Study

December 2005—December 2006



Randall Gas Technologies



Key Challenges CO₂ Retrofits

1. Regeneration steam availability—can steam turbine operate at part load?
2. Major equipment modifications or redundancy
3. Sulfur—additional deep sulfur removal required for most CO₂ sorbents
4. Space limitations—acres needed for current scrubbing
5. Make-up power—satisfy need to maintain baseload output
6. *Scheduling outages for CO₂ retrofits
7. *Post-retrofit dispatch implications due to increase in COE
8. *Retrofit triggering NSPS review
9. *Proposed legislation

*Outside the scope of this analysis



Detailed Systems Analysis Scope

1. Assess 30%, 50%, 70%, 90% and CO₂ capture levels
2. Employ scrubbing technology advances
3. Detailed steam turbine analysis by ALSTOM's steam turbine retrofit group
4. Employ CO₂ capture and compression heat integration
5. Site visits to specify exact equipment location
6. Include make-up power costs in economic analysis



Design Basis: Assumptions

Economic

Dollars (Constant)	2007
Depreciation (Years)	20
Equity (%)	55
Debt (%)	45
Tax Rate (%)	38
After-tax Weighted Cost of Capital (%)	9.67
Capital Charge Factor (%)	17.5
Capacity Factor (%)	85
Make-up Power Cost (¢/kWh)	6.40
CO ₂ Transport and Storage Costs	not included

Location: AEP Conesville Unit #5


- Total 6 units = 2,080 MWe
- Unit #5:
 - Subcritical steam cycle (2400psia/1005°F/1005°F)*
 - Constructed in 1976
 - 463 MW gross (~430 MW net)
 - ESP and Wet lime FGD (95% removal efficiency, 104 ppmv)

Mid-western bituminous coal

Ultimate Analysis (wt.%)	As Rec'd
Moisture	10.1
Carbon	63.2
Hydrogen	4.3
Nitrogen	1.3
Sulfur	2.7
Ash	11.3
Oxygen	7.1
HHV (Btu/lb)	11,293




Existing Plant Modifications



Modified FGD Process

1. Second stage absorber added to achieve 99.7% SO₂ removal efficiency (6.5 ppmv)
2. Estimated EPC cost for each case (30-90%) is \$20.5MM
3. includes an SO₂ Credit equal to \$608/ton in the Variable O&M cost



CO₂ Capture Process Key Parameters


Process Paramater	Units	2006	2001	AES Design
Plant Capacity	Ton/Day	9,350-3,120	9,888	200
CO ₂ Recovery	%	90-30	90	96
CO ₂ in Feed	mol %	12.8	13.9	14.7
SO ₂ in Feed	ppmv	10 (Max)	10 (Max)	10 (Max)
Solvent		MEA	MEA	MEA
Solvent Concentration	Wt. %	30	20	17-18
Lean Loading	mol CO ₂ /mol amine	0.19	0.21	0.10
Rich Loading	mol CO ₂ /mol amine	0.49	0.44	0.41
Steam Use	lbs Steam/lb CO ₂	1.67	2.6	3.45
Stripper Feed Temp	°F	205	210	194
Stripper Bottom Temp	°F	247	250	245
Feed Temp to Absorber	°F	115	105	108

Note: Additional data in “notes pages”

- [Reboiler operated at 45 psia—reduced from 65 psia used in 2000 study](#)
- Absorber contains two beds of structured packing




CO₂ Capture Process



Flue Gas Bypass

Bypass method determined to be least costly method to obtain lower CO₂ recovery levels



CO ₂ (Moles/hr)	Case 1 (90%)	Case 2 (70%)	Case 3 (50%)	Case 4 (30%)
FLUE GAS	19,680	19,680	19,680	19,680
BYPASS	0	4,374	8,746	13,120
ABSORBER FEED	19,680	15,306	10,934	6,560
STACK	1,962	5,924	9,846	13,770
CO ₂ PRODUCT	17,720	13,766	9,822	5,906
# Trains	2	2	2	1

CO₂ Capture, Compression, Dehydration, and Liquefaction

CO₂ compression to 2,015 psia, EOR specifications

Parameter	Wt %	Vol %	ppmv
Carbon Dioxide	96	94.06	940600
C ₂ + and Hydrocarbons	2	2.87	28700
Hydrogen Sulfide	1	1.27	12700
Nitrogen	0.6	0.92	9200
Methane	0.3	0.81	8100
Oxygen	0.03	0.04	400
Mercaptans and Other Sulfides	0.03	0.02	200
Moisture	0.006	0.01	100

Four Stage Process:


Compression → Drying → Refrigeration → Pumping



CO₂ Capture Compression, Dehydration and Liquefaction

1. Compression to 200 Psi

2. Drying to 100 ppmv H₂O



3. Refrigeration to -10°F

4. Pump to 2,015 Psia



CO₂ Capture Process Equipment

	2007 Study		2001 Study	
% CO ₂ Capture	90		96	
CO ₂ Capture Process	No.	ID/Height (ft)	No.	ID/Height (ft)
Absorber	2	34/126	5	27/126
Stripper	2	22/50	9	16/50
Distance from stack	100 ft		1,500 feet	
Heat Exchangers	No.		No.	
Reboilers	10		9	
Stripper CW Cond.	12		9	
Other Heat Exchangers	36		113	
Total Heat Exchangers	58		131	
CO ₂ Compressor	2		7	
Propane Compressor	2		7	
TIC Cost \$MM	370		670	

CO₂ scrubbing technology improvements lead to significant decrease in equipment requirements and capital cost!



Steam Turbine Modifications


Design Assumptions:

- 1. Existing turbine/generator required to operate at maximum load in case of a trip of the MEA plant**
 - All pressures to be within a level that no steam will be blown off
- 2. Feedwater system modifications to allow CO₂ capture and compression system heat integration**
 - CO₂ compressor intercoolers, stripper overhead cooler, refrigeration compressor cooler
- 3. Well within the LP turbine “lower load limit” after significant steam extraction for the 90% case (Conesville #5 instruction manual)**
- 4. New Let Down turbine vs. modifying existing LP turbine**



Steam Turbine Modifications

New Let Down Turbine





1. New LT output between 15 MW (30%) and 62 MW (90%)
2. EPC Cost ~ \$10MM for each case



Steam Turbine Modifications



Alternatives to LDT?

Retrofit solution for 30% Case




Potential solution by properly matching MEA plant requirements and retrofit design



New Equipment Locations Identified



Plot Plan (Absorber location)




Plot Plan – Let Down Turbine, Strippers, & CO₂ Compressors



Plant Performance


- Plant Electrical Output
- Plant Auxiliary Power
- Plant Thermal Efficiency
- Plant CO₂ Emissions

Power Output Distribution




Base load (Net) Output Impact

Losses to Grid



Plant Thermal Efficiency (HHV Basis)



Summary Performance Results

	Base	2001	2006 Study			
% CO ₂ Capture	0	96	90	70	50	30
Gross Power (MW)	463	331	388	406	424	441
Base Plant Load	30	30	30	30	30	30
Gas Cleanup/CO ₂ Capture	-	8	12	9	7	4
CO ₂ Compression	-	42	43	34	23	14
Total Aux. Power (MW)	30	80	85	73	60	48
Net Power (MW)	433	251	303	333	363	392
Heat Rate (Btu/kWh)	9,749	16,875	13,984	12,719	11,670	10,796
Efficiency (HHV)	35	20	24	27	29	32
Energy Penalty¹	-	15	11	8	6	3


¹CO₂ Capture Energy Penalty = Percent points decrease in net power plant efficiency due to CO₂ Capture

Note: 12% Capture penalty for a new sub-critical plant with MEA Capture
8% Capture penalty for a new super-critical plant with MEA Capture


5% Efficiency Improvement




CO₂ Emissions



CO₂ Captured and Emitted



CO₂ Avoided Emissions



Economics

- Capital Costs
- Incremental COE
- Mitigation Costs
- Sensitivity Analyses

Plant Retrofit Capital Costs

EPC Costs (\$1000's)	2001	2007 Study			
% CO ₂ Capture	96	90	70	50	30
CO ₂ Capture & Compression	668,277	368,029	333,406	249,490	181,070
Flue Gas Desulfurization	22,265	22,265	22,265	22,265	22,265
Letdown Steam Turbine	10,516	9,800	9,400	8,900	8,500
Boiler Modifications	0	0	0	0	0
Total Retrofit Costs	701,057	400,094	365,070	280,655	211,835
New Net Output (kW)	251,634	303,317	333,245	362,945	392,067
\$/kW-New Net Output	2,786	1,319	1,095	773	540
\$/kW-Original Net Output*	1,616	922	842	647	488


*Original net output = 433,778 kW

53% Reduction in Incremental Capital Costs



Note: Capital costs from 2001 study were escalated to July 2006 dollars

Economic Results



Note:

Make-up power assessed at 6.40 ¢/kWh


Economic results from 2001 study were escalated to 2006 dollars

Variable O&M cost includes SO₂ Credit at \$608/ton




Economic Results

Cost for Reducing Emissions




Economic Results

CO₂ Avoided Cost



Economic Results

CO₂ Captured Cost



Conclusions

1. No major technical barriers found
2. Compared to the 2001 study, this study with an advanced amine (90% CO₂ Capture case) showed:
 - **Marked improvement in energy penalty and reduction in cost**
3. No Sweet Spot—near linear decrease in incremental COE with reduced CO₂ capture level
4. Sufficient results to answer various definitions of “optimal CO₂ capture” from existing plants

NETL Contact

Jared Ciferno

Office of Systems Analysis and Planning

(412) 386 – 5862

jared.ciferno@netl.doe.gov

