





A 0001781

<p>ENGINEERING DIVISION Permit Review Sheet</p>	<p>SUBJECT: Req by Noah Pritchard to install concrete steps over Citrus laekfront levee at New Orleans</p>
<p>LMN <u>1</u> ED-A</p>	<p>SR. No objection relative to relocation of HC - No Objection </p>
<p>SUSPENSE: * <u>7 June</u> <u>2</u> ED-S  ED-SP ED-SR <u>285</u> ED-SD</p>	<p>ED-FS No Objection provided concrete steps are placed and maintained above the net levee section. 6/14/89 JR</p>
<p>SUSPENSE: * <u>12 June</u> <u>3</u> ED-H  ED-HD <u>✓</u> ED-HC  ED-IHH</p>	
<p>SUSPENSE: * <u>16 June</u> <u>4</u> ED-F ED-FG ED-FD <u>✓</u> ED-FS</p>	
<p>SUSPENSE: * <u>5</u> ED-D ED-DL ED-DW ED-DR ED-DD ED-DG</p>	
<p>*If suspense date cannot be met, furnish Secretary, Chief of Eng Div, the date it can be met.</p>	<p>Continue comments on separate sheet if necessary</p>

 **FILE**

CELMN-OD-05(11-2-240a)

2, JUNE 1989


MEMORANDUM FOR C/ENGR DIV

SUBJECT: REQUEST BY NOAH PRITCHARD TO INSTALL CONCRETE STEPS
OVER THE CITRUS LAKEFRONT LEVEE, VICINITY OF LEVEE STATION
322+52, AT NEW ORLEANS, LOUISIANA, IN ORLEANS PARISH.

1. Forwarded for review, comment, and return.
2. If further assistance is needed, please contact John J. Flanagan, ext 2238.

89-257

Encl
ltr dtd 31 May 89
w/dwg


HENRY R. SCHORR
CHIEF, OPERATIONS AND
READINESS DIVISION

MAY 8, 1989

MR. ALAN FRANCIQUES
ASST. CHIEF ENGINEER
ORLEANS LEVEE BOARD
SUITE 202, ADMINISTRATION BLDG.
NEW ORLEANS LAKEFRONT AIRPORT
NEW ORLEANS, LA. 70126

DEAR SIR,

WE HEREBY APPLY FOR A PERMIT TO BUILD CEMENT STEPS OVER THE
LEVEE AT STATION NO. 322+52. WE PLAN TO BUILD STEPS ACCORDING
TO SPECS OF ENCLOSED BLUEPRINT.

PLEASE REVIEW OUR APPLICATION AND CONFIRM YOUR APPROVAL AT YOUR
EARLIEST CONVENIENCE.

REGARDS



NOAH R. PRITCHARD
2913 DEBOUCHEL BLVD.
MERAUX, LA. 70075
277-1445 (HOME)
582-2362 (WORK)

MAY 31, 1989

MR. WAYNE BOURN
U.S. ARMY CORPS OF ENGINEERS
OPERATIONS AND READINESS
NEW ORLEANS DISTRICT
P.O. BOX 60267
NEW ORLEANS, LA. 70160-0267

DEAR MR. BOURN,

I ENCLOSE FOR YOUR REVIEW COPIES OF A LETTER TO MR. FRANCIQUES,
ASST. CHIEF ENGINEER WITH THE ORLEANS LEVEE BOARD DATED ON MAY 8,
1989 ALONG WITH A COPY OF HIS LETTER IN RESPONSE DATED MAY 10, 1989.

CONSIDERING CURRENT CIRCUMSTANCES WHEREAS ORLEANS LEVEE BOARD
CURRENTLY DOES NOT HAVE JURISDICTION OVER THE LEVEE I REQUEST THAT
YOU REVIEW BOTH LETTERS AND CONFIRM BY RETURN MAIL YOUR APPROVAL TO
CONSTRUCT STEPS OVER THE LEVEE ACCORDING TO ORLEANS LEVEE BOARD
SPECS/BLEUPRINT AND APPROVAL.

I WOULD VERY MUCH APPRECIATE YOUR PROMPT RESPONSE.

THANKS AND REGARDS



NOAH R. PRITCHARD
2913 DEBOUCHEL BLVD.
MERAUX, LA. 70075
277-1445 (HOME)
582-2362 (WORK)

CC: MR. ALAN FRANCIQUES
MS. GENEVA P. GRILLE

The Board of Commissioners

OF THE

Orleans Levee District

SUITE 202 — ADMINISTRATION BUILDING
NEW ORLEANS LAKEFRONT AIRPORT

New Orleans, La.

70126

May 10, 1989



Mr. Noah R. Pritchard
2913 Debouchel Boulevard
Meraux, LA 70075

RE: Steps Over the Citrus Lakefront Levee

Dear Mr. Pritchard:

I am in receipt of your letter dated May 8, 1989, requesting permission to install concrete steps over the above captioned levee to access your camp on the lake side of the levee.

Please be informed that as of this date the Orleans Levee Board has not accepted the work as performed by the U. S. Army Corps of Engineers for the raising of the levee. As such the Corps of Engineers has jurisdiction over the levee.

The Orleans Levee Board is the agency responsible for issuing permits for this type of work to be done on our levees. However, in this instance, approval must be received from the U. S. Army Corps of Engineers. It is noted that the drawing you submitted with your request is the standard Levee Board drawing, #LD-4191, for "Concrete Step Walk Over the Levee". The Orleans Levee Board has no objection to the drawing you plan to use.

I must also point out that a permit from the Louisiana Department of Transportation and Development must be obtained in addition to that received from the U. S. Army Corps of Engineers. Please submit your letter and sketch to Ms. Geneva P. Grille, P. E., District Design, Water Resources and Development Engineer, 7252 Lakeshore Drive, New Orleans, LA 70124-2498 and Mr. Wayne Bourn, Operations and Readiness, U. S. Army Corps of Engineers, New Orleans District, P. O. Box 60267, New Orleans, LA 70160-0267.

If I can be of further assistance, please call me at 246-4000, ext. 187.

Sincerely,





Alan U. Francinques
Assistant Chief Engineer

AJF:lah


xc: Mr. H. B. Lansden
Mr. Richard J. McGinity
Mr. C. E. Bailey
Ms. Geneva Grille
Mr. Wayne Bourn

NOTES

- 1: CONCRETE SHALL BE 6 BAGS OF CEMENT PER CU YD. & CONFORM TO A.S.T.M. DESIGNATION C94 & CONCRETE DELIVERY TICKETS INDICATING THIS MUST BE FURNISHED TO THE C.E.M. ENGINEER.
- 2: IF STEPS ARE POURED INDEPENDENTLY OF THE CONC. APRONS, DEFORMED ERIE RODS SHALL EXTEND 12" TO STEPS & APRONS & SHALL BE SPACED 24" O.C.
- 3: ANY ADDITIONAL CONST. BETWEEN THE LAKE SIDE BOTTOM STEPS & THE SOUTHER R.R. TRACKS, REQUIRES PERMISSION FROM THEM & A SEPARATE PERMISSION FROM THE LEVEE BOARD.
- 4: REINFORCEMENT FOR STEPS & SLOPE PAYMENT SHALL BE 6X 6-4/8 WIRE MESH WEIGHING 42 LBS./100 SQ FT



DETAIL OF STEP CONSTRUCTION



LEVEE CURVEMENT DETAILS

BOARD OF LEVEE COMMISSIONERS
 ORLEANS LEVEE DISTRICT
 CITRUS LAKEFRONT LEVEE
 CONCRETE STEP WALK OVER LEVEE
 JAN 11 1951
 CHIEF ENGINEER
 2191