



**CITY OF ALVIN**

216 W. Sealy • Alvin, Texas 77511 • (281) 388-4200 • FAX (281) 331-7215

October 26, 2001

RECEIVED

OCT 29 2001

TWDB R&PF  
GRANTS MANAGEMENT

Mr. Craig D. Pederson  
Executive Administrator  
Texas Water Development Board  
1700 N. Congress Avenue, Room 513  
P.O. Box 13231, Capital Station  
Austin, Texas 78701

Re: Regional Facility Planning Grant Contract between City of Alvin and the Texas Water Development Board, TWDB Contract No. 2001-483-367, FINAL REPORT Entitled "Regional Surface Water Plant Feasibility Study for Mid-Brazoria County Planning Group"

Dear Mr. Pederson:

Per the City of Alvin's contract with the Texas Water Development Board, enclosed is the FINAL REPORT of the Regional Surface Water Plant Feasibility Study for Mid-Brazoria County Planning Group. As required by the terms of the contract, the following are submitted:

- One (1) electronic copy,
- One (1) unbound single-sided camera-ready original, and
- Nine (9) bound double-sided copies

If you have any questions, please contact me at 281-388-4231.

Sincerely,

Paul A. Hofmann  
City Manager

PAH:lh  
Enclosures

RECEIVED

OCT 29 2001

TWDB R&PF  
GRANTS MANAGEMENT

# Table of Contents

## EXECUTIVE SUMMARY

|   |       |
|---|-------|
| Scope .....                                   | ES-1  |
| Background .....                              | ES-2  |
| Water Demand.....                             | ES-2  |
| Facility Demand.....                          | ES-3  |
| Take Points.....                              | ES-4  |
| Alternative Analysis .....                    | ES-5  |
| Water Treatment Plant Treatment Process ..... | ES-5  |
| Preliminary Water Plant Locations.....        | ES-6  |
| Raw Water .....                               | ES-7  |
| Finished Water Transmission .....             | ES-8  |
| Economic Evaluation .....                     | ES-8  |
| Capital Cost .....                            | ES-8  |
| Operation and Maintenance Costs .....         | ES-9  |
| Present Worth Analysis.....                   | ES-10 |
| GCWA Regional Water Plant Alternative.....    | ES-10 |
| Non-Economic Evaluation.....                  | ES-11 |
| Facility Plan .....                           | ES-11 |
| Conclusions .....                             | ES-12 |
| Recommendations .....                         | ES-12 |

## SECTION 1: INTRODUCTION

|                               |     |
|-------------------------------|-----|
| Background .....              | 1-1 |
| Surface Water Advantages..... | 1-1 |
| Study Purpose.....            | 1-2 |
| Scope of Facility Plan.....   | 1-2 |
| Planning Area.....            | 1-2 |
| Available Surface Water ..... | 1-2 |



# Table of Contents

---

## SECTION 2: PLANNING AREA EXISTING ENVIROSTRUCTURE

|   |            |
|---|------------|
| <b>Water Source and Supply</b> .....                      | <b>2-1</b> |
| Surface Water.....  | 2-1        |
| Groundwater.....  | 2-1        |
| Surface Water Rights.....                                 | 2-1        |
| <b>Mid-Brazoria Existing Facilities Description</b> ..... | <b>2-2</b> |
| City of Manvel .....                                      | 2-2        |
| City of Brookside Village .....                           | 2-3        |
| City of Pearland .....                                    | 2-3        |
| City of Alvin .....                                       | 2-3        |
| City of Hillcrest Village .....                           | 2-5        |
| City of Danbury .....                                     | 2-5        |
| City of Angleton.....                                     | 2-5        |
| City of Iowa Colony .....                                 | 2-5        |

## SECTION 3: REGIONAL WATER SUPPLY

|   |            |
|---|------------|
| <b>Projected Potable Water Demand</b> .....                                       | <b>3-1</b> |
| Current Population and Water Usage.....   | 3-1        |
| Projected Population and Water Usage.....   | 3-1        |
| Participating Utility Projected Population .....                                  | 3-1        |
| Water Demand Projection .....   | 3-2        |
| <b>Average and Peak Day Demand</b> .....  | <b>3-5</b> |
| Water Plant Capacity .....  | 3-5        |
| Selecting the Appropriate Level of Groundwater Usage<br>in the Planning Area..... | 3-5        |
| Assumptions .....   | 3-7        |
| Water Treatment Plant Reserve Capacity .....                                      | 3-8        |
| Water Treatment Plant Capacity Phasing.....                                       | 3-8        |



# Table of Contents

---

|  |             |
|--|-------------|
| Water Treatment Plant Capacity and Construction          |             |
| Recommendation.....                                      | 3-10        |
| <b>Raw Water Source .....</b>                            | <b>3-10</b> |
| Brazos River .....                                       | 3-10        |
| Other Sources.....                                       | 3-10        |
| Trinity River Basin.....                                 | 3-11        |
| Brackish Groundwater .....                               | 3-11        |
| Raw Water Demand .....                                   | 3-11        |
| <b>SECTION 4: DEVELOPMENT OF TREATMENT PROCESS</b>       |             |
| <b>Water Quality.....</b>                                | <b>4-1</b>  |
| Regional Raw Water Quality for Brazos River- .....       | 4-1         |
| Federal and State Standards .....                        | 4-1         |
| <b>Finished Water Quality Goals .....</b>                | <b>4-5</b>  |
| <b>Treatment Process.....</b>                            | <b>4-6</b>  |
| High Rate Conventional Process .....                     | 4-6         |
| <b>Process Criteria .....</b>                            | <b>4-7</b>  |
| Water Treatment Process Costs.....                       | 4-10        |
| <b>SECTION 5: WATER TREATMENT PLANT SITE DEVELOPMENT</b> |             |
| <b>Approach to Site Selection .....</b>                  | <b>5-1</b>  |
| Establishment of Preliminary Siting Criteria .....       | 5-1         |
| Estimated Minimum Acreage Required for a                 |             |
| Water Plant.....   | 5-1         |
| Proximity to the Water Source and Distribution System    | 5-1         |
| Site Surface Features .....                              | 5-2         |
| Proximity to major highways and utilities.....           | 5-2         |
| Identify Candidate Sites .....                           | 5-2         |
| Preliminary Screening.....                               | 5-3         |

# Table of Contents

---

|  |     |
|--|-----|
| Evaluation of Minimum Acreage Requirements .....                                       | 5-3 |
| Evaluation of Proximity of Site to Raw Water Source and<br>Finished Water Demand ..... | 5-4 |
| Proximity of Site to Raw Water Source .....  | 5-4 |
| Proximity of Site to Finished Water Demand .....                                       | 5-4 |
| Evaluation of Site Surface Features .....  | 5-5 |
| Proximity to Major Highway and Utilities .....   | 5-5 |
| Land Ownership .....   | 5-5 |
| Sites Selected for Further Review .....  | 5-6 |

## **SECTION 6: FINISHED AND RAW WATER TRANSMISSION**

|  |            |
|--|------------|
| <b>Finished Water Pipeline .....</b>             | <b>6-1</b> |
| Finished Water Source .....                      | 6-1        |
| Pipeline Corridor Analysis .....                 | 6-1        |
| Take Points .....                                | 6-2        |
| Manvel WTP Site Pipeline Corridor Analysis ..... | 6-3        |
| North Line .....                                 | 6-2        |
| East Corridor .....                              | 6-4        |
| South Corridor .....                             | 6-5        |
| Connection to Iowa Colony .....                  | 6-5        |
| Connection to Angleton and Danbury .....         | 6-6        |
| Alvin WTP Site Pipeline Corridor Analysis .....  | 6-6        |
| North Line .....                                 | 6-6        |
| West Corridor .....                              | 6-7        |
| Connection to Manvel .....                       | 6-7        |
| Connection to Iowa Colony .....                  | 6-8        |
| South Corridor .....                             | 6-9        |
| Connection to Danbury and Angleton .....         | 6-9        |



# Table of Contents

---

|  |             |
|--|-------------|
| <b>Modeling and Pipeline Layout Descriptions.....</b>        | <b>6-11</b> |
| Hydraulic Model .....  | 6-11        |
| Model Assumptions and Layout.....                            | 6-11        |
| Model Results .....  | 6-12        |
| System Storage and Booster Pump Requirements .....           | 6-14        |
| <b>Capital Costs .....</b>                                   | <b>6-16</b> |
| Operating and Maintenance Costs .....                        | 6-17        |
| Alternative Selection .....                                  | 6-18        |
| <b>Raw Water Delivery Systems .....</b>                      | <b>6-18</b> |
| Requirements.....  | 6-19        |
| Raw Water Sources .....                                      | 6-19        |
| Gulf Coast Water Authority .....                             | 6-19        |
| Chocolate Bayou Water Company.....                           | 6-19        |
| Brazos River Authority .....                                 | 6-20        |
| Costs.....   | 6-20        |
| Capital Costs.....   | 6-20        |
| Operating and Maintenance Costs .....                        | 6-20        |
| <b>SECTION 7: ALTERNATIVE SELECTION</b>                      |             |
| <b>Alternative Selection Process.....</b>                    | <b>7-1</b>  |
| Facility Plan Cost Assumptions and Economic Analysis         |             |
| Methodology .....  | 7-1         |
| Capital Costs.....   | 7-2         |
| Construction.....  | 7-2         |
| Engineering.....   | 7-2         |
| Contingency.....   | 7-2         |
| Operating and Maintenance Costs .....                        | 7-3         |
| <b>Water Treatment Plant Site Alternative Analysis .....</b> | <b>7-3</b>  |



# Table of Contents

---

|   |             |
|---|-------------|
| Non-Economic Factors .....                                    | 7-3         |
| Public Acceptance .....                                       | 7-3         |
| Expandability.....  | 7-4         |
| Reliability.....  | 7-4         |
| Environmental Impacts .....                                   | 7-4         |
| Permitting.....   | 7-4         |
| Summary.....  | 7-6         |
| Alternative Water Plant Scenario Costs.....                   | 7-6         |
| Raw Water Conveyance Improvements .....                       | 7-6         |
| Finished Water Transmission .....                             | 7-7         |
| Water Treatment Plant Cost .....                              | 7-8         |
| Land.....   | 7-9         |
| Other Economic Consideration .....                            | 7-9         |
| Present Worth Cost Summary .....                              | 7-10        |
| Raw Water Conveyance System .....                             | 7-10        |
| Site Selection and Finished Water Transmission .....          | 7-11        |
| Project Present Worth Costs.....                              | 7-11        |
| <b>Alternative Well Option.....</b>                           | <b>7-12</b> |
| <b>Recommendations of Water Plant Facility Locations.....</b> | <b>7-13</b> |

## SECTION 8: FACILITY PLAN

|  |            |
|--|------------|
| <b>Regional Operating Strategy.....</b>  | <b>8-1</b> |
| <b>Capital Improvement Program.....</b>  | <b>8-1</b> |
| <b>Facilities Description.....</b>       | <b>8-1</b> |
| Water Treatment Plant.....               | 8-2        |
| Raw Water Delivery System .....          | 8-2        |
| Finished Water Transmission System ..... | 8-3        |

# Table of Contents

---

|   |            |
|---|------------|
| Water Treatment Plant Operations .....                                    | 8-3        |
| Staffing Plan .....   | 8-3        |
| Operations Control.....   | 8-4        |
| <b>UTILITY SERVICE CONCEPTS.....</b>                                      | <b>8-4</b> |
| Electrical .....  | 8-4        |
| Sanitary.....   | 8-4        |
| Sludge Processing .....   | 8-4        |
| Transportation.....   | 8-4        |
| Storm Sewer Management .....  | 8-5        |
| <b>OPINION OF PROBABLE COSTS.....</b>                                     | <b>8-5</b> |
| Construction.....   | 8-5        |
| Operating and Maintenance.....  | 8-7        |
| Funding Mechanism.....  | 8-7        |
| Resource Management Authority.....  | 8-7        |
| <br>  |            |
| <b>SECTION 9: PROJECTED WHOLESALE RATES</b>                               |            |
| <b>OPINION OF PROBABLE COSTS.....</b>                                     | <b>9-1</b> |
| <b>OPINION OF PROBABLE COSTS.....</b>                                     | <b>9-1</b> |
| <br>  |            |
| <b>APPENDIX A: Bibliography</b>   |            |
| <b>APPENDIX B: Resource Management Plan</b>                               |            |
| <b>APPENDIX C: TWDB Population and Water Use Projections</b>              |            |
| <b>APPENDIX D: Treatment Plant Design Criteria and Preliminary Sizing</b> |            |
| <b>APPENDIX E: TC&amp;B Alternative Water Supply Study Report</b>         |            |
| <b>APPENDIX F: Treatment Process Capital and O&amp;M Costs</b>            |            |
| <b>APPENDIX G: TWDB Region H Cost Estimation Schedules</b>                |            |
| <b>APPENDIX H: Modified Region H Raw Water Alternative Costs</b>          |            |





# Table of Contents

---

**APPENDIX I: Raw Water Capital and O&M Costs**

**APPENDIX J: Finished Water Transmission and O&M Costs**

**APPENDIX K: Water Well Alternative Cost**

**APPENDIX L: Progress Meetings**

**APPENDIX M: Correspondence with State Regulatory Authorities**

**APPENDIX N: Comments from State Agencies**

**APPENDIX O: Hydraulic Modeling Results**



# List of Tables

---

|                   |  |              |
|-------------------|--|--------------|
| <b>Table ES-1</b> | <b>Planning Area Surface Water Demand .....</b>  | <b>ES-4</b>  |
| <b>Table ES-2</b> | <b>Requested Flow at Utility Take Points.....</b>  | <b>ES-5</b>  |
| <b>Table ES-3</b> | <b>Capital Expenditure (YR 2000 \$).....</b>   | <b>ES-9</b>  |
| <b>Table ES-4</b> | <b>Annual O&amp;M (YR 2000 \$).....</b>  | <b>ES-10</b> |
| <b>Table ES-5</b> | <b>Plant Site Alternatives Present Worth Summary<br/>(YR 2000 \$) .....</b>                                | <b>ES-10</b> |
| <b>Table ES-6</b> | <b>Facility Plan Capital Costs.....</b>  | <b>ES-11</b> |
| <b>Table 2-1</b>  | <b>Existing Water Permits on Lower Brazos River.....</b>   | <b>2-2</b>   |
| <b>Table 2-2</b>  | <b>City of Pearland Pump Station Information.....</b>  | <b>2-3</b>   |
| <b>Table 2-3</b>  | <b>City of Alvin Water Wells.....</b>  | <b>2-4</b>   |
| <b>Table 2-4</b>  | <b>City of Alvin Water Plant No. 3 .....</b>   | <b>2-4</b>   |
| <b>Table 2-5</b>  | <b>City of Alvin Water Plant No. 4 .....</b>   | <b>2-4</b>   |
| <b>Table 2-6</b>  | <b>City of Alvin Water Plant No. 5 .....</b>   | <b>2-5</b>   |
| <b>Table 2-7</b>  | <b>Existing Infrastructure Review .....</b>  | <b>2-6</b>   |
| <b>Table 3-1</b>  | <b>Year 2000 Population and Average Water<br/>Demand .....</b>   | <b>3-1</b>   |
| <b>Table 3-2</b>  | <b>Projected Population for Participating Utilities<br/>in Planning Area .....</b>                         | <b>3-2</b>   |
| <b>Table 3-3</b>  | <b>Projected Average Water Demand (MGD) for Participating<br/>Utilities in Planning Area .....</b>         | <b>3-2</b>   |
| <b>Table 3-4</b>  | <b>Safety Factors used for Participating Utilities .....</b>   | <b>3-4</b>   |
| <b>Table 3-5</b>  | <b>Projected Modified Average Water Demand (MGD) for<br/>Participating Utilities in Planning Area.....</b> | <b>3-4</b>   |
| <b>Table 3-6</b>  | <b>Peak Daily to Average Daily Flow Peaking Factors and Peak<br/>Demands .....</b>                         | <b>3-5</b>   |
| <b>Table 3-7</b>  | <b>Participating Utility Existing Groundwater Production<br/>Capacity versus existing Demand .....</b>     | <b>3-6</b>   |

# List of Tables

---

|                   |  |             |
|-------------------|--|-------------|
| <b>Table 3-8</b>  | <b>Participating Utility water capacity needs.....</b>   | <b>3-7</b>  |
| <b>Table 3-9</b>  | <b>Reserve Surface Water Treatment Plant Capacity (MGD)....</b>  | <b>3-8</b>  |
| <b>Table 3-10</b> | <b>Surface Water Treatment Plant Demand .....</b>  | <b>3-9</b>  |
| <b>Table 4-1</b>  | <b>Summary of Raw Water Quality .....</b>  | <b>4-2</b>  |
| <b>Table 4-2</b>  | <b>Summary of Federal and State Standards.....</b>   | <b>4-3</b>  |
| <b>Table 4-3</b>  | <b>Summary of Treatment Goals.....</b>   | <b>4-5</b>  |
| <b>Table 4-4</b>  | <b>Criteria for Sizing Water Treatment Processes .....</b>   | <b>4-8</b>  |
| <b>Table 4-5</b>  | <b>Chemical Feed Criteria.....</b>   | <b>4-9</b>  |
| <b>Table 4-6</b>  | <b>Alternative Process Construction Cost Estimate<br/>(YR 2000 \$) .....</b>                                     | <b>4-10</b> |
| <b>Table 4-7</b>  | <b>High Rate Conventional Process O&amp;M Cost Estimate<br/>(YR 2000 \$) .....</b>                               | <b>4-11</b> |
| <b>Table 5-1</b>  | <b>Potential Water Treatment Plant Sites.....</b>  | <b>5-3</b>  |
| <b>Table 5-2</b>  | <b>Proximity of Site to Finished Water Demand .....</b>  | <b>5-5</b>  |
| <b>Table 6-1</b>  | <b>Participating Utility Take Point Information .....</b>  | <b>6-3</b>  |
| <b>Table 6-2</b>  | <b>Manvel North Pipeline Corridor Analysis .....</b>   | <b>6-4</b>  |
| <b>Table 6-3</b>  | <b>Alvin North Pipeline Corridor Analysis.....</b>   | <b>6-7</b>  |
| <b>Table 6-4</b>  | <b>Alvin West Pipeline Corridor Analysis.....</b>  | <b>6-9</b>  |
| <b>Table 6-5</b>  | <b>Alvin South Pipeline Corridor Analysis .....</b>  | <b>6-10</b> |
| <b>Table 6-6</b>  | <b>Model Results for At System Pressure Alternative .....</b>  | <b>6-12</b> |
| <b>Table 6-7</b>  | <b>Model Results for At Ground Storage Tank Delivery<br/>Alternative.....</b>                                    | <b>6-13</b> |
| <b>Table 6-8</b>  | <b>Pump Station Model Results .....</b>  | <b>6-14</b> |
| <b>Table 6-9</b>  | <b>Required Regional Ground Storage Tank Volume (MGD)...</b>   | <b>6-15</b> |
| <b>Table 6-10</b> | <b>Participating Utilities Required GST Volume Under Delivery<br/>to Ground Storage Tank Scenario (MGD).....</b> | <b>6-15</b> |
| <b>Table 6-11</b> | <b>Finished Water Delivery Construction Costs.....</b>   | <b>6-16</b> |



# List of Tables

---

|                   |  |             |
|-------------------|--|-------------|
| <b>Table 6-12</b> | <b>Finished Water Transmission Construction Estimate<br/>(YR 2000 \$) .....</b>                                | <b>6-17</b> |
| <b>Table 6-13</b> | <b>Annual O&amp;M Estimate for Finished Water Transmission<br/>Systems in the Year 2050 (YR 2000 \$) .....</b> | <b>6-18</b> |
| <b>Table 6-14</b> | <b>Raw Water Conveyance Alternative Construction Costs<br/>(YR 2000 \$) .....</b>                              | <b>6-21</b> |
| <b>Table 6-15</b> | <b>Raw Water Conveyance Annual O&amp;M Costs (YR 2000 \$)....</b>  | <b>6-22</b> |
| <b>Table 7-1</b>  | <b>Non-Economic Criteria Weights.....</b>  | <b>7-4</b>  |
| <b>Table 7-2</b>  | <b>Non-Economic Selection Matrix.....</b>  | <b>7-6</b>  |
| <b>Table 7-3</b>  | <b>Raw Water Improvement Construction and O&amp;M Costs<br/>(YR 2000 \$) .....</b>                             | <b>7-7</b>  |
| <b>Table 7-4</b>  | <b>Finished Water Construction and O&amp;M Costs In 1000 \$<br/>(YR 2000 \$) .....</b>                         | <b>7-8</b>  |
| <b>Table 7-5</b>  | <b>Water Treatment Plant Construction and O&amp;M Costs<br/>(YR 2000 \$) .....</b>                             | <b>7-9</b>  |
| <b>Table 7-6</b>  | <b>Site Acquisition Costs.....</b>   | <b>7-9</b>  |
| <b>Table 7-7</b>  | <b>Raw Water Conveyance Alternatives Present Worth<br/>Summary (YR 2000 \$).....</b>                           | <b>7-10</b> |
| <b>Table 7-8</b>  | <b>Plant Site Alternatives Present Worth Summary<br/>(YR 2000 \$) .....</b>                                    | <b>7-11</b> |
| <b>Table 7-9</b>  | <b>Plant Site Alternatives Present Worth Summary<br/>(YR 2000 \$) .....</b>                                    | <b>7-11</b> |
| <b>Table 7-10</b> | <b>Construction and O&amp;M Cost for Alternative Well Option<br/>(YR 2000 \$) .....</b>                        | <b>7-12</b> |
| <b>Table 7-11</b> | <b>Total Present Worth Cost Comparison (YR 2000 \$) .....</b>  | <b>7-12</b> |
| <b>Table 8-1</b>  | <b>Requested Flow at Utility Take Points.....</b>  | <b>8-3</b>  |
| <b>Table 8-2</b>  | <b>Preliminary Opinion of Probable Construction Costs.....</b>   | <b>8-6</b>  |

# List of Tables

---

**Table 8-3**      **Preliminary Opinion of Annual O&M Costs.....8-7**

**Table 9-1**      **Estimated Wholesale Water Rate (\$/1000 Gallons) initial 15  
                         MGD phase – Year 2010 .....9-2**

**Table 9-2**      **Estimated Wholesale Water Rate (\$/1000 Gallons) 10 MGD  
                         expansion – Year 2030 .....9-2**

**Table 9-3**      **Estimated Wholesale Water Rate (\$/1000 Gallons) initial 15  
                         MGD phase – Year 2010 .....9-3**

**Table 9-4**      **Estimated Wholesale Water Rate (\$/1000 Gallons) 10 MGD  
                         expansion – Year 2030 .....9-4**

# List of Figures

---

|             |   | Behind or<br>on Page |
|-------------|---|----------------------|
| Figure ES-1 | Facility Planning Area .....  | ES-2                 |
| Figure ES-2 | Water Demand and Population Projection for the Planning<br>Area.....  | ES-3                 |
| Figure ES-3 | Finished Water Demand Areas.....                                      | ES-4                 |
| Figure ES-4 | Water Treatment Plant Economics (YR 2000).....                        | ES-6                 |
| Figure ES-5 | Water Treatment Plant Sites.....                                      | ES-6                 |
| Figure ES-6 | Raw Water Delivery Alternatives .....                                 | ES-7                 |
| Figure ES-7 | Raw Water Alternative Present Worth Cost (YR 2000 \$)....             | ES-7                 |
| Figure ES-8 | Plant Site Layout.....  | ES-11                |
| Figure 1-1  | Facility Planning Area .....  | 1-2                  |
| Figure 3-1  | Water Demand and Population Projection for the Planing<br>Area.....   | 3-2                  |
| Figure 3-2  | Region H Per Capita Water demands .....                               | 3-4                  |
| Figure 3-3  | Two Phase 25 MGD Regional Water Treatment Plant .....                 | 3-9                  |
| Figure 4-1  | High-Rate Conventional Process Schematic .....                        | 4-6                  |
| Figure 5-1  | Water Treatment Plant Sites.....                                      | 5-2                  |
| Figure 5-2  | Finished Water Demand Areas.....                                      | 5-4                  |
| Figure 5-3  | Manvel Water Treatment Plant Site.....                                | 5-6                  |
| Figure 5-4  | Alvin Water Treatment Plant Site .....                                | 5-6                  |
| Figure 6-1  | Take Points-North Brazoria County .....                               | 6-2                  |
| Figure 6-2  | Take Points-South Brazoria County.....                                | 6-2                  |
| Figure 6-3  | Pipeline Corridors from Manvel Site to North Brazoria<br>County ..... | 6-3                  |
| Figure 6-4  | Pipeline Corridors from Manvel Site to South Brazoria<br>County ..... | 6-5                  |

# List of Figures

---

|             |   | Behind or<br>on Page |
|-------------|---|----------------------|
| Figure 6-5  | Pipeline Corridors from Alvin Site to North Brazoria<br>County .....                                      | 6-7                  |
| Figure 6-6  | Pipeline Corridors from Alvin Site to South Brazoria<br>County .....                                      | 6-10                 |
| Figure 6-7  | Finished Water Pipeline Modeling Results from Site A in<br>Manvel at Pressure .....                       | 6-12                 |
| Figure 6-8  | Finished Water Pipeline Modeling Results from Site A in<br>Manvel at Ground Storage Tanks.....            | 6-12                 |
| Figure 6-9  | Finished Water Pipeline Modeling Results from Site E in<br>Alvin at Pressure .....                        | 6-12                 |
| Figure 6-10 | Finished Water Pipeline Modeling Results from Site E in<br>Alvin at Ground Storage Tanks .....            | 6-12                 |
| Figure 6-11 | Finished Water Pipeline Modeling Results for GCWA WTP<br>at Pressure .....                                | 6-12                 |
| Figure 6-12 | Finished Water Pipeline Modeling Results for GCWA WTP<br>in Ft. Bend County at Ground Storage Tanks ..... | 6-12                 |
| Figure 6-13 | Raw Water Delivery Alternatives .....   | 6-20                 |
| Figure 7-1  | Present Worth Analysis Timeline .....   | 7-1                  |
| Figure 8-1  | High-Rate Conventional Process Schematic .....  | 8-2                  |
| Figure 8-2  | Plant Site Layout.....  | 8-2                  |
| Figure 8-3  | Finished Water Transmission Network from Site A in<br>Manvel at Pressure .....                            | 8-3                  |
| Figure 8-4  | Unit Cost of 25 MGD Surface Water Facility.....   | 8-5                  |
| Figure 9-1  | Estimated Wholesale Water Rate.....   | 9-3                  |
| Figure 9-2  | Estimated Wholesale Water Rate.....   | 9-4                  |

Faced with a growing potable water demand and concerns regarding the long term sustainability of the underlying groundwater aquifer water supply, eight water utilities in the Mid-Brazoria County region have formed a partnership with the State of Texas to evaluate the feasibility of constructing and operating a regional surface water treatment facility. This study reports on the findings of the constructability, feasibility, and preliminary cost of a proposed regional surface facility and associated raw and finished water delivery improvements. Raw surface water supply studies conducted and published by the Region H Water Planning Group of the State Water Plan identify the Brazos River as the raw water source for the study area. Negotiations with Brazos River water rights holders should be conducted by the Mid-Brazoria County Planning Group.

The primary water supply for residents of the Mid-Brazoria County region continues to be the Evangeline and Chicot aquifers. This primary source is more than adequate to meet current municipal, domestic, manufacturing, and agricultural uses throughout Brazoria County. However, studies conducted by the Region H Planning Group indicate the existing groundwater sources will not meet future demand without a decrease in water quality or subsidence.

According to Region H Water Plan, which studied water needs in the 15 counties surrounding Houston, including Brazoria County, additional raw water supplies will be necessary to meet water demands of several communities in the Mid-Brazoria County Region. Region H estimates the existing groundwater supply to be able to sustain community growth through 2030, but overproduction of the aquifer may lead to supply shortages thereafter.

Conversion of the existing potable water sources from a primary groundwater source to a combination of treated surface water and groundwater would not only expand the region's water production capability, but offer the following regional benefits:

- ***Increase water production capabilities.*** As an additional water source is introduced into the area, the growth potential of the area is not limited by water production capacity. By converting to surface water, groundwater slated to be used for domestic purposes can be reallocated for industrial and agricultural uses, thereby allowing greater growth in these economic sectors.
- ***Reduce potential for subsidence.*** As surface water is distributed into the system, groundwater production will decrease. As this production decreases, the potential to drawdown the water level in the underlying aquifer will diminish. If the water table remains high, subsidence will decrease and property damage and localized flooding conditions due to subsidence will be minimized.
- ***Reduce potential for water quality degradation.*** Also, as the aquifer level drops, groundwater quality can progressively degrade, thus requiring additional treatment processes, increasing costs dramatically. A reduction in groundwater pumping will increase the level in the aquifer and increase groundwater quality.

As stated earlier, , Region H reports that the Brazos River will serve as the raw water source for the conversion of the region from groundwater to surface water. In lieu of each municipality in the Mid-Brazoria County Region designing and constructing individual water plants to serve their customers, a regional surface water plant may be a viable and an economically attractive alternative to supply surface water to this region. This study evaluates the feasibility of this alternative.

## SCOPE

This study was authorized to investigate the feasibility of constructing a regional surface water plant, including an analysis of the surface water treatment alternatives and site locations. Through this study,





the estimated cost to plan, design, construct, operate and maintain a regional surface water treatment plant, complete with raw water delivery and finished water transmission, was determined. This study started with the development of the projected water demand for eight Participating Utilities and culminates with a facility plan of the proposed facilities necessary to satisfy this water demand through the year 2050 through a mix of groundwater and treated surface water.

## BACKGROUND

The planning area, shown on **Figure ES-1**, for this study encompasses the northern portion of Brazoria County. Water utilities located in the planning area were contacted regarding their interest in participating in a regional surface water plan and eight utilities elected to be part of this regional planning effort. These Participating Utilities are collectively known as the Mid-Brazoria County Planning Group (MBCPG). MBCPG members include:

- City of Alvin,
- City of Angleton,
- City of Brookside Village,
- City of Danbury,
- City of Hillcrest,
- City of Iowa Colony,
- City of Manvel, and
- City of Pearland


The major surface water feature in this area is the Brazos River. Region H has identified this surface water body as the future raw water source for the potable water needs of the Mid-Brazoria County Region. Water rights for this surface water source are managed through water permits allocated by Texas Natural Resources Conservation Commission (TNRCC). The TNRCC reports that all available water permits for sustainable water rights for Brazos River water have been allocated and that the State is completing the 2002 State Water Plan in which the quantity of available sustainable surface water will be revisited. Major holders of senior lower Brazos River water rights include Gulf Coast Water Authority (GCWA), Chocolate Bayou Water Company (CBWC), Reliant Energy, and the Brazos River Authority (BRA).

Currently, none of the Participating Utilities hold Brazos River water rights. As such, long term raw water contracts or water rights will need to be secured. Region H is in the process of planning water usage through the region and this report assumes that Region H will plan facilities necessary to provide the MBCPG with the required raw surface water.

## WATER DEMAND

The Participating Utilities estimate that the portion of their utilities in the planning area have a current population of 100,000 and an average daily water demand of 11.5 MGD. Over the next 50 years, the population of the Participating Utilities in the planning area and water demand are projected to grow to 216,918 and 23.13 MGD. **Figure ES-2** shows the growth in population and water demand over the planning period. This represents a 101 percent increase in water demand and will require a significant expansion in water production capabilities to meet expected demand.

**FIGURE ES-2  
WATER DEMAND AND POPULATION PROJECTION FOR THE  
PLANNING AREA**



**FACILITY DEMAND**

To meet this potable water demand, the Participating Utilities will need to expand their water production facilities. With conversion from groundwater to surface as part of this facility expansion, the effective split between groundwater and surface water usage is a determining factor on the size of the surface water treatment facilities. Local experience indicates that the utilization of groundwater sources is more cost effective than treating surface water. As such, it is the desire of the Participating Utilities to maximize the use of groundwater to the extent practicable by the availability and quality of groundwater.

The Harris-Galveston Subsidence District, which is a regulatory entity controlling groundwater pumping in the neighboring Harris, Galveston, and Fort Bend Counties, has completed a regional groundwater model which includes the northern portion of Brazoria County. This model indicates that groundwater production in the Mid-Brazoria County region at current withdrawal rate is not expected to negatively impact the availability or quality of the groundwater.

Given these expectations, it is the intention of the Participating Utilities to maintain average annual groundwater production at year 2000 levels through the planning horizon in this study thereby:

- maintaining the current water table level in the underlying aquifer,
- maintaining acceptable groundwater quality,
- mitigating the potential for subsidence, and
- maximizing use of their existing infrastructure.

Therefore, to serve the future average day potable water demand with an effective groundwater production at 11.5 MGD, the Participating Utilities will need to construct surface water treatment facilities with an average annual water capacity equal to the growth in average water demand from year 2000 to the end of the planning horizon.

The Participating Utilities agreed to develop this facility plan based on a plant that delivers a fairly constant supply of surface water and to augment this supply with groundwater from their wells during

periods when supply from the surface water treatment plant was exceeded. The Participating Utilities will activate their wells during times when the water demand exceeds the capacity of the regional surface water plant. Each participating utility noted that they would expand their existing well and storage facilities to meet future peak day demands in lieu of drawing additional water from the surface water plant. Peak hour demands will be met through use of the Participating Utilities individual storage capacity.

Given these assumptions, the Planning Area surface water treatment demands are as follows:

**TABLE ES-1  
PLANNING AREA SURFACE WATER DEMAND**

| Year | Surface Water Demand (MGD) |
|------|----------------------------|
| 2010 | 8                          |
| 2020 | 13                         |
| 2030 | 17                         |
| 2040 | 21                         |
| 2050 | 25                         |


The planning area can be divided into two areas of potable water demand. This division is based on the population within each area. Over one half of the total Participating Utility water demand is allocated for the Cities of Pearland and Brookside Village. The remaining water demand is geographically located in the central and southern portion of the planning area within a ten mile radius of County Road 121 and Hwy 1462 just southeast of Iowa Colony. The two demand areas are located approximately 14 miles apart and are shown on **Figure ES-3**.

Strategic locations for regional surface water treatment facilities were investigated throughout each Demand Area. Due to the relative proximity of the demand to the planning area, the primary focus of a regional surface water plant was central to Demand Area A and B to minimize the overall length of finished water pipelines required to reach each Participating Utility.

## TAKE POINTS

As a wholesale provider of raw and potable water, the MBCPG will contract with each participating utility to deliver water at specified “take points”. Take points are defined as the end point at which the MBCPG will transport potable water to the Participating Utilities. At each of these take points, a flow meter will be installed to record and monitor the total flow delivered to each participating utility. From this point on, the participating utility will be responsible for operation and maintenance of the water distribution system.

Each participating utility requested water to be delivered at pressure either through system pressure from regional water treatment plant high service pump station or through an individual booster pump station located in the Participating Utility. The take points with flow demands are tabulated in **Table ES-2**. The City of Pearland, Brookside Village, and Alvin have noted that their take points may be shifted



MID-BRAZORIA COUNTY PLANNING GROUP/TWDB  
 FACILITY PLAN

FINISHED WATER DEMAND AREAS

FIGURE ES-3

depending on the location of the water treatment plant relative to their city. The following table highlights the alternative take points for each Participating Utility.

**TABLE ES-2  
REQUESTED FLOW UTILITY TAKE POINTS**

| Utility                   | Take Point Number | Address   | Average Day Water Demand (MGD) | Ground Elevation at Take Point (ft) |
|---------------------------|-------------------|---|--------------------------------|-------------------------------------|
| City of Manvel            | 1                 | Iowa Lane and Hwy 6, Manvel TX  | 3.77                           | 55                                  |
| City of Pearland          | 2a                | SH 288 at 518, Pearland TX  | 13.66                          | 60                                  |
|                           | 2b                | SH 35 at 518, Pearland TX   |                                | 40                                  |
| City of Brookside Village | 3a                | Garden Road and Brookside Road  | 0.57                           | 50                                  |
|                           | 3b                | Mykawa Road and Knapp Road  |                                | 50                                  |
| City of Alvin             | 4a                | SH 6, north of Mc Cormick Road  | 4.13                           | 40                                  |
|                           | 4b                | SH 35, at Johnson Road  |                                | 40                                  |
| City of Hillcrest Village | 4a or 4b          | Same as City of Alvin take point  | 0.07                           | 40                                  |
| City of Iowa Colony       | 5                 | At the intersection of County Road 64 and Iowa School Road                            | 0.24                           | 50                                  |
| City of Danbury           | 6                 | 5 <sup>th</sup> Street at St. Spur 8  | 0.48                           | 20                                  |
| City of Angleton          | 7                 | At the intersection of Henderson Road and Krankawa Road in the North part of the City | 2.45                           | 20                                  |


## ALTERNATIVE ANALYSIS

Since the planning area is currently served primarily from groundwater wells, conversion to surface water will require construction of a raw water delivery system, water treatment plant, and finished water transmission system. There are a number of alternative approaches to construct these facilities depending on the location of the water treatment plant. A selection approach was developed and used to ensure that several alternatives were considered and the benefits to each participating utility were taken into consideration in the selection of the final alternatives. The approach consisted of three distinct steps: alternative development, preliminary screening, and participating utility feedback. The entire process used group meetings and participating utility feedback to develop the best alternatives for more detailed evaluation. Final alternative evaluation was based on the economic cost to implement the alternative, including capital costs to construct the facilities and operating and maintenance (O & M) costs over the planning horizon of the project, and the non-economic impact of each alternative on the surrounding community and environment.

**Water Treatment Plant Treatment Process**

Recent Texas Water Development Board (TWDB) studies have compared the treatability of the Brazos River water through various treatment processes. These studies comparing conventional, high-rate conventional, and membrane treatment technologies show that each alternative treatment process will meet federal and state standards, but the high-rate conventional process has the lowest economic cost to construct and operate. As such, the proposed treatment facilities for this study will treat the raw Brazos River water through a high rate conventional water treatment process.

For the high rate conventional process, the capital cost required to construct a 25 MGD water treatment plant were estimated based on established design criteria. Construction costs were estimated based on providing a 15 MGD initial phase in 2010 and a 10 MGD expansion in the year 2030. O & M costs were estimated assuming full production equal to the capacity of the plant. A summary of the water treatment plant capital cost is shown in **Figure ES-4**.



**Preliminary Water Plant Locations**

The Participating Utility Team reviewed the planning area in search of alternative treatment plant locations that met established minimum acreage requirements. In sum, five preliminary sites were identified. After careful evaluation by the Participating Utility Team, several potential water plant sites were eliminated from consideration based on the following criteria: proximity of the proposed plant site to the demand, proximity of the proposed plant site to the raw water source, and acreage of the proposed plant parcel. The Participating Utility Team screened these five sites to two sites based on the relative location of the sites to the demand, raw water source, and access to the site.

After this screening, the following two potential water treatment sites remained:

- Manvel – Hwy 6 and Iowa Lane, and
- Alvin – Hwy 35 and Briscoe Canal.

The locations both the two screened sites and the three sites not selected for further review are shown on **Figure ES-5**.


## Raw Water


Raw water for the regional water plant must be taken from the Brazos River. In a letter report to the TWDB by Turner Collie and Braden dated February 27<sup>th</sup> 2001, three raw water conveyance mechanisms were identified, by which Brazos River water may be transported from the River to the water treatment plant site. The study reviewed each of these alternatives to determine the feasibility of carrying raw water for the MBCPG through each alternative. The reviewed alternatives were:

- 1) Gulf Coast Water Authority (GCWA). In this alternative, the MBCPG would purchase raw water on a per gallon contract basis. As existing GCWA canals carry Brazos River water from the river through Fort Bend, Brazos, and Galveston Counties and both screened alternative water treatment plant locations are adjacent to GCWA canals, no additional facilities are needed in order to transport Brazos River from the river to the either WTP locations.
- 2) Chocolate Bayou Water Company (CBWC). Turner Collie & Braden, through a letter report to the Texas Water Development Board dated February 27 2001 proposed that for this option, the MBCPG would initially purchase the water rights owned by CBWC. By owning water rights, the MBCPG would not have to purchase raw water on an annual basis from another agency, but would utilize their rights to meet the required raw water demand. In purchasing the rights, the MBCPG would construct a raw water pipeline and pump station to transport the water from the CBWC canal to the alternative raw WTP locations.
- 3) Brazos River Authority. In this alternative, the MBCPG would contract for raw water from the Brazos River Authority. To transport the raw water from the Brazos River to the alternative WTP locations, new large diameter raw water pipeline and pump stations will be required.

**Figure ES-6** shows the alternative raw water conveyances options relative to the alternative WTP locations. In comparing the three alternatives based on the present worth cost to construct, operate, and maintain facilities necessary to transport the water to the alternative WTP sites. **Figure ES-7** shows the

**FIGURE ES-7  
RAW WATER ALTERNATIVE PRESENT WORTH  
COST (YR 2000 \$)**





Selected sites  
 Alternate sites

MID-BRAZORIA COUNTY PLANNING GROUP/TWDB  
 FACILITY PLAN

WATER TREATMENT PLANT SITES

FIGURE ES-5



overall present worth costs of the three alternatives.

This present worth analysis is based on assumptions regarding the relative availability and stated cost of raw water. Each aforementioned entity has conditions and requirements regarding sale or purchase of raw water which will impact the overall cost of the raw water for this project. Even with the expected variability in the raw water costs, the evaluation showed that the BRA option is significantly less cost effective than the GCWA or CBWC alternatives. The analysis also showed that with the stated assumptions, the overall economic cost of the CBWC and GCWA alternatives were within the variability of the cost estimates. It is recommended that the MBCPG negotiate with both CBWC and GCWA to develop either a raw water option contract or purchase water rights outright to bring Brazos River water for potable use in the Mid-Brazoria Region. This contract would enable the MBCPG to further solidify the costs associated with bring raw water to the area and would secure raw water availability when the MBCPG is ready to augment their current groundwater supply with treated surface water. Due to the high degree of variability associated with the cost of the CBWC raw water due to potential sale of their water rights to an outside entity, the study compiled total facility costs with GCWA alternative as the raw water transportation mechanism for the regional water plant. *This does not in any way preclude the Planning Group members to negotiate for raw water from other entities.*

## Finished Water Transmission

For each water treatment plant alternative, the finished water transmission system that presents the lowest overall capital and O & M costs was developed. The pipeline alignment was based on the preferred pipeline corridors identified in a pipeline corridor analysis. The analysis reviewed alternative pipeline corridors between the various treatment plant alternatives and the participating utility take points. The preferred pipeline corridors were identified based on the following criteria:

- Minimize overall length of finished water pipelines,
- Minimize construction in urban areas,
- Minimize construction in corridors with numerous existing utilities, wetlands, and private lands requiring easements.

To develop the cost effective sizing of the finished water transmission system components, a hydraulic model was utilized to size pipeline components based on the take point requirements and the preferred pipeline alignments. The goal of the model was determine the minimum sized pipelines and booster pump station pressure that could adequately meet the take point requirements. The results of the model runs for each of the alternatives are provided in **Section 6**.

For each water treatment plant alternative, two modeling scenarios were evaluated to determine the relative economic cost to deliver water to each Participating Utility Take Points at system pressure from the WTP high service pumps or through a through a distributed system in which finished water is delivered to each Ground Storage Tanks and repumped to system pressure for each Participating Utility.

## Economic Evaluation

An economic evaluation was performed for the two different WTP sites alternatives. The following is a summary of the evaluation.

### Capital Cost

The capital costs for each plant site alternative includes costs associated with the finished water pipeline, high service pump station, booster pump stations, easements, and treatment plant facilities. The capital costs also includes engineering construction administration and contingency.

Construction projects have certain unpredictable expenses. To cover the costs of these unpredictable expenses, an allowance for various contingencies is designed to reduce project risk. The contingency will vary according to the type of project, complexity of design, and geographical location. This allowance can be reduced as the design progresses from concept through final construction documents, but some contingency must remain throughout the life of the project as a reserve for events that experience shows will likely occur. Contingency is applied to total construction cost which includes the construction estimate with engineering and construction administration.

The capital costs associated with the identified raw water conveyance for the GCWA option, finished water transmission systems, and water treatment process for each of the identified plant site alternatives, inclusive of engineering and construct administration are shown in **Table ES-3**.

**TABLE ES-3**  
**CAPITAL EXPENDITURE (YR 2000 \$)**

| Alternative        | Phase I<br>Year 2008 | Expansion<br>Year 2028 |
|--------------------|----------------------|------------------------|
| Manvel at Pressure | \$77,979,000         | \$16,142,000           |
| Manvel to GSTs     | \$79,275,000         | \$18,466,000           |
| Alvin at Pressure  | \$87,929,000         | \$16,142,000           |
| Alvin to GSTs      | \$86,565,000         | \$18,466,000           |

## Operation and Maintenance Costs

O & M costs for the facility include the costs associated with producing and delivering the water demand to the Participating Utilities. O & M costs include the following items:

- Electricity,
- Maintenance,
- Chemicals,
- Labor,
- Sludge disposal, and
- Administration

The annual O&M costs for the alternative plant site scenarios are summarized in **Table ES-4**

**TABLE ES-4  
ANNUAL O&M (YR 2000 \$)**

| Alternative        | Phase 1<br>2010-2030 | Phase 2<br>2030-2050 |
|--------------------|----------------------|----------------------|
| Manvel at Pressure | \$4,355,000          | \$6,165,000          |
| Manvel to GSTs     | \$4,445,000          | \$6,295,000          |
| Alvin at Pressure  | \$4,395,000          | \$6,205,000          |
| Alvin to GSTs      | \$4,475,000          | \$6,325,000          |

**Present Worth Analysis**

A present worth analysis was prepared for the purposes of evaluating the identified alternatives. The present worth of an alternative represents the investment required today to construct and operate the recommended raw water improvements, water treatment plant, and finished water transmission system. The present worth analysis of each of the alternatives evaluated is provided in **Table ES-5**.

**TABLE ES-5  
PLANT SITE ALTERNATIVES PRESENT WORTH SUMMARY (YR 2000\$)**

| Alternative                                  | Present Worth Cost (\$M) |
|--|--------------------------|
| Manvel WTP Site Delivering Water At Pressure | \$160                    |
| Manvel WTP Site Delivering Water To GSTs     | \$164                    |
| Alvin WTP Site Delivering Water At Pressure  | \$169                    |
| Alvin WTP Site Delivering Water To GSTs      | \$170                    |

The analysis indicates that the scenario of constructing a new regional water treatment plant at the Manvel site and transmitting water to the Participating Utilities at pressure is less expensive than either delivering water to Ground Storage Tanks or constructing a new plant at the Alvin location.

**GCWA Regional Water Treatment Plant Alternative**

The study also looked at the relative economic cost of participating in a larger regional water treatment plant proposed by the Gulf Coast Water Authority to serve utilities in Fort Bend, Harris, and Brazoria Counties. This regional water treatment plant was studied as part of the TWDB / GCWA Facility Plan study completed in November, 2000. The plant was designed with an ultimate capacity of 150 MGD and would be located in Stafford, Texas. The advantage of combining forces and constructing a larger regional facility is documented cost savings associated with the “economy of scale” in constructing a larger facility. Offsetting this saving would be the cost of a trans-county pipeline. In addition, in this alternative, the MBCPG members would be a raw water customer instead of a wholesale supplier of treated surface water. This study evaluated the benefits and costs of this larger regional plant.

## CONCLUSIONS

- The Mid-Brazoria County region will require surface water conversion to protect the groundwater quality and quantity throughout the planning horizon.
- A 25 MGD high-rate conventional plant at the Manvel site, with associated raw and finished water improvements provides the lowest present worth option for the local regional surface water facility plan
- A unit cost of participation with neighboring communities in Fort Bend and Harris County is less expensive than a local 25 MGD facility serving just the Mid-Brazoria County Region.
- The alternative analysis developed in this study provides a number of sites and plant configurations that are technically and economically feasible.
- Based on the assumptions governing raw water supply costs, the relative present worth cost for either the GCWA or CBWC are significantly less expensive than the alternative of buying contract raw water through the Brazos River Authority.

## RECOMMENDATIONS

- MBCPG should form of join a regional authority with the power to construct and operate regional water supply facilities. The MBCPG members should negotiate raw water contract or purchase for use in this project.
- Investigate Federal and State grants and other available funding sources to help offset project development costs.
- Investigate the feasibility of joining with neighboring communities to benefit for the cost savings associated with a larger regional water treatment plant.
- If the Participating Utilities proceed with a local water treatment plant, a 25 MGD high-rate conventional plant at the Manvel site, with associated finished water improvements should serve as the basis for the development of regional surface water facilities in the planning area.

Construction projects have certain unpredictable expenses. To cover the costs of these unpredictable expenses, an allowance for various contingencies is designed to reduce project risk. The contingency will vary according to the type of project, complexity of design, and geographical location. This allowance can be reduced as the design progresses from concept through final construction documents, but some contingency must remain throughout the life of the project as a reserve for events that experience shows will likely occur. Contingency is applied to total construction cost which includes the construction estimate with engineering and construction administration.

The capital costs associated with the identified raw water conveyance for the GCWA option, finished water transmission systems, and water treatment process for each of the identified plant site alternatives, inclusive of engineering and construct administration are shown in **Table ES-3**.

**TABLE ES-3**  
**CAPITAL EXPENDITURE (YR 2000 \$)**

| Alternative        | Phase I<br>Year 2008 | Expansion<br>Year 2028 |
|--------------------|----------------------|------------------------|
| Manvel at Pressure | \$77,979,000         | \$16,142,000           |
| Manvel to GSTs     | \$79,275,000         | \$18,466,000           |
| Alvin at Pressure  | \$87,929,000         | \$16,142,000           |
| Alvin to GSTs      | \$86,565,000         | \$18,466,000           |

## Operation and Maintenance Costs

O & M costs for the facility include the costs associated with producing and delivering the water demand to the Participating Utilities. O & M costs include the following items:

- Electricity,
- Maintenance,
- Chemicals,
- Labor,
- Sludge disposal, and
- Administration

The annual O&M costs for the alternative plant site scenarios are summarized in **Table ES-4**

**TABLE ES-4  
ANNUAL O&M (YR 2000 \$)**

| Alternative        | Phase 1<br>2010-2030 | Phase 2<br>2030-2050 |
|--------------------|----------------------|----------------------|
| Manvel at Pressure | \$4,355,000          | \$6,165,000          |
| Manvel to GSTs     | \$4,445,000          | \$6,295,000          |
| Alvin at Pressure  | \$4,395,000          | \$6,205,000          |
| Alvin to GSTs      | \$4,475,000          | \$6,325,000          |

**Present Worth Analysis**

A present worth analysis was prepared for the purposes of evaluating the identified alternatives. The present worth of an alternative represents the investment required today to construct and operate the recommended raw water improvements, water treatment plant, and finished water transmission system. The present worth analysis of each of the alternatives evaluated is provided in **Table ES-5**.

**TABLE ES-5  
PLANT SITE ALTERNATIVES PRESENT WORTH SUMMARY (YR 2000\$)**

| Alternative                                  | Present Worth Cost (\$M) |
|--|--------------------------|
| Manvel WTP Site Delivering Water At Pressure | \$160                    |
| Manvel WTP Site Delivering Water To GSTs     | \$164                    |
| Alvin WTP Site Delivering Water At Pressure  | \$169                    |
| Alvin WTP Site Delivering Water To GSTs      | \$170                    |

The analysis indicates that the scenario of constructing a new regional water treatment plant at the Manvel site and transmitting water to the Participating Utilities at pressure is less expensive than either delivering water to Ground Storage Tanks or constructing a new plant at the Alvin location.

**GCWA Regional Water Treatment Plant Alternative**

The study also looked at the relative economic cost of participating in a larger regional water treatment plant proposed by the Gulf Coast Water Authority to serve utilities in Fort Bend, Harris, and Brazoria Counties. This regional water treatment plant was studied as part of the TWDB / GCWA Facility Plan study completed in November, 2000. The plant was designed with an ultimate capacity of 150 MGD and would be located in Stafford, Texas. The advantage of combining forces and constructing a larger regional facility is documented cost savings associated with the “economy of scale” in constructing a larger facility. Offsetting this saving would be the cost of a trans-county pipeline. In addition, in this alternative, the MBCPG members would be a raw water customer instead of a wholesale supplier of treated surface water. This study evaluated the benefits and costs of this larger regional plant.

Based on the unit cost to construct and operate a two-phase 150 MGD plant as reported in the November 2000 TWDB report, the estimated present worth cost to buy treated water from the GCWA and bring the water to the Participating Utilities through a large diameter finished water pipeline is 154 million dollars. This represents a 6 million dollar savings of the low present worth alternative for a smaller Mid-Brazoria County regional water plant.

## Non-Economic Evaluation

The Participating Utility Team met to discuss the non-economic factors involved in site selection and developed the following list of general criteria: Public Acceptance, Expandability, Reliability, Environmental Impacts, and Permitting. An analysis was completed to review this criteria.

The analysis compared the Manvel site against the Alvin site and showed that no significant difference existed between the two sites based on non-economic impacts to the community. Each site has drawbacks and benefits, but no one criteria outweighed another.

## FACILITY PLAN

For the smaller regional water plant alternatives, a facility plan detailing a preliminary site layout, operational requirements, and estimated costs have been developed for the low present cost option. The Manvel site delivering water at pressure from the plant's high service pump station offers the lowest present worth cost and will serve as the basis for the recommended facility plan. However, there is less than a 6% cost difference between all of the siting alternatives.

The facility plan is based on the development of a single 25 MGD high-rate conventional surface water treatment plant at the Manvel site, as shown in **Figure ES-8**. The plant would be developed in two phases. The initial phase would provide 15 MGD to meet the regional surface water conversion requirements for the year 2010. A 10 MGD expansion would be accomplished in year 2030 to satisfy future growth requirements.

The facility plan also includes improvements to the raw water delivery system and the associated finished water transmission systems required to deliver water to the individual participants. A summary of the probable capital costs for the facility plan is presented in **Table ES-6**.

**TABLE ES-6  
FACILITY PLAN CAPITAL COSTS**

| ITEMS                          | COST ( YR 2000 \$)   |                     |
|--------------------------------|----------------------|---------------------|
|                                | 15 MGD Initial Phase | 10 MGD Expansion    |
| Property and Site Improvements | \$760,000            | \$-                 |
| Water Treatment Plant          | \$22,931,000         | \$7,930,000         |
| Finished Water Transmission    | \$23,268,000         | \$1,792,000         |
| Raw Water Improvements         | \$0                  | \$0                 |
| Capital Subtotal               | \$46,959,000         | \$9,722,000         |
| Contingency                    | \$16,440,000         | \$3,400,000         |
| Engineering and Administration | \$14,580,000         | \$3,020,000         |
| <b>Total Capital</b>           | <b>\$77,979,000</b>  | <b>\$16,142,000</b> |

### CONCLUSIONS

- The Mid-Brazoria County region will require surface water conversion to protect the groundwater quality and quantity throughout the planning horizon.
- A 25 MGD high-rate conventional plant at the Manvel site, with associated raw and finished water improvements provides the lowest present worth option for the local regional surface water facility plan
- A unit cost of participation with neighboring communities in Fort Bend and Harris County is less expensive than a local 25 MGD facility serving just the Mid-Brazoria County Region.
- The alternative analysis developed in this study provides a number of sites and plant configurations that are technically and economically feasible.
- Based on the assumptions governing raw water supply costs, the relative present worth cost for either the GCWA or CBWC are significantly less expensive than the alternative of buying contract raw water through the Brazos River Authority.

### RECOMMENDATIONS

- MBCPG should form of join a regional authority with the power to construct and operate regional water supply facilities. The MBCPG members should negotiate raw water contract or purchase for use in this project.
- Investigate Federal and State grants and other available funding sources to help offset project development costs.
- Investigate the feasibility of joining with neighboring communities to benefit for the cost savings associated with a larger regional water treatment plant.
- If the Participating Utilities proceed with a local water treatment plant, a 25 MGD high-rate conventional plant at the Manvel site, with associated finished water improvements should serve as the basis for the development of regional surface water facilities in the planning area.



### BACKGROUND

The primary current water supply for the residents of Brazoria County is groundwater drawn from the underlying Gulf Coast Aquifer. Although existing sources are more than adequate to meet current municipal, domestic, manufacturing, and agricultural uses throughout Brazoria County, the region is concerned about whether existing sources can meet future demand without a decrease in water quality or subsidence. A drop in the groundwater level would force many well owners to lower their wells or find alternative sources of water. In addition, the piezometric head or groundwater level in aquifers serves as a barrier to salt water intrusion from the Gulf of Mexico. A decline in the piezometric head can potentially lead to salt water intrusion, further compromising water quality of the aquifer.

The residents of Brazoria County are considering converting to surface water for domestic use to minimize required groundwater consumption. In Texas, the State controls the use of surface water by allocating water right permits to users. These rights are based on the availability of water and may be superseded by an entity with more senior water rights during drought conditions. The State of Texas through the Texas Water Development Board (TWDB) has established regional planning groups to assist in identifying regional water needs and proposed projects to assure that each region has an adequate supply of water. The Brazoria County Region is part of the State of Texas designated "Region H". Region H comprises 15 counties in and around Houston and is a political entity of the State of Texas charged with defining regional water needs and identifying potential sources of water.

The Region H has just completed their review of the water needs in the area and has compiled a list of proposed projects to supply the region with adequate water supply. For the Mid-Brazoria County Region, the TWDB reports that the Brazos River can serve as the raw water source for the conversion of the region from groundwater to surface water. In lieu of each municipality in the Mid-Brazoria County Region designing and constructing water plants to serve their customers, a regional surface water plant may be a viable and an economically attractive alternative to supply surface water to this region. This study evaluates the feasibility of this alternative.

### SURFACE WATER ADVANTAGES

Although conversion from drinking water comprised primarily of groundwater sources to a blend of treated surface water and groundwater will require an extensive capital investment to the construction of new surface water treatment and transmission facilities, the benefits of such an expansion will enhance and protect the quality of life in the region. By expanding current potable water supplies to include treated surface water, the region will:

- ***Increase water production capabilities.*** As an additional water source is introduced into the area, the growth potential of the area is not limited by water production capacity. By converting to surface water, groundwater slated to be used for domestic purposes can be reallocated for industrial and agricultural uses, thereby allowing greater growth in these economic sectors.
- ***Reduce potential for subsidence.*** As surface water is distributed into the system, groundwater production will decrease. As this production decreases, the potential to drawdown the water level in the underlying aquifer will diminish. If the water table remains high, subsidence will decrease and property damage and localized flooding conditions due to subsidence will be minimized, and
- ***Reduce potential for water quality degradation.*** Also, as the aquifer level drops, groundwater quality progressively degrades, thus requiring additional treatment processes, increasing costs dramatically. A reduction in groundwater pumping will increase the level in the aquifer and increase groundwater quality.

### STUDY PURPOSE

The purpose of this **Regional Surface Water Plant Feasibility Study** is to evaluate alternatives for regional water treatment facilities and transmission piping system to serve Participating Utilities in Mid-Brazoria County Region. This feasibility study will estimate the capital cost to construct a regional water treatment facility inclusive of the cost of raw water pumping and treatment process facilities, potable water pump stations, and potable water pipelines. Operating and maintenance costs for the facility will also be estimated. The study provides a planning horizon through year 2050.

### SCOPE OF FACILITY PLAN

Montgomery Watson has been hired by the City of Alvin to evaluate the feasibility of constructing a new regional surface water treatment plant to serve the Participating Utilities. This study includes the following tasks:

- A determination of the expected water demand for each planning group member,
- An evaluation of alternative water treatment plant site locations,
- A pipeline corridor study,
- A water conservation study,
- Overall capital and operating costs, and
- A facility plan for recommended alternative.

In addition, a cultural resources survey and public information program were included in this study. References used in the preparation of this report are included in **Appendix A**.

### PLANNING AREA

The planning area is located in the Texas Water Development Board Regional Water Planning Area H in southeast Texas. The planning group covers the northern half of Brazoria County and includes many major cities and population centers. Participating Utilities electing to be included in this study are:

- City of Alvin
- City of Angleton
- City of Brookside Village
- City of Danbury
- City of Hillcrest
- City of Iowa Colony
- City of Manvel
- City of Pearland

A map of the planning area is shown in **Figure 1-1**. The Participating Utilities estimate that the portion of their utilities in the planning area have a current population of 97,694 and an average daily water demand of 10.4 MGD.

River basins within the planning are: the lower portion of the Brazos River Basin, the northeast portion of the San Jacinto-Brazos Coastal Basin and the southwest portion of the San Jacinto Coastal Basin.

### AVAILABLE SURFACE WATER

The major surface water feature in this area is the Brazos River. The Brazos River flows diagonally through Fort Bend County from the northwest to the southeast and then serves as the border between

## Section 1 Introduction

---

Brazoria and Fort Bend Counties until the Brazos turns southward and flows through Brazoria County before discharging into the Gulf of Mexico. The State of Texas, through the Texas Natural Resources Conservation Commission (TNRCC), currently allocates water from the Brazos River for agricultural, industrial, and municipal needs through water permits.

The Participating Utilities in the Mid Brazoria County Region do not currently hold any water rights on the Brazos and will need to secure water rights or long term contracts for raw water. The State of Texas through Region H is in the process of planning water usage through the region and this report assumes that Region H will plan facilities necessary to provide the region with the required surface water.





## Section 2

# Planning Area Existing Infrastructure

---

The Participating Utilities plan to minimize the cost of improvements for surface water conversion by maximizing the use of their existing infrastructure. This section reviews the planning area and identifies the existing envirostructure in the planning area and highlights the capacity of the surface water availability and conveyance in the planning area.

### WATER SOURCE AND SUPPLY

Currently, the Mid-Brazoria County Area relies predominantly on groundwater for their potable water needs, with the exception of the City of Angleton, which satisfies part of its water demand by surface water. As the reliability of groundwater supply is reduced in the next five decades, the Brazos River Authority (BRA) and the Gulf Coast Water Authority (GCWA) will continue to be an increasingly viable treated surface water source to the major cities of the Planning Area.

#### Surface water

The Brazos River is the main source of surface water for members of the Planning Area. The Gulf Coast Water Authority currently draws surface water from the Brazos River. Water quality for the Brazos River is presented in **Section 4** of this report.

#### Groundwater

The Region H area has two major aquifers supplying groundwater, the Gulf Coast aquifer, and the Carrizo-Wilcox aquifer. The members of the Planning Group are supplied groundwater from the Gulf Coast aquifer. This aquifer is composed of the Evangeline, Chicot, and Jasper formations, and extends from near the shoreline to approximately 100 to 120 miles inland, to Walker and Trinity counties. The groundwater availability for Brazoria County is 50,315 acre-feet per year.

#### Surface Water Rights

The right to take water from the Brazos is based on the permit allocation from the State of Texas and the date of the permit. Holders of the oldest water permits have first right to take available water from the Brazos River. Junior water rights must wait until all holders of senior water rights have had the chance to receive their allocated water rights. Gulf Coast Water Authority currently holds 3 water permits for diversion of water from the run of the Brazos, the Chocolate Bayou Water Company holds 2 permits, and the Brazos River Authority holds 1 permit. A summary of permits and allocations held by various entities are shown in **Table 2-1**.

## Section 2

# Planning Area Existing Infrastructure

**TABLE 2-1  
EXISTING WATER PERMITS ON LOWER BRAZOS RIVER**

| Permit #              | Date       | Priority No. | Total Withdrawal |            | Maximum Withdrawal Rate        |             |
|-----------------------|------------|--------------|------------------|------------|--------------------------------|-------------|
|                       |            |              | ac-ft / yr.      | MGD        | Cfs<br>(cubic feet per second) | MGD         |
| 1040 - GCWA           | 1/15/1926  | 1            | 99,932           | 89         | 685                            | 443         |
| 1041 - Reliant Energy | 10/23/1926 | 2            | 28,000           | 25         | 385                            | 249         |
| 1145- CBWC            | 2/8/1929   | 3            | 40,000           | 36         | 400                            | 259         |
| 1145 - DOW            | 2/28/1929  | 4            | 20,000           | 18         | 132                            | 85          |
| 1262 - BRA            | 5/9/1938   | 5            | 230,750          | 206        |                                |             |
| 1299 - GCWA           | 2/2/1939   | 6            | 125,000          | 112        | 600                            | 388         |
| 1345/1631 - DOW       | 2/14/1924  | 7            | 150,000          | 134        | 630                            | 407         |
| 1299 - GCWA           | 12/12/1950 | 8            | 50,000           | 45         | 600                            | 388         |
| 1145 - CBWC           | 3/3/1955   | 9            | 40,000           | 36         | 268                            | 173         |
| 1964 - DOW            | 4/4/1960   | 10           | 65,000           | 58         | 630                            | 407         |
| 1145 - CBWC           | 7/25/1983  | 21           | 75,000           | 67         | 900                            | 582         |
| <b>Total</b>          |            | <b>Total</b> | <b>923,682</b>   | <b>824</b> | <b>5230</b>                    | <b>3380</b> |

DOW – DOW Chemical Company

The City of Pearland currently has a water contract, which expires after the year 2010, with the GCWA for 5,559 acre-feet per year. The City of Angleton has a water contract with the Brazosport Water Authority (BWA) for 1,815 acre-feet per year of treated surface water expiring after the year 2040. The City of Angleton is currently using this contract to serve their municipal needs.

### MID-BRAZORIA COUNTY PLANNING GROUP EXISTING FACILITIES DESCRIPTION

The planning area contains municipally owned water systems that deliver potable water to customers. These entities have constructed the infrastructure to withdraw, store, and treat water for delivery and consumption by their customers. Participating Utility water customers in the planning area are served either via water pumped from the Gulf Coast Aquifer, treated surface water from the City of Houston, or contracts with the GCWA and the BWA.

The cities of Pearland and Angleton use treated surface water for a portion, or all of their potable water supplies and supplement water from groundwater wells to meet demand. The other Participating Utilities serve their customers entirely with groundwater. A summary of the Participating Utilities in this study and their water infrastructure are provided below.

#### City of Manvel

The City of Manvel is located in Brazoria County and serves an area bordered by Lewis Lane to the North, SH 288 to the west, Taylor Lane to the south, and Lewis Lane to the east. The City of Manvel ETJ is approximately 23.3 square miles. The city has approximately 4,686 residents with extensive expansion expected in the future. Currently the water needs for the City are met by water wells. The city currently operates a water treatment facility with a rated well production capacity of 175 GPM and a back up well rated at 50 GPM. The primary well was drilled to a depth of approximately 550 feet and has 30 feet of screening. This enables the City to service a maximum of 375 service

## Section 2

# Planning Area Existing Infrastructure

---

connections. The ground storage tank is designed to hold 125,000 gallons with the capability of being expanded to approximately 165,000 gallons. The existing water treatment facility has two 10 HP booster pumps rated to keep pace with the well. The plant also has a 10,000 gallon pressure tank designed to maintain a system pressure near the plant of 57 psi. The current average demand is 0.63 MGD. The service area of the existing plant, located near the intersection of Lewis Lane and School Road, stretches along SH-6 as far west as SH-288. In addition, the City serves customers along FM-1128 as far south as Taylor Lane and north as far as Lewis Lane

The development of Manvel both residentially and commercially will be centralized radially around the intersection of SH-288 and SH-6. The City plans on building a water treatment facility to service this area. The current facility will be used to service the downtown business/residential areas, and any development east of FM 1128, along SH-6.

It is anticipated that the City will experience rapid growth over the next 15 years, with some estimates expecting 10,000 homes to be constructed. Therefore, the City would require a water supply ultimately capable of meeting a demand of approximately 3.15 MGD for residential customers alone within the next twenty years.

### City of Brookside Village

The City of Brookside Village currently has approximately 1,800 residents. The current average water demand is 0.18 MGD, estimated on a 100 gallon per person per day basis. The water demands are met by private water wells. The City currently does not have a community system to meet its water demand.

### City of Pearland

The City of Pearland, located in Harris and Brazoria County, has an existing population of 31,893 residents and an ETJ of approximately 58.4 square miles in the planning area. The City serves its customers through groundwater wells, and a contract with the City of Houston. The City currently has seven water wells having a total capacity of 6,412 GPM. The water distribution system is comprised of eight ground storage tanks having a total capacity of 2,824,000 gallons, and three elevated storage tanks having a total capacity of 1,500,000 gallons. The City also has seven pump stations. **Table 2-2** presents detailed pump station information.

**TABLE 2-2  
CITY OF PEARLAND PUMP STATION INFORMATION**

| Pump Station No. | Location    | Estimated Range of Capacity (GPM) |
|------------------|-------------|-----------------------------------|
| 1                | McLean Road | 520-560                           |
| 2                | Garden Road | 780-840                           |
| 3                | Magnolia    | 720-840                           |
| 4                | Liberty     | 980-1190                          |
| 5                | Alice       | 640-1120                          |
| 6                | SH 518      | 500                               |
| 7                | Old City    | 340-385                           |

## Section 2

# Planning Area Existing Infrastructure

---

### City of Alvin

The City of Alvin, located in Brazoria County, serves a geographic area of 14.8 square miles with a current population of approximately 24,075 residents. The water supply sources for the City currently include water from ground water wells. There is no surface water currently purchased by the City, nor is there any surface water treated and supplied to the system. The City of Alvin water distribution system consists of one pressure plane that includes: five water wells, three booster pump stations, six ground storage tanks, and two elevated storage tanks. **Table 2-3** presents a listing of the water wells. Well number 8 was the most recent well to be constructed, being completed and on-line during the summer of 1999.

**TABLE 2-3  
CITY OF ALVIN WATER WELLS**

| Well No.                 | Diameter (inches) | Estimated Capacity (GPM) | Depth (feet) |
|--------------------------|-------------------|--------------------------|--------------|
| 3                        | 10 ¾              | 1,200                    | 700          |
| 4                        | 14                | 800                      | 700          |
| 6                        | 16                | 900                      | 700          |
| 7                        | 18                | 1,500                    | 700          |
| 8                        | 16                | 1,200                    | 700          |
| Total Capacity 5,600 GPM |                   |                          |              |

The three pump booster stations are referred to as Water Plant No. 3, No. 4, and No. 6. Water Plant No. 3, located on Snyder Street, includes three service pumps and one ground storage tank that is supplied by one water well. The pumping capacity of each of the pumps and storage capacity of the tanks is presented in **Table 2-4**.

**TABLE 2-4  
CITY OF ALVIN WATER PLANT NO. 3**

| Service Pumps        |                 |                 |               |             |
|----------------------|-----------------|-----------------|---------------|-------------|
| No. Pump             | Estimated GPM   | Rated Head      | HP            | RPM         |
| 1                    | 500             | 183             | 30            | 1,750       |
| 2                    | 500             | 183             | 30            | 1,750       |
| 3                    | 500             | 183             | 30            | 1,750       |
| Ground Storage Tanks |                 |                 |               |             |
| Tank No.             | Fed by Well No. | Diameter (feet) | Height (feet) | Volume (MG) |
| 1                    | 3               | 300             | 24            | 1           |



## Section 2

# Planning Area Existing Infrastructure

---

Water Plant No. 4, located on Robinson Street, includes three service pumps and two ground storage tanks that are supplied by two water wells. The pumping capacity of each of the pumps and storage capacity of the tanks is presented in **Table 2-5**.

**TABLE 2-5  
CITY OF ALVIN WATER PLANT NO. 4**

| Service Pumps        |                 |                 |               |             |
|----------------------|-----------------|-----------------|---------------|-------------|
| Pump No.             | Estimated GPM   | Rated Head      | HP            | RPM         |
| 1                    | 450             | 180             | 25            | 1,750       |
| 2                    | 450             | 180             | 25            | 1,750       |
| 3                    | 450             | 180             | 25            | 1,750       |
| Ground Storage Tanks |                 |                 |               |             |
| Tank No.             | Fed by Well No. | Diameter (feet) | Height (feet) | Volume (MG) |
| 1                    | 4 and 8         | 148             | 24            | 0.25        |
| 2                    | 4 and 8         | 104             | 24            | 0.125       |

Water Plant No. 6, located on Brazos Street, includes four service pumps and three storage tanks that are supplied by two water wells. The pumping capacities of each of the pumps and storage capacity of the tanks are presented in **Table 2-6**.

**TABLE 2-6  
CITY OF ALVIN WATER PLANT NO. 6**

| Service Pumps        |                 |                 |               |             |
|----------------------|-----------------|-----------------|---------------|-------------|
| Pump No.             | Estimated GPM   | Rated Head      | HP            | RPM         |
| 1                    | 600             | 170             | 40            | 1,750       |
| 2                    | 600             | 170             | 40            | 1,750       |
| 3                    | 600             | 170             | 40            | 1,750       |
| 4                    | 600             | 170             | 40            | 1,750       |
| Ground Storage Tanks |                 |                 |               |             |
| Tank No.             | Fed by Well No. | Diameter (feet) | Height (feet) | Volume (MG) |
| 1                    | 6 and 7         | 148             | 24            | 0.25        |
| 2                    | 6 and 7         | 148             | 24            | 0.25        |
| 3                    | 6 and 7         | 148             | 24            | 0.25        |

Total theoretical output from all service pumps is 7.6 MGD. The firm capacity is 5.32 MGD with the largest pump out of service.

The City of Alvin water system contains two elevated storage tanks located in the southern area of the City, and they are identified as Verhalen and Dyche Lane.

## Section 2

# Planning Area Existing Infrastructure

---

### City of Hillcrest Village

The City of Hillcrest Village has an approximate area of 25 square miles and a population of approximately 891 residents. The city serves its residents through a total of 2 wells with capacity of 185 and 284 GPM. The City has one storage structure with a capacity of 0.10 MG. The current average demand is 0.11 MG.

### City of Danbury

The residents of Danbury meet their water demand through private wells. The City does not have a community system to meet their water demands.

### City of Angleton

The City of Angleton currently has approximately 20,000 residents. The City has a water contract with the Brazosport Water Authority (BWA) for 1,815 acre-feet per year of treated surface water. In addition to this contract, the City serves its residents through a total of 6 wells with capacity of 450 to 850 GPM per well. It has two storage structures, one ground and one elevated storage tank. The ground storage tank has a capacity of 2.65 MG, and the elevated tank has a capacity of 1 MG. The current average demand is 2.64 MGD. The city has reported experiencing taste and odor problems. It is projected that the city will need a new water plant in the next 5 years.

### City of Iowa Colony

The residents of Iowa Colony meet their water demand through private wells. The City does not have a community system to meet their water demands.

### Summary of Existing Infrastructure

Table 2-7 reviews the existing infrastructure details for cities in the Planning Area.

**TABLE 2-7  
EXISTING INFRASTRUCTURE REVIEW**

| Participating Utilities | Water Wells |                | Storage Capacity |               |        |               | Pump Stations |                       |                     |
|-------------------------|-------------|----------------|------------------|---------------|--------|---------------|---------------|-----------------------|---------------------|
|                         | Number      | Capacity (GPM) | GSTs             |               | ESTs   |               | Number        | Actual Capacity (MGD) | Firm Capacity (MGD) |
|                         |             |                | Number           | Capacity (MG) | Number | Capacity (MG) |               |                       |                     |
| Manvel                  | 1           | 175            | 1                | 1.25          | -      | -             | NA            | NA                    | NA                  |
| Pearland                | 7           | 6,412          | 8                | 2.82          | 3      | 1.15          | 7             | 7.8                   | 6.1                 |
| Alvin                   | 5           | 5,600          | 6                | 2.12          | 2      | -             | 3             | 7.6                   | 5.3                 |
| Hillcrest Village       | 2           | 469            | 1                | 0.10          | -      | -             | NA            | NA                    | NA                  |
| Angleton                | 6           | 5,100          | 1                | 2.65          | 1      | 1             | NA            | NA                    | NA                  |

NA – Not Available



**PROJECTED POTABLE WATER DEMAND**

The size of the regional water plant depends on the potable water requirements of the Participating Utilities to the year 2050. Water and population projections for the Participating Utilities were evaluated and summarized to obtain the projected ultimate capacity for the water plant in the year 2050. The size of the water plant will be governed by the service area of the plant, the projected average and peak potable water demand for the planning area, and percentage of demand that each utility desires to obtain from the plant.

**Current Population and Water Usage**

Data for current population and water usage were taken from the Texas Water Development Board Population & Water Demand Projections: Board Approved Regional Projections to be used in the 2002 State Water Plan. For the Participating Utilities in this study, **Table 3-1** provides the year 2000 population and water use as reported by TWDB through the Region H Board.

**TABLE 3-1**  
**YEAR 2000 POPULATION AND AVERAGE WATER DEMAND**

| Participating Utility       | Year 2000 Planning Area<br>Population | Year 2000 Average<br>Day Water Demand (MGD) |
|-----------------------------|---------------------------------------|---|
| Alvin                       | 24,075                                | 2.94  |
| Angleton                    | 23,870                                | 2.89  |
| Brookside Village           | 2,059                                 | 0.25  |
| Danbury                     | 1,870                                 | 0.22  |
| Hillcrest                   | 891                                   | 0.11  |
| Iowa Colony                 | 851                                   | 0.11  |
| Manvel                      | 5,152                                 | 0.63  |
| Pearland                    | 31,983                                | 4.32  |
| <b>Total for Study Area</b> | <b>90,751</b>                         | <b>11.47</b>                                |

**Projected Population and Water Usage**

Data regarding projected population and water use for the planning area was collected from the TWDB Region H Plan.

The TWDB population and water use projections will serve as a basis for the State’s Year 2002 Water Plan. Detailed breakdowns of the TWDB population and water use projections can be found in **Appendix C – TWDB Population and Water Use Projections**.

For this study, the TWDB Region H data will be used as the official projected population and water use for the planning area.

**Participating Utility Projected Population**

The population projections for the Participating Utilities are reported in the **Table 3-2**. The data lists projected water use and population in 10-year increments to the year 2050.

**TABLE 3-2**  
**PROJECTED POPULATION FOR PARTICIPATING UTILITIES IN PLANNING AREA**

| Participating Utility          | 2000          | 2010           | 2020           | 2030           | 2040           | 2050           |
|--------------------------------|---------------|----------------|----------------|----------------|----------------|----------------|
| Alvin                          | 24,075        | 28,723         | 33,822         | 40,240         | 45,715         | 51,935         |
| Angleton                       | 23,870        | 28,737         | 34,037         | 40,661         | 46,773         | 52,884         |
| Brookside Vill.                | 2,059         | 2,282          | 2,551          | 2,934          | 3,337          | 3,696          |
| Danbury                        | 1,870         | 2,174          | 2,442          | 2,802          | 3,079          | 3,381          |
| Hillcrest                      | 891           | 995            | 1,245          | 1,479          | 1,592          | 1,696          |
| Iowa Colony                    | 851           | 922            | 1,086          | 1,272          | 1,375          | 1,477          |
| Manvel                         | 5,152         | 6,084          | 7,080          | 8,352          | 9,412          | 10,606         |
| Pearland                       | 31,983        | 42,347         | 53,105         | 65,569         | 77,338         | 91,243         |
| <b>Total for Planning Area</b> | <b>90,751</b> | <b>112,264</b> | <b>135,368</b> | <b>163,309</b> | <b>188,621</b> | <b>216,918</b> |

**Water Demand Projection**

Given the Participating Utility population projections, the corresponding TWDB water use projections are shown in **Table 3-3**. These water use projections represent the expected annual water use reported as average daily demand in MGD.


**TABLE 3-3**  
**PROJECTED AVERAGE WATER DEMAND (MGD)**  
**FOR PARTICIPATING UTILITIES IN PLANNING AREA**

| Participating Utility          | 2000         | 2010         | 2020         | 2030         | 2040         | 2050         |
|--------------------------------|--------------|--------------|--------------|--------------|--------------|--------------|
| Alvin                          | 2.94         | 3.27         | 3.65         | 4.23         | 4.71         | 5.30         |
| Angleton                       | 2.89         | 3.28         | 3.68         | 4.23         | 4.73         | 5.34         |
| Brookside Vill.                | 0.25         | 0.27         | 0.28         | 0.31         | 0.34         | 0.38         |
| Danbury                        | 0.22         | 0.24         | 0.25         | 0.27         | 0.30         | 0.32         |
| Hillcrest                      | 0.11         | 0.12         | 0.14         | 0.16         | 0.17         | 0.18         |
| Iowa Colony                    | 0.11         | 0.11         | 0.13         | 0.14         | 0.15         | 0.16         |
| Manvel                         | 0.63         | 0.70         | 0.76         | 0.88         | 0.96         | 1.08         |
| Pearland                       | 4.32         | 5.34         | 6.32         | 7.61         | 8.79         | 10.37        |
| <b>Total for Planning Area</b> | <b>11.47</b> | <b>13.32</b> | <b>15.21</b> | <b>17.83</b> | <b>20.15</b> | <b>23.13</b> |

## Section 3 Regional Water Supply

By the year 2050, the daily water use for the eight utilities is approximately 23 MGD, which represents an increase of approximately 12 MGD over the water demand in the year 2000. The planning area expected population and water demand growth are shown in **Figure 3-1**.


**FIGURE 3-1  
WATER DEMAND AND POPULATION PROJECTION FOR THE  
PLANNING AREA**



The per capita water use figures for each participating utility will vary as several utilities have diverse commercial and industrial centers with differing water use projections and can be seen in the **Figure 3-3**.

Based on the current ETJs, and planned development, some of the Participating Utilities anticipate a faster growth rate than Region H projections. Several Participating Utilities therefore felt the need for safety factors to size the facilities to meet this higher growth rate. These safety factors were incorporated in determining the size of facilities necessary to meet the Participating Utility water demand, are shown in **Table 3-4**. The corresponding water use projections with safety factors to be used in sizing facilities are shown in **Table 3-5**.

**FIGURE 3-2  
REGION H PER CAPITA WATER DEMANDS**



**TABLE 3-4  
SAFETY FACTORS USED FOR PARTICIPATING UTILITIES**

| Participating Utilities | Safety Factor |
|-------------------------|---------------|
| Alvin                   | 1.33          |
| Manvel                  | 4.07          |
| Pearland                | 1.73          |

**TABLE 3-5  
PROJECTED MODIFIED AVERAGE WATER DEMAND (MGD)  
FOR PARTICIPATING UTILITIES IN PLANNING AREA**

| Participating Utility          | 2000         | 2010         | 2020         | 2030         | 2040         | 2050         |
|--------------------------------|--------------|--------------|--------------|--------------|--------------|--------------|
| Alvin                          | 2.94         | 3.27         | 4.86         | 5.62         | 6.26         | 7.05         |
| Angleton                       | 2.89         | 3.28         | 3.68         | 4.23         | 4.73         | 5.34         |
| Brookside Vill.                | 0.25         | 0.27         | 0.28         | 0.31         | 0.34         | 0.38         |
| Danbury                        | 0.22         | 0.24         | 0.25         | 0.27         | 0.30         | 0.32         |
| Hillcrest                      | 0.11         | 0.12         | 0.14         | 0.16         | 0.17         | 0.18         |
| Iowa Colony                    | 0.11         | 0.11         | 0.13         | 0.46         | 0.15         | 0.16         |
| Manvel                         | 0.63         | 2.23         | 3.11         | 3.57         | 3.91         | 4.40         |
| Pearland                       | 4.32         | 8.66         | 10.93        | 13.16        | 15.21        | 17.94        |
| <b>Total for Planning Area</b> | <b>11.47</b> | <b>18.18</b> | <b>23.37</b> | <b>27.78</b> | <b>31.07</b> | <b>35.77</b> |

**AVERAGE AND PEAK DAY DEMAND**

The water use projections reported in **Table 3-5** are for average daily demand. In addition to the average daily water demand, each utility also reported their expected peak day water demand to average day water demand ratio. The peaking factors for each utility are shown in **Table 3-6**. The peaking factor is influenced by the distribution of residential, commercial, and industrial customers throughout the utility.

**TABLE 3-6**  
**PEAK DAILY TO AVERAGE DAILY FLOW PEAKING**  
**FACTORS AND PEAK DEMANDS**

| Participating Utility          | Peaking Factor | Peak Daily Flow in the Year 2050 (MGD) |
|--------------------------------|----------------|--|
| Alvin                          | 1.64           | 11.55                                  |
| Angleton                       | 1.50           | 8.01                                   |
| Brookside Vill.                | 1.50           | 0.57                                   |
| Danbury                        | 1.50           | 0.48                                   |
| Hillcrest                      | 2.61           | 0.47                                   |
| Iowa Colony                    | 1.50           | 0.24                                   |
| Manvel                         | 1.50           | 6.61                                   |
| Pearland                       | 2.00           | 35.88                                  |
| <b>Total for Planning Area</b> |                | <b>63.81</b>                           |

For the overall planning area, the peak daily flow to average daily flow ratio is 1.78. If the water treatment plant were to be sized to meet 100 percent of the water demand at each of the utilities, the plant would be required to deliver at least 64 MGD to meet the peak daily demand for the planning area.

**Water Plant Capacity**

The water plant capacity is defined as the amount of water that each Participating Utility reserves as its allotted “take” from the water plant. One option is to supply the entire water demand (average and peak flow) with water from the surface water plant. Another option is to supply the water demand with a combination of water produced from the new regional water treatment plant and the existing groundwater infrastructure. The Participating Utilities have selected to use their existing infrastructure to minimize the required plant capacity and the associated cost of water production. The following is a discussion on this selection and the ramifications of this choice.

**Selecting the Appropriate Level of Groundwater Usage in the Planning Area**

If the piezometric level in the underlying aquifer remains at or near the current level, experience indicates that groundwater usage remains the most economical method to meet potable water demand. If the groundwater level or quality decreases as expected under an increased groundwater pumping scenario, the cost of providing potable water from groundwater sources will increase. As this scenario unfolds, treated surface water will become a more viable and economic solution to supplement groundwater supplies to meet regional demand and maintain the aquifer and groundwater quality at the current acceptable levels.

## Section 3 Regional Water Supply

The Harris-Galveston Subsidence District has conducted groundwater modeling of the Harris – Galveston-Fort Bend County region to evaluate the effects of proposed groundwater pumping on the availability of water and subsidence of the overlying ground. This modeling effort also covered the northern Brazoria County area. Through this modeling effort, the Harris-Galveston Subsidence District expects groundwater pumping at existing production levels in the Mid-Brazoria County area not to impact the aquifer level and quality at today’s standards. Given this expectation, it is the intention of the Participating Utilities to maintain average day groundwater production at current levels through the planning horizon in this study thereby:

- maintaining the current water table level in the underlying aquifer,
- maintaining acceptable groundwater quality,
- mitigating the potential for subsidence, and
- maximizing use of their existing infrastructure.

Groundwater production will be increased to meet peak daily demands. The existing groundwater capacity of each participating utility in the study and how that relates to their year 2000 water demand are shown in **Table 3-7**. The MBCPG has 3.63 MGD in reserve or excess capacity beyond the projected year 2000 peak demand, but is about 4 MGD short of TNRCC requirements of 0.6 GPM per connection. The relation of the Participating Utility existing production capability and the expected 2050 demand is presented in **Table 3-8**. The region needs to construct production capability of 45.48 MGD to meet the 2050 projected demand. Based on TNRCC requirements of 0.6 GPM per connection, a total additional capacity of 47.5 MGD. The actual capacity that will need to be added may be slightly higher since this does not account for firm capacity pumping with the largest unit out of service.

**TABLE 3-7  
PARTICIPATING UTILITY EXISTING GROUNDWATER PRODUCTION CAPACITY  
VERSUS EXISTING DEMAND**

| Participating Utility          | 2000 Water Production Capacity (MGD) | 2000 Average Water Demand (MGD) | 2000 Peak Water Demand (MGD) | 2000 TNRCC Requirement (MGD)*** |
|--------------------------------|--------------------------------------|---------------------------------|------------------------------|---------------------------------|
| Alvin                          | 4.50                                 | 2.94                            | 4.82                         | 7.32                            |
| Angleton                       | 5.60 *                               | 2.89                            | 4.34                         | 7.26                            |
| Brookside Vill.                | 0.00                                 | 0.25                            | 0.38                         | 0.63                            |
| Danbury                        | 0.00                                 | 0.22                            | 0.33                         | 0.57                            |
| Hillcrest                      | 0.68                                 | 0.11                            | 0.29                         | 0.27                            |
| Iowa Colony                    | 0.00                                 | 0.11                            | 0.17                         | 0.26                            |
| Manvel                         | 0.25                                 | 0.63                            | 0.95                         | 1.57                            |
| Pearland                       | 12.5**                               | 4.32                            | 8.64                         | 9.73                            |
| <b>Total for Planning Area</b> | <b>23.53</b>                         | <b>11.47</b>                    | <b>19.90</b>                 | <b>27.61</b>                    |

\*Includes 1.8 MGD contract for surface water from Brazosport Water Authority

\*\* Includes 5 MGD from a contract of 10 MGD for surface water from City of Houston

\*\*\* Based on 0.6 GPM per connection, Year 2000 population, and 2.84 persons per connection



**TABLE 3-8**  
**PARTICIPATING UTILITY WATER CAPACITY NEEDS**

| Participating Utility          | 2000 Water Production Capacity (MGD) | 2050 Peak Water Demand (MGD) | Additional Capacity needed to meet 2050 Peak Demand (MGD) |
|--------------------------------|--------------------------------------|------------------------------|---|
| Alvin                          | 4.50                                 | 11.55                        | 7.05  |
| Angleton                       | 5.60 *                               | 8.01                         | 2.41  |
| Brookside Vill.                | 0.00                                 | 0.57                         | 0.57  |
| Danbury                        | 0.00                                 | 0.48                         | 0.48  |
| Hillcrest                      | 0.68                                 | 0.47                         | 0.00  |
| Iowa Colony                    | 0.00                                 | 0.24                         | 0.24  |
| Manvel                         | 0.25                                 | 6.61                         | 6.36  |
| Pearland                       | 7.50                                 | 35.88                        | 28.38   |
| <b>Total for Planning Area</b> | <b>18.53</b>                         | <b>63.81</b>                 | <b>45.48</b>  |

\* Includes 1.8 MGD contract for surface water from Brazosport Water Authority

### Assumptions

In meeting the Participating Utilities desire to keep the groundwater production at the current rate, the capacity of the water treatment plant can be calculated as the difference between expected demand and current production. In doing such, the following bullets summarize the recommended assumptions for consideration in determining this water plant capacity:

- Use of Region H Population and Water Demand Projections, with application of safety factors as determined from each participating utility data.
- The City of Angleton’s contract with Brazosport Water Authority for 1.8 MGD of treated surface water will continue through the year 2040. Region H has suggested an extension of the contract.
- For communities with no public water system (all private wells), meet water demand (average and peak day) from the regional surface water facility. The required “take” capacity from the water treatment plant will be equal to the peak day demand of each community.
- For communities, with an existing public water distribution system, average day groundwater production will be maintained at rate equal to current average water demand (11.5 MGD). These Participating Utilities “take” capacity from the water plant will be defined as the projected growth in average water demand over the next 50 years. It is these communities desire to receive a fairly constant supply of surface water and to augment this supply with groundwater from their wells. These communities will activate their wells during times when the daily water demand exceeds their take from the water plant. During winter months, when water demand is typically lower, the

## Section 3 Regional Water Supply

Participating Utilities may not need to operate their wells as the constant flow of the surface water may meet the daily demand in and of itself. During the non-winter months, the Participating Utilities will be required to utilize their groundwater wells to meet the daily water demand.

- The Participating Utilities will meet peak hour demand through water stored in their individual water distribution system infrastructure. The Participating Utilities can draw on their elevated and ground storage tanks to provide water over and above their maximum regional surface water treatment and groundwater production capability to meet hourly fluctuations in demand. Each participating utility noted that they plan on expanding their water distribution facilities to meet future peak flow demands.

### Water Treatment Plant Reserve Capacity

Given these assumptions, the projected water demand for the participating utilities along with the ultimate reserve water plant capacity are shown in **Table 3-9**.

**TABLE 3-9  
RESERVE SURFACE WATER TREATMENT PLANT CAPACITY (MGD)**

| Participating Utility   | 2000 Average Water Demand from Public System (MGD) | 2050 Water Demand (MGD) | Reserve Water Plant Capacity in Year 2050 (Water Demand Growth 2000-2050 (MGD)) |
|---|--|-------------------------|---|
| <b><i>Communities with Existing Central Water Distribution Systems</i></b>    |  |                         |   |
| Alvin   | 2.94   | 7.05 <sup>(1)</sup>     | 3.95  |
| Angleton  | 2.89   | 5.34 <sup>(1)</sup>     | 2.45  |
| Hillcrest   | 0.11   | 0.18 <sup>(1)</sup>     | 0.07  |
| Manvel  | 0.63   | 4.40 <sup>(1)</sup>     | 2.83  |
| Pearland  | 4.32   | 17.94 <sup>(1)</sup>    | 13.31   |
| <b><i>Communities without Existing Central Water Distribution Systems</i></b> |  |                         |   |
| Brookside Village   | 0.0 <sup>(3)</sup>                                 | 0.57 <sup>(2)</sup>     | 0.57  |
| Danbury   | 0.0 <sup>(3)</sup>                                 | 0.48 <sup>(2)</sup>     | 0.48  |
| Iowa Colony   | 0.0 <sup>(3)</sup>                                 | 0.24 <sup>(2)</sup>     | 0.24  |
| <b>Total for Planning Area</b>  | <b>10.89</b>                                       | <b>36.20</b>            | <b>25.31</b>  |

1) Average Water Demand

2) Peak Water Demand, due to the absence of existing wells

3) Demand met through Private Wells, No Existing Public Distribution System

### Water Treatment Plant Capacity Phasing

Assuming that the water treatment is operational by the year 2010, the required capacity of the water treatment plant to meet the demand under the aforementioned assumptions is shown in **Table 3-10**.

Assuming groundwater production for the participating utilities remains at the current level (11.5 MGD), the average day surface water demand (water required from a regional surface water plant to meet average day demands over the expected groundwater production) will increase from 8 MGD in 2010 to 25 MGD



## Section 3 Regional Water Supply


in 2050. The difference between the planned plant capacity in 2050 of 25 MGD and the additional capacity required by TNRCC of 47.5 MGD will be added to the individual systems as required by the addition of groundwater production.

**TABLE 3-10  
SURFACE WATER TREATMENT PLANT DEMAND**

| Year | Water Treatment Plant Reserve Capacity (MGD) |
|------|--|
| 2010 | 8  |
| 2020 | 13   |
| 2030 | 17   |
| 2040 | 21   |
| 2050 | 25   |

The water plant can be constructed in one or two phases. For a one phase construction, a 25 MGD surface water plant could be built by the year 2010 and would serve the area through the planning period. For a two phase construction plan, a 15 MGD surface water plant could be built by 2010 and serve the area until the year 2030. At this time, a 10 MGD expansion would be constructed to supply the area through year 2050.

**Figure 3-3  
Two Phase 25 MGD Regional Water Treatment Plant**



The two phased construction also minimizes the required initial capital outlay by only constructing the size facility to meet current and near term needs. A one phased construction approach would require

expenditure of all capital funds in the first phase to build a facility with enough capacity to meet the water demand for all years in the planning horizon. This one phased approach will result in a higher initial water rate to retire the initial capital debt. Through a two phased construction approach, the capital debt payments can be spread over the entire planning period, thereby lowering the annual cost of the debt repayment and minimizing the annual cost of the water. The two phase construction approach meeting the surface water demand of the Participating Utilities over the planning horizon is shown in **Figure 3-4**.

### Water Treatment Plant Capacity and Construction Recommendation

To offer the lowest apparent rates to the residents, it is recommended that the feasibility study proceed on the basis of constructing a 25 MGD water treatment plant under a two phase construction approach. A 15 MGD facility will be built by 2010 with a 10 MGD expansion in the year 2030.

### RAW WATER SOURCE

The raw water source for the Mid-Brazoria surface water plant is as of yet unsecured. This section identified several options that may be pursued by the Regional Planning Group for securing surface water for use in the Mid-Brazoria County Regional WTP.

#### Brazos River

In the Turner Collie and Braden letter report to the Chairman of Region H, dated February 27, 2001, the adopted strategy was to use the Brazos River as the raw water source for the new surface water plant. This report, attached as **Appendix E**, is dated February 27, 2001 and evaluated the following Brazos River conveyance alternatives:

- Purchase contract raw water from the Brazos River Authority and transport this water to the WTP site via a dedicated pipeline from the Brazos River.
- Purchase contract raw water from the Gulf Coast Water Authority and transport this water to the WTP site via the existing GCWA raw water canals that run from the Brazos River through the Mid-Brazoria Region to Galveston County.
- Purchase water rights or contract water from the Chocolate Bayou Water Company and construct a raw water pipeline to transport water from Chocolate Bayou to the WTP site.

The Region H report evaluated each of these options on overall cost necessary to purchase the water, construct conveyance facilities, and maintain the facilities through the year 2050. Based on their evaluation, the option of drawing water through the Gulf Coast Water Authority was the most economical alternative for using Brazos River Water as the surface water source for the Mid-Brazoria Regional Water Plant.

#### Other Sources

In addition to the Brazos River, water from other sources could serve as the raw or treated water source for the MBCPG participants. The following is a brief synopsis of several identified alternatives to Brazos River water.

### Trinity River Basin

The Trinity River is located along the eastern edge of the City of Houston. The City has constructed storage capacity in Lake Livingston and owns a significant allotment of water rights on this river. The City, through Coastal Water Authority, also has in place a system of canals to transport the water from the river to the City of Houston water treatment plant. The City has indicated they can sell treated water. Current indications place the costs of treated wholesale water from the City of Houston for between \$1.10 and \$1.15 per 1,000 gallons. To utilize this source, the MBCPG would need to

- Contract with the City of Houston for treated water
- Finance and construct a new finished water pipeline from the Cities network near Beltway 8 and Hwy 35 to the participating utilities take points.

### Brackish Groundwater

Groundwater sources near the coast of Brazoria County contain higher levels of TDS than allowed by regulations for use as potable water. Treatment of this brackish water is technologically feasible and this water could serve as an alternate water source for the MBCPG. Historically, treatment of brackish water by reverse osmosis has been cost prohibitive.

Dow Chemical, located in Freeport, Texas, has indicated that they would like to propose on constructing a reverse osmosis brackish groundwater treatment plant in Freeport and provide water transmission pipelines to serve the MBCPG. Dow Chemical would then contract with the MBCPG to sell potable water to the participating utilities.

### Raw Water Demand

The raw water demand placed on the GCWA canal by the new surface water plant will be equal to the finished water flow plus the water losses in the treatment process. It is expected that process will lose about 7 percent of the raw water flow in producing the finished water. Therefore, to meet a finished water demand of 25 MGD, the raw water flow entering the plant should be 26.75 MGD, or 7 percent over the desired finished water capacity.



## Section 4

# Development of Treatment Process

---

This section provides discussion of the raw water quality in the Planning Area, along with descriptions of current and potential federal drinking water regulations that have applicability to treatment of this water. The raw water quality data presented below is a summary of the information presented in the Turner Collie and Braden letter report submitted to the Chairman of Region H, dated February 2001 and the *GCWA Regional Surface Water Plant Facility Feasibility Study for Brazoria, Fort Bend, and West Harris Counties* report dated November, 2000.

## WATER QUALITY

### Regional Raw Water Quality for Brazos River

The GCWA report evaluated the raw water quality of the Brazos River, and listed a summary of the historical raw water data. The water quality data was obtained from two sources: United States Geological Society (USGS) data for the Brazos River at the Richmond – Rosenberg Monitoring Station, and data from the GCWA for the river intake and for the raw water at the existing water treatment plant in Texas City. A summary of the available data provided in the report is shown in **Table 4-1**.

The raw water quality evaluation showed that the Brazos River contained elevated levels of total dissolved solids, aluminum, manganese, bromide, and total organic carbon, but the observed contaminant levels in the raw water is easily treatable through conventional processes.

### Federal and State Standards

Federal standards for drinking water are summarized in **Table 4-2**. Standards for the State of Texas are set by the Texas Natural Resources Conservation Commission. In most cases, Texas standards match federal standards. Some secondary standards are different; Texas has a maximum contaminant level (MCL) of 1,000 mg/l for Total Dissolved Solids, and a chloride MCL of 300 mg/l.

Pending federal regulations must be considered in the evaluation of treatment processes for the proposed plant. The Stage 2 Disinfectants/Disinfection By-Products (D/DBP) Rule is expected to maintain current MCLs for total trihalomethanes (TTHMs) and total haloacetic acids (THAAs) at 80 and 60 ug/l. The rule will become more stringent in that individual monitoring sites will be used to determine compliance, rather than on a system-wide basis. This change will probably have the effect of requiring lower levels of TTHMs and THAAs leaving a treatment plant. The recently promulgated Interim Enhanced Surface Water Treatment Rule (ESWTR) set a goal for disinfection/removal of *Cryptosporidium* of zero, with an MCL of 2-log disinfection/removal. The rule grants 2-logs of disinfection/removal credit to facilities using conventional treatment processes that meet other requirements of the rule. A second Enhanced Surface Water Treatment Rule is expected in the future. This rule is expected to focus on more stringent disinfection/removal requirements for microbiological contaminants, such as *Cryptosporidium*. The Backwash Treatment Rule is in development, and is expected to require all plants to recycle waste washwater from backwashing of filters to the head of the treatment process after equalization. The Backwash Treatment Rule is not expected, at least initially, to set treatment limits.

The Stage 1 D/DBPR and the Interim ESWTR were promulgated in December, 1998. Data related to future changes in these two rules has been collected by utilities, and is now under evaluation by EPA and other agencies and groups. The EPA has formed advisory committees to begin a negotiated process for future regulations. Based on the time required for the negotiations for the most recent two regulations, it is anticipated that the Stage 2 D/DBPR and a future ESWTR may be proposed in the next five to ten years. If proposed in this time frame, it is likely that compliance would be required within an additional three to five years after the rules are actually promulgated.



# Section 4

## Development of Treatment Process

**TABLE 4-1  
SUMMARY OF RAW WATER QUALITY**

| Quality Analysis                     | Unit            | BRAZOS RIVER <sup>(1)</sup> |                      | River Intake <sup>(c)</sup> | Raw Water at WTP <sup>(d)</sup> |
|--------------------------------------|-----------------|-----------------------------|----------------------|-----------------------------|---------------------------------|
|                                      |                 | Average <sup>(a)</sup>      | Range <sup>(b)</sup> |                             |                                 |
| Algae count                          | (cells/ml)      |                             |                      | 14214                       |                                 |
| Alkalinity(as CaCO3)                 | Mg/l            | 136                         | 75 - 234             | 156.6                       | 141                             |
| Aluminium, dissolved                 | Ug/l            | 51                          | 10 - 390             |                             |                                 |
| Ammonia Nitrogen (as N)              | Mg/l            | 0.06                        | 0 - 0.23             | 0.068                       |                                 |
| Apparent Color                       | ACU             |                             |                      |                             |                                 |
| Arsenic                              | Ug/l            | 3.0                         | 1 - 7                |                             |                                 |
| Beryllium                            | Ug/l            | 0.6                         | 0.5 - 2              |                             |                                 |
| Boron, dissolved                     | Ug/l            | 119                         | 60 - 170             |                             |                                 |
| Bromate                              | Mg/l            |                             |                      | 0.26                        | 0.07                            |
| Bromide                              | Mg/l            |                             |                      | 0.26                        |                                 |
| Cobalt (as Co)                       | Ug/l            | 2.9                         | 0 - 60               |                             |                                 |
| Cadmium (as Cd)                      | Ug/l            | 1.4                         | 0 - 3                |                             |                                 |
| Calcium                              | Mg/l            | 60                          | 28 - 100             |                             | 53                              |
| Chloride                             | Mg/l            | 114                         | 12 - 370             | 118                         | 67                              |
| Chromium (as Cr)                     | Ug/l            | 10                          | 0 - 20               |                             |                                 |
| Copper (as Cu)                       | Ug/l            | 16.8                        | 5 - 47               |                             |                                 |
| Dissolved oxygen                     | Mg/l            | 8.6                         | 5.4 - 12             | 6.8                         |                                 |
| DOC                                  | Mg/l            | 11                          | 4.2 - 25             | 4.09                        |                                 |
| Fecal coliform, 7um-mf               | colonies/100 ml | 730                         | 12 - 7,300           |                             |                                 |
| Flouride                             | Mg/L            | 0.3                         | 0.1 - 0.5            |                             |                                 |
| Glyphosate                           | Ug/l            |                             |                      |                             |                                 |
| H <sub>2</sub> S                     | Mg/L            |                             |                      |                             |                                 |
| Iron, Total (as Fe)                  | Ug/l            | 5500                        | 390 - 22,000         | 2650                        | 24                              |
| Kjeldahl Nitrogen                    | Mg/l            | 0.9                         | 0.01 - 7.3           |                             |                                 |
| Lead (as Pb), Total                  | Ug/l            | 24.5                        | 2 - 65               |                             |                                 |
| Lithium (dissolved as Li)            | Ug/l            | 14.3                        | 6 - 30               |                             |                                 |
| Magnesium                            | Mg/l            | 13                          | 3.5 - 71             |                             | 20                              |
| Manganese, Total (as Mn)             | Ug/l            | 205                         | 5 - 740              |                             |                                 |
| Mercury (as Hg), Total               | Ug/l            | 0.2                         | 0.1 - 0.4            |                             |                                 |
| Molybdenum (dissolved as Mo)         | Ug/l            | 10.2                        | 10 - 20              |                             |                                 |
| Nickel (as Ni), Total                | Ug/l            | 8.9                         | 2 - 30               |                             |                                 |
| Nitrate                              | Mg/l            | 0.4                         | 0.01 - 1.5           | 1.47                        | 1.40                            |
| Nitrite                              | Mg/l            | 0.04                        | 0 - 0.29             | 0                           | 0.05                            |
| Odor                                 |                 |                             |                      |                             |                                 |
| Organic Nitrogen                     | Mg/l            | 0.9                         | 0.15 - 4.3           | 0.86                        |                                 |
| Ortho-Phosphate Phosphorus (as P)    | Mg/l            | 0.1                         | 0.01 - 0.13          |                             | 0.18                            |
| PH                                   | Units           | 7.9-8.0                     | 7.4 - 8.5            | 8.4                         | 8.2                             |
| Potassium                            | Mg/l            | 4.7                         | 1.8 - 7.5            |                             |                                 |
| Selenium (as Se), Total              | Ug/l            | 0.5                         | 0 - 1                |                             |                                 |
| Silica                               | Mg/l            | 8.7                         | 0.3 - 40             | 8.4                         |                                 |
| Silver (as Ag), Total                | Ug/l            | 0.6                         | 0 - 1                |                             |                                 |
| Sodium                               | Mg/l            | 80                          | 9.5 - 240            |                             |                                 |
| Specific Conductance                 | Umho/cm         | 770                         | 220 - 1,900          | 700                         |                                 |
| Streptococci fecal, membrane         | colonies/100 ml | 860                         | 20 - 9,100           |                             |                                 |
| Strontium (dissolved as Sr)          | Ug/l            | 570                         | 70 - 1,000           |                             |                                 |
| Sulfate (as SO <sub>4</sub> )        | Mg/l            | 76                          | 16 - 200             |                             | 57                              |
| TDS                                  | Mg/L            | 430                         | 50 - 980             | 440                         | 140                             |
| Temperature                          | OC              | 20                          | 3.5 - 33.5           |                             |                                 |
| Total Hardness, Non Carbonate        | Mg/L            | 70                          | 0 - 190              |                             |                                 |
| Total Hardness, as CaCO <sub>3</sub> | Mg/l            | 200                         | 90 - 470             |                             | 189                             |
| Total Nitrogen N                     | Mg/l            |                             |                      | 0.90                        |                                 |
| Total Organic Carbon (as C)          | Mg/l            | 10                          | 2.7 - 44             | 4.80                        | 4.8                             |
| Total Organic Halogen                | Ug/l            |                             |                      |                             |                                 |
| Total Phosphorus P                   | Mg/l            | 0.2                         | 0.04 - 0.95          | 0.07                        |                                 |
| TSS                                  | Mg/L            | 1150                        | 12 - 7,360           | 280                         | 19.8                            |
| Turbidity                            | NTU             | 150                         | 0.4 - 890            | 160                         | 50                              |
| UV-254                               | 1/cm            |                             |                      | 0.10                        |                                 |
| Vanadium (dissolved as V)            | Ug/l            | 6.1                         | 6 - 8                |                             |                                 |
| Zinc ( as Zn), Total                 | Ug/l            | 60                          | 20 - 120             |                             |                                 |

1 : Richmond-Rosenberg Monitoring Station

a : Average of samples taken from 1970 to 1995.

c : Shannon Lift Station, Year 1990

b : Range of samples taken from 1970 to 1995.

d : Dr. Thomas Mackey Water Treatment Plant





## Section 4

# Development of Treatment Process

**TABLE 4-2  
SUMMARY OF FEDERAL AND STATE STANDARDS**

| Volatile Organic Chemicals     | Max Contaminant Level (mg/l) |
|--------------------------------|------------------------------|
| 1,1-Dichloroethylene           | 0.007                        |
| 1,1,1-Trichloroethane          | 0.2                          |
| 1,1,2-Trichloroethane          | 0.005                        |
| 1,2-Dichloroethane             | 0.005                        |
| 1,2-Dichloropropane            | 0.005                        |
| 1,2,4-Trichlorobenzene         | 0.07                         |
| Benzene                        | 0.005                        |
| Carbon tetrachloride           | 0.005                        |
| Cis-1,2-Dichloroethylene       | 0.07                         |
| Dichloromethane                | 0.005                        |
| Ethylbenzene                   | 0.7                          |
| Monochlorobenzene              | 0.1                          |
| o-Dichlorobenzene              | 0.6                          |
| para-Dichlorobenzene           | 0.075                        |
| Styrene                        | 0.1                          |
| Tetrachloroethylene            | 0.005                        |
| Toluene                        | 1                            |
| trans-1,2-Dichloroethylene     | 0.1                          |
| Trichloroethylene              | 0.005                        |
| Vinyl chloride                 | 0.002                        |
| Xylenes (total)                | 10                           |
| Synthetic Organic Chemicals    | Max Contaminant Level (mg/l) |
| 2,3,7,8-TCDD (Dioxin)*         | $3 \times 10^{-8}$           |
| 2,4-D                          | 0.07                         |
| 2,4,5-TP (Silvex)              | 0.05                         |
| Alachlor                       | 0.002                        |
| Atrazine                       | 0.003                        |
| Benzo(a)pyrene                 | 0.0002                       |
| Carbofuran                     | 0.04                         |
| Chlordane                      | 0.002                        |
| Dalapon                        | 0.2                          |
| Di(2-ethylhexyl)adinate        | 0.4                          |
| Di(2-ethylhexyl)phthalate      | 0.006                        |
| Dibromochloro-propane (DBCP)   | 0.0002                       |
| Dinoseb                        | 0.007                        |
| Diquat                         | 0.02                         |
| Endothall                      | 0.1                          |
| Endrin                         | 0.002                        |
| Ethylene dibromide             | 0.00005                      |
| Glyphosate                     | 0.7                          |
| Heptachlor                     | 0.0004                       |
| Heptachlor epoxide             | 0.0002                       |
| Hexachlorobenzene              | 0.001                        |
| Hexachlorocyclo-pentadiene     | 0.05                         |
| Lindane                        | 0.0002                       |
| Methoxychlor                   | 0.04                         |
| Oxamyl (vydate)                | 0.2                          |
| Pentachlorophenol              | 0.001                        |
| Picloram                       | 0.5                          |
| Polychlorinated biphenyl (PCB) | 0.0005                       |
| Simazine                       | 0.004                        |
| Toxaphene                      | 0.003                        |
| Acrylamide                     | TT                           |
| Epichlorohydrin                | TT                           |



## Section 4

# Development of Treatment Process

**TABLE 4-2 (CONTINUED)**  
**SUMMARY OF FEDERAL AND STATE STANDARDS**

| Disinfection                   | Max Contaminant Level (mg/l)  |
|--------------------------------|-------------------------------|
| Total Trihalomethanes (TTHMs)  | 0.080                         |
| Haloacetic Acids (HAAs)        | 0.060                         |
| Bromate                        | 0.010                         |
| Chlorite                       | 1.0                           |
| Maximum Residual Disinfectant  |                               |
| Chlorine                       | 4.0                           |
| Chloramines                    | 4.0 as Total Chlorine         |
| Chlorine Dioxide               | 0.8                           |
| Enhanced Coagulation           | Treatment Technique           |
| Giardia Lamblia                | 3-log inactivation/removal    |
| Viruses                        | 4-log inactivation/removal    |
| Cryptosporidium                | 2-log inactivation/removal    |
| Inorganics                     | Max Contaminant Level (mg/l)  |
| Antimony                       | 0.006                         |
| Arsenic                        | 0.05                          |
| Asbestos                       | 7 MFL > 10microns             |
| Barium                         | 2                             |
| Beryllium                      | 0.004                         |
| Cadmium                        | 0.005                         |
| Chromium                       | 0.1                           |
| Copper                         | 1.3 action level              |
| Cyanide                        | 0.2                           |
| Fluoride                       | 4.0                           |
| Lead                           | 0.015 action level            |
| Mercury                        | 0.002                         |
| Nickel                         | 0.1                           |
| Nitrate                        | 10 (as N)                     |
| Nitrite                        | 1 (as N)                      |
| Total Nitrate and Nitrite      | 10 (as N)                     |
| Selenium                       | 0.05                          |
| Thallium                       | 0.002                         |
| Secondary Standards            | Max Contaminant Level (mg/l)  |
| Aluminum                       | 0.05 to 0.2                   |
| Chloride                       | 250                           |
| Color                          | 15 color units                |
| Copper                         | 1                             |
| Corrosivity, Sat. Index        | Non-corrosive                 |
| Fluoride                       | 2.0                           |
| Foaming Agents                 | 0.5                           |
| Iron                           | 0.3                           |
| Manganese                      | 0.05                          |
| Odor-TON <sup>b</sup>          | 3                             |
| PH                             | 6.5-8.5                       |
| Silver                         | 0.1                           |
| Sulfate                        | 250                           |
| Total Dissolved Solids         | 500                           |
| Zinc                           | 5                             |
| Solids                         | Max Contaminant Level         |
| Turbidity                      | 0.3 ntu                       |
| Microbiological                |                               |
| Total Coliform                 | Presence/Absence              |
| Radionuclides                  | Max Contaminant Level (pCi/l) |
| Combined Radium-226 and 228    | 5                             |
| Gross Alpha (incl. Radium-228) | 15                            |
| Tritium                        | 20,000                        |
| Strontium-90                   | 8                             |
| Uranium                        | 30 ug/L                       |



## Section 4

# Development of Treatment Process

---

A future ESWTR has not been proposed, nor has EPA suggested what contaminants, nor what levels of treatment may be regulated. It is recommended that the process treatment selection NOT be selected to meet the undefined requirements of the future EWSTR additional disinfection/removal requirements at this time. The federal advisory committee is currently discussing a period of monthly monitoring for *Cryptosporidium*. Based on the monitoring results, action levels would trigger additional inactivation/removal requirements. For example 1.0 to 3.0 oocysts/l of *Cryptosporidium* would trigger an additional 2.0 log inactivation/removal requirement. Multiple approaches for achieving inactivation/removal credit may be allowed, including watershed protection, enhanced turbidity removal, in addition to a mandatory partial disinfection process that is broadly defined as Ultraviolet light, ozone, or membranes.

It is recommended, however, that the treatment process evaluation consider the adaptability of the process to possible changes by this rule. It is recommended that an allocation (both site area and hydraulic head) be set aside for future processes that may be required by this rule.

### FINISHED WATER QUALITY GOALS

The key water quality goals for the proposed WTP are listed in **Table 4-3**. The goals are based on federal Primary and Secondary Standards, and TNRCC standards from its draft proposal for Chapter 290, Subchapter F, Drinking Water Standards Governing Drinking Water Quality and Reporting Requirements for Public Water Supply Systems. The new TNRCC standards are for turbidity, TTHMs, THAAs, bromate, chlorite, and enhanced coagulation.

**TABLE 4-3  
SUMMARY OF TREATMENT GOALS**

| Parameter              | Units | Treatment Goal                | Remarks  |
|------------------------|-------|-------------------------------|--|
| <i>Giardia Lamblia</i> | -     | 0.5-log chemical disinfection | 2.5-log removal provided by conventional process |
| <i>Cryptosporidium</i> | -     | No additional treatment       | 2-log removal provided by conventional process   |
| Viruses                | -     | 2.0-log chemical disinfection | 2-log removal provided by conventional process   |
| Turbidity              | Ntu   | < 0.1                         |  |
| TOC                    | mg/l  | Up to 25 percent removal      |  |
| Total coliform         | -     | Not detectable                |  |
| Alkalinity, Total      | mg/l  | No additional treatment       |  |
| Langlier Index         | mg/l  | Between 0.1 and 0.4           |  |
| Total Hardness         | mg/l  | No additional treatment       |  |
| pH                     | -     | Between 7.5 and 8.0           |  |
| Chlorite               | mg/l  | < 1.0                         |  |
| Total Haloacetic Acids | ug/l  | < 30                          | Quarterly running average in distribution system |
| Total Trihalomethanes  | ug/l  | < 40                          | Quarterly running average in distribution system |

## TREATMENT PROCESS

The recently completed GCWA report performed a detailed evaluation of several alternative treatment processes to determine the most cost effective method of treating Brazos River water. In their report, the GCWA evaluated the following three treatment alternatives.

- Conventional process - The conventional process is similar to the existing Dr. Thomas Mackey WTP in Texas City.
- A high-rate conventional process - The high-rate conventional process assumes that a high-rate pretreatment process is used to reduce the space and cost of pretreatment before filtration.
- A membrane filtration process - The membrane filtration process is experiencing more widespread use in the United States as the cost of membranes and the cost of pumping associated with the membrane treatment is lowered.

The GCWA evaluated the three alternatives in terms of finished water quality, capital costs required to construct the water treatment plant, and the operating and maintenance costs to operate each alternative process facilities. With regards to a 35 MGD water treatment plant, the GCWA report concluded the following:

- The high-rate conventional process had the lowest overall project cost including capital expenditures and operating and maintenance costs over the lifespan of the project,
- The high-rate conventional process met required finished water goals, and
- The high-rate conventional process was easily adaptable to changes in finished water regulations.


As the regional water treatment plant for the Mid-Brazoria County Planning Group will have the same water source and be of a capacity similar to the GCWA 35 MGD plant alternative, a high-rate conventional process plant is also expected to be the most cost-effective treatment process for the proposed 25 MGD MCBPG WTP.

### High Rate Conventional Process

The High-rate conventional process has the following unit operations:

|                              |   |
|------------------------------|---|
| <i>Oxidation</i>             | <i>Chlorine dioxide</i>                         |
| <i>Pretreatment</i>          | <i>High Rate Solids contact (Pulsed Upflow)</i> |
| <i>Filtration</i>            | <i>Media filters</i>                            |
| <i>Adsorption</i>            | <i>Powdered and Granular Activated Carbon</i>   |
| <i>Primary disinfectant</i>  | <i>Chlorine dioxide</i>                         |
| <i>Residual disinfectant</i> | <i>Chloramine</i>                               |

A process schematic for the conventional process with High-Rate Pretreatment is shown in **Figure 4-1**. Pre-oxidation is accomplished with chlorine dioxide. Taste and odor control is accomplished with chlorine dioxide or PAC addition. This treatment process is similar to the conventional process, except that the pretreatment process is solids-contact type utilizing pulsed upflow clarifiers. These proprietary units can be operated at higher rates than is normally allowed for conventional processes. The high-rate process combines two processes into a single unit. The high rate process results in space savings because



MID-BRAZORIA COUNTY PLANNING GROUP/TWDB  
FACILITY PLAN

HIGH-RATE CONVENTIONAL  
PROCESS SCHEMATIC

FIGURE 4-1

## Section 4

# Development of Treatment Process

---

of the smaller basin volume which in-turn results in reduced construction costs. This process is proven with source waters similar to those for this facility. In addition, the clarifiers maintain a sludge blanket, which when used in conjunction with powdered activated carbon, is an efficient process for removing organic material. Filters are assumed to be deep-bed, constant-level, constant loading filters. Media is assumed to be granular activated carbon (for taste and odor control) with an underlayer of sand. Additional processes that may be required by future regulations include post-sedimentation ozone or chlorine dioxide for inactivation of *Cryptosporidium*, and / or post-filtration membrane filtration or UV disinfection. Circular concrete, aboveground tanks are provided for storage of finished water. Sludge from the pretreatment process is sent to a gravity thickener for preliminary separation of solids and water. Thickened sludge is dewatered on-site with centrifuges. Ultimate disposal is to a permitted disposal site. Dirty filter backwash water is equalized and clarified, and then recycled to the head of the treatment process.

### PROCESS CRITERIA

Criteria for unit processes are listed in Table 4-4. Where applicable, criteria is based in TNRCC criteria contained in Subchapter D: Rules and Regulations for Public Water Systems, 290.42, Water Treatment. Criteria for proprietary process equipment, such as the pulsed upflow clarifiers and membranes are based on manufacturer's recommendations. Criteria for other unit processes are based on criteria from "Integrated Design of Water Treatment Facilities" by Kawamura.

## Section 4

# Development of Treatment Process

**TABLE 4-4**  
**CRITERIA FOR SIZING WATER TREATMENT PROCESSES**

| Sizing Criteria                          | Units                           | Value       |
|--|---------------------------------|-------------|
| <b>Mixing</b>                            |                                 |             |
| Type                                     | Pumped Diffusion                |             |
| Velocity Gradient                        | sec <sup>-1</sup>               | 2000        |
| <b>Flocculation Basins</b>               |                                 |             |
| No. Stages                               | Each                            | 4           |
| Velocity Gradient                        | sec <sup>-1</sup>               | 75,60,40,25 |
| Type                                     | Vertical Turbine                |             |
| Detention Time                           | Minutes                         | 30          |
| <b>Conventional Sedimentation Basins</b> |                                 |             |
| Type                                     | Rectangular, Plug Flow          |             |
| L:W Ratio                                |                                 | > 4:1       |
| Depth                                    | Ft                              | 12          |
| Surface Loading Rate                     | gpm/ft <sup>2</sup>             | 0.6         |
| <b>Media Filters</b>                     |                                 |             |
| Type                                     | Deep Bed, Dual Media (GAC/Sand) |             |
| L/d Ratio                                |                                 | 1500        |
| L:W Ratio                                |                                 | 2           |
| Loading Rate (one filter off-line)       | gpm/ft <sup>2</sup>             | 5           |
| Backwash Rate                            | gpm/ft <sup>2</sup>             | 22          |
| Average Filter Runtime                   | Hours                           | 72          |
| Auxiliary Wash Type                      | Air Scour                       |             |
| Auxiliary Wash Rate                      | scfm/sq ft                      | 3.0         |
| <b>Gravity Thickener</b>                 |                                 |             |
| Solids loading rate                      | lb/ft <sup>2</sup>              | 9           |
| Hydraulic Loading Rate                   | gpm/ft <sup>2</sup>             | 0.12        |
| <b>Sludge Lagoon Process</b>             |                                 |             |
| Loading Rate                             | lb/ft <sup>2</sup>              | 14          |
| Minimum length                           | Ft                              | 100         |
| Storage Capacity per Unit                | Months                          | 3           |
| Minimum Number of Units                  | Each                            | 4           |
| <b>Waste Washwater Equalization</b>      |                                 |             |
| Type                                     | Rectangular, Sloped Bottom      |             |
| L:W Ratio                                |                                 | 4           |
| SWD                                      | Ft                              | 16          |
| Storage Volume                           | # of backwashes                 | 3           |
| <b>Waste Washwater Clarification</b>     |                                 |             |
| Clarifier Type                           | Lamella                         |             |
| Clarifier Loading Rate                   | gpm/ft <sup>2</sup>             | 0.2         |
| Sludge Removal                           | %                               | 85          |



## Section 4

# Development of Treatment Process

**TABLE 4-4 (CON'T)**  
**CRITERIA FOR SIZING WATER TREATMENT PROCESSES FEED CRITERIA**

| Sizing Criteria                | Units                               | Value   |
|--------------------------------|-------------------------------------|---------|
| <b>Dewatering</b>              |                                     |         |
| Holding Tank Capacity          | days                                | 4       |
| Holding Tank Depth             | ft                                  | 30      |
| Centrifuge Type                | Solid Bowl                          |         |
| Hydraulic Loading Rate         | Gpm/unit                            | 200     |
| <b>Finished Water Storage</b>  |                                     |         |
| Operational Volume             | Hours                               | 4       |
| Type                           | Above Ground, Pre-stressed Concrete |         |
| <b>High-Rate Clarification</b> |                                     |         |
| Type                           | Pulsed-Upflow                       |         |
| Unit Design Application Rate   | Gpm/ft <sup>2</sup>                 | 2.1     |
| <b>Membrane Filtration</b>     |                                     |         |
| Design Flux                    | gfd                                 | 70      |
| Average Recovery               | %                                   | 90      |
| Temperature                    | Degrees C                           | 10      |
| Maximum TMP                    | psi                                 | 13      |
| Cleaning Cycle                 | Per year                            | 4 (max) |

Expected chemical feed criteria based on other regional water treatment plants treating lower Brazos River water are shown in **Table 4-5**. It should be noted that these chemical doses are preliminary and represent likely chemical doses at the water plant. It would be advantageous to establish a pilot plant to test and optimize chemical doses.

**TABLE 4-5**  
**CHEMICAL FEED CRITERIA**

| Chemical                 | Purpose                                | Avg. Dose (mg/l) | Application Point                              |
|--------------------------|--|------------------|--|
| Ferric sulfate           | Coagulant                              | 30               | Flash Mix Pump                                 |
| Cationic Polymer         | Coagulant Aid                          | 5                | Flash Mix Pump                                 |
| Anionic Polymer          | Flocculant / Filter Aid                | 1                | After Flash Mix Pump and Settled Water Channel |
| Sodium Chlorite          | Form Chlorine Dioxide for Disinfection | 0.8              | Chlorine Dioxide Generator                     |
| Chlorine                 | Form Chlorine Dioxide for Disinfection | 0.8              | Following Low Lift Pumps and Clarifier         |
| Chlorine – BW            | Disinfection                           | 5                | Backwash Supply Pipe                           |
| Chlorine                 | Residual Disinfection                  | 3                | Following Transfer Pumps                       |
| Ammonia                  | Disinfection                           | 1                | Following Transfer Pumps                       |
| PAC                      | Taste and Odor                         | 10               | Following Low Lift Pumps                       |
| Caustic Soda             | pH Adjustments                         | 10               | Following Transfer Pumps                       |
| Fluoride                 | Aesthetics                             | 0.6              | Following Transfer Pumps                       |
| Poly – or orthophosphate | Corrosion Inhibitor                    | 0.5              | Following Transfer Pumps                       |
| Copper Sulfate           | Algae Control                          |                  | Raw Water Reservoir                            |



## Section 4

# Development of Treatment Process

---

### Water Treatment Process Costs

For a high-rate conventional water treatment plant, estimated construction costs were developed based on the preliminary process sizing using the aforementioned design criteria. Estimates of the O&M costs were calculated based on the labor, maintenance, and electrical demands of the plant process based on a capacity of 25 MGD. **Table 4-6** summarizes the construction cost for a two phased construction effort as described in **Section 3**. Details of the construction estimate can be found in **Appendix F**.

**TABLE 4-6**  
**ALTERNATIVE PROCESS CONSTRUCTION COST ESTIMATE (YR 2000\$)**

| Unit  | High Rate Conventional<br>Water Treatment Process |
|---|---|
| Sitework  | \$3,500,000                                       |
| Yard Piping                                       | \$2,125,000                                       |
| Low Lift Pumping                                  | \$792,000   |
| Mixing/Flocculation/Sedimentation                 | \$1,170,000                                       |
| Filters   | \$5,467,000                                       |
| Transfer Pumping                                  | \$780,000   |
| PAC System  | \$250,000   |
| Backwash Equalization Tank                        | \$232,000   |
| Backwash Clarification                            | \$106,000   |
| Gravity thickeners/holding tanks                  | \$16,000  |
| Chemical Systems, Building, Tanks                 | \$5,335,000                                       |
| Sludge Lagoons                                    | \$888,000   |
| Ground Storage Tanks                              | \$2,800,000                                       |
| <b>Subtotal</b>                                   | <b>\$23,461,000</b>                               |
| Electrical, Instrumentation, and Controls         | \$3,050,000                                       |
| <b>Subtotal</b>                                   | <b>\$26,511,000</b>                               |
| Mobilization                                      | \$795,000   |
| <b>Subtotal</b>                                   | <b>\$27,306,000</b>                               |
| Construction Management, Insurance, Bonds, Profit | \$3,550,000                                       |
| <b>Total</b>                                      | <b>\$30,856,000</b>                               |

The high rate conventional plant has an estimated construction cost at \$30.9 M, which equates to \$1.23 cents per gallon of capacity. Construction contingency and engineering fees are not included in these calculations as they are percentages of construction and are independent of the process selection.

The O&M costs to operate the plant include the following items:

- Electricity,
- Maintenance,
- Chemicals,
- Labor,
- Sludge disposal, and
- Administration

The costs for the operating and maintenance were based on recent quotes from vendors and current operations at the GCWA Dr. Thomas Mackey Water Treatment Plant, which treats the same water as

## Section 4

# Development of Treatment Process

expected for this regional water treatment plant. A summary of the O&M costs for a high-rate conventional process appear in Table 4-7.

**TABLE 4-7**  
**HIGH RATE CONVENTIONAL PROCESS O&M COST ESTIMATE (YR 2000\$)**

| O&M Component   | Annual Usage           | Units             | Unit Cost                   | Annual Cost        |
|---|------------------------|-------------------|-----------------------------|--------------------|
| Process Electrical  |                        |                   |                             |                    |
| Chemical  |                        |                   |                             |                    |
| Ferric  | 1256                   | tons              | \$450                       | \$ 565,200         |
| Cationic Polymer  | 209                    | tons              | \$1,000                     | \$ 209,000         |
| Anionic Polymer   | 21                     | tons              | \$1,500                     | \$ 31,500          |
| Sodium Chlorite   | 34                     | tons              | \$1,000                     | \$ 34,000          |
| Chlorine - ClO2   | 35                     | tons              | \$400                       | \$ 14,000          |
| Chlorine - BW   | 10                     | tons              | \$400                       | \$ 4,000           |
| Chlorine - Residual Disinfectant                                    | 114                    | tons              | \$400                       | \$ 45,600          |
| Ammonia   | 38                     | tons              | \$350                       | \$ 13,300          |
| PAC   | 419                    | tons              | \$1,100                     | \$ 460,900         |
| Caustic Soda  | 381                    | tons              | \$600                       | \$ 228,600         |
| Fluoride  | 23                     | tons              | \$1,500                     | \$ 34,500          |
| Corrosion Inhibitor, mg/L   | 19                     | tons              | \$5,200                     | \$ 98,800          |
| <b>Total Chemical</b>   |                        |                   |                             | <b>\$1,739,400</b> |
| Sludge Disposal   | 8,200                  | Yd3               | \$15                        | \$246,000          |
| Maintenance   | 1.7                    | % of construction |                             | \$525,000          |
| GAC Replacement   | 5832                   | Ft3               | \$100                       | \$583,000          |
| <b>Labor</b>  |                        |                   |                             |                    |
|   | <b>Number at Plant</b> |                   | <b>Burdened Hourly Rate</b> |                    |
| Process Operators   | 6                      |                   | \$25.50                     | \$318,000          |
| Electrician, Instrument Tech  | 2                      |                   | \$33.75                     | \$140,000          |
| Maintenance   | 3                      |                   | \$27.00                     | \$168,000          |
| Administration  | 1                      |                   | \$19.50                     | \$41,000           |
| Superintendent  | 1                      |                   | \$49.50                     | \$103,000          |
| <b>Total</b>  | <b>13</b>              |                   | <b>\$28.50</b>              | <b>\$770,000</b>   |
| <b>Administration</b>   | <b>---</b>             |                   | <b>---</b>                  | <b>\$600,000</b>   |
| <b>Total Annual O&amp;M for 25 MGD High Rate Conventional Plant</b> |                        |                   |                             | <b>\$4,702,000</b> |

The high rate conventional O&M costs for a 25 MGD plant is \$4.7 M per annum. These O&M costs exclude high service pumping and raw water delivery costs which are a function of plant location and will be considered in the site location study.

These costs will be entered into part of the alternative selection process for the Regional Surface Water as described in Section 7 of this report.

# Section 5

## Water Treatment Plant Site Development

---

One of the most important steps in this feasibility study is selecting the site for any treatment facility. The decision to select one site over another is complex and is influenced by many diverse criteria. This chapter will review these criteria with respect to several alternative sites throughout the planning area and summarize the benefits and costs associated with each alternative site.

### APPROACH TO SITE SELECTION

One of the first tasks in this study was to identify possible sites of a water treatment facility. In order to evaluate the entire planning area, a selection approach was developed to ensure that all alternatives were considered and that the benefits to each Participating Utility were taken into consideration in the selection of the alternative WTP sites. The approach consisted of the following three steps:

- Establishment of Preliminary Siting Criteria
- Identify Candidate Sites
- Preliminary Screening
- Final Screening

This approach allowed the Participating Utilities to have control over the selection of the water treatment plant site and to offer input at each stage in the process. The following is a detailed description of the site selection process.

### Establishment of Preliminary Siting Criteria

The first step was to identify potential sites for the water treatment plant. The Planning Group reviewed 5 alternative land parcels as potential sites based on the following criteria: estimated required acreage for the water plant, proximity of the plant to the Participating Utilities and the raw water source, proximity to greatest demand areas, surface features, and proximity to major highway and utilities. Each of these criteria is discussed below:

#### Estimated Minimum Acreage Required For A Water Plant

A key siting criterion is the minimum site area required to accommodate the necessary plant facilities. The layout of the facilities on the site has a large impact on the total required area. Water treatment plants with high-rate process units and compact, common-wall construction require less space than conservatively sized stand-alone process basins. According to Kawamura in “Integrated Water Treatment Plant Design”, the required plant area for the basic process facilities of a conventional treatment plant is  $Q^{0.6}$ , where  $Q$  is the ultimate capacity of the plant in MGD. For a design flow of 25 MGD, the minimum plant area would then be 8 acres.

Ideally, the site should also contain ample land for a raw water forebay, sludge disposal, pipeline easements, finished water storage, and future expansion. Based on the data from local water treatment plants, an additional 35 to 80 acres would be required to support these ancillary facilities.

For this preliminary selection of potential water treatment plants, acceptable sites were limited to those with enough acreage to accommodate the basic processes of the water treatment plant. Preference was also given to sites with enough acreage to accommodate the ancillary facilities as well as the basic processes. Therefore the minimum acceptable parcel of land is 7 acres, with a preference for sites with a minimum of 43 acres.

#### Proximity to the Water Source and Distribution System

Another criterion for selecting the location of water plant facilities is the proximity of the plant to the raw water source and the customer. It is desirable to keep the raw water piping as short as practicable to

## Section 5

# Water Treatment Plant Site Development

---

simplify the maintenance and reduce the cost of the raw water pipeline. The new water plant can withdraw water indirectly from the Brazos River through the existing GCWA American and Briscoe Canals, and/or the Chocolate Bayou Water Company, depending on the site location. Sites adjacent to or in very close proximity to the Canals will be given preference, as no raw water pipeline will be required, and less energy will be expended in pumping water consumed by in-plant needs (backwash, sludge, etc.).

Similarly, the water treatment plant site should be located in close proximity to the distribution system. This will minimize the size of the finished water transmission pipelines and the cost of pumping the water to the Participating Utilities. Duplication of the raw water and finished water pipelines should also be avoided.

### Site Surface Features


A potential site should be relatively flat without any major obstacles, such as fault zones, wetlands, areas prone to flooding, or encumbrances. This cursory review of the planning area for potential sites looked for sites in areas without large areas of known wetlands, utility encumbrances, or flood plains. Although wetlands and utilities can be relocated and levees can be built to protect the facility from flooding, these attributes of a site are not desirable and result in additional site work that increases cost and complicates permitting from regulating bodies. Sites without these surface features were given a higher rating in this preliminary site selection.

### Proximity to major highway and utilities

The site should be as close as practicable to major roads and highways to minimize any costs in providing acceptable access to the site for delivery and sludge vehicles. The site should be as close as practicable to existing power lines, sanitary sewer, gas, and storm discharge facilities to minimize costs associated with providing these necessary utilities to the water plant site.

### Identify Candidate Sites

Based on these criteria, the Participating Utilities team assessed the planning area and developed a list of alternative water treatment sites. The location of the sites that were selected by the Participating Utility team are shown in **Figure 5-1**. The listing of these sites with a brief description appears in **Table 5-1**.



Selected sites  
 Alternate sites

MID-BRAZORIA COUNTY PLANNING GROUP/TWDB  
FACILITY PLAN

WATER TREATMENT PLANT SITES

FIGURE 5-1

# Section 5

## Water Treatment Plant Site Development

**TABLE 5-1  
POTENTIAL WATER TREATMENT PLANT SITES**

| Plant Site         | Location                  |              |   | Description   | Approx. Usable Acreage (AC) |
|--------------------|---------------------------|--------------|---|---|-----------------------------|
|                    | Current Owner             | Nearest City | Closest Raw Water Source  |   |                             |
| A – Manvel         | Private                   | Manvel       | GCWA A or B Canal   | SH 6 at Briscoe Canal and Lateral 19 intersection in Manvel                                     | 50                          |
| B – Pearland/Alvin | Private                   | Alvin        | GCWA A Canal  | Near CR 285 and CR 144 west of Friendswood in Alvin ETJ   | 100                         |
| C – Alvin          | Alvin/ Briscoe Properties | Manvel       | GCWA A or B Canal / Chocolate Bayou Water Company Canal (via Pipeline)  | West of Alvin adjacent to Saladino Road. Adjacent to Site D and City of Alvin Landfill Property | 643                         |
| D – Alvin          | Briscoe Properties        | Manvel       | GCWA A or B Canal   | Near Parker Davis and West Road, west of Alvin adjacent to Site C                               | 919                         |
| E – Alvin          | Briscoe Properties        | Alvin        | GCWA A or B Canal or Chocolate Bayou Water Company Canal (via Pipeline) | Hwy 35 and Briscoe Canal south of Alvin   | 278                         |

### Preliminary Screening

The next step in the site selection process was to evaluate these five sites with respect to their preliminary siting criteria. The five sites contained in the preliminary review represent a geographically diverse selection across the planning area, each with a minimum usable acreage of 50 acres, meeting the minimum criteria established above. The following is a general comparison of the five sites in relation to the screening criteria.

### Evaluation of Minimum Acreage Requirements

All five sites have the required minimum acreage with several sites having large open expanses of land available for use. The additional acreage is a valuable attribute of the sites providing land for future expansions, sludge disposal, buffer zone, or a raw water reservoir. The Manvel site is the smallest of the five sites and will yield a constrained site layout.

On the basis of available acreage, Sites B and E in Alvin, and Sites C and D in Manvel, were the most desirable as the large amount of usable land at each of these sites offers the following advantages:

- Operational flexibility. Layout of plant not scripted by limited site configuration,
- Future Expansion Possibilities, and
- Inclusion of Ancillary WTP options. Sludge Disposal, Raw Water Reservoir, Additional Finished Water Storage

## Section 5

# Water Treatment Plant Site Development

---

### Evaluation of Proximity of Site to Raw Water Source and Finished Water Demand

#### *Proximity of Site to Raw Water Source*

All the five selected sites are located close to a GCWA raw water canal. By locating the water plant as close to the raw water source as possible, the raw water transport costs are minimized or in some cases eliminated. The following compares proximity to primary and alternative raw water sources for each site:

Site A, in Manvel, has a distinct advantage in this regard, as it can be served from either the American Canal (through lateral 10) or the Briscoe Canal. This site is also located approximately 5 miles from the existing Chocolate Bayou Water Company raw water pump station.

Of the remaining four sites, Site E in Alvin is the closest to the Chocolate Bayou, which can be the alternative raw water source, the primary being the Gulf Coast Water Authority Briscoe Canal.

Site B, in Pearland/Alvin is adjacent to the Gulf Coast Water Authority American Canal, but does not have any alternate raw water source. Transportation of raw water from the Chocolate Bayou will be expensive, as a major raw water transmission line of approximately 10 miles will be needed.


Sites C and D in Alvin have the Gulf Coast Water Authority Briscoe Canal as the primary water source. Chocolate Bayou can be the alternative source, but a raw water transmission line of over 2 miles will have to be constructed.

#### *Proximity of Site to Finished Water Demand*

The planning area can be divided into two areas of potable water demand. This division is based on the population within each area. For the purpose of this evaluation, the City of Pearland, and the City of Brookside Village constitute "Demand Area A", and comprises of approximately 50% of the total population of the Planning Area. The cities of Manvel, Alvin, Angleton, Danbury, Hillcrest, and Iowa Colony form the "Demand Area B". These two demand areas are shown in **Figure 5-2**. The proximity of the proposed plant location to the water demand is shown in **Table 5-2**. Since it is desirable to locate the plant close to the demand area to minimize the finished water pumping expense, the distance between the demand area centers creates several issues. If a plant is located near one of the demand center, an extensive piping network will be required to transport the finished water across the planning area to the other demand center, resulting in an increased expenditure for pipelines and pumping costs.

Site B is located in Demand Area A. If the water plant is located at this site, 50% of the demand, i.e. City of Pearland and City of Brookside Village, is located within 8 miles. A large finished water main will be required to convey the remaining 50% of the planning area average water demand, or 7.5 MGD, 30 miles to the City of Angleton, 5 miles to the City of Alvin, 7 miles to the City of Manvel, and 3 miles to the City of Pearland. Not only would this require a large transmission main, but the pumping cost to transport 7.5 MGD over the distances mentioned would be substantial.

The plant can be located at three possible sites located in Demand Area B. If the plant is located at Site A, in the City of Manvel, the distribution cost will be reduced, as the plant itself will be located within the city. There will still be the need for a transmission main, over a distance of 6 miles to service Demand Area A, and a transmission main of 20 miles to service the City of Angleton, and 2 miles to serve the City of Alvin. If the plant is located at either Site B or Sites C or D, there will be the need for transmission lines from this site to all the major take points in Distribution Areas A and B. The length of these transmission lines are shown in **Table 5-2**. Conversely, if the plant is located at Site E, transmission lines will have to be constructed for the cities of Angleton, and Manvel, of 16 and 11 miles respectively in



DEMAND AREA A

DEMAND AREA B

MID-BRAZORIA COUNTY PLANNING GROUP/TWDB  
FACILITY PLAN

FINISHED WATER DEMAND AREAS

FIGURE 5-2



## Section 5

# Water Treatment Plant Site Development

---

Distribution Area B. Transmission lines of length 12 miles will have to be constructed to service the cities of Pearland and Brookside Village in Distribution Area A.

The scenario of having the water plant in Demand Area B over a water plant in Demand Area A will result in reduced finished water pipeline capital costs. In addition, the cost of pumping water from one side of the planning area to the other will be less expensive for a water plant in Demand Area B versus a water plant in Demand Area A.

**TABLE 5-2  
PROXIMITY OF SITE TO FINISHED WATER DEMAND**

| Plant Site          | Finished Water Take Points (miles) |        |       |          |
|---------------------|------------------------------------|--------|-------|----------|
|                     | Pearland                           | Manvel | Alvin | Angleton |
| A – Manvel          | 6                                  | 0      | 2     | 20       |
| B – Pearland/ Alvin | 3                                  | 7      | 5     | 30       |
| C – Alvin           | 8                                  | 6      | 4     | 20       |
| D – Alvin           | 8                                  | 6      | 4     | 20       |
| E – Alvin           | 12                                 | 11     | 0     | 16       |

### Evaluation of Site Surface Features

Cursory reviews of each of the five sites revealed the following surface features that impact the sites use as a water treatment plant. The following is a list of these potential impacts:

- Site A is not expected to contain any environmentally sensitive areas. A portion of Site A is within 100-year flood plain, but it is not expected to impact construction of the main facilities.
- Site B contains several drainage facilities that may impact construction of any solids handling facilities or raw water reservoir. Site B contains portions that are inside the 100-year flood plain.
- Sites C and D contain the old City of Alvin municipal landfill, which is now capped. The remaining majority of the site is currently rice farms, and has enough land area to situate a water treatment plant. The site meets regulations governing municipal landfills.
- Site E is not expected to contain any environmentally sensitive areas, but does contain several drainage facilities that may impact construction of any solids handling facilities or raw water reservoir. Site E contains portions that are in the 100-year flood plain.

### Proximity to Major Highway and Utilities

Site A is adjacent to State Highway 6 and is located within ½ mile of State Highway 288. The site is adjacent to an existing Reliant Energy power line. Site E is adjacent to State Highway 35. Power, sewer, and gas service are readily available along the Highway 35 corridor. Site B is 2 miles from the nearest major road, Highway 35. It is adjacent to a proposed residential community where sewer and power facilities would be accessible. Sites C and D is not adjacent to any major highways. The sites contain available power, but would require sewer and gas service.

### Land Ownership

Sites C, D, and E are privately owned. Briscoe Properties, who own these tracts of land, have indicated that they are willing to donate these sites with special stipulations to the City of Alvin. The private

## Section 5

# Water Treatment Plant Site Development

---

landowner would secure water from the Gulf Coast Water Authority and then in turn sell it to the City of Alvin.

### Sites Selected for Further Review

After preliminary review based on the above criteria, the Participating Utility team narrowed the field of alternative sites to two sites, sites A and E. These sites were chosen primarily due to their proximity to both raw water source, and the demand areas, and also due to alternate sources of raw water available to them. These alternatives were then subject to final screening criteria based on the economic and non-economic factors associated with each alternative. Ariel photos of 2 screened sites appear as **Figures 5-3** and **Figure 5-4**. The discussion of these costs and factors each site are described in **Section 7**.



## Section 6

# Finished and Raw Water Transmission

---

Surface water must be transported from the raw water source to the selected plant site and finished water must be transmitted from the plant site to the Participating Utilities Take Points. This section develops facility plans for transporting the raw water from the Brazos River to the regional water treatment plant site and distributing treated water from the regional water treatment facilities to the Participating Utility Take Points.

### FINISHED WATER PIPELINE

From the high service pumps at the regional water treatment facilities, treated water must be transported through a finished water transmission system to the Participating Utilities.

This development of this finished water transmission system plan depends on the following criteria:

- Plant site location
- Participating utilities water demand
- Participating utilities desired water pressure
- The finished water pipelines be installed

The finished water transmission system can be developed based on these criteria. The goal of the finished water transmission system is to deliver water at the specified flow and pressure to the Participating Utilities at the lowest overall project cost. To assist in this analysis, a hydraulic model was utilized to optimize the size of the finished water pipelines and pump stations in order to minimize project costs.

The first step in creating and analyzing the finished water transmission system was to locate the finished water source.

### Finished Water Source

The location of the finished water depends on the location of the regional surface water plant. In **Section 5**, the Participating Utilities Team reviewed five alternative sites and screened out three. The following two sites were selected for further evaluation:

- Site A: Manvel
- Site E: Alvin

### Pipeline Corridor Analysis

The corridor analysis focuses on the route the finished water pipelines will take from the water plant to the Participating Utility Take Points. Given the fixed location of the Take Points and the two alternate water treatment site locations, alternate pipeline corridors were identified to connect the Take Points with the alternate water plant sites. These alternative corridors were then evaluated to determine a preferred routing of the finished water pipelines. Factors considered in the selection of routes include the following:

- Length of corridor
- Known environmental impacts along route
- Land ownership
- Constructability

Each corridor has a general economic costs associated with the construction of a pipeline through the corridor. As the length of the corridor increases, so does the length of the pipeline and the construction costs. Construction cost also increase if the pipeline passes through an environmentally sensitive area.

## Section 6

# Finished and Raw Water Transmission

---

Wetlands for example would require some form of mitigation. If the corridor is owned by a public agency, it is likely that right-of-way for the finished water pipeline can be obtained without expensive surveying and easement agreements. If a corridor traverses private land, pipeline easements will be required. These easements will increase the overall project costs. If the proposed corridor passes through developed areas, the corridor will likely contain existing utilities that will impact the alignment of the pipeline. Construction around these utilities will increase the cost of construction and impact utility services to the surrounding area.

### Take Points

With the selection of alternative water treatment plant sites, the next step towards development of pipeline corridors is to identify finished water Take Points for each Participating Utility. Take Points are defined as the transfer point at which the Mid Brazoria Regional Water Plant will transport potable water to the Participating Utilities. At each of these Take Points, a flow meter will be installed to record and monitor the total flow delivered to each participating utility. From this point on, the participating utility will be responsible for operation and maintenance of the water system.

Each participating utility provided the physical address, desired water pressure, and expected water demand at each preferred “Take Point”. As the alternative water treatment plant sites are scattered across the county, several Participating Utilities have provided alternative Take Points for consideration in the pipeline corridor and finished water pipeline evaluation. These Participating Utilities indicated that they will receive water at whichever Take Point makes better economic sense to lowering the capital and operational cost of the finished water pipeline system. The Take Points can be viewed on **Figure 6-1** and **Figure 6-2** and are summarized on **Table 6-1** by Participating Utility.



**Brookside Village**

**3a**

**3b**

**Knapp**

**Brookside**

**Mykawa**

**Garden**

**2b**

**Pearland**

**2a**

**Manvel**

**1**

Manvel Site

**288**

**1128**

**518**

**6**

**35**

**4a**

**Alvin**


**5**

**Iowa Colony**

MID-BRAZORIA COUNTY PLANNING GROUP/TWDB  
FACILITY PLAN

TAKE POINTS - NORTH BRAZORIA COUNTY

**FIGURE 6-1**



MID-BRAZORIA COUNTY PLANNING GROUP/TWDB  
FACILITY PLAN

TAKE POINTS - NORTH BRAZORIA COUNTY

FIGURE 6-2

## Section 6

# Finished and Raw Water Transmission

**TABLE 6-1  
PARTICIPATING UTILITY TAKE POINT INFORMATION**

| Utility                   | Take Point Number | Address   | Average Water Demand (MGD) | Ground Elevation at Take Point (ft) |
|---------------------------|-------------------|---|----------------------------|-------------------------------------|
| City of Manvel            | 1                 | Iowa Lane and Hwy 6, Manvel TX  | 3.77                       | 55                                  |
| City of Pearland          | 2a                | SH 288 at 518, Pearland TX  | 13.66                      | 60                                  |
|                           | 2b                | SH 35 at 518, Pearland TX   |                            | 40                                  |
| City of Brookside Village | 3a                | Garden Road and Brookside Road  | 0.57                       | 50                                  |
|                           | 3b                | Mykawa Road and Knapp Road  |                            | 50                                  |
| City of Alvin             | 4a                | SH 6, north of Mc Cormick Road  | 4.13                       | 40                                  |
|                           | 4b                | SH 35, at Johnson Road  |                            | 40                                  |
| City of Hillcrest Village | 4a or 4b          | Same as City of Alvin take point  | 0.07                       | 40                                  |
| City of Iowa Colony       | 5                 | At the intersection of County Road 64 and Iowa School Road                            | 0.24                       | 50                                  |
| City of Danbury           | 6                 | 5 <sup>th</sup> Street at St. Spur 8  | 0.48                       | 20                                  |
| City of Angleton          | 7                 | At the intersection of Henderson Road and Krankawa Road in the North part of the City | 2.45                       | 20                                  |


### Manvel WTP Site Pipeline Corridor Analysis

This section presents evaluations of prospective pipeline corridors from a regional water treatment plant located at Site A in Manvel to the Participating Utilities. The Manvel Site is located in the central western portion of the service area with Participating Utilities located to the north, east, and south. Based on the relative location of the Participating Utilities, their Take Points, and demand allocations, the most cost effective manner to serve the Participating Utilities is with three trunk lines feeding to the north, south, and east, respectively. The north line will serve the Cities of Manvel, Pearland, and Brookside Village. The south line will serve the communities of Iowa Colony, Angleton, and Danbury and the east line will serve the Cities of Alvin and Hillcrest Village. The corridor analysis evaluates alternative pipeline corridors to serve these three areas.

#### *North Line*

The north line will serve the City of Pearland and City of Brookside Village. Both the City of Brookside Village and the City of Pearland have noted alternative Take Points for use in the finished water pipeline evaluation. Two identified alternatives are the State Highway 288 corridor and the FM 1128 corridor. **Figure 6-3** shows the two alternative corridors to route water from the proposed Manvel WTP to the City of Pearland and City of Brookside Village.





MID-BRAZORIA COUNTY PLANNING GROUP/TWDB  
FACILITY PLAN

PIPELINE CORRIDORS FROM MANVEL SITE  
TO SOUTH BRAZORIA COUNTY

**FIGURE 6-3**



## Section 6

# Finished and Raw Water Transmission

---

The SH 288 corridor runs north from the Manvel WTP adjacent to Iowa Lane, then turns north in the Texas Department of Transportation (DOT) State Highway 288 right-of-way to the City of Pearland Take Point 2A. After the City of Pearland Take Point, the corridor turns west of FM 518 until Garden Road, where the corridor turns north to the City of Brookside Village Take Point 3A. The total length of this corridor is 5.5 miles to the City of Pearland Take Point and 11.5 miles to the Brookside Village Take Point.

The FM 1128 corridor runs east from proposed WTP site along Highway 6 until FM 1128. The corridor then turns north and runs approximately 5 miles to FM 518 in Pearland and turns east. The corridor splits at the intersection of Garden Road and FM 518 to go north along Garden to the City of Brookside Village Take Point and west along FM 518 to the City of Pearland Take Point 2B. The corridor is approximately 10.5 miles from the Manvel plant to the City of Brookside Village Take Point and 11.5 miles to the City of Pearland Take Point. A common pipe would be utilized between the WTP and the Brookside Village and Pearland Split.

The advantages and disadvantages of the alternative pipeline corridors are shown in **Table 6-2**. Since the City of Pearland is the largest demand in the MCBPG, the pipeline to the City of Pearland will be the largest diameter installed. By selecting the shortest possible route to the City of Pearland Take Point, the overall cost for installing the finished water network will be minimized. As the SH 288 corridor alternative has the shortest route to the City of Pearland Take Point and has no expected adverse environmental impacts, it is anticipated that the SH 288 corridor will result in the lowest cost alternative for North Line.

**TABLE 6-2  
MANVEL NORTH PIPELINE CORRIDOR ANALYSIS**

| Alternative | Advantages   | Disadvantages  |
|-------------|--|--|
| SH 288      | <ul style="list-style-type: none"> <li>• Minimizes pipeline length between WTP and City of Pearland Take Point.</li> <li>• A portion of this route is along public right-of-way.</li> <li>• No adverse environmental impact expected.</li> </ul> | <ul style="list-style-type: none"> <li>• Work Along long portion of FM 518.</li> <li>• Work in State right-of-way alongside of existing utilities</li> </ul> |
| FM 1128     | <ul style="list-style-type: none"> <li>• No adverse environmental impact expected.</li> <li>• Construction along rural roads</li> </ul>  | <ul style="list-style-type: none"> <li>• Significantly increased length of large diameter water main to the City of Pearland</li> </ul>                      |

### *East Corridor*

The east line will serve the City of Alvin. The City of Alvin also indicated several Take Points for consideration. As the City of Alvin west Take Point, No. 4A is the closer to the Manvel WTP site than TP 4B, this Take Point will be used for this alternative. To transport finished water to the City of Alvin, the following two possible corridors exist:

## Section 6

# Finished and Raw Water Transmission

---

- State Highway 6
- Burlington Northern Santa Fe Railroad (BNSFRR)

Both these corridors are a direct path from the Manvel WTP to the City of Alvin TP 4A. The SH 6 corridor utilizes public right of way along TXDOT State Highway 6 between Manvel and Alvin to route the single water line to Alvin. The BNSFRR corridor is parallel to the SH 6 corridor and utilizes the private right of way adjacent to the railroad approximately 1000 feet south of Highway 6. Both of these corridors are 8.5 miles in length.

Construction along this East corridor will require crossings of the Chocolate Bayou and the GCWA Lateral 10 in addition to several other bayous and creeks. As these crossings are common to each corridor, the costs associated with installing a pipeline through these environmentally sensitive areas will be common to both alternatives. The largest difference is that construction in the BNSFRR corridor will require purchase of 8.5 miles of easement from the BNSFRR. This private easement will greatly increase the cost of using this corridor. The SH 6 corridor utilizes public right-of-way and should have available room to install a small (less than 20 inch) water main. **Figure 6-4** highlights the alternative Manvel-East pipeline corridors


As the SH6 corridor should not require private easements, the relative cost of this corridor will be significantly less than construction within the BNSFRR corridor. As a result of this major cost saving and the ease of access to the SH6 corridor, this corridor is recommended as the preferred corridor to the City of Alvin from the Manvel WTP site.

### *South Corridor*

The south corridor will serve the communities of Iowa Colony, Angleton, and Danbury. In reviewing the geography of the area, alternative corridors within public right-of-way were available to individually feed each community with a dedicated line, but the cost of such a network would be cost prohibitive. As Iowa Colony, the City of Angleton, and Danbury generally lie within a straight line from the Manvel WTP site, it would be cost effective to identify a corridor within this straight line to maximize pipeline capacity to meet the needs of all three south Participating Utilities. Fortunately, SH 288 runs between Manvel and Angleton and, according to the Brazoria County TXDOT office, there is available public land with the SH288 right-of-way which could be used as the pipeline corridor. As no major known environmentally sensitive areas or other known construction obstacles are located with the SH 288 south corridor and this corridor is the most direct route between the WTP site and Participating Utilities Take Point, the corridor analysis will focus on the State Highway 288 corridor. **Figure 6-4** shows the alternative feeds along State Highway 288 for Iowa Colony, Angleton, and Danbury.

### *Connection to Iowa Colony*

Iowa Colony's Take Point is located just east of State Highway 288 near the intersection of County Road 64 and Iowa School Road. Routing to this location from State Highway 288 can be achieved in public right of way from County Road 64 to the west or from County Road 48 from the north. Connection via County Road 64 would require a separate small diameter line from State Highway 6. Connection from the north on County Road 48 could be a small tap on a large diameter line that could continue to south towards Angleton. As both corridors have no known concerns, either corridor would be feasible. In terms of cost, the alternative where a common line feeds Iowa Colony and then progresses to the south would maximize use of the carrying capacity in the line and would eliminate construction of a long small diameter line.



- Take points
- Water Treatment Plant site
- Recommended pipeline corridors
- Alternative pipeline corridors

MID-BRAZORIA COUNTY PLANNING GROUP/TWDB  
FACILITY PLAN

PIPELINE CORRIDORS FROM MANVEL SITE  
TO SOUTH BRAZORIA COUNTY

FIGURE 6-4

### *Connection to Angleton and Danbury*

From Iowa Colony, the pipeline corridor will route south along the State Highway 288 right-of-way to the Cities of Angleton and Danbury. There are several alternatives for the pipeline corridor to serve both of these Take Points. These include:

- Continuation of the South Line to the Angleton Take Point along SH 288 and then turning northeast along SH 35 and Spur 28 to the City of Danbury
- Splitting the line near the intersection of SH 288 and North Velasco Street and serving the two Take Points with separate lines.

**Figure 6-4** shows the two alternative pipeline routings.

The advantage of the second alternative, splitting the line, is in the reduced amount of pipeline that would need to be installed. From the flow split near SH 288, the Angleton branch is 7 miles and the Danbury Branch is 7.5 miles long. The combined system pipeline length is 13.8 miles and would consist a great diameter pipeline to handle the increased flow from both Danbury and Angleton in a common line.

More specifically, the flow-split alternative would likely use the following public right-of-ways from the intersection of SH 288 and North Velasco Street:

- Angleton: From North Velasco Street, the corridor will continue south until East Highway 35, where the corridor will turn west until Business 288. On Business 288, the corridor will continue south until reaching the existing water booster pump station on West Henderson Road.
- Danbury: From North Velasco Street, the pipeline will turn east along Chenango School Road for 3.5 miles, and upon reaching Novak road, turn southeast for 2 miles until the Danbury Take Point.

As there are no apparent obstacles to construction in this corridor, this corridor will result in the most cost-effective route to serve the City of Angleton and Danbury.

### *Alvin WTP Site Pipeline Corridor Analysis*

This section evaluates pipeline corridors from a regional water treatment plant located at site E in Alvin to the Participating Utilities. The analysis follows a similar methodology used in the previous section. The Alvin site is located in the central eastern portion of the service area with Participating Utilities located to the north, west, and south. Given the location of the demand centers and their Take Points, the most cost effective manner to serve the Participating Utilities is with three trunk lines feeding to the north, south, and west, respectively. The north line will serve the Cities of Pearland and Brookside Village. The south line will serve the communities of Danbury and Angleton. The west line will serve the Cities of Manvel and Iowa Colony. The corridor analysis evaluates alternative pipeline corridors to serve these three areas.

#### *North Line*

The north corridor will serve the Cities of Pearland and Brookside Village. Both the City of Pearland and Brookside Village have provided alternate Take Points. There are several alternatives for the pipeline corridors to serve these two cities. These include:

## Section 6

# Finished and Raw Water Transmission

---

- State Highway 35
- Burlington Northern Santa Fe Railroad (BNSFRR)

These corridors represent a direct path to the Take Points. The first option utilizes public right-of-way along the TXDOT SH 35. The pipeline along this corridor runs north from the Alvin WTP along SH 35, looping around the City along SH 35. It runs further northwest to the City of Pearland Take Point 2b at the intersection of FM 518 and SH 35. After serving the City of Pearland Take Point, the corridor runs north along SH 35 turning west on Knapp Road to the City of Brookside Village Take Point 3b on Mykawa Road. The length of this pipeline corridor is approximately 14 miles. The second option will place the pipeline along SH 35 for approximately 4 miles, and then along the BNSFRR for another 9 miles. Though the total length of this railroad corridor is less than the SH 35 corridor, construction along the BNSFRR will require purchase of easements along 9 miles of the railroad tract. The SH 35 corridor utilizes public right-of-way and should have available room to install a 36 inch water main.

As a result of this major cost savings, the SH 35 corridor is the preferred corridor to the Cities of Pearland and Brookside Village from the Alvin WTP site. **Figure 6-5** presents the Alvin-North pipeline corridors. The advantages and disadvantages of the alternative corridors are shown in **Table 6-3**.

**TABLE 6-3**  
**ALVIN NORTH PIPELINE CORRIDOR ANALYSIS**

| Alternative | Advantages   | Disadvantages  |
|-------------|--|--|
| SH 35       | <ul style="list-style-type: none"> <li>• It is expected that public right-of-way will be sufficient to install the pipeline.</li> <li>• No adverse environmental impact expected.</li> </ul> | <ul style="list-style-type: none"> <li>• Work in State Right-of-way alongside of existing utilities</li> </ul> |
| BNSFRR      | <ul style="list-style-type: none"> <li>• No adverse environmental impact expected.</li> <li>• Ease of construction along railroad</li> </ul>   | <ul style="list-style-type: none"> <li>• Purchase of private easements</li> </ul>                              |

### *West Corridor*


The west corridor will serve the cities of Manvel and Iowa Colony. Both these cities can be served by a common 20 inch water main along the Briscoe Canal, and then splitting flow to serve Manvel to the north and Iowa Colony to the south. Alternate pipeline corridors, running along SH 6 to Manvel and along FM 1462 to Iowa Colony can also serve these cities.

### *Connection to Manvel*

Two alternate pipeline corridors can serve Manvel:

- State Highway 6
- Briscoe Canal

Pipeline along the SH 6 corridor will run north along Business 35, and then west along SH 6 to the Manvel Take Point 1. Pipeline along this corridor will traverse through a congested area of the City of



MID-BRAZORIA COUNTY PLANNING GROUP/TWDB  
FACILITY PLAN

PIPELINE CORRIDORS FROM ALVIN SITE  
TO SOUTH BRAZORIA COUNTY

FIGURE 6-5

## Section 6

# Finished and Raw Water Transmission

---

Alvin, and it will have to share the public right-of-way with other utilities. The length of this corridor will be 14 miles.

The second alternative would be to install a pipeline along the Briscoe Canal. The pipeline along this corridor will run northwest along the canal all the way to Take Point 1 for the City. The length of this corridor will be 11 miles. Construction along this corridor is expected to be higher, and private easements will need to be purchased.

### *Connection to Iowa Colony*

Two alternate pipeline corridors can serve Iowa Colony:

- Briscoe Canal
- FM 1462

The first option will share the 20 inch pipeline with the City of Manvel along the Briscoe Canal. A smaller 8 inch pipeline can then be branched out from this 20 inch water main to run south along Masters road. It will then run west along CR 64 to the Iowa Colony Take Point 5. The total length of this corridor will be 11.5 miles.

The second option is to build a pipeline running north along Briscoe Canal from the Alvin WTP site, and then southwest along FM 1462. It then turns northwest along CR 121, and then north along CR 67 to the Take Point. The length of this corridor will be 13 miles.

**Table 6-4** summarizes the advantages and disadvantages of the alternative pipeline corridors in the western trunk line from the Alvin WTP site. Though the requirement for easement along the Briscoe Canal will increase the cost associated with pipeline corridors, the Canal has an existing easement for raw water conveyance, and so it will be easier to obtain a finished water easement near the current raw water easement. The increase in cost due to construction along the Briscoe Canal will be offset by the increased construction cost due to longer lengths along the SH 6 corridor and the FM 1462 corridors. As a result of relative cost savings, the Briscoe Canal corridor is the preferred corridor to the cities of Manvel and Iowa Colony. **Figure 6-5** presents the Alvin-West pipeline corridors serving Manvel and Iowa Colony.

**TABLE 6-4**  
**ALVIN WEST PIPELINE CORRIDOR ANALYSIS**

| Alternative   | Advantages   | Disadvantages   |
|---------------|--|---|
| SH 6          | <ul style="list-style-type: none"> <li>• It is expected that public right-of-way will be sufficient to install the pipeline.</li> <li>• No adverse environmental impact expected.</li> </ul> | <ul style="list-style-type: none"> <li>• Work in SH 6 Right-of-way alongside of existing utilities</li> <li>• Increased length compared to Briscoe Canal alternative</li> </ul> |
| Briscoe Canal | <ul style="list-style-type: none"> <li>• No adverse environmental impact expected.</li> <li>• Ease of construction along canal</li> <li>• Reduced cost due to reduced length</li> </ul>      | <ul style="list-style-type: none"> <li>• Purchase of private easements</li> <li>• Need for easements along canal</li> </ul>   |
| FM 1462       | <ul style="list-style-type: none"> <li>• No adverse environmental impact expected.</li> <li>• Construction along public right-of-way</li> </ul>  | <ul style="list-style-type: none"> <li>• Construction along rural roads</li> <li>• Increased length compared to Briscoe Canal alternative</li> </ul>                            |

*South Corridor*

The south corridor will serve the communities of Danbury and Angleton. An analysis of the regional geography shows that two parallel corridors can be used, which can feed both the communities.

*Connection to Danbury and Angleton*

A common water main can be constructed for these cities thus reducing construction costs. The two alternatives are

- State Highway 35
- Burlington Northern Santa Fe Railroad (BNSFRR)

The SH 35 corridor will use the available TXDOT public right-of-way, which is sufficient for a 20 inch pipeline. The pipeline will run south along SH 35, with an 8 inch pipeline line tapped off at Spur 8 to feed Take Point 6 in Danbury. After meeting the City of Danbury water demand, the water main will run further south along SH 35, turning west on FM 523, south along business 288, and finally west on Henderson Road to Take Point 7 in Angleton. The length of the pipeline to the Danbury Take Point will be 12 miles. The length of the corridor from the Alvin WTP site to the Angleton Take Point will be 18 miles.

The alternative BNSFRR option will construct a water main along the railroad. This corridor will also be common for both the cities. The pipeline will run south along FM 2403, and then southwest along BNSFRR to Take Point 6 in Danbury. The pipeline will further run south along BNSFRR after feeding the Danbury Take Point. It will turn east on SH 35, and then north along Velasco Street. Finally it will turn east on Henderson Road to the Angleton Take Point. The length of this corridor to the City of Danbury Take Point will be 12 miles. The length of the corridor from the WTP in Alvin to the Angleton Take Point will be 22 miles.



## Section 6


# Finished and Raw Water Transmission

---

**Table 6-5** summarizes these alternative pipeline corridors in the south trunk of the distribution network. The major differences between the two options are the length and the construction cost associated with the BNSFRR corridor. The BNSFRR corridor is 4 miles longer than the SH 35 corridor to the Angleton Take Point. Construction in the BNSFRR corridor will require purchase of easement from the BNSFRR. This private easement will greatly increase the cost of using this corridor. Compared to this, the SH 35 corridor has a TXDOT public right-of-way. This will significantly reduce construction cost in SH 35 corridor. **Figure 6-6** highlights the alternative Manvel-South pipeline corridors.

**TABLE 6-5  
ALVIN SOUTH PIPELINE CORRIDOR ANALYSIS**

| Alternative | Advantages   | Disadvantages   |
|-------------|--|---|
| SH 35       | <ul style="list-style-type: none"> <li>• It is expected that public right-of-way will be sufficient to install the pipeline.</li> <li>• No adverse environmental impact expected.</li> </ul> | <ul style="list-style-type: none"> <li>• Work in SH 6 Right-of-way alongside of existing utilities</li> </ul> |
| BNSFRR      | <ul style="list-style-type: none"> <li>• No adverse environmental impact expected.</li> <li>• Ease of construction along railroad</li> </ul>   | <ul style="list-style-type: none"> <li>• Purchase of private easements</li> <li>• Increased length</li> </ul> |



- Take points
- Water Treatment Plant site
- Recommended pipeline corridors
- Alternative pipeline corridors

MID-BRAZORIA COUNTY PLANNING GROUP/TWDB  
 FACILITY PLAN

PIPELINE CORRIDORS FROM ALVIN SITE  
 TO SOUTH BRAZORIA COUNTY

**FIGURE 6-6**

### MODELING AND PIPELINE LAYOUT DESCRIPTIONS

To develop the cost effective sizing of the finished water transmission system components, a hydraulic model was utilized to size pipeline components based on the Take Point requirements and the preferred pipeline alignments. The goal of the model was determine the minimum sized pipelines and booster pump station pressure that could adequately meet the Take Point requirements. Hydraulic models of the transmission pipeline system were constructed for each of the two alternative water treatment plant scenarios developed in **Section 5**.

The study looked at the relative economic cost of participating in a larger regional water treatment plant proposed by the Gulf Coast Water Authority to serve utilities in Fort Bend, Harris, and Brazoria Counties. This regional water treatment plant was studied as part of the TWDB / GCWA Facility Plan study completed in November, 2000. The plant was designed with an ultimate capacity of 150 MGD. The advantage of combining forces and constructing a larger regional facility is documented cost savings associated with the “economy of scale” in constructing a larger facility. Offsetting this saving would be the cost of a trans-county pipeline. A hydraulic model connecting the GCWA plant to the eight Mid-Brazoria County Participating Utilities was also constructed. The GCWA alternative is presented to offer the Participating Utilities a comparison with other regional water plans.

For each treatment plant site location, the following two modeling scenarios were evaluated.

- Delivery to each Participating Utility Take Point at a minimum system pressure to meet the Participating Utilities customer demand. The intent of this alternative is to deliver water at a set minimum pressure to the Participating Utilities and to directly feed customer demand from the regional water treatment plant
- Delivery to Participating Utilities Take Point at sufficient pressure to fill existing or proposed ground storage tanks. The intent of this alternative is serve as the Participating Utilities treated surface water supply, but the Participating Utilities would be responsible for repumping the water to meet the required system pressure to serve their customers.

### Hydraulic Model

The program used for the hydraulic modeling was H<sub>2</sub>ONET Utility Suite, which is a GIS based software. The software contains seven subprograms designed to optimize water distribution modeling. The subprogram used for this task was the H<sub>2</sub>ONET Analyzer. H<sub>2</sub>ONET Analyzer enables the modeler to track the flow and velocity of water in each pipe; the pressure, age of water, and fire flow capacity at each node; the height and volume of water in each tank; the discharge pressure/flow, efficiency and energy cost for each pump; the cost of physical improvements; and the movement and fate of water quality constituents as they travel through the distribution system. For this evaluation, only a portion of these modeling capabilities was utilized.

### Model Assumptions and Layout

Several basic parameters and assumptions were used to design the hydraulic model. For this study, the following assumptions were defined:

- Pipeline size based on ultimate demand of Participating Utilities in year 2050
- Maximum velocity in any given pipeline - 8 ft/s
- Hazen and Williams pipe friction coefficient - 130
- Minimum system pressure – 50 psi

## Section 6

# Finished and Raw Water Transmission

- Ground storage tank at Take Points are filled at top of tank
- Ground storage tank at water treatment plant or booster station is empty

Given these assumptions, results from all the hydraulic model scenarios depicting the layout of the demand points, plant location, pressure and pipeline sizes can be seen in **Figures 6-7** through **6-12**.


### Model Results

For each alternative, finished water transmission system consists of the pipeline facilities and high service pump stations. The final quantities of finished water pipelines are shown in **Tables 6-6** and **6-7**. These tables report the finished water pipe lengths as either rural or urban, based on the existing site geography. Rural installations are italicized. Rural installations refer to pipelines that will be installed in open cut trenches with minimal utility crossings, pavement repair, and trenchless installations. Conversely, urban installations refer to pipelines installed in developed areas where frequent trenchless installations, pavement repair, utility conflicts, and traffic control will be required. The type of installation, either rural or urban, will affect the construction cost of the transmission alternatives. The tables also summarize the required length of private landowner easements.

**TABLE 6-6**  
**MODEL RESULTS FOR AT SYSTEM PRESSURE ALTERNATIVE**

| Pipeline Segment                                  | Manvel Plant Site |               | Alvin Plant Site |               | GCWA Plant Site |               |
|---|-------------------|---------------|------------------|---------------|-----------------|---------------|
|   | Length (ft)       | Diameter (in) | Length (ft)      | Diameter (in) | Length (ft)     | Diameter (in) |
| Manvel to Pearland                                | 28,700            | 36            | -                | -             | 28,700          | 36            |
| Pearland to Brookside from Site A                 | 24,800            | 8             | -                | -             | 24,800          | 8             |
| Manvel to Alvin                                   | 31,300            | 18            | -                | -             | 31,300          | 18            |
| Manvel to Node B                                  | 13,100            | 20            | -                | -             | 13,100          | 20            |
| Node B to Iowa Colony                             | 15,500            | 20            | -                | -             | 15,500          | 20            |
| Iowa Colony to Node C                             | 70,400            | 20            | -                | -             | 70,400          | 20            |
| Node C to Danbury                                 | 36,000            | 10            | -                | -             | 36,000          | 10            |
| Node C to Angleton                                | 23,800            | 18            | -                | -             | 23,800          | 18            |
| Site E to Pearland                                | -                 | -             | 78,400           | 42            | -               | -             |
| Pearland to Brookside Village From Site E         | -                 | -             | 12,300           | 8             | -               | -             |
| Site E to Node D                                  | -                 | -             | 45,100           | 20            | -               | -             |
| Node D to Manvel                                  | -                 | -             | 14,300           | 20            | -               | -             |
| Node D to Iowa Colony                             | -                 | -             | 19,900           | 8             | -               | -             |
| Site E to Node E                                  | -                 | -             | 56,100           | 20            | -               | -             |
| Node E to Danbury                                 | -                 | -             | 7,800            | 8             | -               | -             |
| Node E to Angleton                                | -                 | -             | 37,900           | 18            | -               | -             |
| Node A to Pearland                                | 9,500             | 36            | -                | -             | 9,500           | 36            |
| GCWA Plant to Node B                              | -                 | -             | -                | -             | 71,800          | 60            |
| Total Pipe in Rural Areas (ft)                    | 228,300           |               | 259,500          |               | 300,100         |               |
| Total Pipe in Urban Areas (ft)                    | 24,800            |               | 12,300           |               | 24,800          |               |
| Total Pipeline Length (ft)                        | 253,100           |               | 271,800          |               | 324,900         |               |
| Total In-Diameter Foot in Rural Areas(in-dia ft)  |                   | 4,707,000     |                  | 6,506,600     |                 | 9,015,000     |
| Total In-Diameter Foot in Urban Areas (in-dia ft) |                   | 198,400       |                  | 98,400        |                 | 198,400       |
| Total In-Diameter Foot (in-dia ft)                |                   | 4,905,400     |                  | 6,605,000     |                 | 9,213,400     |
| Private Landowner Easements (ft)                  | 55,530            |               | 59,400           |               | 127,330         |               |


Note: Rural installations are designated in Italic Type (gray)



MID-BRAZORIA COUNTY PLANNING GROUP/TWDB  
FACILITY PLAN

FINISHED WATER MODEL RESULT FOR  
SITE A IN MARVEL AT PRESSURE


FIGURE 6-7



MID-BRAZORIA COUNTY PLANNING GROUP/TWDB  
 FACILITY PLAN

FINISHED WATER MODEL RESULT FOR  
 SITE A IN MANVEL AT GROUND STORAGE TANKS


**FIGURE 6-8**



MID-BRAZORIA COUNTY PLANNING GROUP/TWDB  
FACILITY PLAN


FINISHED WATER MODEL RESULT FOR  
SITE E IN ALVIN AT PRESSURE

FIGURE 6-9




MID-BRAZORIA COUNTY PLANNING GROUP/TWDB  
 FACILITY PLAN  
 FINISHED WATER MODEL RESULT FOR  
 SITE E IN ALVIN AT GROUND STORAGE TANKS  
**FIGURE 6-10**





MID-BRAZORIA COUNTY PLANNING GROUP/TWDB  
 FACILITY PLAN  
 FINISHED WATER MODEL RESULT FOR  
 GCWA WTP AT PRESSURE  
**FIGURE 6-11**



MID-BRAZORIA COUNTY PLANNING GROUP/TWDB  
FACILITY PLAN

FINISHED WATER MODEL RESULT FOR  
GCWA WTP AT GROUND STORAGE TANKS

FIGURE 6-12

## Section 6

### Finished and Raw Water Transmission

**TABLE 6-7**  
**MODEL RESULTS FOR AT GROUND STORAGE TANK DELIVERY ALTERNATIVE**

| Pipeline Segment   | Manvel Plant Site |               | Alvin Plant Site |               | GCWA Plant Site |               |
|--|-------------------|---------------|------------------|---------------|-----------------|---------------|
|  | Length (ft)       | Diameter (in) | Length (ft)      | Diameter (in) | Length (ft)     | Diameter (in) |
| <i>Manvel to Pearland</i>                                | 28,700            | 36            | -                | -             | 28,700          | 36            |
| <i>Pearland to Brookside from Site A</i>                 | 24,800            | 8             | -                | -             | 24,800          | 8             |
| <i>Manvel to Alvin</i>                                   | 31,300            | 16            | -                | -             | 31,300          | 16            |
| <i>Manvel to Node B</i>                                  | 13,100            | 20            | -                | -             | 13,100          | 20            |
| <i>Node B to Iowa Colony</i>                             | 15,500            | 20            | -                | -             | 15,500          | 20            |
| <i>Iowa Colony to Node C</i>                             | 70,400            | 18            | -                | -             | 70,400          | 20            |
| <i>Node C to Danbury</i>                                 | 36,000            | 8             | -                | -             | 36,000          | 8             |
| <i>Node C to Angleton</i>                                | 23,800            | 16            | -                | -             | 23,800          | 16            |
| <i>Site E to Pearland</i>                                | -                 | -             | 78,400           | 36            | -               | -             |
| <i>Pearland to Brookside Village From Site E</i>         | -                 | -             | 12,300           | 8             | -               | -             |
| <i>Site E to Node D</i>                                  | -                 | -             | 45,100           | 20            | -               | -             |
| <i>Node D to Manvel</i>                                  | -                 | -             | 14,300           | 18            | -               | -             |
| <i>Node D to Iowa Colony</i>                             | -                 | -             | 19,900           | 6             | -               | -             |
| <i>Site E to Node E</i>                                  | -                 | -             | 56,100           | 18            | -               | -             |
| <i>Node E to Danbury</i>                                 | -                 | -             | 7,800            | 8             | -               | -             |
| <i>Node E to Angleton</i>                                | -                 | -             | 37,900           | 16            | -               | -             |
| <i>Node A to Pearland</i>                                | 9,500             | 36            | -                | -             | 9,500           | 24            |
| <i>GCWA Plant to Node B</i>                              | -                 | -             | -                | -             | 71,800          | 60            |
| <i>Total Pipe in Rural Areas (ft)</i>                    | 228,300           |               | 259,500          |               | 300,100         |               |
| <i>Total Pipe in Urban Areas (ft)</i>                    | 24,800            |               | 12,300           |               | 24,800          |               |
| <i>Total Pipeline Length (ft)</i>                        | 253,100           |               | 271,800          |               | 324,900         |               |
| <i>Total In-Diameter Foot in Rural Areas (in-dia ft)</i> |                   | 4,384,000     |                  | 5,779,800     |                 | 8,718,800     |
| <i>Total In-Diameter Foot in Urban Areas (in-dia ft)</i> |                   | 198,400       |                  | 98,400        |                 | 198,400       |
| <i>Total In-Diameter Foot (in-dia ft)</i>                |                   | 4,582,400     |                  | 5,878,200     |                 | 8,917,200     |
| <i>Private Landowner Easements (ft)</i>                  | 55,530            |               | 59,400           |               | 127,330         |               |

Note: Rural installations are designated in Italic Type (gray)

For each of the scenarios, a high service pump station will be required to deliver water from the water treatment plant to the Participating Utility Take Points. The requirements of the pump station are dependent on the pressure requirements of the Participating Utilities and the headloss associated with flow through the pipelines. To meet the specified pressure and flow requirements at the Participating Utility Take Points, the following pump station pressures will be required. The pump station requirements are shown in **Table 6-8**.



**TABLE 6-8  
PUMP STATION MODEL RESULTS**

| Plant Site Alternative | WTP Pump Station Pressure Setting (psi) |         |
|------------------------|---|---------|
|                        | At Pressure                             | To GSTs |
| Marvel Site            | 95                                      | 65      |
| Alvin Site             | 99                                      | 70      |
| GCWA Site              | 95                                      | 80      |

### System Storage and Booster Pump Requirements

Allocation of potable water storage and booster pump requirements in the system depends on the type of connection that the regional system makes at the tie-in point with the individual Participating Utilities systems. If the potable water is delivered under pressure to each Participating Utilities, the water will be delivered at a pressure sufficient to meet state requirements for pressure maintenance of distribution systems. As a result, additional booster pump stations at each Take Point will not be required. Under this scenario, the most cost-effective method for construction of the required system storage is at the water treatment plant instead of distributed in the system at each Take Point. For the purposes of this study, the cost for water delivered at pressure will assume adequate storage at the water treatment plant. Individual Participating Utilities may wish to consider additional operational storage within their own distribution system.

Under the scenario where water is delivered to the Participating Utilities storage tanks, water from the regional water plant will empty into a ground storage tank instead of into the individual Participating Utilities distribution system. Each utility will be required to have a booster pump station to repump the water to distribution system pressure. As a booster station will be required, a small ground storage tank will improve pump operations as well as provide operations storage for the booster pumps. Under this scenario the most cost-effective manner of constructing the necessary storage is to distribute the storage at the Take Points. This will provide the necessary storage for operation of the booster pumps and meet the state guidelines for construction of storage for the regional system.

Based on the expected demand of each Participating Utility, an estimate of the necessary ground storage capacity and booster pump capacity is shown in **Table 6-9**. This table assumes that each community will have enough storage to meet the TNRCC minimum of 200 gallons of storage per connection and that each community has 2.84 residents per connection (1990 census figures). This scenario gives a daily peak system capacity of 0.3 GPM per connection, which is lower than the TNRCC requirement of 0.6 GPM per connection. New wells will have to be constructed by each Participating Utility to meet this requirement.

## Section 6

# Finished and Raw Water Transmission

**TABLE 6-9**  
**REQUIRED REGIONAL GROUND STORAGE TANK VOLUME (MGD)**

| Participating Utility          | Year 2050 Planning Area Population | Min. Storage Capacity Required by TNRCC (MG) <sup>1</sup> | Existing GST volume required (MG) | Additional Storage Capacity Required (MG) |
|--------------------------------|------------------------------------|---|-----------------------------------|---|
| Alvin                          | 51,935                             | 3.66  | 2.125                             | 1.53                                      |
| Angleton                       | 52,884                             | 3.72  | 3.65                              | 0.07                                      |
| Brookside Vill.                | 3,696                              | 0.26  | 0                                 | 0.26                                      |
| Danbury                        | 3,381                              | 0.24  | 0                                 | 0.24                                      |
| Hillcrest                      | 1,696                              | 0.12  | .10                               | 0.02                                      |
| Iowa Colony                    | 1,477                              | 0.10  | 0                                 | 0.10                                      |
| Manvel                         | 10,606                             | 0.75  | .165                              | 0.58                                      |
| Pearland                       | 91,243                             | 6.43  | 5.84                              | 0.59                                      |
| <b>Total for Planning Area</b> | <b>216,918</b>                     | <b>15.28</b>  | <b>11.88</b>                      | <b>3.40</b>                               |

1) Population / 2.84 persons per connection \* 200 gallons per connection

Under the scenario where the Regional Water Facility is directly feeding water into the distribution system, adequate storage to meet state guidelines will be housed at the water treatment plant. The ground storage tanks at the water treatment plant would have a storage volume of 3.40 MG. This volume is marginal for a 25 MGD plant. A storage volume of 7 MGD is planned for the plant.

Under the scenario where the Regional Water Facility is pumping to distributed ground storage, the distributed ground storage tanks will be sized as shown in **Table 6-10**. The sum of these distributed storage tanks and the storage volume at the water treatment plant will be minimum of 16.37 MG.

**TABLE 6-10**  
**PARTICIPATING UTILITIES REQUIRED GST VOLUME UNDER DELIVERY TO GROUND STORAGE TANK SCENARIO (MGD)**

| Participating Utility          | Water Treatment Plant Finished Water Storage (MG) | Distributed Ground Storage Volume to be Constructed (MG) |
|--------------------------------|---|--|
| Alvin                          | 6.25  | 2.5  |
| Angleton                       |   | 0  |
| Brookside Vill.                |   | .26  |
| Danbury                        |   | .24  |
| Hillcrest                      |   | 0 <sup>1</sup>   |
| Iowa Colony                    |   | .10  |
| Manvel                         |   | 1.95   |
| Pearland                       |   | 5.07   |
| <b>Total for Planning Area</b> |   | <b>6.25</b>  |

1) Storage Included in Alvin System



## Section 6

# Finished and Raw Water Transmission

### Capital Costs

The capital costs associated with constructing finished water delivery system for each water treatment plant were calculated based in the unit costs summarized in **Table 6-11**. These costs are taken from recent bids and vendor estimates of the capital cost for material and labor in constructing the said facilities. For comparison, the unit costs calculated by Region H for similar facilities are shown. Region H cost estimating schedules from the February 2001 report are attached as **Appendix G**. Region H costs are of a reconnaissance field grade estimates and are more conservative than the unit costs developed from recent bids and vendor estimates. For the purposes of this report, the unit costs developed for this project will be used.

**TABLE 6-11**  
**FINISHED WATER DELIVERY UNIT CONSTRUCTION COSTS**

| Category  | Unit Cost            | Source                       | Region H Comparison   |
|---|----------------------|------------------------------|-----------------------|
| Finished Water Pump Station (less than 120 psi) | \$56,000 per MGD     | Recent Pump Station Bids     | \$200,000 per MGD     |
| Finished Water Pump Station (less than 60 psi)  | \$40,000 per MGD     | Recent Pump Station Bids     | \$150,000 per MGD     |
| Pipeline – Rural Installation                   | \$4.00 per in-dia/ft | Recent Pipeline Bids         | \$6.38 per in-dia/ft  |
| Pipeline – Urban Installation                   | \$5.00 per in-dia/ft | Recent Pipeline Bids         | \$10.45 per in-dia/ft |
| Pipeline Easement                               | \$20,000 per Acre    | Recent Easement Acquisitions | N/A                   |
| 2 MG Ground Storage Tank                        | \$750,000            | Vendor Estimate              | \$1,140,000           |
| 1 MG Ground Storage Tank                        | \$450,000            | Vendor Estimate              | \$570,000             |

The probable cost for pipeline installation increases by \$1.00 per inch-diameter-foot for urban installation due to constrictions placed upon construction for increased pavement repair, trenchless installation, utility crossings, traffic control, and limited construction work zones. The price of easements includes fees for the cost of the easement plus additional estimates of legal fees, surveying, and abstracting. Given these unit costs, the summary of the capital costs for the ancillary water delivery items for each plant site alternative is shown in **Table 6-12**. All costs are reported in year 2000 dollars.

## Section 6

# Finished and Raw Water Transmission

**TABLE 6-12**  
**FINISHED WATER TRANSMISSION CONSTRUCTION ESTIMATE**  
**(YR 2000 \$)**

| Construction Item                         | Plant Site Alternative (1000's of \$'s) |                  |                  |                  |                  |                  |
|---|---|------------------|------------------|------------------|------------------|------------------|
|   | Manvel Site                             |                  | Alvin Site       |                  | GCWA Site        |                  |
|   | At Pressure                             | To Storage Tanks | At Pressure      | To Storage Tanks | At Pressure      | To Storage Tanks |
| <b>Finished Water Transmission System</b> |   |                  |                  |                  |                  |                  |
| Pipeline: Rural                           | \$ 18,830                               | \$17,540         | \$ 26,030        | \$23,120         | \$ 36,060        | \$ 34,880        |
| Pipeline: Urban                           | \$990                                   | \$ 990           | \$ 490           | \$ 490           | \$ 990           | \$ 990           |
| Easements                                 | \$760                                   | \$ 760           | \$ 820           | \$ 820           | \$1,750          | \$ 1,750         |
| <b>Subtotal of Pipelines</b>              | <b>\$20,580</b>                         | <b>\$19,290</b>  | <b>\$ 27,340</b> | <b>\$ 24,430</b> | <b>\$ 38,800</b> | <b>\$ 37,620</b> |
| High Service Pump Station                 | \$ 1,400                                | \$ 1,400         | \$1,400          | \$ 1,400         | \$1,400          | \$ 1,400         |
| Booster PS                                | \$0                                     | \$ 1,000         | \$ 0             | \$ 1,000         | \$ 0             | \$ 1,000         |
| Booster PS GST                            | \$0                                     | \$5,540          | \$ 0             | \$5,540          | \$ 0             | \$5,540          |
| GST Increase @ WTP                        | \$3,080                                 | \$ 0             | \$ 3,080         | \$ 0             | \$ 3,080         | \$ 0             |
| <b>Total Construction Estimate</b>        | <b>\$25,060</b>                         | <b>\$ 27,230</b> | <b>\$31,820</b>  | <b>\$ 32,370</b> | <b>\$ 43,280</b> | <b>\$ 45,560</b> |

The analysis shows that a plant at the Manvel site delivering water at pressure will have the least capital costs, approximately 2.5 million dollars less than the similar alternative delivering water to storage tanks from the Manvel WTP site. The analysis shows that the Manvel site is approximately 7.5 million dollars less expensive to construct than a similar transmission network from the Alvin site.

### Operating and Maintenance Costs

Major components of the finished water O&M costs include booster pump station operation and maintenance of the pipeline. All costs are reported in Year 2000 dollars and shown in **Table 6-13**. The following assumptions were made regarding the operation of the finished water transmission system:

- The cost of electricity was assumed to be \$0.06 per KWh
- Maintenance of the finished water pipeline system is equal to .25 percent of the pipeline construction estimate.
- Maintenance of pumps is equal to 3 percent of the pump station construction estimate.
- Water Treatment Plant production of 25 MGD
- Booster Pump Station Operation Head of 50 psi

## Section 6

# Finished and Raw Water Transmission

**TABLE 6-13**  
**ANNUAL O&M ESTIMATE FOR FINISHED WATER TRANSMISSION**  
**SYSTEMS IN THE YEAR 2050 (YR 2000\$)**

| O&M Item                                  | Plant Site Alternative (\$'s) |                  |                  |                  |                  |                  |
|---|-------------------------------|------------------|------------------|------------------|------------------|------------------|
|   | Manvel Site                   |                  | Alvin Site       |                  | GCWA Site        |                  |
|   | At Pressure                   | To Storage Tanks | At Pressure      | To Storage Tanks | At Pressure      | To Storage Tanks |
| <b>Finished Water Transmission System</b> |                               |                  |                  |                  |                  |                  |
| WTP High Service Pump Station Operation   | \$470,000                     | \$320,000        | \$490,000        | \$340,000        | \$470,000        | \$400,000        |
| Maintenance                               | \$40,000                      | \$40,000         | \$40,000         | \$40,000         | \$40,000         | \$40,000         |
| <b>SubTotal</b>                           | <b>\$510,000</b>              | <b>\$360,000</b> | <b>\$530,000</b> | <b>\$380,000</b> | <b>\$510,000</b> | <b>\$440,000</b> |
| <b>Booster Pump</b>                       |                               |                  |                  |                  |                  |                  |
| Pump Station Electricity                  | \$0                           | \$250,000        | \$0              | \$250,000        | \$0              | \$250,000        |
| Maintenance                               | \$0                           | \$30,000         | \$0              | \$30,000         | \$0              | \$30,000         |
| <b>SubTotal</b>                           | <b>\$0</b>                    | <b>\$280,000</b> | <b>\$0</b>       | <b>\$280,000</b> | <b>\$0</b>       | <b>\$280,000</b> |
| Pipeline Maintenance                      | \$50,000                      | \$50,000         | \$70,000         | \$60,000         | \$90,000         | \$90,000         |
| <b>Annual O&amp;M</b>                     | <b>\$560,000</b>              | <b>\$690,000</b> | <b>\$600,000</b> | <b>\$720,000</b> | <b>\$600,000</b> | <b>\$810,000</b> |

### Alternative Selection

The participating utilities determined that the selection of the plant location would be based on both the economic costs of the alternatives and non-economic factors involved with each plant site alternative. This selection process is discussed in detail in **Section 7** of this report.

### RAW WATER DELIVERY SYSTEM

To treat surface water for the Mid Brazoria County area, raw water will need to be brought to the plant site. Per the scope of this project, the raw water transmission alternatives and costs were provided by the Turner Collie and Braden letter report that was submitted to the Chairman of Region H. A copy of the Groups raw water source and alternative evaluation study dated February 2001 is attached as **Appendix E**. It should be noted that there are differences in the facility capacities used in the Region H report and the facility sizes determined as part of this study. Specifically, the following differences will impact the overall costs of the raw water facilities:

- 1) The water treatment plant capacity between the Region H estimates and the reserve WTP capacity used in this study and
- 2) The location of the alternative water treatment plant site locations between the Region H report and the sites selected in Section 5 of this report

For the purposes of calculating the capital and O&M costs of a raw water delivery system for Mid-Brazoria Regional Water Plant Facility Plan, modifications to the Region H numbers have been noted



## Section 6

# Finished and Raw Water Transmission

---

and included in the final cost tables. The following is a summary of raw water transportation needs and overall cost impact.

### Requirements

To meet a finished water demand of 25 MGD, the water plant will need to be sized for an plant influent of 27.5 MGD to account for losses along the treatment train. Approximately 10 percent of the plant influent will be recycled or separated from the water as plant sludge. Accordingly, the raw water supply facilities feeding the plant will have to be sized to accommodate the full design flow of the plant plus appropriate process losses.

### Raw Water Sources

Region H has determined that the surface water source for the Mid-Brazoria Region is the Brazos River. Furthermore, Turner Collie and Braden has completed a study on the alternatives of bringing Brazos River water to a Mid-Brazoria County regional water treatment plant. This study was submitted as a letter report to the Chairman of Region H, and is attached as **Appendix E**. In this study, three alternatives for transporting raw water from the Brazos River to a regional water plant site are identified. Those alternatives are:

- 1) Gulf Coast Water Authority Canals
- 2) Chocolate Bayou Water Company Canals
- 3) Brazos River Authority Pipeline

The following is a brief description of each alternative as report by Region H. Additional detail on each alternative can be found in **Appendix E**.

#### Gulf Coast Water Authority

Gulf Coast Water Authority owns and operates two raw water canals from the Brazos River to Texas City, which carry raw water for industrial, agricultural, and commercial uses for customers in Fort Bend, Brazoria, and Galveston Counties. These canals are located adjacent to the two proposed water treatment plant sites for this study and have ample capacity to carry the required 27.5 MGD from the Brazos River to the plant site.

In this alternative, the MBCPG would purchase raw water on a per gallon contract with the GCWA and this cost would serve as an O&M cost for the production of treated water.

#### Chocolate Bayou Water Company

Chocolate Bayou Water Company owns and operates a canal system that brings water from the Brazos River to industrial and agricultural customers in Brazoria County. The CBWC canals pass within 2 miles of the proposed water treatment sites and Region H suggests constructing a raw water pipeline and pump station to carry the water from the CBWC canal to the plant site.

Region H proposed that for in this option, the MBCPG initially purchase the water rights owned by CBWC. In owning the rights, the MCBPG would eliminate an annual raw water purchase contract with a political agency holding rights, but would be required to invest capital dollars to initially purchase the rights.

Since the Region H report has been published, the water rights held by CBWC have been reportedly sold to the North Harris County Water Authority for a sum of \$100 million dollars, but as of May 24, 2001, the North Harris County Water Authority rejected the final approval of the contract. As a result, the



## Section 6

# Finished and Raw Water Transmission

---

CBWC rights are still on the market and can still be purchased, but the price of these rights may be different than original reported by Region H.

### Brazos River Authority

In this alternative, the MBCPG would contract for raw water with the Brazos River Authority and construct a new raw water pump station and approximately 15 miles of raw water pipeline to transport the required raw water from the Brazos River to the proposed plant site. In this option, the MCBPG would purchase an annual allotment of water from the Brazos River Authority (BRA).

### Costs

The costs associated with a raw water delivery system were calculated by Region H and are included in **Appendix H**. The Region H report assumed a maximum raw water flow of 14 MGD and sized the necessary facilities to provide accordingly. For this study, the raw water costs prepared by Region H were updated to reflect changes in the location of the alternate water plant sites. The following summarizes the changes that were made to the original Region H raw water costs analysis:

- ❖ Ultimate raw water demand of 27.5 MGD. All pump stations were upsized to handle this ultimate flow and pipeline diameters were increased to reflect the additional capacity required.
- ❖ Two Phase construction:
  - 2010: 16.5 MGD Facilities
  - 2030: 11 MGD Facilities
  - Pipelines constructed in first phase
- ❖ For the GCWA alternative, elimination of a raw water pipeline and pump station as the GCWA canals are adjacent to the both of the proposed plant sites. Construction of the water plant forebay will be adjacent to the canals and water will flow by gravity into the forebay.
- ❖ For the CBWC alternative, a 30-inch raw water pipeline will be used to transport 27.5 MGD to the plant site. The original Region H Report sized their facilities for 14 MGD. As both alternative water treatment plant sites are equidistant from the existing CBWC canals, only one cost estimate was prepared as the required length of raw water pipeline will be the same to both water plant sites from the nearest point on the CBWC canal.
- ❖ For the BRA alternative, as the two plant sites are located approximately 14 miles apart, costs for this alternative were determined for both a separate 42" pipeline to Site A in Manvel and to Site E in Alvin. The original Region H Report sized their facilities for 14 MGD.

**Figure 6-13** shows a schematic representation of the modified raw water delivery alternatives using in the cost estimate for this study.

### Capital Costs

For use in this facility plan, the capital costs associated with constructing raw water conveyance delivery system for each alternative identified by Region H were calculated based in the unit costs provided by Region H unit costs with the exception of the unit raw water pipeline price. A unit price of \$4 per inch-diameter-foot of raw water pipeline to reflect recent bid prices on similar projects in the Brazoria County area. **Table 6-14** shows the proposed construction cost for an ultimate raw water flow of 27.5 MGD. Detailed breakdown of each alternative construction cost can be viewed in **Appendix I**.



## Section 6

# Finished and Raw Water Transmission

**TABLE 6-14**  
**RAW WATER CONVEYANCE ALTERNATIVE CONSTRUCTION COSTS (YEAR 2000 \$)**

| Construction Item         | GCWA       | BRA to Site A       | BRA to Site E       | CBWC                |
|---------------------------|------------|---------------------|---------------------|---------------------|
| Phase 1 (2010)            |            |                     |                     |                     |
| Pump Stations             | \$0        | \$5,011,000         | \$7,219,000         | \$3,285,000         |
| Pipelines                 | \$0        | \$6,826,500         | \$21,948,000        | \$1,626,000         |
| Water Rights              | \$0        | \$0                 | \$0                 | \$6,159,000         |
| <b>SubTotal</b>           | <b>\$0</b> | <b>\$11,837,500</b> | <b>\$29,167,000</b> | <b>\$11,070,000</b> |
| Phase 2 (2030)            |            |                     |                     |                     |
| Pump Stations             | \$0        | \$2,491,000         | \$4,624,000         | \$889,000           |
| <b>SubTotal</b>           | <b>\$0</b> | <b>\$2,491,000</b>  | <b>\$4,624,000</b>  | <b>\$889,000</b>    |
| <b>Total Construction</b> |            | <b>\$14,328,500</b> | <b>\$33,791,000</b> | <b>\$11,959,000</b> |

As the raw water can flow by gravity from the GCWA canal to a plant forebay, no additional capital improvements will be necessary to transport the raw water from the Brazos River to the plant site. For both the CBWC and BRA alternatives, new raw water pump stations and pipelines will be necessary to move raw water from the river to the plant site. The estimated capital cost of providing the necessary pump station and pipeline is approximately \$14.3 million for the BRA option to Site A, \$33.7 million for the BRA option to Site E, and \$18.9 million for the CBWC option. The CBWC capital costs include a \$6 million dollar allocation for purchase of 25 MGD firm yield water rights at \$200 per acre-foot of water.

### Operating and Maintenance Costs

O&M costs for providing raw water to the plant site includes booster pump station operation and maintenance, maintenance on the raw water pipeline, and purchase of contract water. All costs are reported in Year 2000 dollars and shown in **Table 6-15**. The following assumptions were made regarding the operation of the raw water transmission system:

- The cost of electricity was assumed to be \$.06 per KWh
- Maintenance of the finished water pipeline system is equal to .25 percent of the pipeline construction estimate.
- Maintenance of pumps is equal to 3 percent of the pump station construction estimate.
- Operation at design capacity



## Section 6

# Finished and Raw Water Transmission

**TABLE 6-15**  
**RAW WATER CONVEYANCE ANNUAL O&M COSTS (YEAR 2000 \$)**

| O&M Item                                  | GCWA             | BRA to Site A      | BRA to Site E      | CWBC             |
|---|------------------|--------------------|--------------------|------------------|
| <b>Phase 1 (2010-2030)</b>                |                  |                    |                    |                  |
| Phase 1 Flow (MGD)                        | 16.5             |                    |                    |                  |
| Raw Water Pump Head (psi)                 | 0                | 40                 | 56                 | 30               |
| Pump Operation                            | \$0              | \$131,000          | \$183,000          | \$131,000        |
| Raw Water Purchase                        | \$542,000        | \$832,000          | \$832,000          | \$0              |
| Maintenance                               | \$0              | \$166,000          | \$268,000          | \$96,000         |
| <b>Total Phase 1 Annual O&amp;M Costs</b> | <b>\$542,000</b> | <b>\$1,129,000</b> | <b>\$1,283,000</b> | <b>\$227,000</b> |
| <b>Phase 2 (2010-2030)</b>                |                  |                    |                    |                  |
| Phase 2 Flow (MGD)                        | 26.5             |                    |                    |                  |
| Raw Water Pump Head (psi)                 | 0                | 40                 | 56                 | 30               |
| Pump Operation                            | \$0              | \$218,000          | \$306,000          | \$218,000        |
| Raw Water Purchase                        | \$903,000        | \$1,386,000        | \$1,386,000        | \$0              |
| Maintenance                               | \$0              | \$342,000          | \$406,000          | \$139,000        |
| <b>Total Phase 2 Annual O&amp;M Costs</b> | <b>\$903,000</b> | <b>\$1,946,000</b> | <b>\$2,098,000</b> | <b>\$357,000</b> |

The analysis shows that the operation of raw water system is least expensive under the CWBC alternative. This alternative is approximately 550,000 dollars cheaper per year than the GCWA option. The BRA option has the highest annual O&M costs as a result of the higher unit cost for raw water from the Brazos River Authority and the operation of the pumps to transport the water over 15 miles to the water treatment plant site.

# Section 7

## Alternative Selection

---

Development of the facility plan to provide the Mid-Brazoria County region with potable water requires selecting a preferred water treatment plant location and associated treated water transmission system. The previous sections have reviewed alternatives for treating Brazos River water and delivering this treated water to the Participating Utilities. This section serves to compare the alternatives and makes facility recommendations. Comparison of these alternatives will be based on the overall project cost, after careful consideration of non-economic factors.

### ALTERNATIVE SELECTION PROCESS

The process for selecting the recommended facility plan includes the development of the lifecycle project costs and the non-economic project impacting each water plant alternative. As these impacts and costs are determined, the alternatives can be compared. Selection of the recommended facility plan will be based on alternatives that offers the greatest flexibility in design, permitting, operations, and public acceptance at the lowest overall project cost. This section is divided into a discussion of the comparison methodology, the project costs of each alternative, and the non-economic impacts of each alternative and culminates in recommended facilities. A discussion of both of the selection criteria follows.


### Facility Plan Cost Assumptions and Economic Analysis Methodology

Each alternative has a dollar amount associated with the capital construction of the infrastructure and the operating and maintenance of the facilities. In order to compare these costs, the timing of the expenditures must be considered in the analysis. To account for this time value of money, a present worth analysis will be conducted. The present worth analysis calculates the required investment in the year 2001 to fund the entire project, including capital expenditures and annual operating and maintenance, over the life span of the project.

A synopsis of the analysis is as follows. All economic costs were calculated in terms of year 2000 dollars and then adjusted by the inflation rate to the year that they would be incurred. An inflation rate was used to accurately assess project costs the year they may be incurred so as not to underestimate their present worth cost. The timeline of expenditures is shown in **Figure 7-1**. Once these costs are plotted in time, the amount of money required to be invested today to fund each year's capital or O&M cost based on an annual interest rate is calculated. This is known as the present worth of the project and can be used to compare all of the alternatives. The following assumptions were used in this analysis:

- 1) Water treatment plant will begin operation in the year 2010.
- 2) Plant capacity will be constructed in two phases.
  - a) The first construction period will commence in the year 2006 with completion in the year 2010. The first phase of construction will consist of:
    - i) 15 MGD water treatment plant
    - ii) Raw water improvements to handle 25 MGD flow for new WTP
    - iii) All finished water infrastructure with capacity for 25 MGD
  - b) The second phase will commence in the year 2026 with completion of a 10 MGD water treatment plant expansion by the year 2030. The raw water pump stations will also be expanded at this time to meet the increased demand.
- 3) Annual Inflation Rate = 3 Percent
- 4) Annual Interest Rate = 6 Percent
- 5) Water Treatment Plant Annual Production
  - a) Year 2010-2030 – 15 MGD
  - b) Year 2030-2050 – 25 MGD





|                                 |
|---------------------------------|
| Present Worth Analysis Timeline |
| Figure 7-1                      |

The costs included in this analysis fall into two major categories: Capital costs to construct the infrastructure and operating and maintenance costs to produce and deliver treated water to the Participating Utilities. A discussion of each of these costs follows.

### Capital Costs

Capital costs contain three distinct categories: Construction, Engineering, and Contingency. Construction represents the costs associated with the materials and labor to build the facilities. Engineering is costs associated with the design, bid, and oversight of the construction process. Contingency is a factor of safety of the unknown costs and is applied to both the construction and the engineering costs.

#### *Construction*

The capital costs include an estimate of the construction costs for a new water treatment plant and distribution system, including but not limited to equipment, land acquisition, site work, concrete, electrical, pipelines, booster stations, contractors overhead and profit, and easements. The costs were compiled from recent projects of similar size and scope. For the purposes of this study, capital costs are assumed to occur at the midpoint of construction.

#### *Engineering*

The cost for engineering and construction administration includes the fee for designing, bidding, and administering the construction contract from the conceptual stage to final acceptance of the work. The engineering costs for this project is estimated at fifteen percent of the construction cost and construction administration cost is assumed to be six percent of the construction costs. GCWA administration costs during this phase are estimated at three percent of construction cost.

#### *Contingency*

Any construction project can have certain unpredictable expenses, including both minor and major changes in preliminary and final design, estimating deviations, rapid price changes in equipment, labor shortages and strikes. To cover the costs of these unpredictable expenses, an allowance for various contingencies is included to reduce project risk. The contingency will vary according to the type of project, complexity of design, and geographical location. This allowance can be reduced as the design progresses from concept through final construction documents, but some contingency must remain throughout the life of the project as a reserve for events that experience shows will likely occur. Contingency is applied to total construction cost which includes the construction estimate with engineering and construction administration included.

Three types of contingency are included in this job: Engineering Estimating, Cost Estimating, and Construction Bidding and Change Order. The contingency for cost estimating covers the unknown project components and fluctuations in the equipment and labor rates and at this early stage is approximated at twenty percent of the construction cost. At this preliminary stage, it should be recognized that the engineering is not based on detailed information and some level of contingency is needed to cover additional costs as the design evolves in detail. For the purposes of this study, a ten percent engineering estimating contingency will be used. Both the engineering estimating and cost estimating contingency should be reduced as the design progresses from conceptual to final. The last contingency component represents change orders during construction and bidding. The contingency will remain with the project until final acceptance of work and is estimated at 5 percent of the construction cost.



### Operating and Maintenance Costs

The operating and maintenance costs for the facility include the costs associated with producing and delivering the water demand to the Participating Utilities. Operation and maintenance costs include, but not limited to the following items:

- Electricity,
- Maintenance,
- Water treatment chemicals,
- Labor,
- Sludge disposal, and
- Administration

### WATER TREATMENT PLANT SITE ALTERNATIVE ANALYSIS

In the previous chapters, alternatives for the water treatment process and treatment plant locations were developed. This alternative analysis will focus on the six plant site alternatives discussed in **Section 5**. A summary of these alternatives is:

- Delivery at Pressure to each Participating Utilities take point from:
  - New regional WTP at Site A in Manvel
  - New regional WTP at Site E in Alvin
  - Proposed GCWA Ft. Bend Regional Water Plant in Stafford, Texas
- Delivery to ground storage tanks at each Participating Utilities take point from:
  - New regional WTP at Site A in Manvel
  - New regional WTP at Site E in Alvin
  - Proposed GCWA Ft. Bend Regional Water Plant in Stafford, Texas

For each of these alternatives, the non-economic impacts for each plant site and the economic costs of the construction and operating of the water treatment plant facilities, finished water transmission, and raw water delivery system were developed. These factors were reviewed and the low-cost alternative that maximizes flexibility in design and plant operations while minimizing impacts to the surrounding community was selected as the recommended facility plan.

### Non-Economic Factors

The project impacts not included as costs are termed as non-economic factors. These impacts are often difficult to quantify in terms of dollars and lend themselves to a more subjective analysis. The methodology for the non-economic criteria evaluation for the redundant raw water alternatives and the water treatment process alternatives is a general discussion of the pros and cons of each alternative.

The methodology for the non-economic factor evaluation for the plant site alternatives is a more complex matrix approach involving distinct criteria and a scoring system. Each criterion appears with a general description of the items included in each category.

|                           |  |
|---------------------------|--|
| <b>Public Acceptance:</b> | Aesthetics of water plant              |
|                           | Community position                     |
|                           | Loss of pastures and agricultural land |
|                           | Impact on adjacent land                |
|                           | Future land use                        |



- Expandability:** Future capacity expansion past year 2050  
Adaptability for future treatment requirements
- Reliability:** On-site storage capacity  
Secondary raw water source
- Environmental Impacts:** Noise  
Traffic  
Wetlands
- Permitting:** Regulatory approval  
Relationship with current land owner

The methodology for evaluating these non-economic factors was first, to establish a relative weight of each of these criteria against one another and second, to score each potential plant site against the criteria. After this was complete, an aggregate score of the sum of the criterion weight times the plant site score was developed. In this manner, subjective factors could be graded and ranked for each alternative. The criteria with the highest grade was given a weight of five, the next highest a four, and so on until the lowest important criteria was assigned a weight of one. The weights assigned by the Participating Utilities to each of the five criteria are shown in **Table 7-1**.

**TABLE 7-1**  
**NON-ECONOMIC CRITERIA WEIGHTS**

| Criteria                | Rank |
|-------------------------|------|
| Public Acceptance       | 2    |
| Expandability           | 3    |
| Reliability / Raw Water | 5    |
| Environmental Impacts   | 1    |
| Permitting              | 4    |

Once the weights were established, each alternative was compared against the criteria and given a favorable, neutral, or unfavorable ranking. A favorable ranking was given a score of 1, neutral a score of 0 and an unfavorable ranking was assigned a -1. A total score for each alternative was then obtained by multiplying the weight of the factor times the “ranking” for each alternative and summing the total for each alternative. This methodology creates a matrix where non-economic factors are reduced to quantifiable terms that can be compared between alternatives.

In selecting the plant site alternative, the plant sites were subjected to a non-economic analysis following the methodology described above. The analysis was used to compare the non-economic factors at the two screened sites (Manvel Site versus the Alvin Site) and the alternative of obtaining treated surface water from the GCWA surface water plant in Fort Bend County. Each site was ranked as favorable, neutral, or unfavorable against each of the five criteria. A summary of the discussion is as follows:

**Public Acceptance**

Each potential water treatment plant sites are located on open agricultural land adjacent to major thoroughfares. Site A in Manvel is along State Highway 6 corridor, which is anticipated to be a commercial zone. Site E in Alvin is along the State Highway 35 corridor and is within the ETJ of the City of Alvin adjacent to their current city limits. The landowners of each property have been contacted and have indicated the potential to sell the land to the Mid Brazoria County Planning Group for use as a

water treatment plant. It is anticipated neither of these sites would be unfavorable in terms of public acceptance and therefore are rated as a positive.

The GCWA plant site is not located within the Mid-Brazoria County region, but is located on a piece of property that is slated for a water plant. Although this location is known as a future location of a water treatment facility and adjacent to an existing wastewater plant and is viewed as an acceptable site, the water treatment plant facility would be owned and operated by another public agency and for that reason, the GCWA site is rated as neutral.

#### Expandability

Each site was also ranked in terms of the potential to expand the plant above and beyond the year 2050 finished water capacity or raw water reservoir capacity considered in the analysis. As the Alvin site contains in excess of 200 acres, an expanded raw water reservoir of up to three days could be provided, in addition to treatment capacity expansion well past 25 MGD. In addition, this site is downstream of an adjoining larger parcel of land owned by the same landowner for which a large raw water reservoir could be constructed. For these reasons, this site was ranked as favorable. The Manvel and GCWA sites meet the requirements to support the water treatment facilities for this project, but future process expansions are limited by the acreage of land at the site. These sites were ranked as neutral.

#### Reliability

On the subject of raw water reliability, both the Manvel and Alvin site have the ability to be fed from either the Gulf Coast Water Authority American Canal or Briscoe Canal. The Manvel Site is adjacent to both Lateral 10 and the Briscoe Canal and can install dual feeds from both of these canals. This raw water redundancy greatly reduces the risk of a raw water outage and makes this a favorable site. The Alvin site is adjacent to the Briscoe Canal only and as a result has a common point of failure in the raw water delivery stream. Even though this site is downstream of the GCWA Lateral 10 and can be feed from both canals, this site is ranked as neutral instead of positive as the water must travel through a common canal. Both sites are also within one mile of the Chocolate Bayou Canal, which could serve as another raw water source, thereby enhancing the reliability of raw water for the site.

The GCWA site can only be fed from the GCWA American canal and does not have cost effective alternative raw water supplies and is rated as neutral.

#### Environmental Impacts

The Manvel site is encumbered by the Chocolate Bayou floodplain and thereby requires additional engineering to mitigate flooding potential in the site. In addition, Brazoria County Drainage District is considering expanding the Bayou to improve storm water drainage and could widen the canal on this property. Due to these concerns, this site is ranked as neutral. The Alvin site also contains two drainage channels that are under consideration for expansion, but due to the large acreage of the site, it is expected that the drainage features will not impact construction of a water treatment plant. As this site does not have any known concerns or other expected concerns, this site is ranked as neutral. The GCWA site does not have any known environmental concerns or other expected surface features which would impact the cost and has been zoned for the construction of a water plant. As a result, this site is ranked as positive.

#### Permitting

Each site will require permits from the State of Texas to construct and operate the facilities. In general, the permits required at each site will be similar and the obstacles to obtaining each permit will also be

similar. For this reason, all sites could be ranked as neutral, but the Alvin site contains an additional layer of permitting that could impact the site. As a condition of placing the water treatment plant on this site, the current landowner would be involved in “wheeling” the raw water to the site. As a third party vendor supplying this water, they would be responsible for meeting state requirements and permits for construction and operation of these facilities. This would be a new venture for this group and could create problems for state acceptance of the project.

**Summary**

Given these discussions, the rankings were entered into the site selection matrix and the total non-economic score for each site alternative was determined. Each alternative’s criteria ranking, criteria weight, and overall score are shown in **Table 7-2**. Both sites have an aggregate score of .33. The Participating Utilities felt that there was no discernable difference between these sites and that siting the plant at the Alvin or Manvel site would have the same impact on the community.

**TABLE 7-2**  
**NON-ECONOMIC SITE SELECTION MATRIX**

| Criteria                | Rank | Weight      | Manvel      | Alvin       | GCWA<br>Regional Plant |
|-------------------------|------|-------------|-------------|-------------|------------------------|
| Public Acceptance       | 3    | 20%         | 1           | 1           | 0                      |
| Expandability           | 4    | 27%         | 0           | 1           | 0                      |
| Reliability / Raw Water | 5    | 33%         | 1           | 0           | 0                      |
| Environmental Impacts   | 1    | 7%          | 0           | 0           | 1                      |
| Permitting              | 2    | 13%         | 0           | 0           | 0                      |
| <b>Total Score</b>      |      | <b>100%</b> | <b>0.53</b> | <b>0.47</b> | <b>.07</b>             |

**Alternative Water Plant Scenario Costs**

To identify the economic cost of each water plant scenario, the construction, operation and maintenance costs of the raw water conveyance system improvements, water treatment facilities, and finished water transmission system for each alternative must be summarized. A present worth analysis was used to relate all of these costs to evaluate the comparative costs of these different alternatives.

**Raw Water Conveyance Improvements**

- In **Section 6** of this report, the raw water improvements for each plant site alternative were identified and the construction and annual operation and maintenance costs were estimated. The raw water improvements will be phased to match the capacity of the water plant and the construction and annual operating costs for a two-phased construction program are shown in **Table 7-3**.

**TABLE 7-3**  
**RAW WATER IMPROVEMENT CONSTRUCTION AND O&M COSTS (YR 2000 \$)**

| Cost Item                                  | Alternative                                    |  |                            |                             |
|--|--|--|----------------------------|-----------------------------|
|  | Alvin or Manvel<br>WTP Site from<br>CBWC Canal | Alvin or Manvel<br>WTP Site from<br>GCWA Canal | Alvin WTP Site<br>from BRA | Manvel WTP<br>Site from BRA |
| <i>Phase 1 Raw Water Pump Stations</i>     | \$3,285,000                                    | \$0  | \$7,219,000                | \$5,011,000                 |
| <i>Phase 1 Raw Water Pipeline</i>          | \$1,626,000                                    | \$0  | \$21,948,000               | \$6,826,500                 |
| <i>Water Rights</i>                        | \$6,159,000                                    | \$0  | \$0                        | \$0                         |
| <b>Total Phase 1 Construction</b>          | <b>\$11,070,000</b>                            | <b>\$0</b>                                     | <b>\$29,167,000</b>        | <b>\$11,837,500</b>         |
| Total Phase 2 Pump Station<br>Construction | \$889,000                                      | \$0  | \$4,624,000                | \$2,491,000                 |
| <b>O&amp;M</b>                             |  |  |                            |                             |
| Annual O&M Year 2010-2030                  | \$227,000                                      | \$542,000                                      | \$1,283,000                | \$1,129,000                 |
| Annual O&M Year 2030-2050                  | \$357,000                                      | \$903,000                                      | \$2,098,000                | \$1,946,000                 |

The costs presented herewith are developed from the information provided by Region H as modified to meet the modified alternative regional water treatment plant locations. It is noted the actual costs for any of these options are highly variable and depend on many factors yet unknown, including

- The actual cost of the Chocolate Bayou Water Company firm water rights. As the CBWC continues to market their water rights to nearby cities and water authorities, the cost of remaining CBWC rights may be more than initially estimated by Region H. The CBWC initially brokered these rights to the North Harris County Water Authority for a sum of \$100M dollars. Due to concerns of the actual firm yield during drought conditions and the regulations surrounding relocation of the take point on the Brazos, no final contract was pursued and the deal has since ended.
- Surface Water Availability on the Brazos River. At this time, the State of Texas indicates that the Brazos River is oversold and is currently working on evaluating the firm yield of the river. The results from the State's evaluation could impact the availability of surface water and the cost thereof
- The final selection of the water treatment plant. If the location of the regional water treatment plant changes, the facilities required to transport raw water to the WTP site will be different than those presented in the is report. As a result, the overall cost of the most cost effective raw water alternative may change.

#### Finished Water Transmission

In **Section 6** of this report, the finished water transmission system for each water plant alternative was developed. The costs for each component were identified and a summary of these costs is shown in **Table 7-4**. The finished water pipelines will be constructed entirely in Phase 1 to minimize the expense of the overall cost of the transmission program.

## Section 7 Alternative Selection

**TABLE 7-4  
FINISHED WATER CONSTRUCTION AND O&M COSTS IN 1000 \$(YR 2000 \$)**

| Construction Item                         | Manvel Site     |                 | Alvin Site      |                 | GCWA Site       |                 |
|---|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|
|   | At Pressure     | To GST          | At Pressure     | To GST          | At Pressure     | To GST          |
| <b>Capital Costs</b>                      |                 |                 |                 |                 |                 |                 |
| <i>Phase 1 High Service Pump Stations</i> | \$840           | \$840           | \$840           | \$840           | \$840           | \$840           |
| <i>Phase 1 Pipelines</i>                  | \$20,580        | \$19,290        | \$27,340        | \$24,430        | \$38,800        | \$37,620        |
| <i>Phase 1 Booster PS and GSTs</i>        | \$1,848         | \$3,924         | \$1,848         | \$3,924         | \$1,848         | \$3,924         |
| <b>Total Phase 1 Capital</b>              | <b>\$23,268</b> | <b>\$24,054</b> | <b>\$30,028</b> | <b>\$29,194</b> | <b>\$41,488</b> | <b>\$42,384</b> |
| <i>Phase 2 High Service Pump Stations</i> | \$560           | \$560           | \$560           | \$560           | \$560           | \$560           |
| <i>Phase 2 Booster PS and GSTs</i>        | \$1,232         | \$2,616         | \$1,232         | \$2,616         | \$1,232         | \$2,616         |
| <b>Total Phase 2 Capital</b>              | <b>\$1,792</b>  | <b>\$3,176</b>  | <b>\$1,792</b>  | <b>\$3,176</b>  | <b>\$1,792</b>  | <b>\$3,176</b>  |
| <b>O&amp;M Costs</b>                      |                 |                 |                 |                 |                 |                 |
| Annual Operating Cost: Year 2010-2030     | \$370           | \$460           | \$410           | \$490           | \$410           | \$550           |
| Annual Operating Cost: Year 2030-2050     | \$560           | \$690           | \$600           | \$720           | \$600           | \$810           |

### Water Treatment Plant Cost

The water treatment plant costs will be based on the capacity of the plant and will be based on a high-rate conventional process. The construction and O&M costs to construct and operate a high-rate conventional plants can be found in the **Appendix F** and are summarized in **Table 7-5**.

For the WTP costs associated with purchasing water from the GCWA Fort Bend Regional Water Treatment Plant, The cost estimates are based on constructing an initial 115 MGD regional WTP with 15 MGD of capacity dedicated to the MBCPG members with a 35 MGD expansion in the year 2030. 10 MGD of this expansion would be dedicated to MCBPG members.

Based on these assumptions, the capital cost for the first phase construction is assumed to be \$0.88 per gallon of capacity constructed. The unit rate for the expansion is calculated as \$0.71 per gallon of capacity added. The O&M costs to treat and distribute potable water was determined to be \$.45 per 1000 gallon during the first twenty years of operation, with a decrease to \$0.44 per 1000 gallons when the plant operates at the full 150 MGD capacity. This O&M rate excludes the cost of raw water supply and transportation, which would add another \$0.07 per 1000 gallons of raw water delivered to the plant site.

**TABLE 7-5**  
**WATER TREATMENT PLANT CONSTRUCTION AND O&M COSTS (YR 2000 \$)**

| Plant Location                                  | Capital              |                       | Annual O&M*           |                        |
|---|----------------------|-----------------------|-----------------------|------------------------|
|   | Phase I<br>Year 2008 | Phase II<br>Year 2028 | Phase I:<br>2010-2030 | Phase II:<br>2030-2050 |
| 25 MGD in new MBCPG Regional WTP                | \$22,940,000         | \$7,925,000           | \$3,443,000           | \$4,702,000            |
| 25 MGD from proposed GCWA Ft. Bend Regional WTP | \$13,950,000         | \$7,100,000           | \$2,464,000           | \$4,015,000            |

\* Excludes the cost of raw water purchase and transportation to the water plant site

In addition to the cost of the water treatment plant cost, each alternative plant site has unique costs related to the land acquisition costs, and other facilities which must be improved to make the plant site suitable for a regional water plant.

### Land

Each plant site has a cost to acquiring the required land for the water treatment plant site. The unit price of the land varies from site to site. Conversations were held with the landowners of each potential water treatment site to determine if the property could be subdivided or if the property was for sale. The unit price of the property and the minimum acreage that would have to be purchased are shown in **Table 7-6**.

**TABLE 7-6**  
**SITE ACQUISITION COSTS**

| Site   | Acreage | Cost Per Acre | Land Cost  |
|--------|---------|---------------|------------|
| Manvel | 54      | \$ 13,000     | \$ 700,000 |
| Alvin  | 200     | \$ 0          | \$ 0       |

The Alvin property is owned by a private landowner who, with several stipulations, will donate the land to the MBCPG free of charge for the right to provide the plant with raw water. As a result, the land cost for the Alvin site is zero, but an additional operational and maintenance charge will be assessed for the private landowner to “wheel” the water to the site.

### Other Economic Consideration

Additional costs not captured above are expected at both of the water treatment plant location. At the Manvel site, it is expected that a flood protection levee will have to be constructed to protect the portion of the site that is within the 100 year flood plain for being submerged during a flood event. The probable construction cost for such a levee is \$60,000.

The Alvin site is provided with the unique stipulation that the water provided to the site must be provided by the private landowner who would be donating the land to the MBCPG for use as a water treatment plant. In addition, the private landowner will construct a reservoir on a portion of their adjacent land to serve as forebay for the plant.

The private landowner has indicated that they would charge a per gallon rate to deliver water to the plant, but at the time of the release of this report, the landowner had not completed an estimated of their unit handling charge. As a result, the O&M calculations for the Alvin site do not include this charge and will need to be modified once the landowner submits their proposal to furnish the water to the Site.

**Present Worth Cost Summary**

Given the economic assumptions and the construction and operating and maintenance costs provided above, each alternative was subject to a present worth analysis to identify the estimated overall costs of each alternative. Due to the relative aforementioned unknowns associated with the alternative raw water delivery projects, the present worth analysis on the overall project will be divided into two distinct sections. The first analysis will focus on the raw water conveyance portion of this project and will evaluate the alternatives in terms of known costs and future impacts to this cost. The second analysis will develop the overall present worth cost of the alternative water treatment plant sites and the associated finished water transmission alternatives.

**Raw Water Conveyance System**

The capital and O&M costs for the raw water delivery for each alternative, including contingency and engineering are summarized in the **Appendix I**. A summary of the capital, annual O&M costs, and present worth of each alternative are shown in **Tables 7-7**.

**TABLE 7-7**  
**RAW WATER CONVEYANCE ALTERNATIVES PRESENT WORTH SUMMARY (YR 2000 \$)**

| Summary Cost Item    | Raw Water Alternative |              |                   |                   |
|----------------------|-----------------------|--------------|-------------------|-------------------|
|                      | 1: GCWA               | 2: CBWC      | 3A: BRA to Site A | 3B: BRA to Site E |
| Phase 1 Capital Cost | \$0                   | \$14,230,000 | \$19,527,500      | \$48,087,000      |
| Phase 2 Capital Cost | \$0                   | \$1,479,000  | \$4,131,000       | \$7,674,000       |
| Phase 1 Annual O&M   | \$542,000             | \$227,000    | \$1,129,000       | \$1,283,000       |
| Phase 2 Annual O&M   | \$903,000             | \$357,000    | \$1,946,000       | \$2,098,000       |
| Present Worth        | \$15,276,000          | \$17,873,000 | \$49,113,000      | \$75,979,000      |

Given the assumptions used for the evaluation of each alternative and the overall variability in the raw water costs due to water availability, the following recommendations regarding raw water conveyance to a Mid-Brazoria Regional Water Plant can be made:

- 1) The BRA options is approximately 3 to 5 times as expensive as either the GCWA or CBWC option and it appears that this is least attractive alternative
- 2) The relative present worth of the CBWC and GCWA alternative are within the variability or contingency of the assumptions used to develop the cost estimate. As a result, we recommend that that MCBPG proceed to negotiate with both entities to develop a raw water option contract to bring Brazos River water for potable use in the Mid-Brazoria Region. This contract would enable the MCBPG to further solidify the costs associated with bring raw water to the area and would secure raw water availability when the MCBPG is ready to augment their current groundwater supply with treated surface water.

## Section 7 Alternative Selection

### Site Selection and Finished Water Transmission

The capital and O&M costs for each alternative WTP site and finished water transmission system, including appropriate contingency and engineering, are summarized in the **Appendix J**. The corresponding results of the present worth analysis are shown in the **Table 7-8** and exclude the capital cost of the constructing the facilities necessary to bring raw water to the site and the O&M cost of operating said raw water conveyance system over the project horizon.

**TABLE 7-8  
PLANT SITE ALTERNATIVES PRESENT WORTH SUMMARY (YEAR 2000 \$)**

| Alternative   | Present Worth Cost (\$M) |
|---|--------------------------|
| Alternative 1A: Manvel Site Delivering Water At Pressure                        | \$160                    |
| Alternative 1B: Manvel Site Delivering Water To GSTs                            | \$164                    |
| Alternative 2A: Alvin Site Delivering Water At Pressure                         | \$169                    |
| Alternative 2B: Alvin Site Delivering Water To GSTs                             | \$170                    |
| Alternative 3A: GCWA Fort Bend County Regional WTP Delivering Water At Pressure | \$154                    |
| Alternative 3B: GCWA Fort Bend County Regional WTP Delivering Water to GSTs     | \$160                    |

Given the aforementioned assumptions, the analysis shows that purchasing water from the GCWA and constructing a large diameter pipeline to serve the Participating Utilities in the Mid-Brazoria County Region is the most cost effective alternative for converting 25 MGD of water demand from groundwater to surface water by the year 2050. The analysis further shows that within each of the three general alternatives, the option of delivering water at minimum distribution pressure to each of the Participating Utilities take points is more cost effective than delivering water to a ground storage tanks and boosting the water to meet individual Participating Utilities system pressure.

### Project Present Worth Costs

To complete the present worth cost of constructing and operating a surface water treatment plant, the costs for raw water conveyance need to be included. **Table 7-9** highlights the range of probable overall project present worth cost assuming raw water costs in accordance with governing assumptions used to in the cost analysis. As the CBWC and GCWA raw water alternatives are within the margin of contingency of each alternative estimate, the overall Project present worth costs are presented as a estimated range.

**TABLE 7-9  
PLANT SITE ALTERNATIVES PRESENT WORTH SUMMARY (YEAR 2000 \$)**

| Alternative                                   | Plant Site Present Worth Cost (\$M) | Raw Water Present Worth Cost (\$M) | Total Present Worth Cost (\$M) |
|---|-------------------------------------|------------------------------------|--------------------------------|
| Alt 1A: Manvel At Pressure                    | \$160                               | \$15.3 - \$17.9                    | \$175.3 - \$177.9              |
| Alt 1B: Manvel To GSTs                        | \$164                               | \$15.3 - \$17.9                    | \$179.3 - \$181.9              |
| Alt 2A: Alvin At Pressure                     | \$169                               | \$15.3 - \$17.9                    | \$184.3 - \$186.9              |
| Alt 2B: Alvin To GSTs                         | \$170                               | \$15.3 - \$17.9                    | \$185.3 - \$187.9              |
| Alt 3A: GCWA Ft Bend Regional WTP At Pressure | \$154                               | \$11.9                             | \$165.9                        |
| Alt 3B: GCWA Ft Bend Regional WTP to GSTs     | \$160                               | \$11.9                             | \$171.9                        |



**ALTERNATE WELL OPTION**

This section presents the cost associated with meeting the regional water demand with ground water. This cost analysis was done to compare the costs of providing a portion of the regional water demand with treated surface water as described above, with an estimate of the capital and O&M costs necessary to serve this demand with groundwater. For the purposes of this study, it was assumed that each Participating Utility would construct new groundwater wells with a capacity equal to their corresponding reserve capacity in the proposed surface water plant. The groundwater construction would be phased in the same manner as the surface water plant, with the sum of the Participating Utilities added groundwater capacity in the year 2010 equal to 15 MGD with a 10 MGD expansion in the year 2030.

The costs shown in **Table 7-10** highlight the corresponding construction and O&M for adding wells for each of the seven Participating Utilities. These costs include the cost of necessary groundwater storage improvements required to meet TNRCC requirements and the cost of additional booster pumps necessary to provide a residual system pressure of 50 psi. A detailed compilation of the construction and O&M costs for wells, booster pump stations and ground storage tanks required under this option is provided in **Appendix K**.

**TABLE 7-10**  
**CONSTRUCTION AND O&M COST FOR ALTERNATE WELL OPTION (YEAR 2000 \$)**

| Participating Utility | Phase 1 (2010-2030) |                     |                    | Phase 2 (2010-2030) |                    |                    |
|-----------------------|---------------------|---------------------|--------------------|---------------------|--------------------|--------------------|
|                       | Demand (MGD)        | Construction        | O&M                | Demand (MGD)        | Construction       | O&M                |
| Alvin                 | 2.31                | \$1,833,000         | \$190,000          | 1.82                | \$1,663,000        | \$343,000          |
| Angleton              | 1.34                | \$682,000           | \$113,000          | 1.11                | \$388,000          | \$207,000          |
| Brookside Vill.       | 0.31                | \$549,000           | \$30,000           | 0.26                | \$198,000          | \$55,000           |
| Danbury               | 0.27                | \$531,000           | \$27,000           | 0.21                | \$193,000          | \$48,000           |
| Hillcrest Village     | 0.00                | \$0                 | \$0                | 0.02                | \$0                | \$0                |
| Iowa Colony           | 0.14                | \$427,000           | \$17,000           | 0.10                | \$186,000          | \$30,000           |
| Manvel                | 2.26                | \$1,899,000         | \$193,000          | 1.51                | \$525,000          | \$320,000          |
| Pearland              | 7.81                | \$4,761,000         | \$664,000          | 5.85                | \$3,705,000        | \$1,161,000        |
| <b>Total</b>          | <b>14.44</b>        | <b>\$10,682,000</b> | <b>\$1,234,000</b> | <b>10.86</b>        | <b>\$6,858,000</b> | <b>\$2,164,000</b> |

*\*Included in City of Alvin*

If these construction and O&M costs are subjected to a present worth analysis, the results show that the present worth cost of the “groundwater” option is \$52,495,000. This is approximately one-third of the present worth cost of the least expensive surface water conversion alternatives. **Table 7-11** shows a comparison of the total present worth cost associated with the three water supply alternatives. Although this option is economically attractive, continued reliance on groundwater may lead a steady deterioration in groundwater quality and quantity.

**TABLE 7-11**  
**TOTAL PRESENT WORTH COST COMPARISON (YR 2000 \$)**

| Water supply alternative              | Total Present Worth Cost (\$M) |
|---------------------------------------|--------------------------------|
| Manvel WTP At Pressure                | \$175.3 - \$177.9              |
| GCWA Ft Bend Regional WTP At Pressure | \$165.9                        |
| Water Well Option                     | \$52.5                         |

## RECOMMENDATIONS OF WATER PLANT FACILITY LOCATIONS

The present worth cost of the plant site alternatives including contingency and engineering ranged from the \$166M to \$190M including the most likely costs for raw water acquisition and conveyance. The present worth analysis indicates that the most cost effective method to convert 25 MGD of potable water demand for seven Participating Utilities in the Mid-Brazoria County region is to combine forces with several larger entities in Fort Bend and Harris Counties in a larger regional water treatment plant. In this manner, the costs of raw water acquisition and treatment are distributed over a larger base water demand and the unit rate for water treatment is lower.

However, if the MBCPG decided to pursue a separate Mid-Brazoria County regional water plant, the most cost effective alternative including raw water conveyance, as described by Region H and modified in **Section 6**, would be to construct a regional water plant at the Manvel site. The main advantage that the Manvel site over the Alvin site is the distance between the site and the City of Pearland take point. As the City of Pearland is the largest single user in the Mid-Brazoria region, the costs of the transmission line to the City represents a large portion of the overall capital cost necessary to construct a regional plant. The Manvel site is approximately 4 miles closer to the City of Pearland site and benefits from the reduced pipeline length to this point.

In addition, pumping from the Manvel site is less expensive as the high service pumps will operate at a lower head due to the positive elevation difference between the Manvel and the Alvin Site.

Based on the results of this study, the following recommendations are made:

- Begin negotiations with Fort Bend and Harris County cities and municipalities to construct a large capacity high-rate conventional process surface water treatment plant in Stafford, Texas to serve the residents of Harris, Brazoria, and Fort Bend Counties with treated surface water. This alternative has the apparent low present worth cost.
- Begin easement acquisition, permitting, preliminary planning and engineering for water plant site, and transmission main alignments.
- If the MBCPG wishes to construct a Mid Brazoria County Regional Water Plant and not participate in a larger regional water plant, the MBCPG should construct a 25 MGD high-rate conventional surface water treatment plant on the Southeast corner of Highway 6 and Iowa Lane in Manvel, Texas. This site has the apparent low present worth cost for a smaller Mid-Brazoria County regional facility and does not have any permitting issues relating to the conveyance of raw water through a private landowner. A facility plan for implementing this regional treatment plant is developed in **Section 8**.

Negotiate with both CBWC and GCWA to develop a raw water option contract to bring Brazos River water for potable use in the Mid-Brazoria Region. This contract would enable the MCBPG to further solidify the costs associated with bring raw water to the area and would secure raw water availability when the MCBPG is ready to augment their current groundwater supply with treated surface water.

## Section 8 Facility Plan

---

Based on the evaluation of treatment and distribution alternatives developed in Section 7, the most economically solution to converting to treated surface water is to combine with neighboring communities and construct a larger regional water treatment plant located in Fort Bend County. In this alternative, a finished water pipeline would transport treated water from the water treatment plant to the MBCPG members. It is our recommendation that the MBCPG begin negotiations with Fort Bend and Harris County cities and municipalities to construct a large capacity high-rate conventional process surface water treatment plant in Stafford, Texas to serve the residents of Harris, Brazoria, and Fort Bend Counties with treated surface water. This alternative has the apparent low present worth cost. A proposed facility plan for this alternative was addressed by the Texas Water Development in a report issued November 2000.

If the MBCPG members decide to construct a Mid Brazoria County Regional Water Plant and not participate in a larger regional water plant, it is our recommendation to construct a 25 MGD high-rate conventional surface water treatment plant near Manvel, Texas. Under this alternative, a high rate conventional water treatment plant at the Manvel plant site with an initial capacity of 15 MGD and an ultimate capacity of 25 MGD would be constructed. This section prepares a facility plan for this alternative to serve the growing water demands of the Participating Utilities through the year 2050, given the following regional operating strategy.

### **REGIONAL OPERATING STRATEGY**

The demand projections are based on maintaining groundwater production at the current rate of 11.5 MGD. The water treatment plant capacity is sized to serve the difference between the expected average demand and current groundwater production. The Participating Utilities will provide the infrastructure to meet peak daily demand and to provide water over and above their maximum regional surface water treatment and groundwater capability to meet daily fluctuations in demand.

### **CAPITAL IMPROVEMENT PROGRAM**

The recommended capital improvement programs to design, construct, and operate a regional water treatment plant and associated transmission facilities will utilize phased construction to match expected surface water demand. This plan assumes that the surface water conversion will be initiated in planning area by the year 2010 and that the current groundwater withdrawal will maintain the aquifer level and quality at current standards.

The first phase will involve engineering and construction for a 15 MGD high-rate conventional water plant and the associated water transmission network. This will meet the projected surface water demand through the year 2030. It is recommended that the entire finished water transmission network be constructed during this phase to minimize future expansion and cost. The design and construction for this phase will require approximately four to five years.

The second phase of the project would expand the treatment plant capacity from 15 MGD to 25 MGD. According to the Participating Utility water demand projections, expansion will be required by the year 2030 to meet expected water demand. The construction for the expansion will require to approximately two years.

### **FACILITIES DESCRIPTION**

The facilities to be constructed fall in to three distinct construction packages: water treatment plant, raw water delivery system, and finished water transmission. Each package will be discussed in detail.



### Water Treatment Plant

The water treatment plant will be located at the Manvel site and will encompass approximately 50 acres. The site will be fenced and access monitored through a front gate. The site will have a storage reservoir, process equipment and administration and maintenance facilities. The process design will utilize a high-rate conventional process with pulsed upflow clarifiers and deep bed, dual media filters. The process flow diagram for the plant is shown on **Figure 8-1**.

Raw water will be stored in a 15 feet deep forebay. Water will then be pumped out of the storage reservoir using vertical turbine pumps to the pulsed-upflow clarifiers after injection of coagulation chemicals. The clarifier effluent will flow through dual media filters containing granular activated carbon. Provisions are made in the site layout for the addition of a future disinfection contact chamber, as future regulations require stricter finished water quality. From the filters, chemicals will be added to control corrosion and provide residual disinfection in the transmission lines and the finished water will be stored in ground storage tanks. High service pumps will then distribute finished water to the take points through the potable water transmission pipelines. Five high service pumps in phase one and two in phase two will be dedicated to provide finished water to the Participating Utilities.


Sludge will be treated through gravity thickeners and sludge drying beds to increase the solids content, thereby decreasing the net volume of sludge requiring ultimate disposal off-site. Design criteria and preliminary sizing of the major process equipment is shown in **Appendix D**. A proposed layout of the major process trains and ancillary facilities are shown on **Figure 8-2**. Facilities shown with dashed lines are future processes and will be built as part of the expansion in the year 2030 or as future regulations require. The layout was designed to maximize common wall construction and to allow for flexibility for additional processes to meet future changes in treatment regulations.

### Raw Water Delivery System

Region H has identified the Brazos River as the raw water source for this regional surface water facility. To carry water from the river to the Manvel plant site, the study evaluated the following three alternative mechanisms:

- Gulf Coast Water Authority (GCWA)
- Brazos River Authority (BRA)
- Chocolate Bayou Water Company (CBWC)

An analysis of the economics associated with these three options was developed in Section 7. This cost analysis was based on assumptions regarding the relative availability and stated cost of raw water. Each aforementioned entity has conditions and requirements regarding sale or purchase of raw water which will impact the overall cost of the raw water for this project. Even with the expected variability in the raw water costs, the evaluation showed that the BRA option is significantly less cost effective than the GCWA or CBWC alternatives. The analysis also showed that with the stated assumptions, the overall economic cost of the CBWC and GCWA alternatives were within the variability of the cost estimates. It is recommended that the MBCPG negotiate with both CBWC and GCWA to develop a raw water option contract to bring Brazos River water for potable use in the Mid-Brazoria Region. This contract would enable the MBCPG to further solidify the costs associated with bringing raw water to the area and would secure raw water availability when the MBCPG is ready to augment their current groundwater supply with treated surface water. Due to the high degree of variability associated with the cost of the CBWC raw water due to potential sale of their water rights to an outside entity, the facility plan will include the GCWA alternative as the raw water transportation mechanism for the regional water plant. *The GCWA option for raw water cost analysis is presented as the baseline known costs for raw*



MID-BRAZORIA COUNTY PLANNING GROUP/TWDB  
FACILITY PLAN

HIGH-RATE CONVENTIONAL  
PROCESS SCHEMATIC

FIGURE 8-1

MONTGOMERY WATSON



*water for this study and is an aid for the Planning Group to negotiate with other entities. This does not in any way preclude the Planning Group members to negotiate for raw water from other entities.*

### Finished Water Transmission System

From the 25 MGD water treatment plant at the Manvel site, the finished water will be delivered to the Participating Utility take points through the transmission network shown in **Figure 8-3**. The network is designed to deliver finished water at pressure. The utilities will take water at a system pressure of 50 psi and will feed water directly into their distribution system. A summary of projected water demands at utility take points is shown in the **Table 8-1**.

**TABLE 8-1**  
**REQUESTED FLOW AT UTILITY TAKE POINTS**

| Participating Utility     | Take Point Number | Address   | Average Water Demand (MGD) |
|---------------------------|-------------------|---|----------------------------|
| City of Manvel            | 1                 | Iowa Lane and Hwy 6, Manvel TX  | 3.77                       |
| City of Pearland          | 2a                | SH 288 at 518, Pearland TX  | 13.66                      |
| City of Brookside Village | 3a                | Garden Road and Brookside Road  | 0.57                       |
| City of Alvin             | 4a                | SH 6, north of Mc Cormick Road  | 4.13                       |
| City of Hillcrest Village | 4a                | Same as City of Alvin take point  | 0.07                       |
| City of Iowa Colony       | 5                 | At the intersection of County Road 64 and Iowa School Road                            | 0.24                       |
| City of Danbury           | 6                 | 5 <sup>th</sup> Street at St. Spur 8  | 0.48                       |
| City of Angleton          | 7                 | At the intersection of Henderson Road and Krankawa Road in the North part of the City | 2.45                       |


### Water Treatment Plant Operations

The water treatment plant will be operated and maintained by the MBCPG. MBCPG will monitor the water quality, make treatment process adjustments, maintain distribution system pressure, and maintain the water treatment and transmission facilities.

### Staffing Plan

The plant will be staffed 24 hours per day. The following staff will be required for operation and maintenance of the water plant and finished water transmission network.

- Process Operators – 6
- Electricians and Instrument Technicians – 2
- Maintenance – 3
- Administration – 1
- Plant Superintendent – 1



MID-BRAZORIA COUNTY PLANNING GROUP/TWDB  
FACILITY PLAN

FINISHED WATER MODEL RESULT FOR  
SITE A IN MARVEL AT PRESSURE

FIGURE 8-3

The plant operations will be divided into three shifts. Two operators will cover the day and swing shifts, with one operator on the night shift. Maintenance and electrical staff will serve as backup operators to handle vacations and sick days. The maintenance and electrical crews will provide O&M services on the raw water delivery system, water treatment plant facilities, and finished water transmission system.

The operators will handle daily laboratory functions for process adjustments at the new plant.

### Operations Control

The regional water plant will be controlled through a Supervisory Control and Data Acquisition (SCADA) system. The SCADA system will provide a platform that will not only provide monitoring and control of the operation facilities, but also provide an interface to other applications including:

- Maintenance management system,
- Electronic operation and maintenance manuals,
- Laboratory information management system,
- Advanced operational strategies and planning through water system hydraulics and water quality models,
- Energy management system,
- Facilities security and protection through a Site Security and Video Surveillance System, and
- Management information system.

## UTILITY SERVICE CONCEPTS

### Electrical

The plant will require electrical service to power the water plant facilities, including low lift pumping, high service pumping, and plant process equipment. It is estimated that the daily electrical demand for a 25 MGD plant will be approximately 20 MW. We recommend that this demand be met through redundant substation feeds from a local electrical utility provider. Conversations with Reliant Energy indicate that power for the plant could be obtained from the Karsten and Manvel substations, thereby provided redundant feeds.

### Sanitary

We recommend that the water treatment plant wastewater be collected and transported to the City of Manvel wastewater treatment plant. Normal wastewater production at the plant will be less than 500 gallons per day with maximum daily production in the range of 2000 gallons per day.

### Sludge Processing

Sludge processing at the plant will consist of gravity thickeners and sludge drying beds. The resulting sludge cake will have a solids content of approximately 45 percent. Once the sludge is adequately dried, the sludge will be hauled off-site by third party vendors for land application. Conversations with various vendors indicate that the cost for hauling and disposing of the centrifuge sludge will be approximately \$325 per truckload. As each sludge drying bed holds 320 cubic yards of dried sludge. As each truck can hold 22 cubic yards, approximately 15 truckloads of sludge will be produced each month.

### Transportation



The Manvel site is located adjacent to Highway 6 just east of State Highway 288. These thoroughfares are more than sufficient to support chemical delivery trucks, sludge trucks, and general operations associated with the plant. A truck scale should be installed inside the water treatment plant site to gauge chemical deliveries and sludge disposal.

**Storm Sewer Management**


It is anticipated that storm water from the site will be collected and discharged into Chocolate Bayou. Permits from the Brazoria County Drainage District and TNRCC will be required.

**OPINION OF PROBABLE COSTS**

**Construction**

A summary of the preliminary opinion of probable construction costs for the recommended facility plan is shown in **Table 8-2**. The costs for the major process components, the raw water delivery system, and the finished water pipelines are provided. These costs are reported in year 2000 dollars and will have to be adjusted for the actual cost in the year of construction. As the design of the facility advances, the level of contingency may be reduced. Without contingency, the estimated capital cost for the first phase of the project, including raw water delivery improvements, water treatment plant, and finished water pipelines is \$47 million. The estimated capital cost for the 10-MGD expansion by the year 2030 is \$10 million. With a 35 percent contingency, the estimated capital costs for the first phase of construction and the year 2030 water treatment plant expansion are \$63 million and \$13 million, respectively for the first phase of construction and the year 2030 water treatment plant expansion. A breakdown of these unit costs by construction package, engineering, and contingency for the 25 MGD facility is shown in **Figure 8-4**.

**FIGURE 8-4**  
**UNIT COST OF 25 MGD SURFACE WATER FACILITY**



## Section 8 Facility Plan

**TABLE 8-2  
PRELIMINARY OPINION OF PROBABLE CONSTRUCTION COSTS**

| ITEMS                                       | COST (\$, YR 2000)   |                     |
|---|----------------------|---------------------|
|   | 15 MGD Initial Phase | 10 MGD Expansion    |
| <b>Water Treatment Plant</b>                |                      |                     |
| Property                                    | \$700,000            | -                   |
| Flood Plain Mitigation                      | \$60,000             | -                   |
| Sitework                                    | \$3,500,000          | -                   |
| Yard Piping                                 | \$1,275,000          | \$850,000           |
| Low Lift Pumping                            | \$660,000            | \$132,000           |
| Mixing/Flocculation/Sedimentation           | \$655,000            | \$515,000           |
| Filters                                     | \$4,100,000          | \$1,367,000         |
| Transfer Pumping                            | \$660,000            | \$120,000           |
| PAC System                                  | \$250,000            | -                   |
| Backwash Equalization Tank                  | \$232,000            | -                   |
| Backwash Clarification                      | \$53,000             | \$53,000            |
| Gravity thickeners/holding tanks            | \$8,000              | \$8,000             |
| Chemical Systems, Building, Tanks           | \$3,850,000          | \$1,485,000         |
| Sludge lagoons                              | \$592,000            | \$296,000           |
| Ground Storage Tanks                        | \$1,600,000          | \$1,200,000         |
| Electrical, Instrumentation, and Controls   | \$2,267,000          | \$783,000           |
| Mobilization                                | \$591,000            | \$204,000           |
| Construction Mgmt, Insurance, Bonds, Profit | \$2,638,000          | \$912,000           |
| <b>Sub Total</b>                            | <b>\$23,691,000</b>  | <b>\$7,828,000</b>  |
| <b>Finished Water Transmission</b>          |                      |                     |
| High Service Pump Station                   | \$840,000            | \$560,000           |
| Booster Pump Station and Ground Storage     | \$1,848,000          | \$1,232,000         |
| Pipelines                                   | \$19,820,000         | -                   |
| Easements                                   | \$760,000            | -                   |
| <b>Sub Total</b>                            | <b>\$23,268,000</b>  | <b>\$1,792,000</b>  |
| <b>Raw Water Improvements<sup>1</sup></b>   | <b>\$-</b>           | <b>\$-</b>          |
| <b>Sub Total</b>                            | <b>\$-</b>           | <b>\$-</b>          |
| <b>Construction Total</b>                   | <b>\$46,959,000</b>  | <b>\$9,717,000</b>  |
| Engineering Contingency (10%)               | \$4,700,000          | \$ 970,000          |
| Construction Contingency (5%)               | \$2,350,000          | \$ 490,000          |
| Cost Contingency (20%)                      | \$9,390,000          | \$1,940,000         |
| <b>Subtotal</b>                             | <b>\$16,440,000</b>  | <b>\$3,400,000</b>  |
| Engineering                                 | \$9,510,000          | \$1,970,000         |
| Construction Administration                 | \$3,170,000          | \$ 660,000          |
| MBCPC Administration                        | \$1,900,000          | \$ 390,000          |
| <b>Total Capital</b>                        | <b>\$77,979,000</b>  | <b>\$16,142,000</b> |

1. GCWA Raw Water Alternative



Therefore, the capital outlay for the first phase is estimated to be between \$2.46 and \$3.30 dollars per gallon of capacity constructed, including water treatment plant, finished water pipelines, raw water delivery improvements, engineering, construction oversight and contingency.

### Operating and Maintenance

The estimated operating and maintenance costs for the water treatment plant, raw water delivery system, and finished water transmission are shown in **Table 8-3**. Annual operating costs over the first 20 years of operation will be \$4.3 million, with annual O&M costs jumping to \$6.1 million after the expansion in the year 2030. This cost represents a unit cost of \$0.78 per 1000 gallon produced during the first 20 years and a unit rate reduction to \$0.67 per 1000 gallon after the plant is expanded to its ultimate capacity of 25 MGD.

**TABLE 8-3**  
**PRELIMINARY OPINION OF ANNUAL O&M COSTS**

| Category                    | Annual O&M Costs (YR 2000 \$)   |                                 |
|-----------------------------|---------------------------------|---------------------------------|
|                             | Year 2010-2030<br>Flow = 15 MGD | Year 2030-2050<br>Flow = 25 MGD |
| <b>Electrical</b>           |                                 |                                 |
| Raw Water                   | -                               | -                               |
| Plant Process               | \$269,000                       | \$363,000                       |
| High Service Pumps          | \$282,000                       | \$470,000                       |
| <b>Sub Total</b>            | <b>\$551,000</b>                | <b>\$833,000</b>                |
| <b>Chemical</b>             | <b>\$1,043,000</b>              | <b>\$1,738,000</b>              |
| <b>Sludge Disposal</b>      | <b>\$74,000</b>                 | <b>\$123,000</b>                |
| <b>Maintenance</b>          |                                 |                                 |
| Raw Water                   | -                               | -                               |
| Plant Process               | \$390,000                       | \$525,000                       |
| Finished Water              | \$88,000                        | \$90,000                        |
| <b>Sub Total</b>            | <b>\$478,000</b>                | <b>\$615,000</b>                |
| <b>GAC Replacement</b>      | <b>\$350,000</b>                | <b>\$583,000</b>                |
| <b>Staff</b>                | <b>\$718,000</b>                | <b>\$770,000</b>                |
| <b>Administration</b>       | <b>\$600,000</b>                | <b>\$600,000</b>                |
| <b>Cost of Raw Water</b>    | <b>\$422,000</b>                | <b>\$703,000</b>                |
| <b>Total Annual O&amp;M</b> |                                 |                                 |

### Funding Mechanism

Funding for the project will be based on grants, loans from the TWDB, revenue bonds based on the sale of water, or taxes depending on how the Authority is structured to finance projects.

### Resource Management Authority

To implement a regional water treatment and transmission system for the Mid Brazoria County Participating Utilities, the members of the MBCPG will need to join or form an authority with the means to control, store, preserve, and distribute water for domestic and commercial purposes. Moreover, this Authority must have legal power to contract for water of Texas and should have entitlement to incur debt to finance and operate the regional facilities. A review of available alternative for use by the MBCPG to implement can be viewed in **Appendix B**. It is our recommendations that the MBCPG work with their legislators to develop and implement a regionally acceptable Authority with the power to negotiate a raw water contract or sale to facilitate the possibility of implementing this or a larger regional facility plan.

## Section 9

# Projected Wholesale Rates

---

The cost of constructing, operating, and maintaining the regional surface water treatment and transmission program as presented in Section 8, will be shared by the Participating Utilities. This section reviews the estimated capital and O&M costs, available funding mechanisms, and projected water demand to estimate a wholesale water rate for the planning region. The wholesale water rate analysis is based on the treatment plant located at site A in the City of Manvel. It should be noted that all economic rates presented in this section are for planning purposes only and do not represent final rates that Participating Utilities will pay for wholesale water. This section assumes that the MBCPG will finance, construct, and operate the new regional water facilities.

The construction costs for the water plant, transmission network, and canal raw water costs will be borne by each of the Participating Utilities based on their contracted reserve capacity. O&M costs will be based on each Participating Utility's wholesale water bill.

### Capital Debt Retirement

It is anticipated that the MBCPG would secure grants or bonds in the amounts necessary to finance the initial construction of the water treatment plant, transmission network, and raw water improvements. Thirty-year financing will provide funding for debt and MBCPG administration costs associated with the revenue bonds needed to construct the project. Prorated capital debt service for each Participating Utility will be fixed throughout the lifespan of the bond. Prorated rates will be based on the amount of contract water purchased and the extent of infrastructure constructed to transport finished water to the individual Participating Utilities.

The total capital debt retirement costs associated with design and construction of raw water improvements, water treatment plant, and transmission network are uniformly distributed to each Participating Utility. Uniformly distributed costs are based on relative percentage of capacity that each Utility "reserves" in the regional water plant. Each Participating Utility pays the same debt service rate associated with constructing the water plant, raw water improvements, and transmission network. This cooperative type plan allows potential utilities in outlying areas to participate in the regional water supply facility at the same rate as the utilities located much closer to the facility. By adding more participating utilities, the design capacity of the regional water plant becomes larger and a unit capital and O&M cost savings can be realized because of the economy of scale.

### WHOLESALE WATER RATES

Wholesale water rate analysis has been performed to project the wholesale water rates. The analysis is based on the following assumptions:

- The facility plan presented in Section 7 will serve the region through the year 2050.
- All numbers presented in the rates are Year 2000 dollars.
- The financial debt service rates are calculated at an estimated interest rate of six percent and a debt service period of 30 years.
- Rates for debt service such as water plant and distribution network construction will be based on Participating Utilities' contract reserve capacity (i.e. the debt service will be applied to each Utility's contracted reserve capacity).
- O&M rates will apply to actual water use (take-or-pay).



## Section 9

# Projected Wholesale Rates

---

MBCPG will obtain grants (as available), loans, and sell bonds to construct a 15 MGD water treatment plant and transmission network in the year 2010. All Participating Utilities would pay the same wholesale water rate regardless of their location or reserve contract amount. The estimated wholesale water rate that each utility would pay under this scenario is \$1.82 per 1,000 gallons, and is presented in **Table 9-1**. The annual debt service payment till the year 2030 will be \$5,573,148.

**TABLE 9-1**  
**ESTIMATED WHOLESALE WATER RATE (\$/1000 GALLONS)**  
**INITIAL 15 MGD PHASE – YEAR 2010**

| Customer                        | Reserve Capacity Rate  |                   |                                 | Take or Pay Rate<br>O&M | Estimated Total Rate |
|---------------------------------|--|-------------------|---------------------------------|-------------------------|----------------------|
|                                 | Debt Service<br>Water Treatment Plant<br>and Transmission<br>Network | Raw Water<br>Cost | Subtotal<br>Reserve<br>Capacity |                         |                      |
| Utilities in<br>Planning Region | \$1.02   | \$0.10            | \$1.12                          | \$0.70                  | \$1.82               |

At year 2030, the plant would undergo an expansion to 25 MGD. **Table 9-2** shows the estimated impact to wholesale water rates under the expanded plant. The estimated wholesale water rate for this phase is \$1.00 per 1000 gallons, while the annual debt service payment from the year 2030 onwards will be \$1,172,196.

**TABLE 9-2**  
**ESTIMATED WHOLESALE WATER RATE (\$/1000 GALLONS)**  
**10 MGD PLANT EXPANSION – YEAR 2030**


| Customer                        | Reserve Capacity Rate                    |                   |                                 | Take or Pay Rate<br>O&M | Estimated Total Rate |
|---------------------------------|--|-------------------|---------------------------------|-------------------------|----------------------|
|                                 | Debt Service<br>Water Treatment<br>Plant | Raw Water<br>Cost | Subtotal<br>Reserve<br>Capacity |                         |                      |
| Utilities in<br>Planning Region | \$0.32                                   | \$0.10            | \$0.42                          | \$0.58                  | \$1.00               |

# Section 9

## Projected Wholesale Rates

Figure 9-1 shows the estimated wholesale water rates for planning purposes as a function of time.

**FIGURE 9-1  
ESTIMATED WHOLESAL WATER RATE**



### GCWA Regional Plant Alternative

These wholesale water rates calculated for the treatment plant located in the City of Manvel, can be compared to wholesale water rates that each utility would have to pay if finished water is taken from the GCWA plant located in Fort Bend County.

The estimated wholesale water rate that each utility would pay under this scenario is \$1.85 per 1,000 gallons, and is presented in **Table 9-3**. The annual debt service payment till the year 2010 will be \$6,687,681.

**TABLE 9-3  
ESTIMATED WHOLESAL WATER RATE (\$/1000 GALLONS)  
INITIAL 15 MGD PHASE – YEAR 2010**

| Customer                        | Reserve Capacity Rate  |                   |                                 | Take or Pay Rate<br>O&M | Estimated Total Rate |
|---------------------------------|--|-------------------|---------------------------------|-------------------------|----------------------|
|                                 | Debt Service<br>Water Treatment Plant<br>and Transmission<br>Network | Raw Water<br>Cost | Subtotal<br>Reserve<br>Capacity |                         |                      |
| Utilities in<br>Planning Region | \$1.22   | \$0.10            | \$1.32                          | \$0.52                  | \$1.85               |

## Section 9

# Projected Wholesale Rates


At year 2030, the plant would undergo an expansion to 25 MGD. **Table 9-4** shows the estimated impact to wholesale water rates under the expanded plant. The estimated wholesale water rate for this phase is \$0.90 per 1000 gallons, while the annual debt service payment from the year 2030 onwards will be \$1,072,674.

**TABLE 9-4**  
**ESTIMATED WHOLESALE WATER RATE (\$/1000 GALLONS)**  
**10 MGD PLANT EXPANSION – YEAR 2030**

| Customer                        | Reserve Capacity Rate                    |                   |                                 | Take or Pay<br>Rate<br>O&M | Estimated<br>Total Rate |
|---------------------------------|--|-------------------|---------------------------------|----------------------------|-------------------------|
|                                 | Debt Service<br>Water Treatment<br>Plant | Raw Water<br>Cost | Subtotal<br>Reserve<br>Capacity |                            |                         |
| Utilities in<br>Planning Region | \$0.29                                   | \$0.10            | \$0.39                          | \$0.51                     | \$0.90                  |

**Figure 9-2** shows the estimated wholesale water rates for planning purposes as a function of time.

**FIGURE 9-2**  
**ESTIMATED WHOLESALE WATER RATE**





## Section 9

# Projected Wholesale Rates

---

### Summary

The wholesale water rate analysis conducted for the Participating Utilities shows that the wholesale water rates for water plant located at the Manvel site, and the for the GCWA water plant are comparable. A present worth analysis was conducted in Section 7, which showed that purchasing water from the GCWA and constructing a large diameter pipeline to serve the Participating Utilities was the most cost-effective alternative.





**Appendix A**  
**Bibliography**

---

## Bibliography

1. Texas Water Development Board: Region H Water Plan, January 2001. Prepared by the Joint Venture of Brown & Root and Turner Collie & Braden, Ekistics Corp. and LBG-Guyton Associates.
2. USGS Water Quality Monitoring Network Data – Station 08114000 Brazos River at Richmond, TX.
3. Regional Surface Water Treatment Plant Feasibility Study for Brazoria, Fort Bend, and Wet Harris Counties, Gulf Coast Water Authority, July 2000. Prepared by Montgomery Watson.
4. Chapter 26, Site Selection Plant Arrangement
5. Kawamura, Susumu, *Integrating Design of Water Treatment Facilities*, John Wiley and Sons, 1991
6. Brazoria County Texas, Soil Survey, United States Department of Agriculture.
7. Briscoe Production Company, Letter dated February 15, 2001.
8. Turner Collie & Braden: Alternative Water Supply Study for Region H Water Planning Group, February 2001, letter report submitted to the Chairman of Region H.
9. Texas Constitution Article 16 – General Provisions, Section 59 “Conservation and Development of Natural Resources; Conservation and Reclamation Districts.”
10. Texas Statutes Water Code – Chapter 36 “Groundwater Conservation Districts” Subchapter A. General Provisions.
11. Texas Statutes Water Code – Chapter 51 “Water Control and Improvement Districts” Subchapter A. General Provisions.
12. Texas Statutes Water Code – Chapter 65 “Special Utility Districts” Subchapter A. General Provisions.

**Appendix B**  
**Water Conservation and Drought Contingency Plan;**  
**Resource Management Authority Alternatives.**

---

## Mid-Brazoria County Planning Group Water Conservation Drought Contingency Plan

The Mid-Brazoria County Planning Group (MBCPC) was formed to investigate the feasibility of creating a regional water authority to provide wholesale surface water to its members. The planning study is partially funded by the Texas Water Development Board (TWDB). TWDB requires that entities for whom it provides planning grants must create a Water Conservation Plan (WCP) and a Drought Contingency Plan (DCP) as a part of the planning process. If it proves feasible for the MBCPC to become a wholesale water provider, it must formally create a water district. The MBCPC will be referred to as “the District” in this document. The WCP and DCP will be adopted by the District when it is formed.

The objective of a WCP is to conserve water supplies and reduce the quantity of water and wastewater that facilities must handle. WCPs promote policies and goals to achieve long-term water use reduction. The objective of a DCP is to establish temporary procedures to reduce water consumption for the duration of an emergency situation.

### Service Area Description

The District will provide wholesale water for municipal use to Alvin, Angleton, Brookside Village, Danbury, Hillcrest, Iowa Colony, Manvel, and Pearland. These communities are all located in Brazoria County. The year 2000 population and average water demands as reported to TWDB by the Region H planning group are shown below in **Table 1**.

**TABLE 1  
YEAR 2000 POPULATION AND AVERAGE WATER DEMAND**

| Customer City     | Year 2000 Planning Area Population | Year 2000 Average Day Water Demand (mgd) |
|-------------------|------------------------------------|--|
| Alvin             | 24,075                             | 2.94                                     |
| Angleton          | 23,870                             | 2.89                                     |
| Brookside Village | 2,059                              | 0.25                                     |
| Danbury           | 1,870                              | 0.22                                     |
| Hillcrest         | 1,000                              | 0.11                                     |
| Iowa Colony       | 851                                | 0.11                                     |
| Manvel            | 5,152                              | 0.63                                     |
| Pearland          | 42,000                             | 4.32                                     |
| <b>Total</b>      | <b>100,877</b>                     | <b>11.47</b>                             |

Data regarding projected population and water use for the customer cities were collected from the TWDB, the Gulf Coast Water Authority (GCWA), and questionnaires provided to the cities.

The TWDB population and water use projections will serve as a basis for the State’s Year 2002 Water Plan. For the WCP, TWDB Region H data will be used as the official projected population and water use for the planning area as shown below in **Table 2**.

**TABLE 2  
PROJECTED POPULATION FOR CUSTOMER CITIES**

| Customer City                  | 2000          | 2010           | 2020           | 2030           | 2040           | 2050           |
|--------------------------------|---------------|----------------|----------------|----------------|----------------|----------------|
| Alvin                          | 24,075        | 28,723         | 33,822         | 40,240         | 45,715         | 51,935         |
| Angleton                       | 23,870        | 28,737         | 34,037         | 40,661         | 46,773         | 52,884         |
| Brookside Vill.                | 2,059         | 2,282          | 2,551          | 2,934          | 3,337          | 3,696          |
| Danbury                        | 1,870         | 2,174          | 2,442          | 2,802          | 3,079          | 3,381          |
| Hillcrest                      | 891           | 995            | 1,245          | 1,479          | 1,592          | 1,696          |
| Iowa Colony                    | 851           | 922            | 1,086          | 1,272          | 1,375          | 1,477          |
| Manvel                         | 5,152         | 6,084          | 7,080          | 8,352          | 9,412          | 10,606         |
| Pearland                       | 31,983        | 42,347         | 53,105         | 65,569         | 77,338         | 91,243         |
| <b>Total for Planning Area</b> | <b>90,751</b> | <b>112,264</b> | <b>135,368</b> | <b>163,309</b> | <b>188,621</b> | <b>216,918</b> |

The water demands used for this WCP are shown below in **Table 3**.

**TABLE 3  
PROJECTED AVERAGE WATER DEMAND (MGD)  
FOR CUSTOMER CITIES**

| Participating Utility          | 2000         | 2010         | 2020         | 2030         | 2040         | 2050         |
|--------------------------------|--------------|--------------|--------------|--------------|--------------|--------------|
| Alvin                          | 2.94         | 3.27         | 4.86         | 5.62         | 6.26         | 7.05         |
| Angleton                       | 2.89         | 3.28         | 3.68         | 4.23         | 4.73         | 5.34         |
| Brookside Vill.                | 0.25         | 0.27         | 0.28         | 0.31         | 0.34         | 0.38         |
| Danbury                        | 0.22         | 0.24         | 0.25         | 0.27         | 0.30         | 0.32         |
| Hillcrest                      | 0.11         | 0.12         | 0.14         | 0.16         | 0.17         | 0.18         |
| Iowa Colony                    | 0.11         | 0.11         | 0.13         | 0.46         | 0.15         | 0.16         |
| Manvel                         | 0.63         | 2.23         | 3.11         | 3.57         | 3.91         | 4.40         |
| Pearland                       | 4.32         | 8.66         | 10.93        | 13.16        | 15.21        | 17.94        |
| <b>Total for Planning Area</b> | <b>11.47</b> | <b>18.18</b> | <b>23.37</b> | <b>27.78</b> | <b>31.07</b> | <b>35.77</b> |

The District will not provide wastewater service to its customers. Each customer city secures separate wastewater services. Therefore, the District will not have direct knowledge of wastewater generation in the potential service areas. The aim of the District is to develop a WCP that will conserve water on a wholesale basis.

### Conservation Goals

The goal of a WCP is reduce water consumption. Reducing unaccounted-for water is the most direct contribution that a wholesale water provider can make to water conservation. Unaccounted-for water is the difference between the quantity of water that is withdrawn from a source of supply and the amount that is actually delivered to its customers. The goal of the District is to keep unaccounted-for water less than 5 percent. Additional water savings proposed in the Texas Water Development Board's Region H Water Plan are shown in **Table 4**. These savings are projected to occur due to the use of Advanced Conservation practices mentioned below. In general, Advanced Conservation practices are those that are more aggressive in terms of the timing of their usage (pro-actively managed to occur at a sooner time) or the application of additional conservation practices.

**TABLE 4  
COMPONENTS OF MUNICIPAL WATER CONSERVATION SAVINGS**

| Area of Municipal Water Use Savings Potential | Expected Conservation Savings  | Advanced Conservation Savings |
|---|--------------------------------|-------------------------------|
| Indoor Plumbing Savings                       | 20.5 gpcd                      | 21.7 gpcd                     |
| Seasonal Water Savings                        | 7.0% of total seasonal use     | 20% of total seasonal use     |
| Dry-Year Irrigation Savings                   | 10.5% of dry year seasonal use | 20% of dry year seasonal use  |
| Other Municipal Savings                       | 5% of total average year use   | 7.5% total average year use   |

**Table 5** presents the estimated water savings accrued by using advanced conservation practices in residential complexes. It should be noted that these are maximum possible savings, which may be difficult to attain as most residential complexes already employ water saving devices like low-flow shower heads and faucet aerators.

**TABLE 5  
INDOOR PLUMBING SAVINGS (MGD)**

| Customer City                   | 2000 | 2010 | 2020 | 2030 | 2040 | 2050 |
|---------------------------------|------|------|------|------|------|------|
| Alvin                           | 0.52 | 0.62 | 0.73 | 0.87 | 0.99 | 1.13 |
| Angleton                        | 0.52 | 0.62 | 0.74 | 0.88 | 1.01 | 1.15 |
| Brookside Vill.                 | 0.04 | 0.05 | 0.06 | 0.06 | 0.07 | 0.08 |
| Danbury                         | 0.04 | 0.05 | 0.05 | 0.06 | 0.07 | 0.07 |
| Hillcrest                       | 0.02 | 0.02 | 0.03 | 0.03 | 0.03 | 0.04 |
| Iowa Colony                     | 0.02 | 0.02 | 0.02 | 0.03 | 0.03 | 0.03 |
| Manvel                          | 0.11 | 0.13 | 0.15 | 0.18 | 0.20 | 0.23 |
| Pearland                        | 0.69 | 0.92 | 1.15 | 1.42 | 1.68 | 1.98 |
| Total savings for Planning Area | 1.97 | 2.44 | 2.94 | 3.54 | 4.09 | 4.71 |

**Table 6** presents the estimated savings in seasonal water use by using advanced conservation practices for the sum of all municipal utilities in the MBCPG.

**TABLE 6  
SEASONAL WATER SAVINGS (MGD)**

| Year                            | 2000 | 2010 | 2020 | 2030 | 2040 | 2050 |
|---------------------------------|------|------|------|------|------|------|
| Total for savings Planning Area | 0.46 | 0.53 | 0.61 | 0.71 | 0.81 | 0.93 |

**Table 7** presents the estimated savings under the “other municipal savings” category as mentioned in **Table 4**.



**TABLE 7  
OTHER MUNICIPAL SAVINGS (MGD)**

| Customer City                          | 2000        | 2010        | 2020        | 2030        | 2040        | 2050        |
|--|-------------|-------------|-------------|-------------|-------------|-------------|
| Alvin                                  | 0.22        | 0.25        | 0.27        | 0.32        | 0.35        | 0.40        |
| Angleton                               | 0.22        | 0.25        | 0.28        | 0.32        | 0.35        | 0.40        |
| Brookside Vill.                        | 0.02        | 0.02        | 0.02        | 0.02        | 0.03        | 0.03        |
| Danbury                                | 0.02        | 0.02        | 0.02        | 0.02        | 0.02        | 0.02        |
| Hillcrest                              | 0.01        | 0.01        | 0.01        | 0.01        | 0.01        | 0.01        |
| Iowa Colony                            | 0.01        | 0.01        | 0.01        | 0.01        | 0.01        | 0.01        |
| Manvel                                 | 0.05        | 0.05        | 0.06        | 0.07        | 0.07        | 0.08        |
| Pearland                               | 0.32        | 0.40        | 0.47        | 0.57        | 0.66        | 0.78        |
| <b>Total savings for Planning Area</b> | <b>0.86</b> | <b>1.00</b> | <b>1.14</b> | <b>1.34</b> | <b>1.51</b> | <b>1.73</b> |

**Table 8** assigns a dollar value to the total estimated water savings mentioned above. These were calculated by using the water rates calculated in **Section 9**.

**TABLE 8  
ESTIMATED TOTAL SAVINGS (\$)**

| Year                                   | 2000             | 2010               | 2020               | 2030               | 2040               | 2050               |
|--|------------------|--------------------|--------------------|--------------------|--------------------|--------------------|
| <b>Total for savings Planning Area</b> | <b>\$840,000</b> | <b>\$1,013,000</b> | <b>\$1,197,000</b> | <b>\$1,429,000</b> | <b>\$1,638,000</b> | <b>\$1,882,000</b> |

**Practices to Measure Water Diverted from Source and Delivered to Customers**

The projected water source for the District is the Brazos River. Water will be diverted from GCWA’s canal system and delivered to the District’s plant site via a short side stream canal. At the water treatment plant, the water will be pumped into the plant process train. Flow will be measured at the diversion point from GCWA and at the raw water pump station.

Finished water will be delivered to the customer cities’ take points via transmission mains. Flow will be monitored at the District’s finished water pump station and at the take points.

**Monitoring and Record Management Program**

The District’s flow meters will be monitored 24 hours per day by a SCADA system. The central monitoring location will be at the water treatment plant. The flow monitoring installations will be checked weekly unless greater frequency is warranted.

Records will be kept in accordance with TNRCC rules and regulations. Records will be retained in accordance with the records retention schedules issued by the Texas State Library and Archives Commission as provided by §203.041 (a)(2), Local Government Code.

**Metering, Leak Detection, & Repair Program**

In order to prevent loss of water through leaks in the District system, the District will:

- Test and calibrate all metering equipment.
- Purchase leak detection equipment and test the transmission system for leaks.
- Inspect the diversion canal for leaks or unauthorized withdrawals.
- Make timely repairs of leaks.

### **Contract Requirement of Customer Water Conservation Plan**

Customers who enter into contracts for wholesale water service will be required to develop and implement a WCP. The customer WCPs will be required to use proven conservation strategies including:

- Consumer education

The Participating Utilities will inform the customers of ways to conserve water. The following methods can be used to inform water users:

- Periodic Newspaper Articles
- Water Saving Brochure Handouts at billing office
- Water Saving tips on water bills
- Periodic mail outs of brochures on Water Saving Tips inside and outside the home
- Assisting customers at their homes and business to help locate water leaks

Suggestions on ways to save water which may be included in the information, are listed below

#### **A. Bathroom:**

1. Take a shower instead of taking a bath. Showers with low-flow showerheads often use less water.
2. Install a low-flow showerhead that limits the flow from the shower to less than three gallons per minute.
3. Take short showers and install a cutoff valve or turn the water off while soaping and back on again only to rinse.
4. Do not use hot water when cold water will do. Water and energy can be saved by washing hands with soap and cold water; hot water should only be added when hands are especially dirty.
5. Reduce the level of water being used in the bath tub by one or two inches if a shower is not available.
6. Turn water off when brushing teeth until it is time to rinse.
7. Do not let the water run when washing hands. Instead, hands should be wet, and water should be turned on again to rinse. A cutoff valve may also be installed on the faucet.
8. Shampoo hair in the shower. Shampooing in the shower takes only a little more water than is used to shampoo hair during a bath and much less than shampooing and bathing separately.

9. When shaving, fill the lavatory basin with hot water instead of letting the water run continuously.
10. Test toilets for leaks. Add a few drops of food coloring or a dye tablet to the water in the tank, but do not flush the toilet. Watch to see if the coloring appears in the bowl within few minutes. If it does, the toilet has a silent leak that needs to be repaired.
11. Use a toilet tank displacement device such as a plastic bottle that is filled with stones or water, recapped and placed in the toilet tank. These devices will reduce the volume of water in the tank but will still provide enough for flushing. (Bricks are not recommended since they will crumble and could damage the working mechanism.) Displacement devices are not recommended with new low-volume flush toilets.
12. Never use the toilet to dispose off cleansing tissues, cigarette butts or other trash. This wastes a great deal of water and also places unnecessary load on the sewage treatment plant or septic tank.
13. When remodeling a bathroom or building a new home, install a new low-volume flush toilet that uses only 1.6 gallons per flush.
14. Install faucet aerators to reduce water consumption.

B. Kitchen:

1. Scrape the dishes clean instead of rinsing them before washing. There is no need to rinse unless they are heavily soiled.
2. Use a pan of water or place a stopper in the sink for washing and rinsing pots, pans, dishes and cooking implements, rather than turning on the water faucet each time a rinse is needed.
3. Never run the dishwasher without a full load. This practice will save water, energy, detergent and money.
4. Use the garbage disposal sparingly or start a compost pile.
5. Keep a container of drinking water in the refrigerator. Running water from the tap until it is cool is wasteful. Both water and energy can be saved by keeping cold water in a picnic jug on a kitchen counter to avoid opening the refrigerator door frequently.
6. Use a small pan of cold water when cleaning vegetables, rather than letting the water run over them.
7. Use only a little water in the pot and put a lid on it for cooking most food.
8. Always keep water conservation in mind, and think of other ways to save in the kitchen. Small kitchen savings, from not making too much coffee or letting ice cubes melt in a sink, can add up in a years time.

C. Laundry:

1. Wash only a full load when using an automatic washing machine (32 to 59 gallons are required per load).
2. Whenever possible, use the lowest water level setting on the washing machine for light or partial loads.
3. Use cold water as often as possible to save energy and to conserve the hot water for uses that cold water cannot serve.

D. Appliances and Plumbing:

1. Check water requirements of various models and brands when considering purchasing any new appliance. Some use less water than others.
2. Check all water line connections and faucets for leaks. A slow drip can waste as much as 170 gallons of water each day, or 5,000 gallons per month.
3. Learn to repair faucets so that drips can be corrected promptly. It is easy to do costs very little, and can mean substantial savings in plumbing and water bills.
4. Check for hidden water leakage such as a leak between the water meter and the house. To check, turn off all indoor and outdoor faucets and water-using appliances. If the meter continues to run or turn, a leak probably exists and needs to be located.
5. Insulate all hot water pipes to reduce the delays (and wasted water) experienced while waiting for water to “run hot”.
6. Do not set the heater thermostat is too high. Extremely hot settings waste water and energy because the water often has to be cooled with cold water before it can be used.
7. Use a moisture meter to determine when houseplants need water. More plants die from over-watering than from being on the dry side.

E. Out-of-door Use:

1. Water only when needed. Look at the grass, feel the soil, or use a soil moisture meter to determine when to water.
2. Do not over-water. Soil can absorb only so much moisture, and the rest simply runs off. A timer will help, and either a kitchen timer or an alarm clock will do. One and a half inches of water applied once a week in the summer will keep most of Texas grasses alive and healthy.
3. Water lawns early in the morning during the hot summer months. Other wise, much of the water used on the lawn can simply evaporate between the sprinkler and the grass.
4. To avoid excessive evaporation, use a sprinkler that produces large drops of water rather than a fine mist. Sprinklers that send droplets out on a low angle also help control evaporation.
5. Set automatic sprinkler systems to provide thorough, but infrequent watering. Pressure regulation devices should be set to design specifications. Rain shut off devices can prevent watering in the rain.
6. Use drip irrigation systems for bedded plants, trees, shrubs, or turn soaker hoses upside down so the holes are on the bottom. This will help avoid evaporation.
7. Water slowly for better absorption, and never water on windy days.
8. Position sprinklers and hoses so they will not be watering the streets or sidewalks.
9. Condition the soil with mulch or compost before planting grass or flower beds so that water will soak in rather than run off.
10. Fertilize lawns at least twice a year for root stimulation, but do not over fertilize. Grass with a good root system makes a better use of less water and is more drought tolerant.

11. Do not scalp lawns when mowing during hot weather. Taller grass holds moisture better. Grass should be cut fairly often, so that only ½ to ¾ inch is trimmed off.
12. Use a watering can or hand water with the hose in small areas of the lawn that need more frequent watering.
13. Use water-wise plants. Choose plants that have low water requirements, are drought tolerant, and are adapted to the area where they are to be planted.
14. Consider decorating some areas of the lawn with wood chips, rocks, gravel, or other materials now available that require no water at all.
15. Do not “sweep” walks and driveways with the hose. Use a broom or rake instead.
16. When washing the car, use a bucket of soapy water and turn on the hose only for rinsing.

- Water conservation plumbing codes
- Water conservation rate structures

A water rate structure that encourages water conservation will be implemented. An example of this is using an increasing block rate method to determine the monthly water bill.

- Universal metering and meter maintenance program
- Leak detection and repair
- Water conservation plumbing retrofit program

This measure will involve the distribution of low-flow showerheads, toilet tank dams, and leak detection tablets to residents.

Homes built before 1980 generally do not have low flow showerheads, low flush toilets or faucet operators. In Texas, the state has required 1.6 gpf toilets, 3.0 gpm showerheads, and 2.5 gpm faucets since 1992. To promote indoor water conservation, the homeowners would be given retrofit kits with sufficient equipment and instructions to retrofit two bathrooms. Retrofit kits would contain easy-to-install low flow showerheads, faucet aerators, and toilet tank retrofit devices. Customers in existing buildings that do not have water saving devices will be encouraged to replace their old plumbing fixtures.

- Appliance Labeling

An appliance-labeling program would provide customers with point-of-purchase information, including an equipment tag, similar to the Appliance Energy Efficient programs operated by electric utilities. Water efficient appliances would receive a distinguishing label so that they stand out on the retail sales floor. The tag would also show how each appliance compares with others in its category. The MBCPG would have to work closely with appliance manufacturers and electric and gas utilities to develop equipment tags. Dealers would be trained to use the labels and point-of-purchase materials. The MBCPG would then mount a campaign encouraging customers to buy water saving appliances.

- Water-efficient landscaping

This program will offer incentives to new and existing single- and small multifamily customers to install water-efficient landscaping and irrigation systems. Multifamily customers with more than three acres of turf could qualify for one of the other nonresidential audit/rebate programs.

Incentives could take the form of rebates for replacing turf with water-efficient landscaping. Suggested rebates could be made available for each of the items below.

- New landscaping with a limit on the amount of turf.
- Relandscaping involving turf removal.
- If the customer chose to install an in-ground irrigation system to serve new turf areas, the system would be designed with low-precipitation-rate sprinkler heads that achieve 100 percent coverage and include a controller that allows three irrigation cycles per day.
- If the customer was removing turf to earn a rebate, and if an in-ground irrigation system was already in place, the system would be modified so the valves serving any remaining turf and the valves serving the new low-water-conserving landscaping would be on separate stations.

## **Drought Contingency Plan**

DCPs are necessary to conserve water supplies for the highest priority uses in times of shortage and to preserve the water necessary for human sustenance. Drought conditions are usually the result of extended periods of below average rainfall, but could result from equipment failure. This plan will provide an orderly procedure for the curtailment of water to customer cities.

### **Public and Agency Involvement**

The provisions of the DCP will apply to all customers of the District. Before implementing the plan, the District will afford its customers an opportunity to comment by:

- Furnishing a copy of the draft plan for comment
- Conducting a public meeting on the draft plan
- Publishing notices in area newspapers about the public meeting

The District service area is located within Region H Water Planning Group. The adopted DCP will be furnished to the planning group.

### **Triggering Conditions and Response Stages**

Drought triggers for individual customer cities and the corresponding responses will be as follows:

- ***Mild drought*** will be initiated by water use equal to or greater than 85 percent of customer's average contract quantity for 5 consecutive days. The District will:
  - Notify the customer of the drought condition level.
  - Require the customer to begin their DCP for a mild condition.
  - Require that the customer publish an article in the local newspaper and issue a press release to the electronic media.
- ***Moderate drought*** will be initiated by water use equal to or greater than 90 percent of the customer's average contract quantity for 4 consecutive days. The District will:
  - Notify the customer of the drought condition level.
  - Require that the customer begin their DCP for a moderate condition.
  - Require that the customer publish an article in the local newspaper and issue a press release to the electronic media.

- Monitor the customer’s DCP response.
- **Severe drought** will be initiated by water use equal to or greater than 95 percent of the customer’s average contract quantity for 3 consecutive days. The District will:
  - Notify the customer of the drought condition level.
  - Require the customer to begin their DCP for a severe condition.
  - Require the customer to publish an article in the local newspaper and issue a press release to the electronic media.
  - Monitor the customer’s DCP response.
  - Allocate water as needed.
- **Critical drought** will be initiated by water use equal to or greater than 100 percent of the customer’s average contract quantity for 3 consecutive days. The District will:
  - Notify the customer of the drought condition level.
  - Require the customer to begin their DCP for a critical condition.
  - Require the customer to publish an article in the local newspaper and issue a press release to the electronic media.
  - Request strict enforcement of the DCP by the customer.
  - Monitor the customer’s DCP response.
  - Allocate water as needed.

System-wide triggers will be based on water levels in the lower Brazos River. This information will be obtained through GCWA. System wide drought triggers are as follows:

- **Normal, wet conditions.**
  - Hempstead Gage stage greater than or equal to 14.00 feet or 2200 cubic feet per second (cfs).
  - Richmond Gage stage greater than or equal to 12.19 feet or 1700 cfs.
- **Mild drought conditions.**
  - Hempstead Gage stage less than or equal to 13.71 feet or 2000 cfs.
  - Richmond Gage stage less than or equal to 11.93 feet or 1500 cfs.
- **Moderate drought conditions.**
  - Hempstead Gage stage less than or equal to 13.41 feet or 1800 cfs.
  - Richmond Gage stage less than or equal to 11.65 feet or 1300 cfs.
- **Severe drought conditions.**
  - Hempstead Gage stage less than or equal to 12.93 feet or 1500 cfs.
  - Richmond Gage stage less than or equal to 11.23 feet or 1000 cfs.

In the event that a system-wide drought stage is triggered, all customer cities will be required to respond according to the corresponding individual system responses.

### **Termination of Drought Response Stages**

Individual customer drought response stages will be terminated by the District when customer water use is reduced to less than 85 percent of average contract values for 3 consecutive days. The District will notify the affected customer city when drought conditions are terminated.

System-wide drought response stages will be terminated when river levels return to normal conditions. The District will notify the customer cities when this condition has been reached.

### **Water Allocation Procedures**

Water allocation procedures will begin when drought conditions reach the severe stage. At this stage customers may be restricted to 85 percent of their average contract amount. The customers may supplement their water use with their own groundwater wells.

### **Variances**

The District may grant a temporary variance if implementation of water allocation procedures could cause an emergency condition affecting public health, welfare, or safety if one or more of the following conditions are met:

- Compliance with the plan cannot be technically accomplished.
- Alternative methods can be implemented which will achieve the same level of water reduction.

Customers requesting a variance from the DCP must file a petition with the District within 5 days after allocation procedures have been implemented. The petition must include the following information:

- Detailed statement of how the allocation adversely effects the petitioner.
- Description of the relief required.
- Period time for the variance is sought.
- Alternative measures that the petitioner proposes to implement.

Variations will include a timetable for compliance and will expire when allocation procedures are no longer in effect.

### **Enforcement**

The provisions of the DCP shall be included in each customer contract. Failure of customers to comply may be subject to civil action to enjoin the non-compliant customers for breach of contract.

### **Plan Review and Revisions**

The District will review and update the DCP at least every 5 years.

### **Reservoir Operations Plan**

The District has no plans to construct or operate a reservoir.

### **Means for Implementation and Enforcement**

The General Manager of the District or an appointed representative will act as the Administrator for the WCP. The Administrator will oversee the execution and implementation of the plan as well as all record keeping for the program. To initiate the WCP, the Board of Directors of the District will:

- Pass a resolution adopting the plan.
- Adopt an ordinance to implement the legal documents necessary to enforce the plan.



## **Mid-Brazoria County Planning Group Resource Management Authority Alternatives**

To implement a regional water treatment and transmission system for the Mid Brazoria County Participating Utilities, the members of the MBCPG will need to join or form an authority with the means to control, store, preserve, and distribute water for domestic and commercial purposes. Moreover, this Authority must have legal power to contract for water of Texas and should have entitlement to incur debt to finance and operate the regional facilities.

In addition to forming an Authority to implement and operate the required facilities, the MBCPG may also wish to evaluate groundwater conservation to ensure that this vital resource is protected to meet the MBCPG members existing and future demand.

### **Groundwater Protection**

Under current Texas water law, surface water is controlled and allocated by the State of Texas. Groundwater, on the other hand, falls under the “rule of capture”, where groundwater belongs to the entity that can capture it. Unless special legislature is enacted, groundwater in the State of Texas is unregulated and a private or public entity could install and operate a new water well to achieve the maximum production allowable by the underground conditions. Pumping by one particular well or well owner is not limited by the impact of that well or well owner on other adjacent wells. In essence, a well owner may pump as much water as feasible, even if that production level will decrease the water level in such a manner where adjacent wells will go “dry”.

The Texas Constitution through Section 59 of Article XVI provides for the creation of groundwater conservation districts. More specifically, Section 59 reads:

*“In order to provide for the conservation, preservation, protection, recharging, and prevention of waste of groundwater, and of groundwater reservoirs of their subdivisions, and to control subsidence caused by withdrawal of water from those groundwater reservoirs or their subdivisions, consistent with the objectives of Section 59, Article XVI, Texas Constitution, groundwater conservation districts may be created as provided by this chapter. Groundwater conservation districts created as provided by this chapter are the state’s preferred method of groundwater management.”*

Chapter 36 of the Texas Water Code stipulates the requirements for creation and management of a groundwater conservation district. This code provides for the establishment of authorities with the power to regulate spacing of water wells, the production from water wells, or both.

This section reviews the options available to the MBCPG to provide an Authority to manage, construct, and oversee this vital project.

A review of current Texas law indicates the following three general options available to the MBCPG:

- 1) Contract through an existing regional water control and improvement district with legal authority to construct, implement, finance, operate and maintain facilities necessary to provide potable water to the members of the Mid-Brazoria County Planning Group.
- 2) Create a new regional water authority to construct, implement, finance, operate, and maintain the regional water facilities
- 3) Create a non-profit water corporation to construct, implement, finance, operate, and maintain the regional water facilities

## **Contract with Existing Authority**

Within the South Central Texas area, the Brazos River Authority (BRA) and the Gulf Coast Water Authority (GCWA) are existing regional water providers created by the legislature to conserve, transport and distribute water to public and private corporations. These entities are existing regional water providers that:

- a) have legal authority to provide water to communities within the MBCPG,
- b) have experience operating a surface water plant treating Brazos River water,
- c) have sufficient bonding capabilities to finance the project.

A review of each of these existing political subdivisions follows:

### **Gulf Coast Water Authority**

Gulf Coast Water Authority has the authority “to conserve, store, transport, treat and purify, distribute, sell and deliver water, both surface and underground, to persons, corporations, both public and private, political subdivisions of the State and others, and may purchase, construct, or lease all property, works, and facilities, both within and without the District necessary for such purposes” (59<sup>th</sup> Legislature, Chapter 712). The Gulf Coast Water Authority is headquartered in Texas City, Texas and currently operates numerous facilities including the Dr. Thomas Mackey Water Treatment Plant in Texas City, Texas which treats and distributes water diverted from the Brazos River to customers throughout the Gulf Coast Region.

### **Brazos River Authority**

The Brazos River Authority was created by the Texas Legislature in 1929 with statutory authority to conserve and develop the surface water resources of the entire Brazos River basin in Texas, and make those resources available for all beneficial uses. The Brazos River Authority is headquartered in Waco, Texas and currently operates several water treatment plants along the Brazos river.

## **Create New Regional Authority**

Section 59 of the Article XVI of the Texas Constitution authorizes the creation and operation of regional districts for water, sanitary sewer, drainage, and municipal solid waste disposal. Under this law, the MBCPG could create a regional authority to finance, manage, and operate the facilities to bring treated surface water to the area and conserve the existing groundwater resources. Creation of a new authority can be brought about by one of two general means. The MBCPG could follow the rules outlined under existing Texas Water Code to form an Authority charged with creating, managing, implementing, and operating a regional water treatment and distribution facilities, or the MBCPG could petition the State of Texas Legislature to promulgate the creation of a new district.

### **Creation of a New Authority under Existing Rules**

Under the Texas Water Code, the state legislature has established rules for establishing new political subdivisions of the state charged with providing wholesale potable water. The Texas Water Code allows for the formation of the one of the following with power to control water of the State:

- Water Control and Improvement District (WCID), Texas Water Code Chapter 51
- Municipal Utility District (MUD), Texas Water Code Chapter 54
- Water Improvement District(WID), Texas Water Code Chapter 55
- Regional District (RD), Texas Water Code Chapter 59

Any authority created under one of the provisions of Texas Water Code would allow the MBCPG members to form a regional political subdivision of the State of Texas with the power to:

- Purchase, own, hold, lease, and otherwise acquire sources of water supply,
- Build, operate, and maintain facilities for the transportation of water, and
- Sell water to towns, cities, and other political subdivisions of this state, to private business entities, and to individuals.

Each District created under an existing Texas Water Code provision will have an elected board of directors and can own land, condemn property, and can furnish water for domestic, commercial, or industrial purposes. The difference in which legal framework a new Authority is created under depends on how the MBCPG wishes to structure the Authority. In general, the differences between the existing alternate types of Districts are the rules for District formation and the financial capabilities of the District.

***District Formation***

The following is a generalized list of steps required to formulate a new District under the Texas Water Code. The steps vary by which Authority the MBCPG would choose to form and a detailed list of general steps is presented below in Table 3-8. One assumption governing this table is that the land area to be included in the proposed district would fall within a single county and that no other district would encompass the same land. If the proposed district encompasses land in more than one county or includes land chartered into another district of the same type, the steps towards Authority formation will include several additional steps, including final review and approval by the Texas Natural Resources Conservation Commission (TNRCC).

**TABLE 3-8 - STEPS TO CREATING A REGIONAL WATER DISTRICT  
RULES UNDER EXISTING TEXAS WATER CODE PROVISIONS**

|   | WCID   | MUD   | WID   | RD  |
|---|--|---|---|---|
| <b><i>Petition by:</i></b>              | A petition for creation must be signed by at least 50 residents of the proposed district |   |   | Petition by County Commissioners                          |
| <b><i>Initial Consideration by:</i></b> | Consideration of Petition by County Commissioners (Single County District)               | Resolution in Support by an City in the Proposed District | County Commissioner Approval for General Election | Resolution in Support by an City in the Proposed District |
| <b><i>Review Authority:</i></b>         |  | Recommendation by County Commissioners                    |   |   |
| <b><i>Final Approval:</i></b>           | Confirmation Vote from Municipal Electors  | TNRCC Board Approval                                      | Confirmation Vote from Municipal Electors         | TNRCC Board Approval                                      |

## ***Financial Powers***

By creating a District charged with providing wholesale water to the residents of the mid Brazoria County region, each region has rules for how the District can obtain operating and capital funds and who must approve expenditure of those funds. Each of the aforementioned existing District frameworks provides for the authority to levy ad valorem property taxes. Each type of District can issue debt through bonds backed either by property taxes or revenue from the facilities to be constructed with the bonds. Bonds backed by property taxes must be approved by a majority vote of the District residents. Revenue bonds may be issued by District Board Resolution, but are subject to certain provision under each type of District.

Under a WCID, the District is required to assess taxes until the District can prove, by showing 3 years of history, that revenue from facilities finances through the bonds can meet the debt on the structure without default. At that point, the WCID can suspend ad valorem taxes. If revenue falls short, taxes must be reissued to cover the debt of the financed facility. A MUD must receive TNRCC approval for any bond issuance covering a project that existing outside of an established municipality or City ETJ.

## **Legislate a New District**

The MBCPG can proceed with the creation of a new regional water district under Section 59 of Article XVI of the Texas Constitution. The MBCPG would need to have a state legislator sponsor a bill in the State of Texas House or Senate hereby legislating the creation of the new district. Similarly, the Brazos River Authority and the Gulf Coast Water Authority were both created in this fashion. It is plausible that an Authority could be legislated for the mid-Brazoria County Region with the power to conserve and regulate groundwater usage and to conserve, transport and distribute water to public and private corporations. In having the legislature craft a bill creating a new authority, the legislature will include the powers of the new district including provisions for appointing or electing directors, funding mechanisms, reporting, and service area. Last, it is likely the legislature would consider the value of creating a new Authority within areas of an existing river authority, presumably overlapping an existing represented jurisdiction with the capability to already provide service.

## **Create Local Government Corporation**

Chapter 67 of the Texas Water Code outlines provisions for the creation and operation of a nonprofit corporation with the authority to build, operate, and maintain water treatment and distribution facilities. The proposed corporation would make an application to the Secretary of the State in the same manner as a private corporation and would have the ability to issue bonds, notes, or warrants to finance any project. The corporation may contract with any political subdivision, federal agency, or other entity for the acquisition, construction, or maintenance of a project or improvement for an authorized purpose.

## **Alternative Summary**

**Table 3-9** summarizes the benefits and obstacles to creating and operating a regional water authority under one of the discussed alternatives. By contracting with an existing authority of the State of Texas, the MBCPG would not need to formulate any other regional district. If the MBCPG chooses to create a new district, it is recommended that a Regional District (RD) be formed under the Texas Water Code. As mentioned in **Table 3-8**, a RD can be formed with the least number of political steps. The RD requires the least amount of political support and does not require a municipal election. The RD will be self-sufficient and flexible. WCIDs and MUDs require municipal confirmation votes, thus additional time and political obstacles are encountered.

**TABLE 3-9: RESOURCE MANAGEMENT ALTERNATIVES**

| Alternative   | Advantages   | Disadvantages   |
|---|--|---|
| Contract with Existing Authority                                    | <ul style="list-style-type: none"> <li>• Existing Authority with power to implement and finance necessary improvements</li> <li>• No requirement for creation of another regional authority</li> <li>• Leverage Administration Costs Across Larger Area</li> <li>• Experience in O&amp;M of Regional Water Treatment and Distribution Systems</li> </ul> | <ul style="list-style-type: none"> <li>• No Protection of Groundwater Sources</li> <li>• No Representation on Board</li> </ul>  |
| Create New District Under Existing Water Code Rules and Regulations | <ul style="list-style-type: none"> <li>• No additional rules required to establish authority</li> <li>• Authority can be created with a petition, approval of county commissioners and voters of new District</li> </ul>   | <ul style="list-style-type: none"> <li>• Require approval of voters</li> <li>• Perception of entity with unlimited taxing potential.</li> </ul>   |
| Create New Authority by Legislative Action                          | <ul style="list-style-type: none"> <li>• Authority creation does not require petition or voter approval</li> <li>• Rules and governing provisions can be customized</li> <li>• Can establish power to regulate groundwater protection and potable water treatment and distribution</li> </ul>  | <ul style="list-style-type: none"> <li>• Legislature may not pass bill creating new district</li> <li>• Legislature may not usurp existing river authority with capability to provide service.</li> </ul>                         |
| Establish a Non Profit Water Corporation                            | <ul style="list-style-type: none"> <li>• Creation through application to Texas Secretary of State</li> <li>• Can design, build, and operate water treatment and distribution facilities</li> </ul>   | <ul style="list-style-type: none"> <li>• No Taxing Authority</li> <li>• No Authority to Regulate Groundwater Withdrawal</li> <li>• Borrowed money is not tax exempt and therefore usually carries higher interest rate</li> </ul> |



**Appendix C**  
**TWDB Population and Water Use Projections**

---

**POPULATION & CONSUMPTIVE WATER DEMAND FORECASTS**  
 (Water use in acre-feet per year)  
 PREPARED BY TURNER COLLIE & BRADEN INC.

**BRAZORIA COUNTY**  
**MOST LIKELY GROWTH SCENARIO**

| Forecast Item            | 1990   | 2000   | 2010   | 2020   | 2030   | 2040   | 2050   |
|--------------------------|--------|--------|--------|--------|--------|--------|--------|
| <b>ALVIN</b>             |        |        |        |        |        |        |        |
| Population               | 19,220 | 24,075 | 28,723 | 33,822 | 40,240 | 45,715 | 51,935 |
| 1990 Use                 | 2,589  |        |        |        |        |        |        |
| Below Normal Rainfall    |        |        |        |        |        |        |        |
| * Expected Conservation  |        | 3,290  | 3,668  | 4,092  | 4,733  | 5,274  | 5,934  |
| Advanced Conservation    |        | 3,182  | 3,443  | 3,826  | 4,462  | 5,018  | 5,643  |
| Normal rainfall          |        |        |        |        |        |        |        |
| Expected Conservation    |        | 3,020  | 3,378  | 3,751  | 4,327  | 4,762  | 5,410  |
| Advanced Conservation    |        | 2,912  | 3,185  | 3,523  | 4,102  | 4,609  | 5,178  |
| <b>ANGLETON</b>          |        |        |        |        |        |        |        |
| Population               | 17,140 | 23,870 | 28,737 | 34,037 | 40,661 | 46,372 | 52,884 |
| 1990 Use                 | 2,015  |        |        |        |        |        |        |
| Below Normal Rainfall    |        |        |        |        |        |        |        |
| * Expected Conservation  |        | 3,235  | 3,670  | 4,117  | 4,737  | 5,298  | 5,983  |
| Advanced Conservation    |        | 3,128  | 3,444  | 3,850  | 4,509  | 5,090  | 5,746  |
| Normal rainfall          |        |        |        |        |        |        |        |
| Expected Conservation    |        | 2,887  | 3,219  | 3,621  | 4,190  | 4,622  | 5,272  |
| Advanced Conservation    |        | 2,781  | 3,058  | 3,394  | 3,963  | 4,467  | 5,036  |
| <b>BAILEY'S PRAIRIE</b>  |        |        |        |        |        |        |        |
| Population               | 634    | 735    | 758    | 769    | 812    | 857    | 903    |
| 1990 Use                 | 89     |        |        |        |        |        |        |
| Below Normal Rainfall    |        |        |        |        |        |        |        |
| * Expected Conservation  |        | 108    | 106    | 102    | 104    | 106    | 110    |
| Advanced Conservation    |        | 105    | 98     | 93     | 96     | 100    | 104    |
| Normal rainfall          |        |        |        |        |        |        |        |
| Expected Conservation    |        | 102    | 99     | 96     | 97     | 99     | 103    |
| Advanced Conservation    |        | 99     | 93     | 88     | 91     | 94     | 97     |
| <b>BRAZORIA</b>          |        |        |        |        |        |        |        |
| Population               | 2,717  | 3,276  | 3,945  | 4,619  | 5,461  | 5,829  | 6,222  |
| 1990 Use                 | 339    |        |        |        |        |        |        |
| Below Normal Rainfall    |        |        |        |        |        |        |        |
| * Expected Conservation  |        | 382    | 430    | 471    | 538    | 562    | 592    |
| Advanced Conservation    |        | 371    | 402    | 434    | 508    | 535    | 565    |
| Normal rainfall          |        |        |        |        |        |        |        |
| Expected Conservation    |        | 357    | 393    | 434    | 495    | 510    | 544    |
| Advanced Conservation    |        | 341    | 371    | 404    | 465    | 489    | 516    |
| <b>BROOKSIDE VILLAGE</b> |        |        |        |        |        |        |        |
| Population               | 1,470  | 2,059  | 2,282  | 2,551  | 2,934  | 3,337  | 3,696  |
| 1990 Use                 | 207    |        |        |        |        |        |        |
| Below Normal Rainfall    |        |        |        |        |        |        |        |
| * Expected Conservation  |        | 283    | 297    | 311    | 345    | 385    | 422    |
| Advanced Conservation    |        | 274    | 276    | 285    | 322    | 362    | 397    |
| Normal rainfall          |        |        |        |        |        |        |        |
| Expected Conservation    |        | 251    | 260    | 272    | 302    | 333    | 365    |
| Advanced Conservation    |        | 242    | 242    | 251    | 283    | 318    | 348    |



|                         |        |        |        |        |        |        |        |
|-------------------------|--------|--------|--------|--------|--------|--------|--------|
| CLUTE                   |        |        |        |        |        |        |        |
| Population              | 8,910  | 10,445 | 12,963 | 15,169 | 17,936 | 19,144 | 20,433 |
| 1990 Use                | 1,282  |        |        |        |        |        |        |
| Below Normal Rainfall   |        |        |        |        |        |        |        |
| * Expected Conservation |        | 1,579  | 1,830  | 2,039  | 2,351  | 2,466  | 2,609  |
| Advanced Conservation   |        | 1,533  | 1,742  | 1,920  | 2,230  | 2,359  | 2,495  |
| Normal rainfall         |        |        |        |        |        |        |        |
| Expected Conservation   |        | 1,381  | 1,597  | 1,784  | 2,049  | 2,123  | 2,266  |
| Advanced Conservation   |        | 1,345  | 1,525  | 1,682  | 1,949  | 2,059  | 2,174  |
| DANBURY                 |        |        |        |        |        |        |        |
| Population              | 1,447  | 1,870  | 2,174  | 2,442  | 2,804  | 3,079  | 3,381  |
| 1990 Use                | 177    |        |        |        |        |        |        |
| Below Normal Rainfall   |        |        |        |        |        |        |        |
| * Expected Conservation |        | 246    | 266    | 279    | 308    | 332    | 360    |
| Advanced Conservation   |        | 236    | 245    | 255    | 286    | 310    | 338    |
| Normal rainfall         |        |        |        |        |        |        |        |
| Expected Conservation   |        | 197    | 209    | 218    | 242    | 255    | 280    |
| Advanced Conservation   |        | 189    | 195    | 203    | 227    | 244    | 266    |
| FREEPORT                |        |        |        |        |        |        |        |
| Population              | 11,389 | 14,344 | 15,374 | 16,696 | 18,796 | 20,062 | 21,413 |
| 1990 Use                | 2,426  |        |        |        |        |        |        |
| Below Normal Rainfall   |        |        |        |        |        |        |        |
| * Expected Conservation |        | 3,069  | 3,151  | 3,291  | 3,622  | 3,798  | 4,029  |
| Advanced Conservation   |        | 2,989  | 2,997  | 3,086  | 3,432  | 3,640  | 3,862  |
| Normal rainfall         |        |        |        |        |        |        |        |
| Expected Conservation   |        | 2,443  | 2,497  | 2,601  | 2,842  | 2,966  | 3,142  |
| Advanced Conservation   |        | 2,377  | 2,376  | 2,450  | 2,737  | 2,876  | 3,046  |
| HILLCREST               |        |        |        |        |        |        |        |
| Population              | 695    | 891    | 995    | 1,245  | 1,479  | 1,592  | 1,696  |
| 1990 Use                | 101    |        |        |        |        |        |        |
| Below Normal Rainfall   |        |        |        |        |        |        |        |
| * Expected Conservation |        | 127    | 134    | 157    | 182    | 189    | 200    |
| Advanced Conservation   |        | 121    | 123    | 144    | 169    | 178    | 186    |
| Normal rainfall         |        |        |        |        |        |        |        |
| Expected Conservation   |        | 118    | 126    | 148    | 169    | 177    | 184    |
| Advanced Conservation   |        | 115    | 116    | 135    | 157    | 166    | 175    |
| HOLIDAY LAKES           |        |        |        |        |        |        |        |
| Population              | 1,039  | 1,423  | 1,833  | 2,264  | 2,782  | 3,256  | 3,811  |
| 1990 Use                | 141    |        |        |        |        |        |        |
| Below Normal Rainfall   |        |        |        |        |        |        |        |
| * Expected Conservation |        | 175    | 203    | 231    | 274    | 314    | 363    |
| Advanced Conservation   |        | 163    | 172    | 178    | 215    | 248    | 286    |
| Normal rainfall         |        |        |        |        |        |        |        |
| Expected Conservation   |        | 158    | 181    | 203    | 240    | 274    | 320    |
| Advanced Conservation   |        | 145    | 152    | 155    | 184    | 212    | 243    |

|                         |        |        |        |        |        |        |        |
|-------------------------|--------|--------|--------|--------|--------|--------|--------|
| <b>IOWA COLONY</b>      |        |        |        |        |        |        |        |
| Population              | 675    | 851    | 922    | 1,086  | 1,272  | 1,375  | 1,477  |
| 1990 Use                | 95     |        |        |        |        |        |        |
| Below Normal Rainfall   |        |        |        |        |        |        |        |
| * Expected Conservation |        | 123    | 128    | 143    | 161    | 170    | 178    |
| Advanced Conservation   |        | 120    | 119    | 130    | 149    | 160    | 169    |
| Normal rainfall         |        |        |        |        |        |        |        |
| Expected Conservation   |        | 118    | 121    | 135    | 152    | 159    | 169    |
| Advanced Conservation   |        | 115    | 113    | 124    | 143    | 151    | 159    |
| <b>JONES CREEK</b>      |        |        |        |        |        |        |        |
| Population              | 2,160  | 2,532  | 3,187  | 3,729  | 4,409  | 4,706  | 5,023  |
| 1990 Use                | 272    |        |        |        |        |        |        |
| Below Normal Rainfall   |        |        |        |        |        |        |        |
| * Expected Conservation |        | 343    | 400    | 439    | 504    | 527    | 557    |
| Advanced Conservation   |        | 332    | 371    | 401    | 469    | 496    | 523    |
| Normal rainfall         |        |        |        |        |        |        |        |
| Expected Conservation   |        | 272    | 314    | 343    | 390    | 406    | 428    |
| Advanced Conservation   |        | 261    | 293    | 313    | 365    | 385    | 405    |
| <b>LAKE JACKSON</b>     |        |        |        |        |        |        |        |
| Population              | 22,776 | 27,171 | 32,034 | 37,429 | 44,287 | 50,046 | 56,555 |
| 1990 Use                | 3,266  |        |        |        |        |        |        |
| Below Normal Rainfall   |        |        |        |        |        |        |        |
| * Expected Conservation |        | 3,683  | 4,091  | 4,528  | 5,208  | 5,717  | 6,461  |
| Advanced Conservation   |        | 3,591  | 3,840  | 4,235  | 4,912  | 5,494  | 6,145  |
| Normal rainfall         |        |        |        |        |        |        |        |
| Expected Conservation   |        | 3,591  | 3,948  | 4,360  | 5,011  | 5,549  | 6,208  |
| Advanced Conservation   |        | 3,470  | 3,731  | 4,067  | 4,762  | 5,269  | 5,955  |
| <b>MANVEL</b>           |        |        |        |        |        |        |        |
| Population              | 3,733  | 5,152  | 6,084  | 7,080  | 8,352  | 9,412  | 10,606 |
| 1990 Use                | 519    |        |        |        |        |        |        |
| Below Normal Rainfall   |        |        |        |        |        |        |        |
| * Expected Conservation |        | 710    | 784    | 856    | 983    | 1,075  | 1,212  |
| Advanced Conservation   |        | 687    | 730    | 785    | 917    | 1,013  | 1,140  |
| Normal rainfall         |        |        |        |        |        |        |        |
| Expected Conservation   |        | 624    | 681    | 746    | 852    | 928    | 1,033  |
| Advanced Conservation   |        | 601    | 634    | 690    | 795    | 886    | 986    |
| <b>OYSTER CREEK</b>     |        |        |        |        |        |        |        |
| Population              | 912    | 1,205  | 1,266  | 1,482  | 1,752  | 1,870  | 1,996  |
| 1990 Use                | 130    |        |        |        |        |        |        |
| Below Normal Rainfall   |        |        |        |        |        |        |        |
| * Expected Conservation |        | 185    | 184    | 204    | 234    | 245    | 259    |
| Advanced Conservation   |        | 178    | 173    | 188    | 218    | 230    | 244    |
| Normal rainfall         |        |        |        |        |        |        |        |
| Expected Conservation   |        | 147    | 146    | 161    | 183    | 191    | 201    |
| Advanced Conservation   |        | 142    | 136    | 149    | 173    | 180    | 190    |

|                              |        |        |        |        |        |        |        |
|------------------------------|--------|--------|--------|--------|--------|--------|--------|
| <b>PEARLAND (P)</b>          |        |        |        |        |        |        |        |
| Population                   | 17,234 | 29,480 | 39,464 | 49,742 | 61,929 | 73,332 | 86,834 |
| 1990 Use                     | 2,788  |        |        |        |        |        |        |
| <b>Below Normal Rainfall</b> |        |        |        |        |        |        |        |
| * Expected Conservation      |        | 4,458  | 5,569  | 6,631  | 8,046  | 9,364  | 11,088 |
| Advanced Conservation        |        | 4,293  | 5,217  | 6,129  | 7,562  | 8,871  | 10,408 |
| <b>Normal rainfall</b>       |        |        |        |        |        |        |        |
| Expected Conservation        |        | 4,260  | 5,305  | 6,352  | 7,700  | 8,953  | 10,505 |
| Advanced Conservation        |        | 4,128  | 4,995  | 5,850  | 7,215  | 8,461  | 9,921  |
| <b>RICHWOOD</b>              |        |        |        |        |        |        |        |
| Population                   | 2,732  | 3,203  | 4,170  | 4,959  | 5,961  | 6,797  | 7,750  |
| 1990 Use                     | 294    |        |        |        |        |        |        |
| <b>Below Normal Rainfall</b> |        |        |        |        |        |        |        |
| * Expected Conservation      |        | 377    | 448    | 505    | 588    | 647    | 738    |
| Advanced Conservation        |        | 362    | 420    | 461    | 541    | 609    | 694    |
| <b>Normal rainfall</b>       |        |        |        |        |        |        |        |
| Expected Conservation        |        | 326    | 383    | 428    | 494    | 548    | 616    |
| Advanced Conservation        |        | 312    | 355    | 394    | 461    | 518    | 582    |
| <b>SURFSIDE BEACH</b>        |        |        |        |        |        |        |        |
| Population                   | 611    | 769    | 837    | 995    | 1,178  | 1,371  | 1,534  |
| 1990 Use                     | 156    |        |        |        |        |        |        |
| <b>Below Normal Rainfall</b> |        |        |        |        |        |        |        |
| * Expected Conservation      |        | 222    | 232    | 265    | 309    | 353    | 393    |
| Advanced Conservation        |        | 216    | 220    | 248    | 291    | 336    | 373    |
| <b>Normal rainfall</b>       |        |        |        |        |        |        |        |
| Expected Conservation        |        | 199    | 209    | 239    | 279    | 318    | 354    |
| Advanced Conservation        |        | 195    | 199    | 225    | 264    | 304    | 337    |
| <b>SWEENEY</b>               |        |        |        |        |        |        |        |
| Population                   | 3,297  | 3,680  | 4,180  | 4,891  | 5,782  | 6,172  | 6,589  |
| 1990 Use                     | 414    |        |        |        |        |        |        |
| <b>Below Normal Rainfall</b> |        |        |        |        |        |        |        |
| * Expected Conservation      |        | 457    | 482    | 526    | 596    | 623    | 657    |
| Advanced Conservation        |        | 437    | 445    | 487    | 557    | 587    | 619    |
| <b>Normal rainfall</b>       |        |        |        |        |        |        |        |
| Expected Conservation        |        | 416    | 435    | 477    | 537    | 560    | 591    |
| Advanced Conservation        |        | 400    | 407    | 438    | 505    | 532    | 561    |
| <b>WEST COLUMBIA</b>         |        |        |        |        |        |        |        |
| Population                   | 4,372  | 5,482  | 6,035  | 6,720  | 7,671  | 8,363  | 9,118  |
| 1990 Use                     | 530    |        |        |        |        |        |        |
| <b>Below Normal Rainfall</b> |        |        |        |        |        |        |        |
| * Expected Conservation      |        | 744    | 763    | 798    | 877    | 936    | 1,011  |
| Advanced Conservation        |        | 712    | 710    | 731    | 816    | 880    | 950    |
| <b>Normal rainfall</b>       |        |        |        |        |        |        |        |
| Expected Conservation        |        | 584    | 601    | 624    | 678    | 711    | 776    |
| Advanced Conservation        |        | 565    | 554    | 572    | 636    | 684    | 735    |

|                         |         |         |         |         |         |         |         |
|-------------------------|---------|---------|---------|---------|---------|---------|---------|
| COUNTY - OTHER          |         |         |         |         |         |         |         |
| Population              | 68,544  | 78,720  | 83,556  | 91,092  | 102,276 | 111,831 | 135,982 |
| 1990 Use                | 9,652   |         |         |         |         |         |         |
| Below Normal Rainfall   |         |         |         |         |         |         |         |
| * Expected Conservation |         | 10,902  | 10,811  | 11,160  | 12,051  | 12,786  | 15,400  |
| Advanced Conservation   |         | 10,461  | 10,069  | 10,146  | 11,142  | 12,042  | 14,497  |
| Normal rainfall         |         |         |         |         |         |         |         |
| Expected Conservation   |         | 9,567   | 9,491   | 9,716   | 10,432  | 11,016  | 13,251  |
| Advanced Conservation   |         | 9,214   | 8,842   | 8,909   | 9,754   | 10,529  | 12,657  |
| MUNICIPAL TOTALS        |         |         |         |         |         |         |         |
| Population              | 191,707 | 241,233 | 279,519 | 322,819 | 378,774 | 424,518 | 489,838 |
| 1990 Use                | 27,482  |         |         |         |         |         |         |
| Below Normal Rainfall   |         |         |         |         |         |         |         |
| * Expected Conservation |         | 34,698  | 37,647  | 41,145  | 46,751  | 51,167  | 58,556  |
| Advanced Conservation   |         | 33,491  | 35,256  | 38,012  | 43,803  | 48,558  | 55,384  |
| Normal rainfall         |         |         |         |         |         |         |         |
| Expected Conservation   |         | 31,018  | 33,593  | 36,709  | 41,661  | 45,460  | 52,018  |
| Advanced Conservation   |         | 29,949  | 31,572  | 34,016  | 39,231  | 43,433  | 49,567  |
| MANUFACTURING           | 199,242 | 228,424 | 257,569 | 274,057 | 288,204 | 316,451 | 344,404 |
| S.E. POWER COOLING      | 0       | 0       | 0       | 0       | 0       | 0       | 0       |
| MINING                  | 954     | 1,511   | 1,305   | 1,169   | 1,114   | 1,043   | 1,063   |
| IRRIGATION              | 113,389 | 131,207 | 118,758 | 108,276 | 104,256 | 101,833 | 101,833 |
| LIVESTOCK               | 1,261   | 1,066   | 1,066   | 1,066   | 1,066   | 1,066   | 1,066   |

---

|                         |         |         |         |         |         |         |         |
|-------------------------|---------|---------|---------|---------|---------|---------|---------|
| TOTAL COUNTY WATER USE  | 342,328 |         |         |         |         |         |         |
| Below Normal Rainfall   |         |         |         |         |         |         |         |
| * Expected Conservation |         | 396,906 | 416,345 | 425,713 | 441,391 | 471,560 | 506,922 |
| Advanced Conservation   |         | 395,699 | 413,954 | 422,580 | 438,443 | 468,951 | 503,750 |
| Normal Rainfall         |         |         |         |         |         |         |         |
| Expected Conservation   |         | 393,226 | 412,291 | 421,277 | 436,301 | 465,853 | 500,384 |
| Advanced Conservation   |         | 392,157 | 410,270 | 418,584 | 433,871 | 463,826 | 497,933 |

\* Municipal use for cities excludes any wholesale municipal sales and identified sales to industrial users

\* Below normal rainfall with expected conservation is the primary municipal water use scenario.

**Appendix D**  
**Treatment Plant Design Criteria and Preliminary Sizing**

## Appendix D

# Water Treatment Plant Design Criteria and Preliminary Sizing

### DESIGN CRITERIA FOR 25 MGD HIGH-RATE CONVENTIONAL TREATMENT PLANT

| Criteria                       | Unit                            | Value   |         |
|--------------------------------|---------------------------------|---------|---------|
| <b>Plant Capacity</b>          |                                 |         |         |
| Finished Water Flow            | MGD                             | 27      |         |
| Raw Water Flow                 | MGD                             | 27      |         |
| <b>Raw Water Reservoir</b>     |                                 |         |         |
| Capacity                       | MGD                             | 48      |         |
| Area                           | acres                           | 10      |         |
| Depth                          | ft                              | 15      |         |
| Storage Volume                 | day                             | 2       |         |
| <b>Low Lift Pumping</b>        |                                 |         |         |
| Number of Units                | each                            | 3       |         |
| Type                           | Vertical Turbine                |         |         |
| Pump Capacity                  | MGD                             | 8.5     |         |
| Pump Head                      | ft                              | 50      |         |
| Total Installed Motor Capacity | HP                              | 400     |         |
| <b>Mixing</b>                  |                                 |         |         |
| No. of Pumps                   | each                            | 2       |         |
| Type of Pump                   | Vertical Centrifugal            |         |         |
| Capacity                       | MGD                             | 1.3     |         |
| <b>Clarifier</b>               |                                 |         |         |
| Clarifier Type                 | Pulsed-Upflow                   |         |         |
|                                |                                 | Phase 1 | Phase 2 |
| Unit Capacity                  | MGD                             | 15      | 10      |
| Number of Units                | each                            | 2       | 1       |
| Length                         | ft                              | 128     | 93      |
| Width                          | ft                              | 46      | 42      |
| Average Daily Sludge Flow      | gpd                             | 383,000 |         |
| <b>Media Filters</b>           |                                 |         |         |
| Type                           | Deep Bed, Dual Media (GAC/Sand) |         |         |
| No.                            | each                            | 8       |         |
| Surface Area Per Filter        | ft <sup>2</sup>                 | 521     |         |
| <b>Transfer Pumping</b>        |                                 |         |         |
| Number of Units                | each                            | 3       |         |
| Type                           | Vertical Turbine                |         |         |
| Pump Capacity                  | MGD                             | 8.5     |         |
| Pump Head                      | ft                              | 50      |         |
| Total Installed Motor Capacity | HP                              | 400     |         |
| <b>High Service Pumping</b>    |                                 |         |         |
| Number of Units                | each                            | 5       |         |
| Type                           | Vertical Turbine                |         |         |
| Pump Capacity                  | MGD                             | 25      |         |
| Pump Head                      | Ft                              | 170     |         |
| Total Installed Motor Capacity | HP                              | 1065    |         |

## Appendix D Water Treatment Plant Design Criteria and Preliminary Sizing

### DESIGN CRITERIA FOR 25 MGD HIGH-RATE CONVENTIONAL TREATMENT PLANT SOLIDS PROCESSING

| Criteria                             | Unit                       | Value   |
|--------------------------------------|----------------------------|---------|
| <b>Gravity Thickener</b>             |                            |         |
| Type                                 | Circular, Center Rake      |         |
| Solids Capacity                      | Ft <sup>2</sup>            | 923     |
| Hydraulic Capacity                   | Ft <sup>2</sup>            | 1,113   |
| No of Units                          | Each                       | 2       |
| SWD                                  | Ft                         | 14      |
| Diameter                             | Ft                         | 38      |
| Percent Solids                       | %                          | 6       |
| <b>Waste Washwater Equalization</b>  |                            |         |
| Type                                 | Rectangular, Sloped Bottom |         |
| Number of Units                      | Each                       | 2       |
| Length                               | Ft                         | 93      |
| Width                                | Ft                         | 23.21   |
| SWD                                  | Ft                         | 16      |
| Storage Volume                       | Gal                        | 515,700 |
| Average Daily Backwash Flow          | Gpd                        | 464,130 |
| <b>Waste Washwater Clarification</b> |                            |         |
| Clarifier Type                       | Lamella                    |         |
| Diameter                             | Ft                         | 31      |
| Effective Area                       | Ft <sup>2</sup>            | 597     |
| Total Settling Area                  | Ft <sup>2</sup>            | 746     |
| Number of Units                      | Each                       | 2       |
| <b>Recycle Pumps</b>                 |                            |         |
| Number of Units                      | Each                       | 3       |
| Type                                 | Vertical Turbine           |         |
| Capacity                             | Gpm                        | 240     |
| Motor Size                           | Hp                         | 10      |
| <b>Sludge Drying Bed</b>             |                            |         |
| Total effective area                 | Ft <sup>2</sup>            | 182,000 |
| Number of Units                      | Each                       | 6       |
| Length                               | Ft                         | 500     |
| Width                                | Ft                         | 61      |
| Percent Solids                       | %                          | 45      |
| Average Annual Quantity Disposed     | Cy                         | 500,000 |

## Appendix D

# Water Treatment Plant Design Criteria and Preliminary Sizing

### DESIGN CRITERIA FOR 25 MGD HIGH-RATE CONVENTIONAL TREATMENT PLANT BUILDINGS

| Criteria                        | Unit            | Value  |
|---------------------------------|-----------------|--------|
| <b>Administration</b>           | Ft <sup>2</sup> |        |
| Laboratory                      | Ft <sup>2</sup> | 1,500  |
| Offices / Reception             | Ft <sup>2</sup> | 3,000  |
| Conference                      | Ft <sup>2</sup> | 1,000  |
| Restrooms / Lockers / Kitchen   | Ft <sup>2</sup> | 1,000  |
| Control Room                    | Ft <sup>2</sup> | 1,000  |
| File Storage                    | Ft <sup>2</sup> | 1,000  |
| General Storage                 | Ft <sup>2</sup> | 1,500  |
| <b>Total</b>                    | Ft <sup>2</sup> | 10,000 |
| <b>Maintenance Building</b>     |                 |        |
| Garage                          | Ft <sup>2</sup> | 3,000  |
| Instrument / Mechanics Shop     | Ft <sup>2</sup> | 4,000  |
| Offices / Restroom              | Ft <sup>2</sup> | 1,000  |
| Storage                         | Ft <sup>2</sup> | 5,000  |
| <b>Total</b>                    | Ft <sup>2</sup> | 13,000 |
| <b>Chemical Building</b>        | Ft <sup>2</sup> | 10,000 |
| <b>Outside Chemical Storage</b> | Ft <sup>2</sup> | 15,000 |
| <b>Ground Storage</b>           |                 |        |
| Number of Units                 | Each            | 4      |
| Diameter                        | Ft              | 131    |
| Height                          | Ft              | 30     |



**Appendix E**  
**TC&B Alternative Water Supply Study Report**

---


# Turner Collie & Braden Inc.

Engineers • Planners • Project Managers

P.O. Box 130089  
Houston, Texas 77219-0089  
5757 Woodway 77057-1599  
713 780-4100  
Fax 713 780-0838

February 27, 2001

Mr. Jim Adams, P.E.  
Region H Chairman  
San Jacinto River Authority  
P.O. Box 329  
Conroe, Texas 77305



**Re: Mid-Brazoria County Regional Water Planning Area  
Alternative Water Supply Study for Region H Water Planning Group  
TWDB Contract No. 99-483-294**

Dear Mr. Adams:

Turner Collie & Braden Inc. is pleased to present you with the results of the above-mentioned study. The purpose of this letter report is to present the results of the Alternative Water Supply Study prepared for the Mid-Brazoria County Regional Water Planning Area ("the Planning Area"). The following letter report summarizes the scope of work addressed, the methodology used, and the results obtained during completion of the study. This study was authorized by the TWDB to be performed with contingency funds through the Region H Regional Water Planning Group.

## **Purpose and Objectives**

The Mid-Brazoria County Planning Area encompasses much of the northern portion of Brazoria County including the municipalities of Alvin, Angleton, Danbury, Hillcrest, Iowa Colony, Manvel, Brookside Village, and the portion of Pearland within Brazoria County. It is included within the Region H Regional Planning Group established by the TWDB as a result of Senate Bill 1. *Exhibit 1* provides a map of the overall Planning Area indicating the locations of municipalities, major roadways, canal alignments, and the proposed location for a regional water treatment plant for the Planning Area.

The current Region H water plan does not identify shortages for any communities other than Alvin, Angleton, and Pearland. Region H addressed the City of Alvin shortage through municipal conservation and a new contract for water from the Gulf Coast Water Authority (GCWA). Pearland currently has a water contract, which expires after the year 2010, with the GCWA for 5,559 acre-feet per year. However, it is understood for this study that Pearland currently has no infrastructure in place to use this contract water for potable means. Pearland's shortage was addressed by Region H through an extension of this contract. Angleton has a water contract with the Brazosport Water Authority (BWA) for 1,815 acre-feet per year of treated surface water expiring after the year 2040. The City of Angleton is currently using this contract water to serve their municipal needs. Region H addressed the shortage for Angleton through an extension to this water contract. The remainder of the Planning Area is expected to continue to use groundwater.

# Turner Collie & Braden Inc.

Mr. James Adams, P.E.

February 27, 2001

Page 2

The communities involved in the Mid-Brazoria County Planning Area have several concerns. First, they are concerned about the continued availability of groundwater in a county that does not have a groundwater conservation district to protect and conserve the supply. The community officials recognize that Region H only allocated groundwater based on the sustainable yield of the aquifer, but there is no legal requirement for such a limitation. Nothing prevents a large water-user from moving into the area and pumping large quantities of groundwater from the aquifer and potentially affecting all of the current users. Second, the communities in the Planning Area want to know the costs of the various supply choices available to them so they can make an informed decision regarding their future water supply or supplies. Third, participants realize that two supply sources increase the reliability of each of their systems.

For the reasons noted above, the Mid-Brazoria County Planning Group submitted an application for funding for a facilities plan to the Texas Water Development Board. TWDB received and reviewed the application and funded a portion of it. However, all of the task items dealing with the alternative sources of supply available to the area were removed from the facilities planning grant application and the Group was informed that this portion of the work requires a contingency funds request to the Region H Regional Water Planning Group. This directive from TWDB resulted in the separation of the following scope of services from the facilities planning grant and the accomplishment of these tasks through an amendment to the Region H planning scope. The individual tasks are as shown below.

## Scope of Work

The following scope of work was completed for this study:

- 1) Define the population projections for the Planning Area for the 50-year planning period 2000 through 2050.
- 2) Define the total municipal water demand projections for the Planning Area for the 50-year planning period 2000 through 2050.
- 3) Define the municipal surface water demand projections for the Planning Area for the 50-year planning period 2000 through 2050.
- 4) Review and revise the recommended water management strategy included in the Region H planning documents for meeting water shortages in the City of Alvin to include additional capacity sufficient to meet the water needs of the Planning Area.
- 5) Assess the feasibility and economics of diverting raw water directly from the Brazos River to a regional water treatment plant to serve the Planning Area.

# Turner Collie & Braden Inc.

Mr. James Adams, P.E.

February 27, 2001

Page 3

- 6) Assess the feasibility and economics of diverting raw water from existing Chocolate Bayou Water Company canals to a regional water treatment plant to serve the Planning Area.
- 7) Compare the costs of alternative water supplies and present the advantages and disadvantages of each alternative.
- 8) Compare the cost of converting to a dual water source (surface and groundwater) to the cost of continuing to use groundwater as the primary source of water for the Planning Area.

## Population and Water Demands

The population and water demand projections used in this study were obtained from the Region H planning documents. The Region H Planning Group provided projections of population and water demand for all counties within the Region H study area for the 50-year planning period from 2000 to 2050.

The population projections for the municipalities included in the Planning Area were obtained directly from Region H planning documents. The Region H planning documents also provide county-other population projections for all of Brazoria County. However, the Planning Area for this study does not encompass all of Brazoria County. Therefore, the county-other population projections for the Mid-Brazoria Planning Area were made by applying a population density factor (capita per area), developed for the entire Brazoria County area, to the non-incorporated area within the Planning Area. *Table 1* provides a summary of the population projections for the Planning Area for the 50-year planning period.

**Table 1**  
**Mid-Brazoria Planning Area Population Projections**

| Year                  | Population Projections |                |                |                |                |                |
|-----------------------|------------------------|----------------|----------------|----------------|----------------|----------------|
|                       | 2000                   | 2010           | 2020           | 2030           | 2040           | 2050           |
| Alvin                 | 24,075                 | 28,723         | 33,822         | 40,240         | 45,715         | 51,935         |
| Angleton              | 23,870                 | 28,737         | 34,037         | 40,661         | 46,372         | 52,884         |
| Danbury               | 1,870                  | 2,174          | 2,442          | 2,804          | 3,079          | 3,381          |
| Hillcrest             | 891                    | 995            | 1,245          | 1,479          | 1,592          | 1,696          |
| Iowa Colony           | 851                    | 922            | 1,086          | 1,272          | 1,375          | 1,477          |
| Manvel                | 5,152                  | 6,084          | 7,080          | 8,352          | 9,412          | 10,606         |
| Brookside Village     | 2,059                  | 2,282          | 2,551          | 2,934          | 3,337          | 3,696          |
| Pearland              | 29,480                 | 39,464         | 49,742         | 61,929         | 73,332         | 86,834         |
| Brazoria County-Other | 25,097                 | 26,637         | 29,039         | 32,605         | 35,650         | 43,349         |
| <b>Total</b>          | <b>113,345</b>         | <b>136,018</b> | <b>161,044</b> | <b>192,276</b> | <b>219,864</b> | <b>255,858</b> |

# Turner Collie & Braden Inc.

Mr. James Adams, P.E.

February 27, 2001

Page 4

Total water demand projections for the municipalities included in the Planning Area were obtained directly from Region H planning documents. The Region H planning documents also provide county-other water demand projections for all of Brazoria County. However, the Planning Area for this study does not encompass all of Brazoria County. Therefore, the county-other water demand projections for the Mid-Brazoria County Planning Area were made by applying a water usage factor (acre-feet per capita), developed for the entire Brazoria County incorporated area, to the population of the non-incorporated area within the Planning Area. *Table 2* provides a summary of the water demand projections for the Planning Area for the 50-year planning period.

**Table 2**  
**Mid-Brazoria Total Water Demand Projections**

| Year                  | Water Demand (acre-feet per year) |               |               |               |               |               |
|-----------------------|-----------------------------------|---------------|---------------|---------------|---------------|---------------|
|                       | 2000                              | 2010          | 2020          | 2030          | 2040          | 2050          |
| Alvin                 | 3,290                             | 3,668         | 4,092         | 4,733         | 5,274         | 5,934         |
| Angleton              | 3,235                             | 3,670         | 4,117         | 4,737         | 5,298         | 5,983         |
| Danbury               | 246                               | 266           | 279           | 308           | 332           | 360           |
| Hillcrest             | 127                               | 134           | 157           | 182           | 189           | 200           |
| Iowa Colony           | 123                               | 128           | 143           | 161           | 170           | 178           |
| Manvel                | 710                               | 784           | 856           | 983           | 1,075         | 1,212         |
| Brookside Village     | 283                               | 297           | 311           | 345           | 385           | 422           |
| Pearland              | 4,458                             | 5,569         | 6,631         | 8,046         | 9,364         | 11,088        |
| Brazoria County-Other | 3,476                             | 3,446         | 3,558         | 3,842         | 4,076         | 4,909         |
| <b>Total</b>          | <b>15,948</b>                     | <b>17,962</b> | <b>20,144</b> | <b>23,337</b> | <b>26,163</b> | <b>30,286</b> |

Based on the Region H plan, most of the above municipalities would continue to meet their projected water demands through continued groundwater use. The cities of Danbury, Hillcrest, Iowa Colony, Manvel, and Brookside Village, according to Region H, would all meet their projected 2050 water demand through groundwater. The cities of Alvin, Angleton, Pearland and the Brazoria County-Other population, would require additional water supplies to meet projected demands. According to Region H, approximately 50 percent of the total 2050 water demand for the Planning Area would be required to come from sources other than local groundwater supplies.

Therefore, in conformance with the results from Region H planning, it has been assumed for this study that 50 percent of the total water demand in the Planning Area will be met through additional surface water supplies. This additional surface water supply will serve primarily the cities of Alvin, Angleton, and Pearland as well as that population in Brazoria County-Other. This 50 percent includes the water contracts currently in place between Angleton and the BWA and Pearland and the GCWA. It has been assumed, for convenience in this study, that these existing water contracts would either be cancelled, transferred, or maintained. If the contracts were maintained and extended over time, this would then free up surface water supplies that could be used to meet projected water demands in other areas (i.e.

Mr. James Adams, P.E.  
 February 27, 2001  
 Page 5

Brazoria County-Other) of the Planning Area. Table 3 provides a summary of the estimated surface water demands for the Planning Area for the 50-year planning period.

**Table 3**  
**Mid-Brazoria Surface Water Demand Projections**

| Year                  | Surface Water Demand (acre-feet per year) |              |               |               |               |               |
|-----------------------|---|--------------|---------------|---------------|---------------|---------------|
|                       | 2000                                      | 2010         | 2020          | 2030          | 2040          | 2050          |
| Alvin                 | 1,645                                     | 1,834        | 2,046         | 2,367         | 2,637         | 2,967         |
| Angleton              | 1,618                                     | 1,835        | 2,059         | 2,369         | 2,649         | 2,992         |
| Danbury               | 123                                       | 133          | 140           | 154           | 166           | 180           |
| Hillcrest             | 64  | 67           | 79            | 91            | 95            | 100           |
| Iowa Colony           | 62  | 64           | 72            | 81            | 85            | 89            |
| Manvel                | 355                                       | 392          | 428           | 492           | 538           | 606           |
| Brookside Village     | 142                                       | 149          | 156           | 173           | 193           | 211           |
| Pearland              | 2,229                                     | 2,785        | 3,316         | 4,023         | 4,682         | 5,544         |
| Brazoria County-Other | 1,738                                     | 1,723        | 1,779         | 1,921         | 2,038         | 2,455         |
| <b>Total</b>          | <b>7,974</b>                              | <b>8,981</b> | <b>10,072</b> | <b>11,669</b> | <b>13,082</b> | <b>15,143</b> |

### Groundwater Supply Source

For this study, two groundwater supply scenarios have been investigated. The first scenario is included as a means of cost comparison only and assumes that the Planning Area will be served throughout the study period using 100 percent groundwater, with the exception of the 1,815 acre-feet of treated surface water currently used by Angleton. It should be noted that Region H has indicated that the sustainable yield of the groundwater supply in this area would not support this level of groundwater use in the Planning Area. Again, this scenario is included for cost comparison purposes only. The second scenario, more in line with Region H, assumes that groundwater will be supplemented by a surface water supply source of 50 percent of the total demand.

Information obtained from the Planning Area participants and from the Texas Natural Resource Conservation Commission (TNRCC) public water supply system database was reviewed to estimate the total existing well capacity in the Planning Area. The TNRCC database provides total well capacity information for public water supply systems in Texas. According to this information, additional well capacity will be required for the Planning Area in order to meet the projected 2050 water demands assuming no supplemental source from surface water. Approximately 1,500 gallons per minute of additional well capacity was estimated to be required in the Planning Area to meet the projected water demand to the planning decade 2050 assuming that no additional surface water supply is provided for in the area. For this study, it was assumed that this additional well capacity would be required in the 2040 planning decade.

# Turner Collie & Braden Inc.

Mr. James Adams, P.E.  
February 27, 2001  
Page 6

Although there appears to be ample groundwater sources to meet short-term and even near long-term water demands, concerns associated with subsidence, future limitations on groundwater pumping, and potential groundwater quality issues indicate that planning for a second source of water (i.e., surface water) is prudent. The Planning Area will maximize usability of each water source, conserve available groundwater, and reduce subsidence by combining surface water and groundwater.

There is no good repository of groundwater quality data for private well owner. However, based on conversations with the Brazoria County Health Department and the TNRCC, there does appear to be some groundwater quality issues associated with high levels of total dissolved solids in wells, particularly in the southern portion of the region. These quality issues could be exacerbated by a continued reliance on groundwater as the primary water source for the area.

## Alternative Surface Water Supply Sources

Alternative water supplies identified for this study include available or potentially available supplies from the Gulf Coast Water Authority (GCWA), Brazos River Authority (BRA), and the Chocolate Bayou Water Company (CBWC). For this study it was assumed that water would be diverted from the existing Briscoe Canal in the GCWA system, existing canals in the CBWC system, and directly from the Brazos River in the BRA system.

### Gulf Coast Water Authority

#### *Supply Source Alternative 1*

Under this scenario, the Planning Area would develop and construct a regional water treatment plant at a site currently owned by the City of Alvin for use in meeting the long-term surface water needs in the Planning Area. The Planning Area would purchase contract water from GCWA, beginning immediately, to meet the projected surface water demands for the area. Water would be diverted from the existing GCWA Briscoe Canal, located south of Alvin, to the proposed regional water treatment plant. See Exhibit 2 for the location of the facilities. This alternative is a version of the selected surface water option provided for Alvin only in the Region H plan, but scaled up to provide the estimated needs of the Mid-Brazoria Planning Area.

### Brazos River Authority

The BRA commonly makes water available for sale under long-term contracts for municipal, industrial, irrigation, and other uses throughout the Brazos River basin and the adjacent coastal areas. The BRA currently has a standard System Water Availability Agreement under which water supply is contracted for long-term use. Currently, all of the BRA's available water supply in its basinwide system is committed; however, efforts are underway to increase the amount of system water supply available for contract.

# Turner Collie & Braden Inc.

Mr. James Adams, P.E.

February 27, 2001

Page 7

The BRA estimates that approximately 75,000 acre-feet per year of increased system water supply could be made available for contract through the return of excess water supply currently under contract by industrial customers; increased firm yield in the BRA's system of reservoirs; and potential third-party, long-term lease of water supplies. This estimated water supply exceeds the 2050 projected water demands for the Planning Area.

In addition, the development of proposed reservoirs in the Brazos River basin could also provide for additional future long-term sources of water for the Planning Area. Proposed reservoirs in the Brazos River basin for this 50-year study period include Little River Reservoir in Milam County, and Allen Creek Reservoir in Austin County, both of which are included in the Region H plan.

For the purpose of developing a cost comparison with other alternatives, it was assumed that the Brazos River water would be obtained through a pump station and pipeline from the Brazos River directly to the proposed regional plant identified above. In fact, the canals mentioned in the alternatives above could be used to convey water purchased from the BRA, but it was not possible to determine a conveyance cost for such water in the canals if the canals were used strictly for conveyance and if the water was not purchased from the canal owner.

## *Supply Source Alternative 2*

Under this scenario, the Planning Area would develop and construct a regional water treatment plant at the Alvin site for use in meeting the long-term surface water needs in the Planning Area. The Planning Area would purchase contract water from the BRA, beginning immediately, to meet the projected surface water demands for the area. Water would be diverted directly from the Brazos River from a new raw water pump station to the proposed regional water treatment plant. See *Exhibit 2* for the locations of these described facilities.

## Chocolate Bayou Water Company

Water obtained from the Chocolate Bayou Water Company differs from the previous alternatives by the fact that CBWC is interested in selling the rights to water supplies that they currently own and control. All of the other alternatives noted above involve contracts for water service, with contract costs that must be paid for as long as the water is being used, and in fact even prior to the water being used if access to the supply is to be guaranteed. The water obtained from CBWC would be from a purchase of the water rights, which would result in a capital cost that would be financed for a period of time. At the end of that time, the water would be paid for and no further cost per acre-foot of raw water used would be incurred. Over a long period of time, this would result in significant cost savings.

## *Supply Source Alternative 3*

Under this scenario, the Planning Area would develop and construct a regional water treatment plant at the Alvin site for use in meeting the long-term surface water needs in the Planning Area. The Planning Area would purchase water rights from CBWC to meet the projected surface water demands for the area.



# Turner Collie & Braden Inc.

Mr. James Adams, P.E.

February 27, 2001

Page 8

Water would be diverted from the existing CBWC canal system to the proposed regional water treatment plant. See *Exhibit 2* for the locations of these described facilities.

## Estimates of Probable Costs for Surface Water Development

Planning level costs were developed following the methodology prepared in the Senate Bill 1 Region H Planning report, "*Cost Estimating Procedures TWDB Region H.*" Detailed cost analysis spreadsheets, provided in *Appendix A*, were prepared for each water supply source alternative. The cost estimating spreadsheets, provided in *Appendix A*, develop two main categories of costs: project costs, which include capital costs and other project-related costs, and annual costs. All costs are adjusted to the second quarter of 1999 to be consistent with Region H.

These spreadsheets develop the detailed costs for each major item identified as well as present a summary of costs associated with each supply source alternative. The Region H cost methodology was used so that cost comparisons developed in this effort would be comparable to those developed in the Region H effort. *Appendix B* provides a copy of the Region H cost estimating procedures.

It should be noted here that the Region H cost estimation worksheets include averages of costs that are greatly influenced by construction in highly congested areas. It is anticipated that costs developed specifically for Brazoria County will be lower. However, the purpose of this study is solely to compare the alternatives. As long as all alternatives are compared in terms of Region H costs, then the comparison is equitable among alternatives.

For this study, only the costs for water supply (i.e., cost of water, conveyance, and treatment) were developed. The costs associated with distribution are not included in the costs estimates developed for this study. It was assumed, for each alternative, that a regional water treatment plant would be constructed and that treated water would be distributed to the individual users. The costs for distribution were assumed to be the same for each alternative. The purpose of this study is to provide a relative comparison of costs between alternative water sources and not to serve as a means to develop water rates or a detailed facility plan.

## Estimates of Probable Costs for Groundwater Development

~~Costs associated with the continued use of groundwater~~ as a water source for the area include well operation and maintenance (O&M), ~~rehabilitation~~, and ~~replacement~~. For this study, costs associated with well O&M and rehabilitation were estimated using a study previously conducted by TC&B for the Fort Bend County Surface Water Supply Corporation, dated November 1997. Costs associated with well O&M and rehabilitation, developed for the November 1997 study, were adjusted based on Engineering News Record (ENR) cost factors to present day values. On that basis, the estimated costs for well O&M

# Turner Collie & Braden Inc.

Mr. James Adams, P.E.  
February 27, 2001  
Page 9

and rehabilitation, used in this study, is \$0.41 per 1,000 gallons and \$0.03 per 1,000 gallons, respectively.

As mentioned previously, this study assumes that approximately 1,500 gallons per minute (gpm) of additional well capacity will be required in the Planning Area to meet projected water demands for the area, assuming no contribution from a supplemental surface water supply. For this study, it was assumed that new wells would be constructed to produce approximately 1,000 gpm per well. Therefore, this study assumed that two new wells would be constructed in the planning year 2040 to meet projected 2050 water demands.

Based on Region H costs, the average cost of a 1,000-gpm water well is approximately \$500,000, in round numbers. Therefore, the cost of additional well capacity, for the scenario that does not include surface water supply, is \$1,000,000. The debt service associated with the new well costs was assumed to begin in 2040 at 6 percent interest over a ten-year service period resulting in an annual cost of \$135,870.

## Discussion of Results

### Surface Water Cost Analysis

Table 4 provides a summary of the annual costs developed for each alternative surface water source for this study. Table 4 includes costs associated with capital, operation and maintenance, engineering, water supply, land, environmental, and debt service for each alternative. All costs are annualized costs and are provided in units of dollars per 1,000 gallons for each planning decade.

**Table 4**  
**Surface Water Cost Estimate Summary**

| Year | GCWA<br>(\$/1,000 gallons) | BRA<br>(\$/1,000 gallons) | CBWC<br>(\$/1,000 gallons) |
|------|----------------------------|---------------------------|----------------------------|
| 2010 | \$2.20                     | \$2.99                    | \$2.22                     |
| 2020 | \$2.27                     | \$3.04                    | \$2.28                     |
| 2030 | \$2.35                     | \$3.31                    | \$2.37                     |
| 2040 | \$1.52                     | \$2.04                    | \$1.49                     |
| 2050 | \$1.41                     | \$1.89                    | \$1.39                     |

Based on the cost estimates developed for this study, the following observations are made:

# Turner Collie & Braden Inc.

Mr. James Adams, P.E.  
February 27, 2001  
Page 10

- 1) The GCWA alternative source supply provides the lowest cost of water in the planning years 2010, 2020, and 2030.
- 2) The CBWC alternative source supply provides the lowest cost of water in the planning years 2040 and 2050.
- 3) The BRA alternative source supply provides the highest cost of water in all the planning years studied.

The GCWA alternative source supply and the CBWC alternative source supply each consisted of pump stations and pipelines of similar sizes and lengths (plus or minus 2 miles); therefore, infrastructure costs for these alternatives were similar. The BRA alternative source supply required the pumping of water from the Brazos River to the regional treatment plant approximately 14 miles. Therefore the infrastructure associated with the BRA alternative source supply was more expensive.

It should be noted that an arrangement could potentially be made to purchase carrying capacity in existing CBWC or GCWA canals to convey water purchased from the BRA to a location closer to the proposed regional treatment plant to significantly reduce costs associated with this alternative. However, this was not analyzed for this study due to the significant unknowns in costs associated with this potential contractual arrangement.

The cost differences between the GCWA and the CBWC supply source alternatives were primarily associated with how the raw water would be purchased from the two entities. Water purchased from the GCWA will be in the form of contract water. The contract water rate used for the GCWA for this study was \$29.32 per acre-foot per year. This expense is assumed to be constant for every planning decade and would be based on the amount of water contracted each year. The cost of contract water is not based on use but is instead based on the volume contracted by a customer of GCWA for a given time period. For this study, \$29.32 per acre-foot was used for each planning decade. No increase in raw water costs was incorporated into the analysis. However, as demands increase over the 50-year planning period, GCWA is expected to acquire additional water from the BRA per the Region H plan. The actual source or cost of this additional BRA supply is unknown at this time; but it could impact future contract rates.

CBWC is interested in selling their water rights. Due to current market conditions associated with surface water, the value for these rights is unknown and can only be determined through negotiations between CBWC and an interested buyer. A value of \$200 per acre-foot was used for this analysis. A value of \$200 per acre-foot results in annual costs for the 2010 planning decade that are relatively competitive with the GCWA alternative. The purchase of water rights above \$200 per acre-foot would result in annual costs higher than the GCWA alternative.

This water cost would be incurred once and would guarantee the purchaser of the volume of water purchased in perpetuity. No additional costs associated with the purchase of water would be incurred following the purchase of water rights. Therefore, the advantages associated with this alternative are not

# Turner Collie & Braden Inc.

Mr. James Adams, P.E.  
February 27, 2001  
Page 11

realized until the later planning decades after the debt service for the earlier decades is paid off. This advantage would only be further realized in decades beyond the 50-year planning period.

In addition, it was assumed that the Planning Area would purchase only the volume of water rights from the CBWC required to meet their 2050 water need. CBWC owns water rights in excess of 200,000 acre-feet, of which approximately 80,000 acre-feet are considered firm yield rights. CBWC may be more likely to sell their firm yield rights in full as opposed to a portion of the total required to meet the Planning Area's water needs. If purchased in full, the Planning Area would have to make a larger initial financial commitment than was assumed in the study, and if deemed appropriate, could sell some or all of the excess rights to a third party to help defray costs. However, due to the degree of uncertainty associated with this issue, the CBWC alternative was assessed assuming the purchase of only the water rights required to meet 2050 water demands. The requirement to purchase CBWC water rights in full, as opposed to the assumptions for this study, would reduce the economic advantages associated with this alternative in the outer years, particularly if a third-party buyer of the excess capacity could not be identified.

There are considerable similarities in cost among the various alternatives. It should also be emphasized that the purpose of developing the cost estimates for each source is to provide a common reference for comparison. Many assumptions had to be made which impacted the analysis because some of the information that is needed can only be obtained through protracted contract negotiations. However, the analysis does provide a common means of comparing the alternatives if one recognizes the need to investigate further. The other salient point here is that the costs are close enough to each other that, in all likelihood, the selection of the final alternative will be based on factors other than cost alone.

## Comparison of Groundwater and Surface Water Supply Costs

A cost comparison was also conducted between groundwater and surface water supplies for the Planning Area. For this study, it was assumed that the Planning Area would convert up to 50 percent of the total water demand to a surface water supply while meeting the remaining 50 percent with existing groundwater supplies. Therefore, a groundwater cost component exists with each alternative surface water supply.

Cost estimates for the 50-year planning period were prepared for the following scenarios: 1) the total projected water demand for the Planning Area would be met by 100 percent groundwater supplies, with the exception of the Angleton contract water from the BWA (1,815 acre-feet) and 2) a "blended" water supply consisting of 50 percent surface water and 50 percent groundwater would be used to meet projected demands. Groundwater costs were developed using unit costs for O&M and rehabilitation, discussed in previous sections of this report. For comparison purposes, the total annual costs used for the surface water component of this analysis were based on obtaining water from the GCWA from the Briscoe Canal (see *Appendix A*).

# Turner Collie & Braden Inc.

Mr. James Adams, P.E.  
February 27, 2001  
Page 12

The costs associated with the Angleton surface water contract were also added to the 100-percent groundwater alternative. Based on Region H, the contract cost for treated water from the GCWA is \$225 per acre-foot. This cost was applied to the 1,815 acre-feet of contract water every year for the 50-year study period for this alternative.

*Appendix C* summarizes the annual costs over the 50-year planning period for the two scenarios referenced above. The shaded columns represent the annual unit costs (\$ per 1,000 gallons) associated with using only groundwater to meet projected demands and the use of "blended" water to meet demands. *Attachment C* graphically illustrates this comparison.

*Table 5* below provides the summary of cost comparison for this analysis on a dollar per 1,000 gallons basis.

**Table 5**  
**Summary of Cost Comparison**

| Year | Groundwater Cost<br>(\$/1,000 gallons) | Blended Water Cost<br>(\$/1,000 gallons) |
|------|--|--|
| 2010 | \$0.52                                 | \$1.32                                   |
| 2020 | \$0.51                                 | \$1.36                                   |
| 2030 | \$0.50                                 | \$1.35                                   |
| 2040 | \$0.51                                 | \$1.00                                   |
| 2050 | \$0.50                                 | \$0.95                                   |

Based on this analysis, the cost of using groundwater as the sole source of water for the Planning Area would remain virtually constant, between \$0.52 and \$0.50, throughout the planning period, not accounting for inflation. The cost of converting to a blended water source would decrease over time, as debt service is paid down, from a high of \$1.36 in the year 2020 to a low of \$0.95 in the year 2050.

It should be noted here that the management strategy currently incorporated in the Region H water plan for the City of Alvin, namely water service from GCWA, appears to be the most cost-effective option based on the information available. This information will be presented to the Mid-Brazoria Regional Planning Area for their determination as to whether or not to continue this strategy. The decision of whether an amendment to the plan is needed can only be made by the Mid-Brazoria Group after their consideration of the foregoing information.

# Turner Collie & Braden Inc.

Mr. James Adams, P.E.  
February 27, 2001  
Page 13

We appreciate the opportunity to work with you on this project and look forward to a continued relationship with you in the future. If you have any questions concerning this report or wish to discuss it in more detail, please feel free to call Michael Reedy at (713) 267-3127 or Mark Lowry at (713) 267-3293.

Sincerely,  
Turner Collie & Braden Inc

Michael V. Reedy, P.E.  
Project Manager

DOCUMENT IS FOR INTERIM REVIEW  
AND NOT INTENDED FOR CONSTRUCTION,  
BIDDING, OR PERMIT PURPOSES

Mark Lowry, P.E.  
Technical Director

REBECCA G. OLIVE \_\_\_\_\_, P.E.

49625

TEXAS SERIAL NO.

2/27/01

DATE





Rebecca G. Olive, P.E.  
Associate Vice President


MR/pr

Copy: Mr. Dick Carter, P.E.  
City of Alvin  
Director of Public Works  
and Engineering

# Mid-Brazoria County Regional Planning Area

## Legend

-  Cities
-  Planning Area
-  Canal Alignment
-  Potential WTP Site




0 6000 Feet  
 Sources: Digital Raster Graphics (DRG) 24k USGS  
 National, Texas  
 JUKF, Texas  
 Thompson, Texas

**LEGEND**

- ▣ Proposed Regional WTP Site
- ▲ Existing CBWC Pump Stations
- ▲ Proposed CBWC Pump Station
- ▲ Proposed GOWA Pump Station
- ▲ Proposed Brazos Pump Station
- ..... Existing GOWA Canal
- ..... Proposed GOWA Pipeline
- ..... Existing CBWC Canal
- ..... Proposed CBWC Pipeline
- ..... Proposed Brazos Pipeline

Mid-Brazoria County  
 Regional Water Planning Area  
 Alternative Water Supply Study  
 Water Supply Alternatives  
**TurnerCollie & Braden Inc.**  
 Engineers • Planners • Project Managers  
 2 37-00610-002 January 2001





**Appendix A**

**Surface Water Supply Cost Analysis Spreadsheets**

GCWA Briscoe Canal Pump Station Pipeline

|                |       |             |      |              |      |       |   |
|----------------|-------|-------------|------|--------------|------|-------|---|
| Lpipeline =    | 10350 | Length      | 9000 | Rural        | 9000 | Urban | 0 |
| Number Lines = | 12    | Fitting Fac | 1.15 |              |      |       |   |
|                |       | mgd         | 16   | gpm per line | 5556 |       |   |
|                |       |             |      |              | 0    |       |   |

| Plant Component | Flow |      | Pipe Dia<br>inches | Pipe Area<br>ft <sup>2</sup> | Velocity<br>fps |
|-----------------|------|------|--------------------|------------------------------|-----------------|
|                 | mgd  | gpm  |                    |                              |                 |
| 14 mgd option   | 8    | 5556 | 18                 | 1.767                        | 7.00            |
| 14 mgd option   | 8    | 5556 | 20                 | 2.182                        | 5.67            |
| 14 mgd option   | 8    | 5556 | 22                 | 2.640                        | 4.69            |

Hazen and Williams  
C= 110

Briscoe Canal WL = 45  
Proposed Treatment Plant WL = 40  
Assumed Static (feet) = -5  
Discharge Pressure = 23  
Total Static = 18

100 psi =  
230 ft

Power Cost =  
0.06  
Hours =  
8760

| Q    | Q     | Pipe   | Pipe A          | Vel  | Length | Fric Loss (ft) | Static | TDH | Brake | Pipe        | Pump Sta    | Total       |
|------|-------|--------|-----------------|------|--------|----------------|--------|-----|-------|-------------|-------------|-------------|
| gpm  | cfs   | inches | ft <sup>2</sup> | fps  | ft     | C=             | Head   | ft  | HP    | Cost        | Cost        | Cost        |
| 5556 | 12.38 | 18     | 1.77            | 7.00 | 10350  | 118.51         | 18     | 137 | 479   | \$1,863,000 | \$4,245,000 | \$6,108,000 |
| 5556 | 12.38 | 20     | 2.18            | 5.67 | 10350  | 70.84          | 18     | 89  | 312   | \$2,070,000 | \$2,786,000 | \$4,836,000 |
| 5556 | 12.38 | 22     | 2.64            | 4.69 | 10350  | 44.60          | 18     | 63  | 220   | \$2,587,500 | \$1,947,000 | \$4,534,500 |

| Annual Power | Annual Power |
|--------------|--------------|
| Cost         | KW-HR        |
| \$188,000    | 3,128,000    |
| \$123,000    | 2,038,000    |
| \$87,000     | 1,435,000    |

| Cost Estimating Worksheet   |       |              |            |            |         |                     |
|---|-------|--------------|------------|------------|---------|---------------------|
| Scenario 1: 14 MGD untreated water will be purchased from GCWA and diverted to the proposed water plant |       |              |            |            |         |                     |
| Phase I: 8 MGD (2010)   |       |              |            |            |         |                     |
| Item  | Notes | Unit Cost    | Percentage | Quantity   | Units   | Updated Cost        |
| <b>Pump Stations</b>  |       |              |            |            |         |                     |
| Raw water Pump Station  |       | \$2,766,000  | 60%        | 1          | LS      | \$1,659,600         |
| Intake Structure  |       | \$1,659,600  | 20%        | 1          | LS      | \$331,920           |
| Power Connection  |       | 125          | 60%        | 312        | HP      | \$23,396            |
| Standby Power   |       | \$1,659,600  | 35%        | 1          | LS      | \$580,860           |
| <b>Piping</b>   |       |              |            |            |         |                     |
| Open Cut Trenches   |       |              |            |            |         |                     |
| Pipe @ 20" in rural areas   |       | \$100        |            | 9,000      | LF      | \$900,000           |
| Pipe @ 20" in urban areas   |       | \$165        |            | 0          | LF      | \$0                 |
| Trenchless construction   |       |              |            |            |         |                     |
| Pipe @ 20"  |       | \$1,295      |            | 0          | LF      | \$0                 |
| <b>Water Treatment Plant</b>  |       | \$27,474,000 | 60%        | 1          | LS      | \$16,484,400        |
| Standby Power   |       | 16,484,400   | 35%        | 1          | LS      | \$5,769,540         |
| Power Connection  |       | 125          | 60%        | 6,060      | HP      | \$454,500           |
| <b>Purchase Contract Water (2001-2009)</b>  |       | \$29.32      | 9          | 8,959      | AF      | \$2,364,101         |
| <b>Total Capital Cost</b>   |       |              |            |            |         | <b>\$28,568,317</b> |
| <b>Engineering, Legal Costs and Contingencies</b>   |       |              |            |            |         |                     |
| Pipeline  |       | 30%          |            | 900,000    | \$      | \$270,000           |
| Other Facilities  |       | 35%          |            | 25,304,216 | \$      | \$8,856,475         |
| <b>Land Acquisition</b>   |       |              |            |            |         |                     |
| Right of Way Pipeline in rural areas  |       | 8,000        | 100%       | 12         | acres   | \$99,174            |
| Right of Way Pipeline in urban areas  |       | 10,748       | 100%       | 0          | acres   | \$0                 |
| Pump Station Site acquisition   |       | 2,000        | 100%       | 4          | acres   | \$8,000             |
| Water Treatment Plant Site acquisition  |       | 2,000        | 100%       | 20         | acres   | \$40,000            |
| Property Surveying  |       | 10%          |            | 147,174    | \$      | \$14,717            |
| <b>Environmental &amp; Archaeology Studies and Mitigation</b>   |       |              |            |            |         |                     |
| Pipeline  |       | \$25,000     | 100%       | 2          | Mile    | \$42,614            |
| Other   |       | 100%         | 100%       | 48,000     | Land\$  | \$48,000            |
| <b>Remaining Interest During Construction</b>   |       |              |            |            |         |                     |
| Loan Rate   |       | 6.0%         |            |            |         |                     |
| Rate of Return on Investments   |       | 4.0%         |            |            |         |                     |
| Duration of Project ( yr)   |       | 2.0          |            |            |         | \$2,847,000         |
| <b>Total Project Cost</b>   |       |              |            |            |         | <b>\$40,794,297</b> |
| <b>Annual Costs</b>   |       |              |            |            |         |                     |
| Debt Service (6%, 30 years)   |       | 6.0%         |            | 30         | yr      | \$2,963,661         |
| Pipeline O&M  |       | 1.0%         |            | 900,000    | \$      | \$9,000             |
| Intake and Pump Stations O&M  |       | 2.5%         |            | 2,595,776  | \$      | \$64,894            |
| Water Treatment Plant O&M   |       | \$2,730,000  | 60%        | 1          | LS      | \$1,638,000         |
| Pumping Energy Costs  |       | \$0.06       | 60%        | 2,038,000  | kW-hr   | \$73,368            |
| Plant Energy Costs  |       | \$0.06       | 60%        | 39,586,000 | kW-hr   | \$1,425,096         |
| Purchase of Raw Water   |       | \$29.32      |            | 8,959      | acft    | \$262,665           |
| <b>Total Annual Cost - 2010</b>   |       |              |            |            |         | <b>\$6,436,685</b>  |
| <b>Available Project Yield (acft/yr)</b>  |       |              |            | 8,959      | acft/yr | 8,959               |
| <b>Annual Cost of Water (\$/acft)</b>   |       |              |            |            |         | <b>\$718</b>        |
| <b>Annual Cost of Water (\$/1000 gal)</b>   |       |              |            |            |         | <b>\$2.20</b>       |

| Cost Estimating Worksheet   |       |              |                      |            |         |                    |
|---|-------|--------------|----------------------|------------|---------|--------------------|
| Scenario 1: 14 MGD untreated water will be purchased from GCWA and diverted to the proposed water plant |       |              |                      |            |         |                    |
| Phase II: 9 MGD (2020)  |       |              |                      |            |         |                    |
| Item  | Notes | Unit Cost    | Percentage per phase | Quantity   | Units   | Updated Cost       |
| <b>Pump Stations</b>  |       |              |                      |            |         |                    |
| Raw water Pump Station  |       | \$2,766,000  | 10%                  | 1          | LS      | \$276,600          |
| Intake Structure  |       | \$276,600    | 20%                  | 1          | LS      | \$55,320           |
| Power Connection  |       | 125          | 10%                  | 312        | HP      | \$3,899            |
| Standby Power   |       | \$276,600    | 35%                  | 1          | LS      | \$96,810           |
| <b>Piping</b>   |       |              |                      |            |         |                    |
| Open Cut Trenches   |       |              |                      |            |         |                    |
| Pipe @ 20" in rural areas   |       | \$100        |                      | 0          | LF      | \$0                |
| Pipe @ 20" in urban areas   |       | \$165        |                      | 0          | LF      | \$0                |
| Trenchless construction   |       |              |                      |            |         |                    |
| Pipe @ 20"  |       | \$1,295      |                      | 0          | LF      | \$0                |
| <b>Water Treatment Plant</b>  |       | \$27,474,000 | 10%                  | 1          | LS      | \$2,747,400        |
| Standby Power   |       | \$2,747,400  | 35%                  | 1          | LS      | \$961,590          |
| Power Connection  |       | 125          | 10%                  | 6,060      | HP      | \$75,750           |
| <b>Total Capital Cost</b>   |       |              |                      |            |         | <b>\$4,217,369</b> |
| <b>Engineering, Legal Costs and Contingencies</b>   |       |              |                      |            |         |                    |
| Pipeline  |       | 30%          |                      | 0          | \$      | \$0                |
| Other Facilities  |       | 35%          |                      | 4,217,369  | \$      | \$1,476,079        |
| <b>Land Acquisition</b>   |       |              |                      |            |         |                    |
| Right of Way Pipeline in rural areas  |       | 8,000        | 0%                   | 0          | acres   | \$0                |
| Right of Way Pipeline in urban areas  |       | 10,748       | 0%                   | 0          | acres   | \$0                |
| Pump Station Site acquisition   |       | 2,000        | 0%                   | 4          | acres   | \$0                |
| Water Treatment Plant Site acquisition  |       | 2,000        | 0%                   | 20         | acres   | \$0                |
| Property Surveying  |       | 10%          |                      | 0          | \$      | \$0                |
| <b>Environmental &amp; Archaeology Studies and Mitigation</b>   |       |              |                      |            |         |                    |
| Pipeline  |       | \$25,000     | 0%                   | 0          | Mile    | \$0                |
| Other   |       | 100%         | 0%                   | 0          | Land\$  | \$0                |
| <b>Remaining Interest During Construction</b>   |       |              |                      |            |         |                    |
| Loan Rate   |       | 6.0%         |                      |            |         |                    |
| Rate of Return on Investments   |       | 4.0%         |                      |            |         |                    |
| Duration of Project ( yr)   |       | 2.0          |                      |            |         | \$456,000          |
| <b>Total Project Cost</b>   |       |              |                      |            |         | <b>\$6,149,449</b> |
| <b>Annual Costs</b>   |       |              |                      |            |         |                    |
| Debt Service (6%, 30 years)   |       | 6.0%         |                      | 30         | yr      | \$446,751          |
| Annual Cost from Phase I  |       |              |                      |            |         | \$6,436,685        |
| Pipeline O&M  |       | 1.0%         |                      | 0          | \$      | \$0                |
| Intake and Pump Stations O&M  |       | 2.5%         |                      | 432,629    | \$      | \$10,816           |
| Water Treatment Plant O&M   |       | 2,730,000    | 10%                  | 1          | LS      | \$273,000          |
| Pumping Energy Costs  |       | \$0.06       | 10%                  | 2,038,000  | kW-hr   | \$12,228           |
| Plant Energy Costs  |       | \$0.06       | 10%                  | 39,586,000 | kW-hr   | \$237,516          |
| Purchase of Raw Water   |       | \$29.32      |                      | 1,120      | acft    | \$32,833           |
| <b>Total Annual Cost - 2020</b>   |       |              |                      |            |         | <b>\$7,449,828</b> |
| <b>Available Project Yield (acft/yr)</b>  |       |              |                      | 10,078     | acft/yr | 10,078             |
| <b>Annual Cost of Water (\$/acft)</b>   |       |              |                      |            |         | \$739              |
| <b>Annual Cost of Water (\$/1000 gal)</b>   |       |              |                      |            |         | \$2.27             |

Cost estimate Mid-Brazoria Regional Water Planning  
GCWA, Supply Source Alternative No. 2

12/19/00  
Prepared by JA

| Cost Estimating Worksheet   |       |              |                      |            |         |                    |
|---|-------|--------------|----------------------|------------|---------|--------------------|
| Scenario 1: 14 MGD untreated water will be purchased from GCWA and diverted to the proposed water plant |       |              |                      |            |         |                    |
| Phase III: 10 MGD (2030)  |       |              |                      |            |         |                    |
| Item  | Notes | Unit Cost    | Percentage per phase | Quantity   | Units   | Updated Cost       |
| <b>Pump Stations</b>  |       |              |                      |            |         |                    |
| Raw water Pump Station  |       | \$2,766,000  | 10%                  | 1          | LS      | \$276,600          |
| Intake Structure  |       | \$276,600    | 20%                  | 1          | LS      | \$55,320           |
| Power Connection  |       | 125          | 10%                  | 312        | HP      | \$3,899            |
| Standby Power   |       | \$276,600    | 35%                  | 1          | LS      | \$96,810           |
| <b>Piping</b>   |       |              |                      |            |         |                    |
| Open Cut Trenches   |       |              |                      |            |         |                    |
| Pipe @ 20" in rural areas   |       | \$100        |                      | 9,000      | LF      | \$900,000          |
| Pipe @ 20" in urban areas   |       | \$165        |                      | 0          | LF      | \$0                |
| Trenchless construction   |       |              |                      |            |         |                    |
| Pipe @ 60"  |       | \$1,295      |                      | 0          | LF      | \$0                |
| <b>Water Treatment Plant</b>  |       | \$27,474,000 | 10%                  | 1          | LS      | \$2,747,400        |
| Standby Power   |       | \$2,747,400  | 35%                  | 1          | LS      | \$961,590          |
| Power Connection  |       | \$125        | 10%                  | 6,060      | HP      | \$75,750           |
| <b>Total Capital Cost</b>   |       |              |                      |            |         | <b>\$5,117,369</b> |
| <b>Engineering, Legal Costs and Contingencies</b>   |       |              |                      |            |         |                    |
| Pipeline  |       | 30%          |                      | 900,000    | \$      | \$270,000          |
| Other Facilities  |       | 35%          |                      | 4,217,369  | \$      | \$1,476,079        |
| <b>Land Acquisition</b>   |       |              |                      |            |         |                    |
| Right of Way Pipeline in rural areas  |       | 8,000        | 0%                   | 12         | acres   | \$0                |
| Right of Way Pipeline in urban areas  |       | 10,748       | 0%                   | 0          | acres   | \$0                |
| Pump Station Site acquisition   |       | 2,000        | 0%                   | 4          | acres   | \$0                |
| Water Treatment Plant Site acquisition  |       | 2,000        | 0%                   | 20         | acres   | \$0                |
| Property Surveying  |       | 10%          |                      | 0          | \$      | \$0                |
| <b>Environmental &amp; Archaeology Studies and Mitigation</b>   |       |              |                      |            |         |                    |
| Pipeline  |       | \$25,000     | 0%                   | 0          | Mile    | \$0                |
| Other   |       | 100%         | 0%                   | 0          | Land\$  | \$0                |
| <b>Remaining Interest During Construction</b>   |       |              |                      |            |         |                    |
| Loan Rate   |       | 6.0%         |                      |            |         |                    |
| Rate of Return on Investments   |       | 4.0%         |                      |            |         |                    |
| Duration of Project (yr)  |       | 2.0          |                      |            |         | \$550,000          |
| <b>Total Project Cost</b>   |       |              |                      |            |         | <b>\$7,413,449</b> |
| <b>Annual Costs</b>   |       |              |                      |            |         |                    |
| Debt Service (6%, 30 years)   |       | 6.0%         |                      | 30         | yr      | \$538,579          |
| Annual Cost from Phase II   |       |              |                      |            |         | \$7,449,828        |
| Pipeline O&M  |       | 1.0%         |                      | 900,000    | \$      | \$9,000            |
| Intake and Pump Stations O&M  |       | 2.5%         |                      | 432,629    | \$      | \$10,816           |
| Water Treatment Plant O&M   |       | 2,730,000    | 10%                  | 1          | LS      | \$273,000          |
| Pumping Energy Costs  |       | \$0.06       | 10%                  | 2,038,000  | kW-hr   | \$12,228           |
| Plant Energy Costs  |       | \$0.06       | 10%                  | 39,586,000 | kW-hr   | \$237,516          |
| Purchase of Raw Water   |       | \$29.32      |                      | 1,120      | acft    | \$32,833           |
| <b>Total Annual Cost - 2030</b>   |       |              |                      |            |         | <b>\$8,563,800</b> |
| <b>Available Project Yield (acft/yr)</b>  |       |              |                      | 11,198     | acft/yr | <b>11,198</b>      |
| <b>Annual Cost of Water (\$/acft)</b>   |       |              |                      |            |         | <b>\$765</b>       |
| <b>Annual Cost of Water (\$/1000 gal)</b>   |       |              |                      |            |         | <b>\$2.35</b>      |

| Cost Estimating Worksheet   |       |              |                      |                |        |                    |
|---|-------|--------------|----------------------|----------------|--------|--------------------|
| Scenario 1: 14 MGD untreated water will be purchased from GCWA and diverted to the proposed water plant |       |              |                      |                |        |                    |
| Phase IV: 12 MGD (2040)   |       |              |                      |                |        |                    |
| Item  | Notes | Unit Cost    | Percentage per phase | Quantity       | Units  | Updated Cost       |
| <b>Pump Stations</b>  |       |              |                      |                |        |                    |
| Raw water Pump Station  |       | \$2,766,000  | 10%                  | 1              | LS     | \$276,600          |
| Intake Structure  |       | \$276,600    | 20%                  | 1              | LS     | \$55,320           |
| Power Connection  |       | \$125        | 10%                  | 312            | HP     | \$3,899            |
| Standby Power   |       | \$276,600    | 35%                  | 1              | LS     | \$96,810           |
| <b>Piping</b>   |       |              |                      |                |        |                    |
| Open Cut Trenches   |       |              |                      |                |        |                    |
| Pipe @ 20" in rural areas   |       | \$100        |                      | 0              | LF     | \$0                |
| Pipe @ 20" in urban areas   |       | \$165        |                      | 0              | LF     | \$0                |
| Trenchless construction   |       |              |                      |                |        |                    |
| Pipe @ 60"  |       | \$1,295      |                      | 0              | LF     | \$0                |
| <b>Water Treatment Plant</b>  |       | \$27,474,000 | 10%                  | 1              | LS     | \$2,747,400        |
| Standby Power   |       | \$2,747,400  | 35%                  | 1              | LS     | \$961,590          |
| Power Connection  |       | \$125        | 10%                  | 6,060          | HP     | \$75,750           |
| <b>Total Capital Cost</b>   |       |              |                      |                |        | <b>\$4,217,369</b> |
| <b>Engineering, Legal Costs and Contingencies</b>   |       |              |                      |                |        |                    |
| Pipeline  |       | 30%          |                      | 0              | \$     | \$0                |
| Other Facilities  |       | 35%          |                      | \$4,217,369    | \$     | \$1,476,079        |
| <b>Land Acquisition</b>   |       |              |                      |                |        |                    |
| Right of Way Pipeline in rural areas  |       | \$8,000      | 0                    | 0              | acres  | \$0                |
| Right of Way Pipeline in urban areas  |       | \$10,748     | 0                    | 0              | acres  | \$0                |
| Pump Station Site acquisition   |       | \$2,000      | 0                    | 4              | acres  | \$0                |
| Water Treatment Plant Site acquisition  |       | \$2,000      | 0                    | 20             | acres  | \$0                |
| Property Surveying  |       | 10%          |                      | 0              | \$     | \$0                |
| <b>Environmental &amp; Archaeology Studies and Mitigation</b>   |       |              |                      |                |        |                    |
| Pipeline  |       | \$25,000     | 0                    | 0              | Mile   | \$0                |
| Other   |       | 100%         | 0                    | 0              | Land\$ | \$0                |
| <b>Remaining Interest During Construction</b>   |       |              |                      |                |        |                    |
| Loan Rate   |       | 6%           |                      |                |        |                    |
| Rate of Return on Investments   |       | 4%           |                      |                |        |                    |
| Duration of Project ( yr)   |       | 2            |                      |                |        | \$456,000          |
| <b>Total Project Cost</b>   |       |              |                      |                |        | <b>\$6,149,449</b> |
| <b>Annual Costs</b>   |       |              |                      |                |        |                    |
| Debt Service (6%, 30 years)   |       | 6%           |                      | 30             | yr     | \$446,751          |
| Annual Cost from Phase III  |       |              |                      |                |        | \$5,600,139        |
| Pipeline O&M  |       | 1%           |                      | 0              | \$     | \$0                |
| Intake and Pump Stations O&M  |       | 2.5%         |                      | \$432,629      | \$     | \$10,816           |
| Water Treatment Plant O&M   |       | \$2,730,000  | 10%                  | 1              | LS     | \$273,000          |
| Pumping Energy Costs  |       | \$0.06       | 10%                  | 2,038,000      | kW-hr  | \$12,228           |
| Plant Energy Costs  |       | \$0.06       | 10%                  | 39,586,000     | kW-hr  | \$237,516          |
| Purchase of Raw Water   |       | \$29.32      |                      | 2,240          | acft   | \$65,666           |
| <b>Total Annual Cost - 2040</b>   |       |              |                      |                |        | <b>\$6,646,116</b> |
| <b>Available Project Yield (acft/yr)</b>  |       |              |                      | 13,438 acft/yr |        | \$13,438           |
| <b>Annual Cost of Water (\$/acft)</b>   |       |              |                      |                |        | \$495              |
| <b>Annual Cost of Water (\$/1000 gal)</b>   |       |              |                      |                |        | \$1.52             |

| Cost Estimating Worksheet   |       |              |                      |                  |       |              |
|---|-------|--------------|----------------------|------------------|-------|--------------|
| Scenario 1: 14 MGD untreated water will be purchased from GCWA and diverted to the proposed water plant |       |              |                      |                  |       |              |
| Phase V: 14 MGD (2050)  |       |              |                      |                  |       |              |
| Item  | Notes | Unit Cost    | Percentage per phase | Quantity         | Units | Updated Cost |
| <b>Pump Stations</b>  |       |              |                      |                  |       |              |
| Raw water Pump Station  |       | \$2,766,000  | 10%                  | 1 LS             |       | \$276,600    |
| Intake Structure  |       | \$276,600    | 20%                  | 1 LS             |       | \$55,320     |
| Power Connection  |       | \$125        | 10%                  | 312 HP           |       | \$3,899      |
| Standby Power   |       | \$276,600    | 35%                  | 1 LS             |       | \$96,810     |
| <b>Piping</b>   |       |              |                      |                  |       |              |
| Open Cut Trenches   |       |              |                      |                  |       |              |
| Pipe @ 20" in rural areas   |       | \$100        |                      | 0 LF             |       | \$0          |
| Pipe @ 20" in urban areas   |       | \$165        |                      | 0 LF             |       | \$0          |
| Trenchless construction   |       |              |                      |                  |       |              |
| Pipe @ 60"  |       | \$1,295      |                      | 0 LF             |       | \$0          |
| <b>Water Treatment Plant</b>  |       | \$27,474,000 | 10%                  | 1 LS             |       | \$2,747,400  |
| Standby Power   |       | \$2,747,400  | 35%                  | 1 LS             |       | \$961,590    |
| Power Connection  |       | \$125        | 10%                  | 6,060 HP         |       | \$75,750     |
| <b>Total Capital Cost</b>   |       |              |                      |                  |       | \$4,217,369  |
| <b>Engineering, Legal Costs and Contingencies</b>   |       |              |                      |                  |       |              |
| Pipeline  |       | 30%          |                      | \$0 \$           |       | \$0          |
| Other Facilities  |       | 35%          |                      | \$4,217,369 \$   |       | \$1,476,079  |
| <b>Land Acquisition</b>   |       |              |                      |                  |       |              |
| Right of Way Pipeline in rural areas  |       | \$8,000      | 0                    | 0 acres          |       | \$0          |
| Right of Way Pipeline in urban areas  |       | \$10,748     | 0                    | 0 acres          |       | \$0          |
| Pump Station Site acquisition   |       | \$2,000      | 0                    | 4 acres          |       | \$0          |
| Water Treatment Plant Site acquisition  |       | \$2,000      | 0                    | 20 acres         |       | \$0          |
| Property Surveying  |       | 10%          |                      | 0 \$             |       | \$0          |
| <b>Environmental &amp; Archaeology Studies and Mitigation</b>   |       |              |                      |                  |       |              |
| Pipeline  |       | \$25,000     | 0                    | 0 Mile           |       | \$0          |
| Other   |       | 100%         | 0                    | 0 Land\$         |       | \$0          |
| <b>Remaining Interest During Construction</b>   |       |              |                      |                  |       |              |
| Loan Rate   |       | 6%           |                      |                  |       |              |
| Rate of Return on Investments   |       | 4%           |                      |                  |       |              |
| Duration of Project ( yr)   |       | 2            |                      |                  |       | \$456,000    |
| <b>Total Project Cost</b>   |       |              |                      |                  |       | \$6,149,449  |
| <b>Annual Costs</b>   |       |              |                      |                  |       |              |
| Debt Service (6%, 30 years)   |       | 6%           |                      | 30 yr            |       | \$446,751    |
| Annual Cost from Phase IV   |       |              |                      |                  |       | \$6,199,365  |
| Pipeline O&M  |       | 1%           |                      | 0 \$             |       | \$0          |
| Intake and Pump Stations O&M  |       | 2.5%         |                      | \$432,629 \$     |       | \$10,816     |
| Water Treatment Plant O&M   |       | \$2,730,000  | 10%                  | 1 LS             |       | \$273,000    |
| Pumping Energy Costs  |       | \$0.06       | 10%                  | 2,038,000 kW-hr  |       | \$12,228     |
| Plant Energy Costs  |       | \$0.06       | 10%                  | 39,586,000 kW-hr |       | \$237,516    |
| Purchase of Raw Water   |       | \$29.32      |                      | 1,568 acft       |       | \$45,966     |
| <b>Total Annual Cost - 2050</b>   |       |              |                      |                  |       | \$7,225,642  |
| <b>Available Project Yield (acft/yr)</b>  |       |              |                      | 15,677 acft/yr   |       | \$15,677     |
| <b>Annual Cost of Water (\$/acft)</b>   |       |              |                      |                  |       | \$461        |
| <b>Annual Cost of Water (\$/1000 gal)</b>   |       |              |                      |                  |       | \$1.41       |

Brazos River Authority Pump Station Pipeline

|            |       |             |       |              |       |       |   |
|------------|-------|-------------|-------|--------------|-------|-------|---|
| Lipeline = | 83950 | Length      | 73000 | Rural        | 73000 | Urban | 0 |
|            |       | Fitting Fac | 1.15  |              |       |       |   |
|            |       | mgd         | 16    | gpm per line | 5556  |       |   |

| Plant Component | Flow |      | Pipe Dia<br>inches | Pipe Area<br>ft <sup>2</sup> | Velocity<br>fps |
|-----------------|------|------|--------------------|------------------------------|-----------------|
|                 | mgd  | gpm  |                    |                              |                 |
| 14 mgd option   | 8    | 5556 | 18                 | 1.767                        | 7.00            |
| 14 mgd option   | 8    | 5556 | 20                 | 2.182                        | 5.67            |
| 14 mgd option   | 8    | 5556 | 22                 | 2.640                        | 4.69            |

Brazos River WL = 50  
 Proposed Treatment Plant WL = 40  
 Assumed Static (feet) = -10 Power Cost =  
 Discharge Pressure = 23 0.06  
 Hours = 8760  
 Total Static = 13

100 psi =  
 230 ft

Hazen and Williams  
 C = 110

| Q<br>gpm | Q<br>cfs | Pipe<br>inches | Pipe A<br>ft <sup>2</sup> | Vel<br>fps | Length<br>ft | Fric Loss (ft)<br>C= | TDH<br>ft | Static<br>Head<br>ft | Brake<br>HP | Pipe         |              | Pump Sta     |      | Total |  |
|----------|----------|----------------|---------------------------|------------|--------------|----------------------|-----------|----------------------|-------------|--------------|--------------|--------------|------|-------|--|
|          |          |                |                           |            |              |                      |           |                      |             | Cost         | Cost         | Cost         | Cost |       |  |
| 5556     | 12.38    | 18             | 1.77                      | 7.00       | 83950        | 961.25               | 974       | 13                   | 3417        | \$15,111,000 | \$12,506,000 | \$27,617,000 |      |       |  |
| 5556     | 12.38    | 20             | 2.18                      | 5.67       | 83950        | 575.41               | 588       | 13                   | 2064        | \$16,790,000 | \$10,509,000 | \$27,299,000 |      |       |  |
| 5556     | 12.38    | 22             | 2.64                      | 4.69       | 83950        | 361.73               | 375       | 13                   | 1314        | \$20,987,500 | \$8,504,000  | \$29,491,500 |      |       |  |

| Annual Power<br>Cost | Annual Power<br>KW-HR |
|----------------------|-----------------------|
| \$1,340,000          | 22,321,000            |
| \$516,000            | 8,586,000             |



| Cost Estimating Worksheet  |       |              |            |            |         |                     |
|--|-------|--------------|------------|------------|---------|---------------------|
| Scenario 1: 14 MGD untreated water will be purchased from BRA and diverted to the proposed water plant |       |              |            |            |         |                     |
| Phase I: 8 MGD (2010)  |       |              |            |            |         |                     |
| Item   | Notes | Unit Cost    | Percentage | Quantity   | Units   | Updated Cost        |
| <b>Pump Stations</b>   |       |              |            |            |         |                     |
| Raw water Pump Station   |       | \$10,508,000 | 60%        | 1          | LS      | \$6,304,800         |
| Intake Structure   |       | \$6,304,800  | 20%        | 1          | LS      | \$1,260,960         |
| Power Connection   |       | 125          | 60%        | 2,064      | HP      | \$154,780           |
| Standby Power  |       | \$6,304,800  | 35%        | 1          | LS      | \$2,206,680         |
| <b>Piping</b>  |       |              |            |            |         |                     |
| Open Cut Trenches  |       |              |            |            |         |                     |
| Pipe @ 20" in rural areas  |       | \$100        |            | 73,000     | LF      | \$7,300,000         |
| Pipe @ 20" in urban areas  |       | \$165        |            | 0          | LF      | \$0                 |
| Trenchless construction  |       |              |            |            |         |                     |
| Pipe @ 20"   |       | \$1,295      |            | 0          | LF      | \$0                 |
| <b>Water Treatment Plant</b>   |       | \$27,474,000 | 60%        | 1          | LS      | \$16,484,400        |
| Standby Power  |       | 16,484,400   | 35%        | 1          | LS      | \$5,769,540         |
| Power Connection   |       | 125          | 60%        | 6,060      | HP      | \$454,500           |
| <b>Purchase Contract Water (2001-2009)</b>   |       | \$27         | 9          | 8,959      | AF      | \$2,177,037         |
| <b>Total Capital Cost</b>  |       |              |            |            |         | <b>\$42,112,697</b> |
| <b>Engineering, Legal Costs and Contingencies</b>  |       |              |            |            |         |                     |
| Pipeline   |       | 30%          |            | 7,300,000  | \$      | \$2,190,000         |
| Other Facilities   |       | 35%          |            | 32,635,660 | \$      | \$11,422,481        |
| <b>Land Acquisition</b>  |       |              |            |            |         |                     |
| Right of Way Pipeline in rural areas   |       | 8,000        | 100%       | 101        | acres   | \$804,408           |
| Right of Way Pipeline in urban areas   |       | 10,748       | 100%       | 0          | acres   | \$0                 |
| Pump Station Site acquisition  |       | 2,000        | 100%       | 4          | acres   | \$8,000             |
| Water Treatment Plant Site acquisition   |       | 2,000        | 100%       | 20         | acres   | \$40,000            |
| <b>Property Surveying</b>  |       | 10%          |            | 852,408    | \$      | \$85,241            |
| <b>Environmental &amp; Archaeology Studies and Mitigation</b>  |       |              |            |            |         |                     |
| Pipeline   |       | \$25,000     | 100%       | 14         | Mile    | \$345,644           |
| Other  |       | 100%         | 100%       | 48,000     | Land\$  | \$48,000            |
| <b>Remaining Interest During Construction</b>  |       |              |            |            |         |                     |
| Loan Rate  |       | 6.0%         |            |            |         |                     |
| Rate of Return on Investments  |       | 4.0%         |            |            |         |                     |
| Duration of Project ( yr)  |       | 2.0          |            |            |         | \$4,391,000         |
| <b>Total Project Cost</b>  |       |              |            |            |         | <b>\$61,447,470</b> |
| <b>Annual Costs</b>  |       |              |            |            |         |                     |
| Debt Service (6%, 30 years)  |       | 6.0%         |            | 30         | yr      | \$4,464,092         |
| Pipeline O&M   |       | 1.0%         |            | 7,300,000  | \$      | \$73,000            |
| Intake and Pump Stations O&M   |       | 2.5%         |            | 9,927,220  | \$      | \$248,180           |
| Water Treatment Plant O&M  |       | \$2,730,000  | 60%        | 1          | LS      | \$1,638,000         |
| Pumping Energy Costs   |       | \$0.06       | 60%        | 13,481,000 | kW-hr   | \$485,316           |
| Plant Energy Costs   |       | \$0.06       | 60%        | 39,586,000 | kW-hr   | \$1,425,096         |
| Purchase of Raw Water  |       | \$45.00      |            | 8,959      | acft    | \$403,135           |
| <b>Total Annual Cost - 2010</b>  |       |              |            |            |         | <b>\$8,736,820</b>  |
| <b>Available Project Yield (acft/yr)</b>   |       |              |            | 8,959      | acft/yr | 8,959               |
| <b>Annual Cost of Water (\$/acft)</b>  |       |              |            |            |         | \$975               |
| <b>Annual Cost of Water (\$/1000 gal)</b>  |       |              |            |            |         | \$2.99              |

| Cost Estimating Worksheet  |       |              |                      |            |         |                    |
|--|-------|--------------|----------------------|------------|---------|--------------------|
| Scenario 1: 14 MGD untreated water will be purchased from BRA and diverted to the proposed water plant |       |              |                      |            |         |                    |
| Phase II: 9 MGD (2020)   |       |              |                      |            |         |                    |
| Item   | Notes | Unit Cost    | Percentage per phase | Quantity   | Units   | Updated Cost       |
| <b>Pump Stations</b>   |       |              |                      |            |         |                    |
| Raw water Pump Station   |       | \$10,508,000 | 10%                  | 1          | LS      | \$1,050,800        |
| Intake Structure   |       | \$1,050,800  | 20%                  | 1          | LS      | \$210,160          |
| Power Connection   |       | 125          | 10%                  | 2,064      | HP      | \$25,797           |
| Standby Power  |       | \$1,050,800  | 35%                  | 1          | LS      | \$367,780          |
| <b>Piping</b>  |       |              |                      |            |         |                    |
| Open Cut Trenches  |       |              |                      |            |         |                    |
| Pipe @ 20" in rural areas  |       | \$100        |                      | 0          | LF      | \$0                |
| Pipe @ 20" in urban areas  |       | \$165        |                      | 0          | LF      | \$0                |
| Trenchless construction  |       |              |                      |            |         |                    |
| Pipe @ 20"   |       | \$1,295      |                      | 0          | LF      | \$0                |
| <b>Water Treatment Plant</b>   |       | \$27,474,000 | 10%                  | 1          | LS      | \$2,747,400        |
| Standby Power  |       | \$2,747,400  | 35%                  | 1          | LS      | \$961,590          |
| Power Connection   |       | 125          | 10%                  | 6,060      | HP      | \$75,750           |
| <b>Total Capital Cost</b>  |       |              |                      |            |         | <b>\$5,439,277</b> |
| <b>Engineering, Legal Costs and Contingencies</b>  |       |              |                      |            |         |                    |
| Pipeline   |       | 30%          |                      | 0          | \$      | \$0                |
| Other Facilities   |       | 35%          |                      | 5,439,277  | \$      | \$1,903,747        |
| <b>Land Acquisition</b>  |       |              |                      |            |         |                    |
| Right of Way Pipeline in rural areas   |       | 8,000        | 0%                   | 0          | acres   | \$0                |
| Right of Way Pipeline in urban areas   |       | 10,748       | 0%                   | 0          | acres   | \$0                |
| Pump Station Site acquisition  |       | 2,000        | 0%                   | 4          | acres   | \$0                |
| Water Treatment Plant Site acquisition   |       | 2,000        | 0%                   | 20         | acres   | \$0                |
| <b>Property Surveying</b>  |       | 10%          |                      | 0          | \$      | \$0                |
| <b>Environmental &amp; Archaeology Studies and Mitigation</b>  |       |              |                      |            |         |                    |
| Pipeline   |       | \$25,000     | 0%                   | 0          | Mile    | \$0                |
| Other  |       | 100%         | 0%                   | 0          | Land\$  | \$0                |
| <b>Remaining Interest During Construction</b>  |       |              |                      |            |         |                    |
| Loan Rate  |       | 6.0%         |                      |            |         |                    |
| Rate of Return on Investments  |       | 4.0%         |                      |            |         |                    |
| Duration of Project ( yr)  |       | 2.0          |                      |            |         | \$588,000          |
| <b>Total Project Cost</b>  |       |              |                      |            |         | <b>\$7,931,023</b> |
| <b>Annual Costs</b>  |       |              |                      |            |         |                    |
| Debt Service (6%, 30 years)  |       | 6.0%         |                      | 30         | yr      | \$576,180          |
| Annual Cost from Phase I   |       |              |                      |            |         | \$8,736,820        |
| Pipeline O&M   |       | 1.0%         |                      | 0          | \$      | \$0                |
| Intake and Pump Stations O&M   |       | 2.5%         |                      | 1,654,537  | \$      | \$41,363           |
| Water Treatment Plant O&M  |       | 2,730,000    | 10%                  | 1          | LS      | \$273,000          |
| Pumping Energy Costs   |       | \$0.06       | 10%                  | 13,481,000 | kW-hr   | \$80,886           |
| Plant Energy Costs   |       | \$0.06       | 10%                  | 39,586,000 | kW-hr   | \$237,516          |
| Purchase of Raw Water  |       | \$45.00      |                      | 1,120      | acft    | \$50,392           |
| <b>Total Annual Cost - 2020</b>  |       |              |                      |            |         | <b>\$9,996,157</b> |
| <b>Available Project Yield (acft/yr)</b>   |       |              |                      | 10,078     | acft/yr | 10,078             |
| <b>Annual Cost of Water (\$/acft)</b>  |       |              |                      |            |         | <b>\$992</b>       |
| <b>Annual Cost of Water (\$/1000 gal)</b>  |       |              |                      |            |         | <b>\$3.04</b>      |

| Cost Estimating Worksheet  |       |              |                      |            |         |                     |
|--|-------|--------------|----------------------|------------|---------|---------------------|
| Scenario 1: 14 MGD untreated water will be purchased from BRA and diverted to the proposed water plant |       |              |                      |            |         |                     |
| Phase III: 10 MGD (2030)   |       |              |                      |            |         |                     |
| Item   | Notes | Unit Cost    | Percentage per phase | Quantity   | Units   | Updated Cost        |
| <b>Pump Stations</b>   |       |              |                      |            |         |                     |
| Raw water Pump Station   |       | \$10,508,000 | 10%                  | 1          | LS      | \$1,050,800         |
| Intake Structure   |       | \$1,050,800  | 20%                  | 1          | LS      | \$210,160           |
| Power Connection   |       | 125          | 10%                  | 2,064      | HP      | \$25,797            |
| Standby Power  |       | \$1,050,800  | 35%                  | 1          | LS      | \$367,780           |
| <b>Piping</b>  |       |              |                      |            |         |                     |
| Open Cut Trenches  |       |              |                      |            |         |                     |
| Pipe @ 20" in rural areas  |       | \$100        |                      | 73,000     | LF      | \$7,300,000         |
| Pipe @ 20" in urban areas  |       | \$165        |                      | 0          | LF      | \$0                 |
| Trenchless construction  |       |              |                      |            |         |                     |
| Pipe @ 20"   |       | \$1,295      |                      | 0          | LF      | \$0                 |
| <b>Water Treatment Plant</b>   |       | \$27,474,000 | 10%                  | 1          | LS      | \$2,747,400         |
| Standby Power  |       | \$2,747,400  | 35%                  | 1          | LS      | \$961,590           |
| Power Connection   |       | \$125        | 10%                  | 6,060      | HP      | \$75,750            |
| <b>Total Capital Cost</b>  |       |              |                      |            |         | <b>\$12,739,277</b> |
| <b>Engineering, Legal Costs and Contingencies</b>  |       |              |                      |            |         |                     |
| Pipeline   |       | 30%          |                      | 7,300,000  | \$      | \$2,190,000         |
| Other Facilities   |       | 35%          |                      | 5,439,277  | \$      | \$1,903,747         |
| <b>Land Acquisition</b>  |       |              |                      |            |         |                     |
| Right of Way Pipeline in rural areas   |       | 8,000        | 0%                   | 101        | acres   | \$0                 |
| Right of Way Pipeline in urban areas   |       | 10,748       | 0%                   | 0          | acres   | \$0                 |
| Pump Station Site acquisition  |       | 2,000        | 0%                   | 4          | acres   | \$0                 |
| Water Treatment Plant Site acquisition   |       | 2,000        | 0%                   | 20         | acres   | \$0                 |
| Property Surveying   |       | 10%          |                      | 0          | \$      | \$0                 |
| <b>Environmental &amp; Archaeology Studies and Mitigation</b>  |       |              |                      |            |         |                     |
| Pipeline   |       | \$25,000     | 0%                   | 0          | Mile    | \$0                 |
| Other  |       | 100%         | 0%                   | 0          | Land\$  | \$0                 |
| <b>Remaining Interest During Construction</b>  |       |              |                      |            |         |                     |
| Loan Rate  |       | 6.0%         |                      |            |         |                     |
| Rate of Return on Investments  |       | 4.0%         |                      |            |         |                     |
| Duration of Project ( yr)  |       | 2.0          |                      |            |         | \$1,347,000         |
| <b>Total Project Cost</b>  |       |              |                      |            |         | <b>\$18,180,023</b> |
| <b>Annual Costs</b>  |       |              |                      |            |         |                     |
| Debt Service (6%, 30 years)  |       | 6.0%         |                      | 30         | yr      | \$1,320,759         |
| Annual Cost from Phase II  |       |              |                      |            |         | \$9,996,157         |
| Pipeline O&M   |       | 1.0%         |                      | 7,300,000  | \$      | \$73,000            |
| Intake and Pump Stations O&M   |       | 2.5%         |                      | 1,654,537  | \$      | \$41,363            |
| Water Treatment Plant O&M  |       | 2,730,000    | 10%                  | 1          | LS      | \$273,000           |
| Pumping Energy Costs   |       | \$0.06       | 10%                  | 13,481,000 | kW-hr   | \$80,886            |
| Plant Energy Costs   |       | \$0.06       | 10%                  | 39,586,000 | kW-hr   | \$237,516           |
| Purchase of Raw Water  |       | \$45.00      |                      | 1,120      | acft    | \$50,392            |
| <b>Total Annual Cost - 2030</b>  |       |              |                      |            |         | <b>\$12,073,073</b> |
| <b>Available Project Yield (acft/yr)</b>   |       |              |                      | 11,198     | acft/yr | 11,198              |
| <b>Annual Cost of Water (\$/acft)</b>  |       |              |                      |            |         | <b>\$1,078</b>      |
| <b>Annual Cost of Water (\$/1000 gal)</b>  |       |              |                      |            |         | <b>\$3.31</b>       |

| Cost Estimating Worksheet  |       |              |                      |            |                |              |
|--|-------|--------------|----------------------|------------|----------------|--------------|
| Scenario 1: 14 MGD untreated water will be purchased from BRA and diverted to the proposed water plant |       |              |                      |            |                |              |
| Phase IV: 12.6 MGD (2040)  |       |              |                      |            |                |              |
| Item   | Notes | Unit Cost    | Percentage per phase | Quantity   | Units          | Updated Cost |
| <b>Pump Stations</b>   |       |              |                      |            |                |              |
| Raw water Pump Station   |       | \$10,508,000 | 10%                  |            | 1 LS           | \$1,050,800  |
| Intake Structure   |       | \$1,050,800  | 20%                  |            | 1 LS           | \$210,160    |
| Power Connection   |       | \$125        | 10%                  | 2,064      | HP             | \$25,797     |
| Standby Power  |       | \$1,050,800  | 35%                  |            | 1 LS           | \$367,780    |
| <b>Piping</b>  |       |              |                      |            |                |              |
| Open Cut Trenches  |       |              |                      |            |                |              |
| Pipe @ 20" in rural areas  |       | \$100        |                      |            | 0 LF           | \$0          |
| Pipe @ 20" in urban areas  |       | \$165        |                      |            | 0 LF           | \$0          |
| Trenchless construction  |       |              |                      |            |                |              |
| Pipe @ 20"   |       | \$1,295      |                      |            | 0 LF           | \$0          |
| <b>Water Treatment Plant</b>   |       | \$27,474,000 | 10%                  |            | 1 LS           | \$2,747,400  |
| Standby Power  |       | \$2,747,400  | 35%                  |            | 1 LS           | \$961,590    |
| Power Connection   |       | \$125        | 10%                  | 6,060      | HP             | \$75,750     |
| <b>Total Capital Cost</b>  |       |              |                      |            |                | \$5,439,277  |
| <b>Engineering, Legal Costs and Contingencies</b>  |       |              |                      |            |                |              |
| Pipeline   |       | 30%          |                      |            | 0 \$           | \$0          |
| Other Facilities   |       | 35%          |                      |            | \$5,439,277 \$ | \$1,903,747  |
| <b>Land Acquisition</b>  |       |              |                      |            |                |              |
| Right of Way Pipeline in rural areas   |       | \$8,000      | 0                    |            | 0 acres        | \$0          |
| Right of Way Pipeline in urban areas   |       | \$10,748     | 0                    |            | 0 acres        | \$0          |
| Pump Station Site acquisition  |       | \$2,000      | 0                    |            | 4 acres        | \$0          |
| Water Treatment Plant Site acquisition   |       | \$2,000      | 0                    |            | 20 acres       | \$0          |
| Property Surveying   |       | 10%          |                      |            | 0 \$           | \$0          |
| <b>Environmental &amp; Archaeology Studies and Mitigation</b>  |       |              |                      |            |                |              |
| Pipeline   |       | \$25,000     | 0                    |            | 0 Mile         | \$0          |
| Other  |       | 100%         | 0                    |            | 0 Land\$       | \$0          |
| <b>Remaining Interest During Construction</b>  |       |              |                      |            |                |              |
| Loan Rate  |       | 6%           |                      |            |                |              |
| Rate of Return on Investments  |       | 4%           |                      |            |                |              |
| Duration of Project ( yr)  |       | 2            |                      |            |                | \$588,000    |
| <b>Total Project Cost</b>  |       |              |                      |            |                | \$7,931,023  |
| <b>Annual Costs</b>  |       |              |                      |            |                |              |
| Debt Service (6%, 30 years)  |       | 6%           |                      |            | 30 yr          | \$576,180    |
| Annual Cost from Phase III   |       |              |                      |            |                | \$7,608,981  |
| Pipeline O&M   |       | 1%           |                      |            | 0 \$           | \$0          |
| Intake and Pump Stations O&M   |       | 2.5%         |                      |            | \$1,654,537 \$ | \$41,363     |
| Water Treatment Plant O&M  |       | \$2,730,000  | 10%                  |            | 1 LS           | \$273,000    |
| Pumping Energy Costs   |       | \$0.06       | 10%                  | 13,481,000 | kW-hr          | \$80,886     |
| Plant Energy Costs   |       | \$0.06       | 10%                  | 39,586,000 | kW-hr          | \$237,516    |
| Purchase of Raw Water  |       | \$45         |                      |            | 2,240 acft     | \$100,784    |
| <b>Total Annual Cost - 2040</b>  |       |              |                      |            |                | \$8,918,711  |
| <b>Available Project Yield (acft/yr)</b>   |       |              |                      | 13,438     | acft/yr        | \$13,438     |
| <b>Annual Cost of Water (\$/acft)</b>  |       |              |                      |            |                | \$664        |
| <b>Annual Cost of Water (\$/1000 gal)</b>  |       |              |                      |            |                | \$2.04       |

| Cost Estimating Worksheet  |       |              |                      |             |                |              |
|--|-------|--------------|----------------------|-------------|----------------|--------------|
| Scenario 1: 14 MGD untreated water will be purchased from BRA and diverted to the proposed water plant |       |              |                      |             |                |              |
| Phase V: 14 MGD (2050)   |       |              |                      |             |                |              |
| Item   | Notes | Unit Cost    | Percentage per phase | Quantity    | Units          | Updated Cost |
| <b>Pump Stations</b>   |       |              |                      |             |                |              |
| Raw water Pump Station   |       | \$10,508,000 | 10%                  |             | 1 LS           | \$1,050,800  |
| Intake Structure   |       | \$1,050,800  | 20%                  |             | 1 LS           | \$210,160    |
| Power Connection   |       | \$125        | 10%                  | 2,064       | HP             | \$25,797     |
| Standby Power  |       | \$1,050,800  | 35%                  |             | 1 LS           | \$367,780    |
| <b>Piping</b>  |       |              |                      |             |                |              |
| Open Cut Trenches  |       |              |                      |             |                |              |
| Pipe @ 20" in rural areas  |       | \$100        |                      |             | 0 LF           | \$0          |
| Pipe @ 20" in urban areas  |       | \$165        |                      |             | 0 LF           | \$0          |
| Trenchless construction  |       |              |                      |             |                |              |
| Pipe @ 20"   |       | \$1,295      |                      |             | 0 LF           | \$0          |
| <b>Water Treatment Plant</b>   |       | \$27,474,000 | 10%                  |             | 1 LS           | \$2,747,400  |
| Standby Power  |       | \$2,747,400  | 35%                  |             | 1 LS           | \$961,590    |
| Power Connection   |       | \$125        | 10%                  | 6,060       | HP             | \$75,750     |
| <b>Total Capital Cost</b>  |       |              |                      |             |                | \$5,439,277  |
| <b>Engineering, Legal Costs and Contingencies</b>  |       |              |                      |             |                |              |
| Pipeline   |       | 30%          |                      |             | \$0 \$         | \$0          |
| Other Facilities   |       | 35%          |                      |             | \$5,439,277 \$ | \$1,903,747  |
| <b>Land Acquisition</b>  |       |              |                      |             |                |              |
| Right of Way Pipeline in rural areas   |       | \$8,000      | 0                    |             | 0 acres        | \$0          |
| Right of Way Pipeline in urban areas   |       | \$10,748     | 0                    |             | 0 acres        | \$0          |
| Pump Station Site acquisition  |       | \$2,000      | 0                    |             | 4 acres        | \$0          |
| Water Treatment Plant Site acquisition   |       | \$2,000      | 0                    |             | 20 acres       | \$0          |
| Property Surveying   |       | 10%          |                      |             | 0 \$           | \$0          |
| <b>Environmental &amp; Archaeology Studies and Mitigation</b>  |       |              |                      |             |                |              |
| Pipeline   |       | \$25,000     | 0                    |             | 0 Mile         | \$0          |
| Other  |       | 100%         | 0                    |             | 0 Land\$       | \$0          |
| <b>Remaining Interest During Construction</b>  |       |              |                      |             |                |              |
| Loan Rate  |       | 6%           |                      |             |                |              |
| Rate of Return on Investments  |       | 4%           |                      |             |                |              |
| Duration of Project ( yr)  |       | 2            |                      |             |                | \$588,000    |
| <b>Total Project Cost</b>  |       |              |                      |             |                | \$7,931,023  |
| <b>Annual Costs</b>  |       |              |                      |             |                |              |
| Debt Service (6%, 30 years)  |       | 6%           |                      |             | 30 yr          | \$576,180    |
| Annual Cost from Phase IV  |       |              |                      |             |                | \$8,342,531  |
| Pipeline O&M   |       | 1%           |                      |             | 0 \$           | \$0          |
| Intake and Pump Stations O&M   |       | 2.5%         |                      | \$1,654,537 | \$             | \$41,363     |
| Water Treatment Plant O&M  |       | \$2,730,000  | 10%                  |             | 1 LS           | \$273,000    |
| Pumping Energy Costs   |       | \$0.06       | 10%                  | 13,481,000  | kW-hr          | \$80,886     |
| Plant Energy Costs   |       | \$0.06       | 10%                  | 39,586,000  | kW-hr          | \$237,516    |
| Purchase of Raw Water  |       | \$45         |                      |             | 2,240 acft     | \$100,784    |
| <b>Total Annual Cost - 2050</b>  |       |              |                      |             |                | \$9,652,260  |
| <b>Available Project Yield (acft/yr)</b>   |       |              |                      | 15,677      | acft/yr        | \$15,677     |
| <b>Annual Cost of Water (\$/acft)</b>  |       |              |                      |             |                | \$616        |
| <b>Annual Cost of Water (\$/1000 gal)</b>  |       |              |                      |             |                | \$1.89       |

Chocolate Bayou Pump Station Pipeline

|                |       |        |       |             |       |       |       |   |
|----------------|-------|--------|-------|-------------|-------|-------|-------|---|
| Pipeline =     | 13340 | Length | 11600 | Fitting Fac | Rural | 11600 | Urban | 0 |
| Number Lines = | 2     |        |       |             |       |       |       |   |
|                |       | mgd    | gpm   | per line    |       |       |       |   |
|                |       | 16     | 5556  |             |       |       |       |   |
|                |       |        | 0     |             |       |       |       |   |
|                |       |        | 0     |             |       |       |       |   |

| Plant Component | Flow |       | Pipe Dia<br>inches | Pipe Area<br>ft <sup>2</sup> | Velocity<br>fps |
|-----------------|------|-------|--------------------|------------------------------|-----------------|
|                 | mgd  | cfs   |                    |                              |                 |
| 14 mgd option   | 8    | 12.38 | 18                 | 1.767                        | 7.00            |
| 14 mgd option   | 8    | 12.38 | 20                 | 2.182                        | 5.67            |
| 14 mgd option   | 8    | 12.38 | 22                 | 2.640                        | 4.69            |

End of Existing Canal WL = 40  
 Proposed Treatment Plant WL = 40  
 Assumed Static (feet) = 0  
 Discharge Pressure = 23  
 Total Static = 23  
 Power Cost = 0  
 0.06  
 Hours = 8760

100 psi =  
230 ft

Hazen and Williams  
C = 110

90 mgd option

| Q    | Pipe   | Length | Fric Loss (ft) | Static | TDH | Brake | Pump Sta    | Total       |
|------|--------|--------|----------------|--------|-----|-------|-------------|-------------|
| gpm  | inches | ft     | C=             | Head   | ft  | HP    | Cost        | Cost        |
| 5556 | 18     | 13340  | 152.75         | 23     | 176 | 616   | \$5,464,000 | \$7,865,200 |
| 5556 | 20     | 13340  | 94.44          | 23     | 114 | 401   | \$3,558,000 | \$6,226,000 |
| 5556 | 22     | 13340  | 57.48          | 23     | 80  | 282   | \$2,503,000 | \$5,838,000 |

| Annual Power | Annual Power |
|--------------|--------------|
| Cost         | KW-HR        |
| \$242,000    | 4,027,000    |
| \$158,000    | 2,622,000    |
| \$111,000    | 1,844,000    |

Cost estimate Mid-Brazoria Regional Water Planning  
Chocolate Bayou, Supply Source Alternative No. 3

2/26/01  
Prepared by JA

| Cost Estimating Worksheet  |       |              |            |               |       |                     |
|--|-------|--------------|------------|---------------|-------|---------------------|
| Scenario 1: 14 MGD untreated water will be purchased from Chocolate Bayou and diverted to the proposed water plant |       |              |            |               |       |                     |
| Phase I: 8 MGD (2010)  |       |              |            |               |       |                     |
| Item   | Notes | Unit Cost    | Percentage | Quantity      | Units | Updated Cost        |
| <b>Pump Stations</b>   |       |              |            |               |       |                     |
| Raw water Pump Station   |       | \$3,558,000  | 60%        | 1             | LS    | \$2,134,800         |
| Intake Structure   |       | \$2,134,800  | 20%        | 1             | LS    | \$426,960           |
| Power Connection   |       | \$125        | 60%        | 401           | HP    | \$30,102            |
| Standby Power  |       | \$2,134,800  | 35%        | 1             | LS    | \$747,180           |
| <b>Piping</b>  |       |              |            |               |       |                     |
| Open Cut Trenches  |       |              |            |               |       |                     |
| Pipe @ 20" in rural areas  |       | \$100        |            | 11,600        | LF    | \$1,160,000         |
| Pipe @ 20" in urban areas  |       | \$165        |            | 0             | LF    | \$0                 |
| Trenchless construction  |       |              |            |               |       |                     |
| Pipe @ 20"   |       | \$1,295      |            | 0             | LF    | \$0                 |
| <b>Water Treatment Plant</b>   |       | \$27,474,000 | 60%        | 1             | LS    | \$16,484,400        |
| Standby Power  | No    | 16,484,400   | 35%        | 1             | LS    | \$5,769,540         |
| Power Connection   |       | \$125        | 60%        | 6,060         | HP    | \$454,500           |
| Purchase Water Rights  |       | \$200        | 100%       | 15,677        | AF    | \$3,135,400         |
| <b>Total Capital Cost</b>  |       |              |            |               |       | <b>\$30,342,882</b> |
| <b>Engineering, Legal Costs and Contingencies</b>  |       |              |            |               |       |                     |
| Pipeline   |       | 30%          |            | 1,160,000     | \$    | \$348,000           |
| Other Facilities   |       | 35%          |            | 26,047,482    | \$    | \$9,116,619         |
| <b>Land Acquisition</b>  |       |              |            |               |       |                     |
| Right of Way Pipeline in rural areas   |       | 8,000        | 100%       | 16 acres      |       | \$127,824           |
| Right of Way Pipeline in urban areas   |       | 10,748       | 100%       | 0 acres       |       | \$0                 |
| Pump Station Site acquisition  |       | 2,000        | 100%       | 4 acres       |       | \$8,000             |
| Water Treatment Plant Site acquisition   |       | 2,000        | 100%       | 20 acres      |       | \$40,000            |
| Property Surveying   |       | 10%          |            | 175,824       | \$    | \$17,582            |
| <b>Environmental &amp; Archaeology Studies and Mitigation</b>  |       |              |            |               |       |                     |
| Pipeline   |       | \$25,000     | 100%       | 2 Mile        |       | \$54,924            |
| Other  |       | 100%         | 100%       | 48,000 Land   | \$    | \$48,000            |
| <b>Remaining Interest During Construction</b>  |       |              |            |               |       |                     |
| Loan Rate  |       | 6.0%         |            |               |       |                     |
| Rate of Return on Investments  |       | 4.0%         |            |               |       |                     |
| Duration of Project ( yr)  |       | 2.0          |            |               |       | \$2,958,000         |
| <b>Total Project Cost</b>  |       |              |            |               |       | <b>\$43,061,831</b> |
| <b>Annual Costs</b>  |       |              |            |               |       |                     |
| Debt Service (6%, 30 years)  |       | 6.0%         |            | 30 yr         |       | \$3,128,395         |
| Pipeline O&M   |       | 1.0%         |            | 1,160,000     | \$    | \$11,600            |
| Intake and Pump Stations O&M   |       | 2.5%         |            | 3,339,042     | \$    | \$83,476            |
| Water Treatment Plant O&M  |       | \$2,730,000  | 60%        | 1             | LS    | \$1,638,000         |
| Pumping Energy Costs   |       | \$0.06       | 60%        | 2,622,000     | kW-hr | \$94,392            |
| Plant Energy Costs   |       | \$0.06       | 60%        | 39,586,000    | kW-hr | \$1,425,096         |
| Existing CBWC Facility Energy Costs  |       | \$0.06       | 60%        | 2,622,000     | kW-hr | \$94,392            |
| <b>Total Annual Cost - 2010</b>  |       |              |            |               |       | <b>\$6,475,351</b>  |
| <b>Available Project Yield (acft/yr)</b>   |       |              |            | 8,959 acft/yr |       | 8,959               |
| <b>Annual Cost of Water (\$/acft)</b>  |       |              |            |               |       | \$723               |
| <b>Annual Cost of Water (\$/1000 gal)</b>  |       |              |            |               |       | \$2.22              |

Cost estimate Mid-Brazoria Regional Water Planning  
 Chocolate Bayou, Supply Source Alternative No. 3

2/26/01  
 Prepared by JA

| Cost Estimating Worksheet  |       |              |                      |            |         |                    |
|--|-------|--------------|----------------------|------------|---------|--------------------|
| Scenario 1: 14 MGD untreated water will be purchased from Chocolate Bayou and diverted to the proposed water plant |       |              |                      |            |         |                    |
| Phase II: 9 MGD (2020)   |       |              |                      |            |         |                    |
| Item   | Notes | Unit Cost    | Percentage per phase | Quantity   | Units   | Updated Cost       |
| <b>Pump Stations</b>   |       |              |                      |            |         |                    |
| Raw water Pump Station   |       | \$3,558,000  | 10%                  | 1          | LS      | \$355,800          |
| Intake Structure   |       | \$355,800    | 20%                  | 1          | LS      | \$71,160           |
| Power Connection   |       | 125          | 10%                  | 401        | HP      | \$5,017            |
| Standby Power  |       | \$355,800    | 35%                  | 1          | LS      | \$124,530          |
| <b>Piping</b>  |       |              |                      |            |         |                    |
| Open Cut Trenches  |       |              |                      |            |         |                    |
| Pipe @ 20" in rural areas  |       | \$100        |                      | 0          | LF      | \$0                |
| Pipe @ 20" in urban areas  |       | \$165        |                      | 0          | LF      | \$0                |
| Trenchless construction  |       |              |                      |            |         |                    |
| Pipe @ 20"   |       | \$1,295      |                      | 0          | LF      | \$0                |
| <b>Water Treatment Plant</b>   |       | \$27,474,000 | 10%                  | 1          | LS      | \$2,747,400        |
| Standby Power  |       | \$2,747,400  | 35%                  | 1          | LS      | \$961,590          |
| Power Connection   |       | 125          | 10%                  | 6,060      | HP      | \$75,750           |
| <b>Total Capital Cost</b>  |       |              |                      |            |         | <b>\$4,341,247</b> |
| <b>Engineering, Legal Costs and Contingencies</b>  |       |              |                      |            |         |                    |
| Pipeline   |       | 30%          |                      | 0          | \$      | \$0                |
| Other Facilities   |       | 35%          |                      | 4,341,247  | \$      | \$1,519,436        |
| <b>Land Acquisition</b>  |       |              |                      |            |         |                    |
| Right of Way Pipeline in rural areas   |       | 8,000        | 0%                   | 0          | acres   | \$0                |
| Right of Way Pipeline in urban areas   |       | 10,748       | 0%                   | 0          | acres   | \$0                |
| Pump Station Site acquisition  |       | 2,000        | 0%                   | 4          | acres   | \$0                |
| Water Treatment Plant Site acquisition   |       | 2,000        | 0%                   | 20         | acres   | \$0                |
| Property Surveying   |       | 10%          |                      | 0          | \$      | \$0                |
| <b>Environmental &amp; Archaeology Studies and Mitigation</b>  |       |              |                      |            |         |                    |
| Pipeline   |       | \$25,000     | 0%                   | 0          | Mile    | \$0                |
| Other  |       | 100%         | 0%                   | 0          | Land\$  | \$0                |
| <b>Remaining Interest During Construction</b>  |       |              |                      |            |         |                    |
| Loan Rate  |       | 6.0%         |                      |            |         |                    |
| Rate of Return on Investments  |       | 4.0%         |                      |            |         |                    |
| Duration of Project ( yr)  |       | 2.0          |                      |            |         | \$469,000          |
| <b>Total Project Cost</b>  |       |              |                      |            |         | <b>\$6,329,683</b> |
| <b>Annual Costs</b>  |       |              |                      |            |         |                    |
| Debt Service (6%, 30 years)  |       | 6.0%         |                      | 30         | yr      | \$459,845          |
| Annual Cost from Phase I   |       |              |                      |            |         | \$6,475,351        |
| Pipeline O&M   |       | 1.0%         |                      | 0          | \$      | \$0                |
| Intake and Pump Stations O&M   |       | 2.5%         |                      | 556,507    | \$      | \$13,913           |
| Water Treatment Plant O&M  |       | 2,730,000    | 10%                  | 1          | LS      | \$273,000          |
| Pumping Energy Costs   |       | \$0.06       | 10%                  | 2,622,000  | kW-hr   | \$15,732           |
| Plant Energy Costs   |       | \$0.06       | 10%                  | 39,586,000 | kW-hr   | \$237,516          |
| Existing CBWC Facility Energy Costs  |       | \$0.06       | 10%                  | 2,622,000  | kW-hr   | \$15,732           |
| <b>Total Annual Cost - 2020</b>  |       |              |                      |            |         | <b>\$7,491,088</b> |
| <b>Available Project Yield (acft/yr)</b>   |       |              |                      | 10,078     | acft/yr | 10,078             |
| <b>Annual Cost of Water (\$/acft)</b>  |       |              |                      |            |         | <b>\$743</b>       |
| <b>Annual Cost of Water (\$/1000 gal)</b>  |       |              |                      |            |         | <b>\$2.28</b>      |



| Cost Estimating Worksheet  |       |              |                      |          |                  |              |
|--|-------|--------------|----------------------|----------|------------------|--------------|
| Scenario 1: 14 MGD untreated water will be purchased from Chocolate Bayou and diverted to the proposed water plant |       |              |                      |          |                  |              |
| Phase IV: 12.6 MGD (2040)  |       |              |                      |          |                  |              |
| Item   | Notes | Unit Cost    | Percentage per phase | Quantity | Units            | Updated Cost |
| <b>Pump Stations</b>   |       |              |                      |          |                  |              |
| Raw water Pump Station   |       | \$3,558,000  | 10%                  |          | 1 LS             | \$355,800    |
| Intake Structure   |       | \$355,800    | 20%                  |          | 1 LS             | \$71,160     |
| Power Connection   |       | \$125        | 10%                  |          | 401 HP           | \$5,017      |
| Standby Power  |       | \$355,800    | 35%                  |          | 1 LS             | \$124,530    |
| <b>Piping</b>  |       |              |                      |          |                  |              |
| Open Cut Trenches  |       |              |                      |          |                  |              |
| Pipe @ 20" in rural areas  |       | \$100        |                      |          | 0 LF             | \$0          |
| Pipe @ 20" in urban areas  |       | \$165        |                      |          | 0 LF             | \$0          |
| Trenchless construction  |       |              |                      |          |                  |              |
| Pipe @ 20"   |       | \$1,295      |                      |          | 0 LF             | \$0          |
| <b>Water Treatment Plant</b>   |       | \$27,474,000 | 10%                  |          | 1 LS             | \$2,747,400  |
| Standby Power  |       | \$2,747,400  | 35%                  |          | 1 LS             | \$961,590    |
| Power Connection   |       | \$125        | 10%                  |          | 6,060 HP         | \$75,750     |
| <b>Total Capital Cost</b>  |       |              |                      |          |                  | \$4,341,247  |
| <b>Engineering, Legal Costs and Contingencies</b>  |       |              |                      |          |                  |              |
| Pipeline   |       | 30%          |                      |          | 0 \$             | \$0          |
| Other Facilities   |       | 35%          |                      |          | \$4,341,247 \$   | \$1,519,436  |
| <b>Land Acquisition</b>  |       |              |                      |          |                  |              |
| Right of Way Pipeline in rural areas   |       | \$8,000      | 0                    |          | 0 acres          | \$0          |
| Right of Way Pipeline in urban areas   |       | \$10,748     | 0                    |          | 0 acres          | \$0          |
| Pump Station Site acquisition  |       | \$2,000      | 0                    |          | 4 acres          | \$0          |
| Water Treatment Plant Site acquisition   |       | \$2,000      | 0                    |          | 20 acres         | \$0          |
| Property Surveying   |       | 10%          |                      |          | 0 \$             | \$0          |
| <b>Environmental &amp; Archaeology Studies and Mitigation</b>  |       |              |                      |          |                  |              |
| Pipeline   |       | \$25,000     | 0                    |          | 0 Mile           | \$0          |
| Other  |       | 100%         | 0                    |          | 0 Land\$         | \$0          |
| <b>Remaining Interest During Construction</b>  |       |              |                      |          |                  |              |
| Loan Rate  |       | 6%           |                      |          |                  |              |
| Rate of Return on Investments  |       | 4%           |                      |          |                  |              |
| Duration of Project ( yr)  |       | 2            |                      |          |                  | \$469,000    |
| <b>Total Project Cost</b>  |       |              |                      |          |                  | \$6,329,683  |
| <b>Annual Costs</b>  |       |              |                      |          |                  |              |
| Debt Service (6%, 30 years)  |       | 6%           |                      |          | 30 yr            | \$459,845    |
| Annual Cost from Phase III   |       |              |                      |          |                  | \$5,508,376  |
| Pipeline O&M   |       | 1%           |                      |          | 0 \$             | \$0          |
| Intake and Pump Stations O&M   |       | 2.5%         |                      |          | \$556,507 \$     | \$13,913     |
| Water Treatment Plant O&M  |       | \$2,730,000  | 10%                  |          | 1 LS             | \$273,000    |
| Pumping Energy Costs   |       | \$0.06       | 10%                  |          | 2,622,000 kW-hr  | \$15,732     |
| Plant Energy Costs   |       | \$0.06       | 10%                  |          | 39,586,000 kW-hr | \$237,516    |
| Existing CBWC Facility Energy Costs  |       | \$0.06       | 10%                  |          | 2,622,000 kW-hr  | \$15,732     |
| <b>Total Annual Cost - 2040</b>  |       |              |                      |          |                  | \$6,524,113  |
| <b>Available Project Yield (acft/yr)</b>   |       |              |                      |          | 13,438 acft/yr   | \$13,438     |
| <b>Annual Cost of Water (\$/acft)</b>  |       |              |                      |          |                  | \$486        |
| <b>Annual Cost of Water (\$/1000 gal)</b>  |       |              |                      |          |                  | \$1.49       |

Cost estimate Mid-Brazoria Regional Water Planning  
Chocolate Bayou, Supply Source Alternative No. 3

2/26/01  
Prepared by JA

| Cost Estimating Worksheet  |       |              |                      |            |         |                    |
|--|-------|--------------|----------------------|------------|---------|--------------------|
| Scenario 1: 14 MGD untreated water will be purchased from Chocolate Bayou and diverted to the proposed water plant |       |              |                      |            |         |                    |
| Phase III: 10 MGD (2030)   |       |              |                      |            |         |                    |
| Item   | Notes | Unit Cost    | Percentage per phase | Quantity   | Units   | Updated Cost       |
| <b>Pump Stations</b>   |       |              |                      |            |         |                    |
| Raw water Pump Station   |       | \$3,558,000  | 10%                  | 1          | LS      | \$355,800          |
| Intake Structure   |       | \$355,800    | 20%                  | 1          | LS      | \$71,160           |
| Power Connection   |       | 125          | 10%                  | 401        | HP      | \$5,017            |
| Standby Power  |       | \$355,800    | 35%                  | 1          | LS      | \$124,530          |
| <b>Piping</b>  |       |              |                      |            |         |                    |
| Open Cut Trenches  |       |              |                      |            |         |                    |
| Pipe @ 20" in rural areas  |       | \$100        |                      | 11,600     | LF      | \$1,160,000        |
| Pipe @ 20" in urban areas  |       | \$165        |                      | 0          | LF      | \$0                |
| Trenchless construction  |       |              |                      |            |         |                    |
| Pipe @ 20"   |       | \$1,295      |                      | 0          | LF      | \$0                |
| <b>Water Treatment Plant</b>   |       |              |                      |            |         |                    |
| Water Treatment Plant  |       | \$27,474,000 | 10%                  | 1          | LS      | \$2,747,400        |
| Standby Power  |       | \$2,747,400  | 35%                  | 1          | LS      | \$961,590          |
| Power Connection   |       | \$125        | 10%                  | 6,060      | HP      | \$75,750           |
| <b>Total Capital Cost</b>  |       |              |                      |            |         | <b>\$5,501,247</b> |
| <b>Engineering, Legal Costs and Contingencies</b>  |       |              |                      |            |         |                    |
| Pipeline   |       | 30%          |                      | 1,160,000  | \$      | \$348,000          |
| Other Facilities   |       | 35%          |                      | 4,341,247  | \$      | \$1,519,436        |
| <b>Land Acquisition</b>  |       |              |                      |            |         |                    |
| Right of Way Pipeline in rural areas   |       | 8,000        | 0%                   | 16         | acres   | \$0                |
| Right of Way Pipeline in urban areas   |       | 10,748       | 0%                   | 0          | acres   | \$0                |
| Pump Station Site acquisition  |       | 2,000        | 0%                   | 4          | acres   | \$0                |
| Water Treatment Plant Site acquisition   |       | 2,000        | 0%                   | 20         | acres   | \$0                |
| Property Surveying   |       | 10%          |                      | 0          | \$      | \$0                |
| <b>Environmental &amp; Archaeology Studies and Mitigation</b>  |       |              |                      |            |         |                    |
| Pipeline   |       | \$25,000     | 0%                   | 0          | Mile    | \$0                |
| Other  |       | 100%         | 0%                   | 0          | Land\$  | \$0                |
| <b>Remaining Interest During Construction</b>  |       |              |                      |            |         |                    |
| Loan Rate  |       | 6.0%         |                      |            |         |                    |
| Rate of Return on Investments  |       | 4.0%         |                      |            |         |                    |
| Duration of Project ( yr)  |       | 2.0          |                      |            |         | \$590,000          |
| <b>Total Project Cost</b>  |       |              |                      |            |         | <b>\$7,958,683</b> |
| <b>Annual Costs</b>  |       |              |                      |            |         |                    |
| Debt Service (6%, 30 years)  |       | 6.0%         |                      | 30         | yr      | \$578,190          |
| Annual Cost from Phase II  |       |              |                      |            |         | \$7,491,088        |
| Pipeline O&M   |       | 1.0%         |                      | 1,160,000  | \$      | \$11,600           |
| Intake and Pump Stations O&M   |       | 2.5%         |                      | 556,507    | \$      | \$13,913           |
| Water Treatment Plant O&M  |       | 2,730,000    | 10%                  | 1          | LS      | \$273,000          |
| Pumping Energy Costs   |       | \$0.06       | 10%                  | 2,622,000  | kW-hr   | \$15,732           |
| Plant Energy Costs   |       | \$0.06       | 10%                  | 39,586,000 | kW-hr   | \$237,516          |
| Existing CBWC Facility Energy Costs  |       | \$0.06       | 10%                  | 2,622,000  | kW-hr   | \$15,732           |
| <b>Total Annual Cost - 2030</b>  |       |              |                      |            |         | <b>\$8,636,771</b> |
| <b>Available Project Yield (acft/yr)</b>   |       |              |                      | 11,198     | acft/yr | 11,198             |
| <b>Annual Cost of Water (\$/acft)</b>  |       |              |                      |            |         | \$771              |
| <b>Annual Cost of Water (\$/1000 gal)</b>  |       |              |                      |            |         | \$2.37             |

Cost estimate Mid-Brazoria Regional Water Planning  
 Chocolate Bayou, Supply Source Alternative No. 3

2/26/01  
 Prepared by JA

| Cost Estimating Worksheet  |       |              |                      |             |         |              |
|--|-------|--------------|----------------------|-------------|---------|--------------|
| Scenario 1: 14 MGD untreated water will be purchased from Chocolate Bayou and diverted to the proposed water plant |       |              |                      |             |         |              |
| Phase V: 14 MGD (2050)   |       |              |                      |             |         |              |
| Item   | Notes | Unit Cost    | Percentage per phase | Quantity    | Units   | Updated Cost |
| <b>Pump Stations</b>   |       |              |                      |             |         |              |
| Raw water Pump Station   |       | \$3,558,000  | 10%                  | 1           | LS      | \$355,800    |
| Intake Structure   |       | \$355,800    | 20%                  | 1           | LS      | \$71,160     |
| Power Connection   |       | \$125        | 10%                  | 401         | HP      | \$5,017      |
| Standby Power  |       | \$355,800    | 35%                  | 1           | LS      | \$124,530    |
| <b>Piping</b>  |       |              |                      |             |         |              |
| Open Cut Trenches  |       |              |                      |             |         |              |
| Pipe @ 20" in rural areas  |       | \$100        |                      | 0           | LF      | \$0          |
| Pipe @ 20" in urban areas  |       | \$165        |                      | 0           | LF      | \$0          |
| Trenchless construction  |       |              |                      |             |         |              |
| Pipe @ 20"   |       | \$1,295      |                      | 0           | LF      | \$0          |
| <b>Water Treatment Plant</b>   |       | \$27,474,000 | 10%                  | 1           | LS      | \$2,747,400  |
| Standby Power  |       | \$2,747,400  | 35%                  | 1           | LS      | \$961,590    |
| Power Connection   |       | \$125        | 10%                  | 6,060       | HP      | \$75,750     |
| <b>Total Capital Cost</b>  |       |              |                      |             |         | \$4,341,247  |
| <b>Engineering, Legal Costs and Contingencies</b>  |       |              |                      |             |         |              |
| Pipeline   |       | 30%          |                      | \$0         | \$      | \$0          |
| Other Facilities   |       | 35%          |                      | \$4,341,247 | \$      | \$1,519,436  |
| <b>Land Acquisition</b>  |       |              |                      |             |         |              |
| Right of Way Pipeline in rural areas   |       | \$8,000      | 0                    | 0           | acres   | \$0          |
| Right of Way Pipeline in urban areas   |       | \$10,748     | 0                    | 0           | acres   | \$0          |
| Pump Station Site acquisition  |       | \$2,000      | 0                    | 4           | acres   | \$0          |
| Water Treatment Plant Site acquisition   |       | \$2,000      | 0                    | 20          | acres   | \$0          |
| Property Surveying   |       | 10%          |                      | 0           | \$      | \$0          |
| <b>Environmental &amp; Archaeology Studies and Mitigation</b>  |       |              |                      |             |         |              |
| Pipeline   |       | \$25,000     | 0                    | 0           | Mile    | \$0          |
| Other  |       | 100%         | 0                    | 0           | Land\$  | \$0          |
| <b>Remaining Interest During Construction</b>  |       |              |                      |             |         |              |
| Loan Rate  |       | 6%           |                      |             |         |              |
| Rate of Return on Investments  |       | 4%           |                      |             |         |              |
| Duration of Project ( yr)  |       | 2            |                      |             |         | \$469,000    |
| <b>Total Project Cost</b>  |       |              |                      |             |         | \$6,329,683  |
| <b>Annual Costs</b>  |       |              |                      |             |         |              |
| Debt Service (6%, 30 years)  |       | 6%           |                      | 30          | yr      | \$459,845    |
| Annual Cost from Phase IV  |       |              |                      |             |         | \$6,064,268  |
| Pipeline O&M   |       | 1%           |                      | 0           | \$      | \$0          |
| Intake and Pump Stations O&M   |       | 2.5%         |                      | \$556,507   | \$      | \$13,913     |
| Water Treatment Plant O&M  |       | \$2,730,000  | 10%                  | 1           | LS      | \$273,000    |
| Pumping Energy Costs   |       | \$0.06       | 10%                  | 2,622,000   | kW-hr   | \$15,732     |
| Plant Energy Costs   |       | \$0.06       | 10%                  | 39,586,000  | kW-hr   | \$237,516    |
| Existing CBWC Facility Energy Costs  |       | \$0.06       | 10%                  | 2,622,000   | kW-hr   | \$15,732     |
| <b>Total Annual Cost - 2050</b>  |       |              |                      |             |         | \$7,080,006  |
| <b>Available Project Yield (acft/yr)</b>   |       |              |                      | 15,677      | acft/yr | \$15,677     |
| <b>Annual Cost of Water (\$/acft)</b>  |       |              |                      |             |         | \$452        |
| <b>Annual Cost of Water (\$/1000 gal)</b>  |       |              |                      |             |         | \$1.39       |

**Appendix B**

**Cost Estimating Procedures TWDB Region H**

## COST ESTIMATING PROCEDURES TWDB REGION H

The cost estimates of this study are expressed as one of three main categories that were dictated by TWDB guidelines: capital costs, other project costs, and annual project costs. Capital costs consist of all material, labor, and equipment expenses that are expended in the construction activities of a project. Other project costs include expenses that are not directly associated with the construction activities, such as engineering, land and easement acquisition, environmental studies, mitigation, and construction interest. Annual project costs consist of all costs that are incurred by the project upon implementation, either in repayment of borrowed funds or operating and maintaining the facility. Table 1 illustrates the primary components of the preliminary cost estimate. Cost estimating methods for the technical evaluation of alternatives considered for use in Texas TWDB Region H are explained in the following sections.

**TABLE 1 MAJOR ESTIMATING CATEGORIES**

|  |                      |  |   |                            |  |
|--|----------------------|--|---|----------------------------|--|
| <b>PROJECT COSTS</b>   |                      |  |   |                            |  |
| <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="padding: 5px;"><b>CAPITAL COSTS</b></td> </tr> <tr> <td style="padding: 5px;"> <ol style="list-style-type: none"> <li>1. Pump Stations</li> <li>2. Pipelines</li> <li>3. Water Treatment Plants</li> <li>4. Water Storage Tanks</li> <li>5. Off-Channel Reservoirs</li> <li>6. Well Fields                             <ul style="list-style-type: none"> <li>- Injection</li> <li>- Recovery</li> <li>- ASR Wells</li> </ul> </li> <li>7. Dams &amp; Reservoirs</li> <li>8. Relocations</li> <li>9. Water Distribution System Improvements</li> <li>10. Other Items</li> </ol> </td> </tr> </table>  | <b>CAPITAL COSTS</b> | <ol style="list-style-type: none"> <li>1. Pump Stations</li> <li>2. Pipelines</li> <li>3. Water Treatment Plants</li> <li>4. Water Storage Tanks</li> <li>5. Off-Channel Reservoirs</li> <li>6. Well Fields                             <ul style="list-style-type: none"> <li>- Injection</li> <li>- Recovery</li> <li>- ASR Wells</li> </ul> </li> <li>7. Dams &amp; Reservoirs</li> <li>8. Relocations</li> <li>9. Water Distribution System Improvements</li> <li>10. Other Items</li> </ol> | <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="padding: 5px;"><b>OTHER PROJECT COSTS</b></td> </tr> <tr> <td style="padding: 5px;"> <ol style="list-style-type: none"> <li>1. Engineering, Financial &amp; Legal Services, and Contingencies                             <ul style="list-style-type: none"> <li>- Includes Design, Bidding &amp; Construction Phase Services, Geotechnical, and Surveying</li> </ul> </li> <li>2. Land and Easements                             <ul style="list-style-type: none"> <li>- Land Purchases</li> <li>- Temporary Easements</li> <li>- Permanent Easements</li> <li>- Includes Legal Services, Sales Commisions, &amp; Surveying</li> </ul> </li> <li>3. Environmental - Studies and Mitigation                             <ul style="list-style-type: none"> <li>- Environmental &amp; Archaeology Studies</li> <li>- Permitting</li> <li>- Mitigation</li> </ul> </li> <li>4. Interest During Construction</li> </ol> </td> </tr> </table> | <b>OTHER PROJECT COSTS</b> | <ol style="list-style-type: none"> <li>1. Engineering, Financial &amp; Legal Services, and Contingencies                             <ul style="list-style-type: none"> <li>- Includes Design, Bidding &amp; Construction Phase Services, Geotechnical, and Surveying</li> </ul> </li> <li>2. Land and Easements                             <ul style="list-style-type: none"> <li>- Land Purchases</li> <li>- Temporary Easements</li> <li>- Permanent Easements</li> <li>- Includes Legal Services, Sales Commisions, &amp; Surveying</li> </ul> </li> <li>3. Environmental - Studies and Mitigation                             <ul style="list-style-type: none"> <li>- Environmental &amp; Archaeology Studies</li> <li>- Permitting</li> <li>- Mitigation</li> </ul> </li> <li>4. Interest During Construction</li> </ol> |
| <b>CAPITAL COSTS</b>   |                      |  |   |                            |  |
| <ol style="list-style-type: none"> <li>1. Pump Stations</li> <li>2. Pipelines</li> <li>3. Water Treatment Plants</li> <li>4. Water Storage Tanks</li> <li>5. Off-Channel Reservoirs</li> <li>6. Well Fields                             <ul style="list-style-type: none"> <li>- Injection</li> <li>- Recovery</li> <li>- ASR Wells</li> </ul> </li> <li>7. Dams &amp; Reservoirs</li> <li>8. Relocations</li> <li>9. Water Distribution System Improvements</li> <li>10. Other Items</li> </ol>   |                      |  |   |                            |  |
| <b>OTHER PROJECT COSTS</b>   |                      |  |   |                            |  |
| <ol style="list-style-type: none"> <li>1. Engineering, Financial &amp; Legal Services, and Contingencies                             <ul style="list-style-type: none"> <li>- Includes Design, Bidding &amp; Construction Phase Services, Geotechnical, and Surveying</li> </ul> </li> <li>2. Land and Easements                             <ul style="list-style-type: none"> <li>- Land Purchases</li> <li>- Temporary Easements</li> <li>- Permanent Easements</li> <li>- Includes Legal Services, Sales Commisions, &amp; Surveying</li> </ul> </li> <li>3. Environmental - Studies and Mitigation                             <ul style="list-style-type: none"> <li>- Environmental &amp; Archaeology Studies</li> <li>- Permitting</li> <li>- Mitigation</li> </ul> </li> <li>4. Interest During Construction</li> </ol> |                      |  |   |                            |  |

|  |
|--|
| <b>ANNUAL COSTS</b>  |
| <ol style="list-style-type: none"> <li>1. Debt Service</li> <li>2. Operation &amp; Maintenance (O&amp;M)</li> <li>3. Pumping Energy Costs</li> <li>4. Purchase of Water (if applicable)</li> </ol> |

## 1 CAPITAL COSTS

Capital costs, generally known as construction costs, have been compiled from a variety of reliable sources and analyzed for trends that can be used for estimating purposes. Once a trend has been identified, a set of representative values is entered into a cost table, from which the user can easily and efficiently locate a cost estimate. Each cost table is explained in the detail in the following sections. All data was adjusted to the Second Quarter of 1999 by using the Engineering News Record's Construction Cost Index (ENR CCI) ratio. The ENR CCI value for the Second Quarter of 1999 is 6018, determined by averaging the index values of April, May, and June of 1999 (6008, 6006, and 6039, respectively). For example, to update a representative cost from January of 1997 (ENR CCI value 5765), the cost from January of 1997 would be multiplied by the ratio of 6018 over 5765. The ENR CCI values are based on representative (steel, cement, and lumber) material and labor construction costs, averaged across 20 cities. The index measures the amount of money it would cost to purchase a theoretical quantity of services and goods in one year, as opposed to another. Monthly index values are reported from 1977 to the present and annual average values are reported back to 1908.

### 1.1 Pump Stations

The cost of a pump station depends upon a wide variety of conditions, including pump discharge, pumping head, pump type, site conditions, desired usage, and structural design. In constructing a preliminary estimate of the cost of a pump station, the intent is not to determine the pump type or details of the station structural design, but rather to estimate the cost of a general station capable of pumping the desired discharge at the necessary head conditions. Regional pump station project cost estimates and construction records were used to adjust published EPA historical pump station cost data. By using a comprehensive and reliable source of pump station cost data, recognizing the trend, and then adjusting that trend to similar projects in the region, a representative set of values for this region was determined. The cost table for this section, shown in Table 2, displays the costs for pump stations at a variety of horsepower requirements, based on peak discharge and design head. Higher horsepower requirements may require multiple pump stations.

Pump stations are generally classified as transmission or intake type structures, depending on the source of the water coming into the station. Intake stations normally pump water from a raw water source, such as a river or reservoir, and therefore require an intake structure to insure that proper flow conditions into the station are permitted. Transmission stations normally act as boosters in a plant or pipeline and do not require intake structures since the inlet pipe flow conditions are fairly constant. The total cost for the intake of a pump station has been estimated as an additional 20 percent of the pump station construction cost. While 10 percent is structural additions, the other 10 percent is trash rack screens and miscellaneous rack cleaning equipment.

**TABLE 2 PUMP STATION COSTS**

| Pump Station Horsepower<br>(HP)  | Pump Station Construction Cost<br>(\$) |
|--|--|
| 0  | 0                                      |
| 700  | 6,205,000                              |
| 1000   | 7,632,000                              |
| 2000   | 10,404,000                             |
| 3000   | 12,026,000                             |
| 4000   | 13,177,000                             |
| 5000   | 14,069,000                             |
| 6000   | 14,799,000                             |
| 7000   | 15,415,000                             |
| 8000   | 15,949,000                             |
| 9000   | 16,420,000                             |
| 10000  | 16,842,000                             |
| 12000  | 17,571,000                             |
| 15000  | 18,464,000                             |
| 20000  | 19,614,000                             |
| <sup>1</sup> Values as of Second Quarter 1999.<br><sup>2</sup> Add 20 percent for pumps stations with intake structures.<br><sup>3</sup> Add 35 percent for pumps stations with standby power. |  |

All electrical costs, with the exception of standby power, are included in the base pump station construction cost. Standby power, normally either a diesel generator or a dual power feed, is necessary to insure that the pump station can remain operational in the event of a power failure. Standby power is an optional feature which has been estimated as an additional 35 percent of the base pump station construction cost.

The costs of pump stations located in water treatment plants are accounted for in the water treatment plant cost table.

## 1.2 Pipelines

Pipeline capital costs are dependent upon a variety of factors, including pipe material used, trenching slopes and depths, fill material quality, frequency of valves/fittings, number of obstruction crossings, necessity of pavement removal and replacement, utility interference, traffic control, geologic conditions, and degree of urbanization. Due to the lack of significant quantities of rock in the primarily sandy clay soil of the region, only one soil type was analyzed. Table 3 shows the unit costs for pipe diameters from 12-inches to 144-inches, based on level of urban development.

**TABLE 3 PIPELINE UNIT COSTS**

| Pipe Diameter<br>(inches) | Rural Construction<br>(\$ / LF) | Urban Construction<br>(\$ / LF) |
|---------------------------|---------------------------------|---------------------------------|
| 12                        | 55                              | 90                              |
| 14                        | 65                              | 110                             |
| 16                        | 75                              | 130                             |
| 18                        | 90                              | 145                             |
| 20                        | 100                             | 165                             |
| 24                        | 125                             | 210                             |
| 27                        | 145                             | 240                             |
| 30                        | 170                             | 280                             |
| 33                        | 185                             | 305                             |
| 36                        | 205                             | 340                             |
| 42                        | 245                             | 405                             |
| 48                        | 285                             | 475                             |
| 54                        | 335                             | 555                             |
| 60                        | 380                             | 635                             |
| 64                        | 410                             | 685                             |
| 66                        | 430                             | 710                             |
| 72                        | 485                             | 805                             |
| 78                        | 525                             | 870                             |
| 84                        | 575                             | 955                             |
| 90                        | 625                             | 1,040                           |
| 96                        | 675                             | 1,125                           |
| 102                       | 725                             | 1,210                           |
| 108                       | 780                             | 1,295                           |
| 114                       | 830                             | 1,385                           |
| 120                       | 885                             | 1,475                           |
| 144                       | 1,105                           | 1,840                           |

<sup>1</sup> Values as of Second Quarter 1999.



The unit costs are based on open cut construction methods, with the exception of special crossings. Special crossings at railroads, streets, and rivers will likely be accomplished by horizontal boring, also known as pipe jacking. Horizontal boring costs are shown in Table 4.

**TABLE 4 PIPELINE CROSSING UNIT COSTS**

| Pipe Diameter<br>(inches)                                | Total Cost<br>(\$ / LF) |
|--|-------------------------|
| 4  | 560                     |
| 6  | 565                     |
| 8  | 580                     |
| 10   | 610                     |
| 12   | 600                     |
| 16   | 680                     |
| 18   | 745                     |
| 20   | 730                     |
| 24   | 845                     |
| 30   | 940                     |
| 36   | 1045                    |
| 42   | 1170                    |
| 48   | 1295                    |
| 54   | 1430                    |
| 60   | 1565                    |
| 66   | 1650                    |
| 72   | 1730                    |
| 78   | 1795                    |
| 84   | 1850                    |
| <sup>1</sup> Values as of Second Quarter 1999.           |                         |
| <sup>2</sup> Costs based on Horizontal Boring (Jacking). |                         |

### 1.3 Water Treatment Plants

Water treatment plant capital costs are shown in Table 5 for three alternative treatment methods. One process is used almost exclusively on groundwater sources. The other two processes use filtration, mostly for surface water sources, and the quality of the source water normally dictates which one is used.

Groundwater is commonly treated by chlorination only, because the process is relatively inexpensive compared to filtration and the treatment equipment is small enough that each groundwater well can normally have its own. The most common of the surface water treatment methods is conventional filtration treatment. When influent suspended solids concentrations are sufficiently low that they are completely removed by filtration and result in a reasonable backwash cycle on the filtration units, direct filtration can be used. The direct filtration plant is essentially the same as the conventional filtration plant,

except the sedimentation process is deleted. Wastewater effluent is sometimes reclaimed for aquifer injection or non-potable use, but this process is discussed later in Section 1.11.

**TABLE 5 WATER TREATMENT PLANT COSTS**

| Plant Capacity (MGD)                | Groundwater Chlorination | Direct Filtration | Conventional Filtration |
|-------------------------------------|--------------------------|-------------------|-------------------------|
|                                     | Plant Cost (\$)          | Plant Cost (\$)   | Plant Cost (\$)         |
| 1                                   | 385,000                  | 2,862,000         | 3,578,000               |
| 10                                  | 2,246,000                | 16,682,000        | 20,852,000              |
| 50                                  | 7,000,000                | 52,000,000        | 65,000,000              |
| 75                                  | 10,500,000               | 78,000,000        | 97,500,000              |
| 100                                 | 14,000,000               | 104,000,000       | 130,000,000             |
| 150                                 | 21,000,000               | 156,000,000       | 195,000,000             |
| 200                                 | 28,000,000               | 208,000,000       | 260,000,000             |
| † Values as of Second Quarter 1999. |                          |                   |                         |

As can be seen in Table 6, the choice of treatment methods is dictated by both the quality of the influent water source and the intended destination of the treated water. Surface waters treated by direct filtration and wastewater reclamation are not intended for conveyance to a public water distribution system. The reason for this is that surface water and wastewater effluent normally has a high suspended solids content and the treatment processes cannot remove enough of the suspended solids to produce a water quality necessary for public water supplies.

**TABLE 6 WATER TREATMENT METHOD DESCRIPTIONS**

| Water Treatment Method    | Source      |               |            | Destination                |                                  |
|---------------------------|-------------|---------------|------------|----------------------------|----------------------------------|
|                           | Groundwater | Surface Water | Wastewater | Aquifer or Non-Potable Use | Public Water System Distribution |
| Groundwater Chlorination  | ●           |               |            | ●                          | ●                                |
| Direct Filtration         | ●           |               |            | ●                          | ●                                |
| Direct Filtration         |             | ●             |            | ●                          |                                  |
| Conventional (Filtration) |             | ●             |            | ●                          | ●                                |
| Wastewater Reclamation    |             |               | ●          | ●                          |                                  |

#### 1.4 Storage Tanks

Storage tanks are used in a variety of different water supply systems, including pump stations, distribution systems, and pipelines. Several factors influence the cost of storage tanks, including frequency of use, capacity, type of construction materials, location, architectural treatment, and corrosion resistance. Steel tanks are normally constructed in elevated or ground-level locations, while prestressed concrete tanks are normally constructed at or below grade. Concrete does not require cathodic protection or any type of protective exterior coating. Below grade tanks require no architectural treatment, but have higher excavation and backfill costs. The costs of storage tanks are shown in Table 7 are based on ground-level prestressed concrete construction for a range of capacities.

**WATER STORAGE TANK COSTS**

| Storage Capacity<br>(MG)  | Cost<br>(\$) |
|---|--------------|
| 0.01  | 161,998      |
| 0.05  | 192,277      |
| 0.10  | 250,864      |
| 0.5   | 494,717      |
| 1.0   | 741,476      |
| 2.0   | 1,105,507    |
| 4.0   | 1,662,686    |
| 6.0   | 2,226,462    |
| 7.5   | 2,691,516    |
| 9.0   | 3,065,107    |
| 10.0  | 3,302,218    |
| 15.0  | 4,709,555    |
| <sup>1</sup> Values as of Second Quarter 1999.<br><sup>2</sup> Costs based on ground level prestressed concrete construction. |              |

**1.5 Off-Channel Reservoirs**

An off-channel reservoir is a reservoir that receives minimal or no natural inflow. Two methods are normally employed in the construction of off-channel reservoirs. A dam can be constructed along a minor tributary or a ring dike can be constructed. Since little or no natural inflow reaches the reservoir, water is normally supplied by pumping from a nearby river or other location. The cost of the off-channel reservoir is highly dependent on the height of the levees that are constructed and the area of land that is available for use. Land costs will be considerably higher for a shorter ring dike with a much larger circumference that can still hold the same capacity as a taller ring dike with a smaller circumference. Table 8 shows the cost of off-channel reservoirs for a range of capacities.

OFF-CHANNEL RESERVOIR COSTS

| Storage Volume<br>(ac-ft) | Ring Dike Cost<br>(\$) |
|---------------------------|------------------------|
| 500                       | 965,000                |
| 1,000                     | 1,393,000              |
| 2,500                     | 2,313,000              |
| 5,000                     | 4,590,000              |
| 7,500                     | 5,733,000              |
| 10,000                    | 6,733,000              |
| 12,500                    | 7,642,000              |
| 15,000                    | 10,788,000             |
| 17,500                    | 11,732,000             |
| 20,000                    | 15,728,000             |
| 22,000                    | 16,542,000             |
| 25,000                    | 17,705,000             |

<sup>1</sup> Values as of Second Quarter 1999.  
<sup>2</sup> Values are based on ring dike construction.  
<sup>3</sup> Values also used for cost of dams on minor tributaries.

1.6 Well Fields

The costs for public water supply wells are shown in Table 9, as estimated by LBG-Guyton Associates, Inc. The costs include well completion, pumps, and all other necessary facilities. Irrigation wells costs are assumed to amount to 55 percent of public water supply well costs for wells of equivalent depth and capacity.

**PUBLIC SUPPLY WELL COSTS**

| Well Depth<br>(feet)   | Well Capacity (gpm) |            |            |            |            |
|--|---------------------|------------|------------|------------|------------|
|  | 200                 | 400        | 700        | 1,000      | 1,500      |
| <b>Static Water Level Less Than 200 Feet Below Land Surface</b>  |                     |            |            |            |            |
| 300  | \$ 150,000          | \$ 229,200 | \$ 250,800 | -          | -          |
| 500  | \$ 180,000          | \$ 260,400 | \$ 285,600 | \$ 404,400 | -          |
| 700  | \$ 235,000          | \$ 282,000 | \$ 308,400 | \$ 430,800 | \$ 459,600 |
| 1,000  | \$ 270,000          | \$ 328,800 | \$ 355,200 | \$ 469,200 | \$ 498,000 |
| 1,500  | \$ 310,000          | \$ 340,200 | \$ 405,600 | \$ 520,200 | \$ 564,000 |
| <b>Static Water Levels Between 200 and 300 Feet Below Land Surface</b>   |                     |            |            |            |            |
| 500  | \$ 160,000          | \$ 221,000 | -          | -          | -          |
| 700  | \$ 190,000          | \$ 224,400 | \$ 315,800 | \$ 440,200 | \$ 470,600 |
| 1,000  | \$ 240,000          | \$ 335,400 | \$ 365,600 | \$ 485,500 | \$ 530,100 |
| 1,500  | \$ 320,000          | \$ 350,900 | \$ 415,600 | \$ 530,900 | \$ 600,500 |
| <b>Static Water Levels Between 300 and 400 Feet Below Land Surface</b>   |                     |            |            |            |            |
| 500  | \$ 170,000          | -          | -          | -          | -          |
| 700  | \$ 210,000          | \$ 238,000 | \$ 350,000 | \$ 470,000 | \$ 500,000 |
| 1,000  | \$ 260,000          | \$ 414,400 | \$ 367,200 | \$ 510,000 | \$ 550,000 |
| 1,500  | \$ 330,000          | \$ 415,000 | \$ 564,000 | \$ 690,000 | \$ 750,000 |
| <b>Static Water Levels Between 400 and 500 Feet Below Land Surface</b>   |                     |            |            |            |            |
| 1,000  | \$ 283,000          | \$ 400,800 | \$ 485,800 | \$ 596,400 | -          |
| 1,500  | \$ 328,000          | \$ 434,400 | \$ 576,000 | \$ 767,000 | -          |
| <sup>1</sup> Values as of Second Quarter 1999.<br><sup>2</sup> Costs based on underreamed, gravel-packed wells, with steel casing and stainless steel screens.<br><sup>3</sup> Costs as estimated by LBG-Guyton Associates.<br><sup>4</sup> Irrigation well costs assumed to be 55% of above public water supply well cost values. |                     |            |            |            |            |

### 1.7 Dams and Reservoirs

Dam and reservoir construction costs were estimated on an individual case basis due to the unique nature of each project. Most dams and reservoirs that are currently under consideration have been studied in detail in the past and the previous cost estimates normally include both construction cost and other project costs. In most cases, the cost estimates from these previous studies were used, after adjusting the costs with the ENR CCI to the Second Quarter of 1999.

### 1.8 Relocations

In some cases, projects required the use of lands that contain existing facilities or improvements. While relocation of existing utilities, roads, homes, businesses, and other facilities is oftentimes an option, outright purchase cost of the land must be allowed for in

cases where it is not deemed acceptable to relocate. Relocation cost estimates are addressed on an individual project basis due to the variation in the cost of the land and facilities which require relocation.

### **1.9 Water Distribution System Improvements**

A water distribution system is used to distribute water throughout the service area by means of pump stations, piping, valves, storage tanks, and a variety of other equipment and facilities. When a city or entity requires additional water, improvements to the water distribution system are normally necessary. The cost of the water distribution system improvements varies considerably, based on the extent of the existing and proposed facilities and the wide variety of facilities that make up a water distribution system. Costs are estimated on an individual basis using previous proposed water distribution facility studies and cost estimates.

### **1.10 Stilling Basins**

Stilling basins are normally used in water distribution systems to decrease the water flow velocity and allow sediment to settle out prior to discharging into a canal, reservoir, or other body of water. Stilling basin costs are estimated based on a target detention time of two hours and includes all excavation and hauling costs necessary to construct the basin. Optional mechanical sedimentation basin dredging equipment is not included. Stilling basin construction costs, when applicable, are estimated as \$2,800 per cfs of discharge.

### **1.11 Wastewater Reclamation Plants**

Wastewater effluent can be treated by a variety of methods for aquifer or other non-potable uses. The reverse osmosis membrane treatment method, including denitrification, was used to estimate the wastewater reclamation plant costs that are shown in Table 10. Reclaimed wastewater should not be sent directly to a public water distribution system.

TABLE 10 WASTEWATER RECLAMATION PLANT COSTS

| Plant Capacity (MGD) | Wastewater Reclamation Plant Cost (\$) |
|----------------------|--|
| 1                    | 5,048,000                              |
| 10                   | 25,301,000                             |
| 50                   | 51,500,000                             |
| 75                   | 77,250,000                             |
| 100                  | 103,000,000                            |
| 150                  | 154,500,000                            |
| 200                  | 206,000,000                            |

<sup>1</sup> Values as of Second Quarter 1999.  
<sup>2</sup> Based on Reverse Osmosis Membrane process, with Denitrification, from Trans-Texas Water Program, Southeast Area, Technical Memorandum entitled "Wastewater Reclamation", March 19, 1998.

## 2 OTHER PROJECT COSTS

### 2.1 Engineering, Financial and Legal Services, and Contingencies

Engineering, financial and legal services, and contingencies are estimated as a lump sum, according to TWDB guidelines, as 30 percent of the total construction cost for pipelines and 35 percent of the total construction cost for all other types of projects.

### 2.2 Land and Easements

Land related costs for a project are typically one of two types: land permanently purchased for construction of a facility, or easement costs. The amount and cost of land purchased for various types of projects is considered on an individual project basis, taking into consideration similar project experience. Easement costs, on the other hand, can vary considerably in a single project, based on the variety of site conditions that a pipeline may encounter along its path. Easements are generally acquired for pipeline projects and can normally be classified as temporary or permanent. Permanent easements are purchased for the land that the pipeline will remain in once it is completed, including a wide enough buffer zone to allow maintenance access and protect the pipeline from other parallel utilities. Temporary easements are "rented" to allow extra room for material and equipment staging, as well as other construction related activities.

Land related costs include legal services, sales commissions, and surveying. Ten percent of the total land and easement costs is added to account for all legal services, sales commissions, and surveying associated with the land related purchases. Land costs can vary considerably throughout the region, based on degree of urbanization and other economic factors. County appraisal district records, previous project estimates, and other land value sources are used to estimate the land related costs.

### 2.3 Environmental and Archaeology Studies, Permitting, and Mitigation

Costs for environmental studies, archaeological studies, permitting, and mitigation are estimated on an individual project basis, taking into consideration previous project estimates, the judgement of qualified professionals, and any other available information. In the case of reservoir projects, mitigation costs were generally equal to the land value of the acreage that would be inundated.

### 2.4 Interest During Construction

Interest during construction is calculated as the cost of the interest on the borrowed funds, less the return on the unspent portion of the borrowed funds that are invested during construction. Interest during construction is calculated, according to TWDB guidelines, as the total interest accrued by a 6 percent annual interest rate on the total borrowed funds at the end of the construction phase, less a 4 percent annual rate of return on investment of unspent funds.



### 3 ANNUAL COSTS

Annual costs are expenses which the owner of the project can expect once the project is completed. Each of these costs is described in detail in the following subsections.

#### 3.1 Debt Service

Debt service is the total annual payment that is required to repay borrowed funds. Debt service was calculated according to TWDB Section 1.71 of Exhibit B, assuming an annual interest rate of 6 percent and a repayment period of 40 years for reservoir projects and 30 years for all other projects.

#### 3.2 Operation and Maintenance

Operation and maintenance (O&M) costs include all labor and materials required to run the facility and keep it operational, including periodic repair and/or replacement of facility equipment. In accordance with TWDB guidelines, O&M costs are calculated as 1 percent of the total estimated construction costs for pipelines, distribution facilities, tanks, and wells, 1.5 percent of the total estimated construction costs for dams and reservoirs, and 2.5 percent of the total estimated construction costs for intake structures and pump stations. Water treatment plant cost estimates are shown in Table 10 below.

**TABLE 11 OPERATION AND MAINTENANCE COSTS FOR WATER TREATMENT PLANTS**

| Plant Capacity (MGD) | Groundwater Chlorination Plant Cost (\$) | Direct Filtration Plant Cost (\$) | Conventional (Filtration) Plant Cost (\$) | Wastewater Reclamation Plant Cost (\$) |
|----------------------|--|-----------------------------------|---|--|
| 1                    | 146,000                                  | 156,000                           | 195,000                                   | 211,700                                |
| 10                   | 1,460,000                                | 1,560,000                         | 1,950,000                                 | 2,117,000                              |
| 50                   | 7,300,000                                | 7,800,000                         | 9,750,000                                 | 10,585,000                             |
| 75                   | 10,950,000                               | 11,700,000                        | 14,625,000                                | 15,877,500                             |
| 100                  | 14,600,000                               | 15,600,000                        | 19,500,000                                | 21,170,000                             |
| 150                  | 21,900,000                               | 23,400,000                        | 29,250,000                                | 31,755,000                             |
| 200                  | 29,200,000                               | 31,200,000                        | 39,000,000                                | 42,340,000                             |

<sup>1</sup> Values as of Second Quarter 1999.


#### 3.3 Pumping Energy Costs

Power costs are calculated on an annual basis, using calculated horsepower input and a power purchase cost of \$0.06 per kWh, per TWDB guidelines.

#### 3.4 Purchase of Water

The purchase of water, if applicable to the management strategy being considered, is dependent on the source and type (raw or treated) of water being purchased. The cost is

addressed on an individual project basis due to the wide variety of water types and sources.



#### 4 PRESENTATION OF COST ESTIMATES

Each water management strategy is provided with a cost estimate that shows total construction costs, total project costs (the sum of construction costs and other project costs), and total annual project costs. The unit cost of each alternative per unit of water delivered (total project cost per acre-foot of water delivered) is also presented for further comparison. Each site specific alternative provides as much detail in the estimate as is necessary to accurately estimate the management strategy that is being considered. Once the detailed cost estimate is completed for each shortage, the values from the detailed estimates are included in the Table 11 summary table.


**Appendix C**

**Cost Comparison of Groundwater and Blended Water Supplies**

| 100 % Groundwater Alternative |                      |                        |                      |                         |                           |                   |             |                |               |                      |                      |                    |
|-------------------------------|----------------------|------------------------|----------------------|-------------------------|---------------------------|-------------------|-------------|----------------|---------------|----------------------|----------------------|--------------------|
| Year                          | Total Demand (ac-Ft) | Total Demand (gallons) | BWA Contract (ac-Ft) | Total GW Demand (ac-Ft) | Total GW Demand (gallons) | BWA Contract Cost | GW O&M Cost | GW Rehab. Cost | New Well Cost | Total Annual GW Cost | Total Annual GW Cost | Cumulative GW Cost |
| 2010                          | 17962                | 5852536906             | 1815                 | 16147                   | 5261157634                | \$408,375         | \$2,157,075 | \$157,835      |               | \$2,723,284          | \$0.52               | \$2,723,284        |
| 2011                          | 18180                | 5923632750             | 1815                 | 16365                   | 5332253478                | \$408,375         | \$2,186,224 | \$159,968      |               | \$2,754,567          | \$0.52               | \$5,477,851        |
| 2012                          | 18398                | 5994728594             | 1815                 | 16583                   | 5403349322                | \$408,375         | \$2,215,373 | \$162,100      |               | \$2,785,849          | \$0.52               | \$8,263,700        |
| 2013                          | 18617                | 6065824438             | 1815                 | 16802                   | 5474445166                | \$408,375         | \$2,244,523 | \$164,233      |               | \$2,817,131          | \$0.51               | \$11,080,830       |
| 2014                          | 18835                | 6136920282             | 1815                 | 17020                   | 5545541010                | \$408,375         | \$2,273,672 | \$166,366      |               | \$2,848,413          | \$0.51               | \$13,929,244       |
| 2015                          | 19053                | 6208016126             | 1815                 | 17238                   | 5616636854                | \$408,375         | \$2,302,821 | \$168,499      |               | \$2,879,695          | \$0.51               | \$16,808,939       |
| 2016                          | 19271                | 6279111971             | 1815                 | 17456                   | 5687732699                | \$408,375         | \$2,331,970 | \$170,632      |               | \$2,910,977          | \$0.51               | \$19,719,916       |
| 2017                          | 19489                | 6350207815             | 1815                 | 17674                   | 5758828543                | \$408,375         | \$2,361,120 | \$172,765      |               | \$2,942,260          | \$0.51               | \$22,662,176       |
| 2018                          | 19708                | 6421303659             | 1815                 | 17893                   | 5829924387                | \$408,375         | \$2,390,269 | \$174,898      |               | \$2,973,542          | \$0.51               | \$25,635,717       |
| 2019                          | 19926                | 6492399503             | 1815                 | 18111                   | 5901020231                | \$408,375         | \$2,419,418 | \$177,031      |               | \$3,004,824          | \$0.51               | \$28,640,541       |
| 2020                          | 20144                | 6563495347             | 1815                 | 18329                   | 5972116075                | \$408,375         | \$2,448,568 | \$179,163      |               | \$3,036,106          | \$0.51               | \$31,676,647       |
| 2021                          | 20463                | 6667532483             | 1815                 | 18648                   | 6076153211                | \$408,375         | \$2,491,223 | \$182,285      |               | \$3,081,882          | \$0.51               | \$34,758,530       |
| 2022                          | 20783                | 6771569619             | 1815                 | 18968                   | 6180190347                | \$408,375         | \$2,533,878 | \$185,406      |               | \$3,127,659          | \$0.51               | \$37,886,189       |
| 2023                          | 21102                | 6875606755             | 1815                 | 19287                   | 6284227483                | \$408,375         | \$2,576,533 | \$188,527      |               | \$3,173,435          | \$0.50               | \$41,059,624       |
| 2024                          | 21421                | 6979643891             | 1815                 | 19606                   | 6388264619                | \$408,375         | \$2,619,188 | \$191,648      |               | \$3,219,211          | \$0.50               | \$44,278,835       |
| 2025                          | 21741                | 7083681026             | 1815                 | 19926                   | 6492301754                | \$408,375         | \$2,661,844 | \$194,769      |               | \$3,264,988          | \$0.50               | \$47,543,823       |
| 2026                          | 22060                | 7187718162             | 1815                 | 20245                   | 6596338890                | \$408,375         | \$2,704,499 | \$197,890      |               | \$3,310,764          | \$0.50               | \$50,854,587       |
| 2027                          | 22379                | 7291755298             | 1815                 | 20564                   | 6700376026                | \$408,375         | \$2,747,154 | \$201,011      |               | \$3,356,540          | \$0.50               | \$54,211,127       |
| 2028                          | 22698                | 7395792434             | 1815                 | 20883                   | 6804413162                | \$408,375         | \$2,789,809 | \$204,132      |               | \$3,402,317          | \$0.50               | \$57,613,444       |
| 2029                          | 23018                | 7499829570             | 1815                 | 21203                   | 6908450298                | \$408,375         | \$2,832,465 | \$207,254      |               | \$3,448,093          | \$0.50               | \$61,061,537       |
| 2030                          | 23337                | 7603866706             | 1815                 | 21522                   | 7012487434                | \$408,375         | \$2,875,120 | \$210,375      |               | \$3,493,869          | \$0.50               | \$64,555,407       |
| 2031                          | 23620                | 7695945924             | 1815                 | 21805                   | 7104566652                | \$408,375         | \$2,912,872 | \$213,137      |               | \$3,534,384          | \$0.50               | \$68,089,791       |
| 2032                          | 23902                | 7788025143             | 1815                 | 22087                   | 7196645871                | \$408,375         | \$2,950,825 | \$215,899      |               | \$3,574,899          | \$0.50               | \$71,664,690       |
| 2033                          | 24185                | 7880104362             | 1815                 | 22370                   | 7288725090                | \$408,375         | \$2,988,377 | \$218,662      |               | \$3,615,414          | \$0.50               | \$75,280,104       |
| 2034                          | 24467                | 7972183581             | 1815                 | 22652                   | 7380804309                | \$408,375         | \$3,026,130 | \$221,424      |               | \$3,655,929          | \$0.50               | \$78,936,033       |
| 2035                          | 24750                | 8064262800             | 1815                 | 22935                   | 7472883528                | \$408,375         | \$3,063,882 | \$224,187      |               | \$3,696,444          | \$0.49               | \$82,632,477       |
| 2036                          | 25033                | 8156342019             | 1815                 | 23218                   | 7564962747                | \$408,375         | \$3,101,635 | \$226,949      |               | \$3,736,959          | \$0.49               | \$86,369,436       |
| 2037                          | 25315                | 8248421238             | 1815                 | 23500                   | 7657041966                | \$408,375         | \$3,139,387 | \$229,711      |               | \$3,777,473          | \$0.49               | \$90,146,909       |
| 2038                          | 25598                | 8340500457             | 1815                 | 23783                   | 7749121185                | \$408,375         | \$3,177,140 | \$232,474      |               | \$3,817,988          | \$0.49               | \$93,964,897       |
| 2039                          | 25880                | 8432579676             | 1815                 | 24065                   | 7841200404                | \$408,375         | \$3,214,892 | \$235,236      |               | \$3,858,503          | \$0.49               | \$97,823,401       |
| 2040                          | 26163                | 8524658894             | 1815                 | 24348                   | 7933279622                | \$408,375         | \$3,252,645 | \$237,998      | \$135,870     | \$4,034,888          | \$0.51               | \$101,858,289      |
| 2041                          | 26575                | 8658998109             | 1815                 | 24760                   | 8067618837                | \$408,375         | \$3,307,724 | \$242,029      | \$135,870     | \$4,093,997          | \$0.51               | \$105,952,286      |
| 2042                          | 26988                | 8793337323             | 1815                 | 25173                   | 8201958051                | \$408,375         | \$3,362,803 | \$246,059      | \$135,870     | \$4,153,107          | \$0.51               | \$110,105,392      |
| 2043                          | 27400                | 8927676537             | 1815                 | 25585                   | 8336297265                | \$408,375         | \$3,417,882 | \$250,089      | \$135,870     | \$4,212,216          | \$0.51               | \$114,317,608      |
| 2044                          | 27812                | 9062015751             | 1815                 | 25997                   | 8470636479                | \$408,375         | \$3,472,961 | \$254,119      | \$135,870     | \$4,271,325          | \$0.50               | \$118,588,933      |
| 2045                          | 28225                | 9196354966             | 1815                 | 26410                   | 8604975694                | \$408,375         | \$3,528,040 | \$258,149      | \$135,870     | \$4,330,434          | \$0.50               | \$122,919,368      |
| 2046                          | 28637                | 9330694180             | 1815                 | 26822                   | 8739314908                | \$408,375         | \$3,583,119 | \$262,179      | \$135,870     | \$4,389,544          | \$0.50               | \$127,308,911      |
| 2047                          | 29049                | 9465033394             | 1815                 | 27234                   | 8873654122                | \$408,375         | \$3,638,198 | \$266,210      | \$135,870     | \$4,448,653          | \$0.50               | \$131,757,564      |
| 2048                          | 29461                | 9599372608             | 1815                 | 27646                   | 9007993336                | \$408,375         | \$3,693,277 | \$270,240      | \$135,870     | \$4,507,762          | \$0.50               | \$136,265,326      |
| 2049                          | 29874                | 9733711823             | 1815                 | 28059                   | 9142332551                | \$408,375         | \$3,748,356 | \$274,270      | \$135,870     | \$4,566,871          | \$0.50               | \$140,832,197      |
| 2050                          | 30286                | 9868051037             | 1815                 | 28471                   | 9276671765                | \$408,375         | \$3,803,435 | \$278,300      | \$135,870     | \$4,625,981          | \$0.50               | \$145,458,178      |

| Year | Total Demand (ac-ft) | Total Demand (gallons) | Total SW Demand (ac-ft) | Total SW Demand (gallons) | BWA Contract (ac-ft) | BWA Contract Cost | Annual SW Cost 2010 | Annual SW Cost 2020 | Annual SW Cost 2030 | Annual SW Cost 2040 | Annual SW Cost 2050 | Total Cost  | GW O&M Cost | GW Rehab. Cost | Total GW Cost | Total Annual Blended Cost | Total Annual Blended Cost | Cumulative Blended Cost |
|------|----------------------|------------------------|-------------------------|---------------------------|----------------------|-------------------|---------------------|---------------------|---------------------|---------------------|---------------------|-------------|-------------|----------------|---------------|---------------------------|---------------------------|-------------------------|
| 2010 | 17962                | 5852536906             | 8981                    | 2926268453                | 1815                 | \$408,375         | \$6,436,685         |                     |                     |                     |                     | \$6,436,685 | \$1,199,770 | \$87,788       | \$1,287,558   | \$7,724,243               | \$7,724,243               | \$7,724,243             |
| 2011 | 18180                | 5923632750             | 9090                    | 2961816375                | 1815                 | \$408,375         | \$6,436,685         |                     |                     |                     |                     | \$6,436,685 | \$1,214,345 | \$88,854       | \$1,303,199   | \$7,739,884               | \$15,464,127              | \$15,464,127            |
| 2012 | 18398                | 5994728594             | 9199                    | 2997364297                | 1815                 | \$408,375         | \$6,436,685         |                     |                     |                     |                     | \$6,436,685 | \$1,228,919 | \$89,921       | \$1,318,840   | \$7,755,525               | \$23,219,653              | \$23,219,653            |
| 2013 | 18617                | 6065824438             | 9308                    | 3033780377                | 1815                 | \$408,375         | \$6,436,685         |                     |                     |                     |                     | \$6,436,685 | \$1,243,494 | \$90,987       | \$1,334,481   | \$7,771,166               | \$30,990,819              | \$30,990,819            |
| 2014 | 18835                | 6138920282             | 9417                    | 3068460141                | 1815                 | \$408,375         | \$6,436,685         |                     |                     |                     |                     | \$6,436,685 | \$1,258,069 | \$92,054       | \$1,350,122   | \$7,786,807               | \$38,777,626              | \$38,777,626            |
| 2015 | 19053                | 6208016126             | 9527                    | 3104008063                | 1815                 | \$408,375         | \$6,436,685         |                     |                     |                     |                     | \$6,436,685 | \$1,272,643 | \$93,120       | \$1,365,764   | \$7,802,449               | \$46,580,075              | \$46,580,075            |
| 2016 | 19271                | 6278111971             | 9636                    | 3139555985                | 1815                 | \$408,375         | \$6,436,685         |                     |                     |                     |                     | \$6,436,685 | \$1,287,218 | \$94,187       | \$1,381,405   | \$7,818,090               | \$54,398,165              | \$54,398,165            |
| 2017 | 19489                | 6350207815             | 9745                    | 3175103907                | 1815                 | \$408,375         | \$6,436,685         |                     |                     |                     |                     | \$6,436,685 | \$1,301,793 | \$95,253       | \$1,397,046   | \$7,833,731               | \$62,231,895              | \$62,231,895            |
| 2018 | 19708                | 6421303659             | 9854                    | 3210651829                | 1815                 | \$408,375         | \$6,436,685         |                     |                     |                     |                     | \$6,436,685 | \$1,316,367 | \$96,320       | \$1,412,687   | \$7,849,372               | \$70,081,267              | \$70,081,267            |
| 2019 | 19926                | 6492399503             | 9963                    | 3246199752                | 1815                 | \$408,375         | \$6,436,685         |                     |                     |                     |                     | \$6,436,685 | \$1,330,942 | \$97,386       | \$1,428,328   | \$7,865,013               | \$77,946,280              | \$77,946,280            |
| 2020 | 20144                | 6563495347             | 10072                   | 3281747674                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,345,517 | \$98,452       | \$1,443,969   | \$7,880,654               | \$85,826,934              | \$85,826,934            |
| 2021 | 20362                | 6634591191             | 10181                   | 3317295597                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,360,092 | \$99,517       | \$1,459,606   | \$7,900,146               | \$93,727,080              | \$93,727,080            |
| 2022 | 20580                | 6705687041             | 10290                   | 3352843520                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,374,667 | \$100,582      | \$1,475,245   | \$7,919,621               | \$101,742,325             | \$101,742,325           |
| 2023 | 20798                | 6776782891             | 10399                   | 3388391443                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,389,242 | \$101,647      | \$1,490,884   | \$7,939,136               | \$108,631,511             | \$108,631,511           |
| 2024 | 21016                | 6847878741             | 10508                   | 3423939366                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,403,817 | \$102,712      | \$1,506,526   | \$7,958,651               | \$115,538,037             | \$115,538,037           |
| 2025 | 21234                | 6918974591             | 10617                   | 3459487289                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,418,392 | \$103,777      | \$1,522,169   | \$7,978,166               | \$122,460,206             | \$122,460,206           |
| 2026 | 21452                | 6990070441             | 10726                   | 3495035212                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,432,967 | \$104,842      | \$1,537,811   | \$7,997,681               | \$129,381,387             | \$129,381,387           |
| 2027 | 21670                | 7061166291             | 10835                   | 3530583135                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,447,542 | \$105,907      | \$1,553,453   | \$8,017,196               | \$136,302,568             | \$136,302,568           |
| 2028 | 21888                | 7132262141             | 10944                   | 3566131058                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,462,117 | \$106,972      | \$1,569,095   | \$8,036,711               | \$143,223,749             | \$143,223,749           |
| 2029 | 22106                | 7203357991             | 11053                   | 3601678981                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,476,692 | \$108,037      | \$1,584,737   | \$8,056,226               | \$150,144,930             | \$150,144,930           |
| 2030 | 22324                | 7274453841             | 11162                   | 3637226904                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,491,267 | \$109,102      | \$1,600,379   | \$8,075,741               | \$157,066,111             | \$157,066,111           |
| 2031 | 22542                | 7345549691             | 11271                   | 3672774827                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,505,842 | \$110,167      | \$1,616,021   | \$8,095,256               | \$164,087,292             | \$164,087,292           |
| 2032 | 22760                | 7416645541             | 11380                   | 3708322750                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,520,417 | \$111,232      | \$1,631,663   | \$8,114,771               | \$171,008,473             | \$171,008,473           |
| 2033 | 22978                | 7487741391             | 11489                   | 3743870673                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,534,992 | \$112,297      | \$1,647,305   | \$8,134,286               | \$178,029,654             | \$178,029,654           |
| 2034 | 23196                | 7558837241             | 11598                   | 3779418596                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,549,567 | \$113,362      | \$1,662,947   | \$8,153,801               | \$185,050,835             | \$185,050,835           |
| 2035 | 23414                | 7629933091             | 11707                   | 3814966519                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,564,142 | \$114,427      | \$1,678,589   | \$8,173,316               | \$192,072,016             | \$192,072,016           |
| 2036 | 23632                | 7691028941             | 11816                   | 3850514442                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,578,717 | \$115,492      | \$1,694,231   | \$8,192,831               | \$199,093,197             | \$199,093,197           |
| 2037 | 23850                | 7762124791             | 11925                   | 3886062365                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,593,292 | \$116,557      | \$1,709,873   | \$8,212,346               | \$206,114,378             | \$206,114,378           |
| 2038 | 24068                | 7833220641             | 12034                   | 3921610288                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,607,867 | \$117,622      | \$1,725,515   | \$8,231,861               | \$213,135,559             | \$213,135,559           |
| 2039 | 24286                | 7904316491             | 12143                   | 3957158211                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,622,442 | \$118,687      | \$1,741,157   | \$8,251,376               | \$220,156,740             | \$220,156,740           |
| 2040 | 24504                | 7975412291             | 12252                   | 3992706134                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,637,017 | \$119,752      | \$1,756,800   | \$8,270,891               | \$227,177,921             | \$227,177,921           |
| 2041 | 24722                | 8046508091             | 12361                   | 4028254057                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,651,592 | \$120,817      | \$1,772,442   | \$8,290,406               | \$234,199,102             | \$234,199,102           |
| 2042 | 24940                | 8117603891             | 12470                   | 4063801980                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,666,167 | \$121,882      | \$1,788,084   | \$8,309,921               | \$241,220,283             | \$241,220,283           |
| 2043 | 25158                | 8188703691             | 12579                   | 4099349903                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,680,742 | \$122,947      | \$1,803,726   | \$8,329,436               | \$248,241,464             | \$248,241,464           |
| 2044 | 25376                | 8259803491             | 12688                   | 4134897826                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,695,317 | \$124,012      | \$1,819,368   | \$8,348,951               | \$255,262,645             | \$255,262,645           |
| 2045 | 25594                | 8330903291             | 12797                   | 4170445749                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,709,892 | \$125,077      | \$1,835,010   | \$8,368,466               | \$262,283,826             | \$262,283,826           |
| 2046 | 25812                | 8402003091             | 12906                   | 4205993672                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,724,467 | \$126,142      | \$1,850,652   | \$8,387,981               | \$269,305,007             | \$269,305,007           |
| 2047 | 26030                | 8473102891             | 13015                   | 4241541595                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,739,042 | \$127,207      | \$1,866,294   | \$8,407,496               | \$276,326,188             | \$276,326,188           |
| 2048 | 26248                | 8544202691             | 13124                   | 4277089518                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,753,617 | \$128,272      | \$1,881,936   | \$8,427,011               | \$283,347,369             | \$283,347,369           |
| 2049 | 26466                | 8615302491             | 13233                   | 4312637441                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,768,192 | \$129,337      | \$1,897,578   | \$8,446,526               | \$290,368,550             | \$290,368,550           |
| 2050 | 26684                | 8686402291             | 13342                   | 4348185364                | 1815                 | \$408,375         | \$6,436,685         | \$7,449,828         |                     |                     |                     | \$7,449,828 | \$1,782,767 | \$130,402      | \$1,913,220   | \$8,466,041               | \$297,389,731             | \$297,389,731           |

Comparison of Blended Water Supply and Groundwater Supply Costs



**Appendix F**  
**Treatment Process Capital and O & M Costs**

---



### CAPITAL COSTS FOR 25 MGD HIGH RATE CONVENTIONAL SYSTEM (2 PHASE)

| Unit  | Units       | Quantity  | Cost Estimate | Notes  |
|---|-------------|-----------|---------------|--|
| Sitework  | per acre    | 20        | \$3,500,000   |  |
| Yard Piping                                       | per mgd     | 25        | \$2,125,000   |  |
| Low Lift Pumping                                  | per mgd     | 27.5      | \$792,000     | Includes VFDs  |
| Mixing/Flocculation/Sedimentation                 | per unit    | 3         | \$1,170,000   | Superpulsators   |
| Filters   | per sf      | 3644      | \$5,467,000   | Deep bed, GAC/sand, air scour  |
| Transfer Pumping                                  | per mgd     | 26.5      | \$780,000     | Includes VFDs  |
| PAC System  | per sys     | 2         | \$250,000     | Silo storage   |
| Backwash Equalization Tank                        | per gal     | 257850    | \$232,000     | Tank and recycle pumps   |
| Backwash Clarification                            | per mgd     | 0.6       | \$106,000     | Lamella settlers   |
| Gravity thickeners/holding tanks                  | per mgd     | 0.4       | \$16,000      |  |
| Chemical Systems, Building, Tanks                 | ls per sys. | 22        | \$5,335,000   | Chlorine, caustic soda, ammonia, ferric, PEC, PEA, chlorine dioxide, flouride, orthophosphate, spare |
| Sludge Lagoons                                    | per acre    | 5.07      | \$888,000     |  |
| Ground Storage Tanks                              | per gal     | 7,000,000 | \$2,800,000   |  |
| Subtotal  |             |           | \$23,461,000  |  |
| Electrical, Instrumentation, and Controls         |             |           | \$3,050,000   | Allowance (13%)  |
| Subtotal  |             |           | \$26,511,000  |  |
| Mobilization                                      |             |           | \$795,000     | Allowance (3%)   |
| Subtotal  |             |           | \$27,306,000  |  |
| Construction Management, Insurance, Bonds, Profit |             |           | \$3,550,000   | Allowance (13%)  |
| Construction Cost Subtotal                        |             |           | \$30,856,000  |  |
| Total Capital Cost                                |             |           | \$30,860,000  | Rounded  |
|   |             |           | \$1.23        | Per Gallon of Capacity   |

Notes:

1. 25 MGD Finished Water Capacity
2. 15 MGD First Phase

## CAPITAL COSTS FOR 15 MGD INTIAL PHASE - HIGH RATE CONVENTIONAL SYSTEM

| Unit  | Unit Cost | Units       | Quantity  | Cost Estimate       | Notes  |
|---|-----------|-------------|-----------|---------------------|--|
| Sitework  | \$175,000 | per acre    | 20.0      | \$3,500,000         |  |
| Yard Piping                                       | \$85,000  | per mgd     | 15.0      | \$1,275,000         |  |
| Low Lift Pumping                                  | \$40,000  | per mgd     | 16.5      | \$660,000           | Includes VFDs  |
| Mixing/Flocculation/Sedimentation                 | \$327,500 | per unit    | 2.0       | \$655,000           | Superpulsators   |
| Filters   | \$1,500   | per sf      | 2,733.0   | \$4,100,000         | Deep bed, GAC/sand, air scour  |
| Transfer Pumping                                  | \$40,000  | per mgd     | 16.5      | \$660,000           | Includes VFDs  |
| PAC System  | \$125,000 | per sys     | 2.0       | \$250,000           | Silo storage   |
| Backwash Equalization Tank                        | \$0.90    | per gal     | 257,850.0 | \$232,000           | Tank and recycle pumps   |
| Backwash Clarification                            | \$175,000 | per mgd     | 0.3       | \$53,000            | Lamella settlers   |
| Gravity thickeners/holding tanks                  | \$40,000  | per mgd     | 0.2       | \$8,000             |  |
| Chemical Systems, Building, Tanks                 | \$350,000 | ls per sys. | 11.0      | \$3,850,000         | Chlorine, caustic soda, ammonia, ferric, PEC, PEA, chlorine dioxide, flouride, orthophosphate, spare |
| Sludge Lagoons                                    | \$175,000 | per acre    | 3.4       | \$592,000           |  |
| Ground Storage Tanks                              | \$0.40    | per gal     | 4,000,000 | \$1,600,000         |  |
| Subtotal  |           |             |           | <b>\$17,435,000</b> |  |
| Electrical, Instrumentation, and Controls         | 13%       |             |           | \$2,267,000         | Allowance (13%)  |
| Subtotal  |           |             |           | <b>\$19,702,000</b> |  |
| Mobilization                                      | 3%        |             |           | \$591,000           | Allowance (3%)   |
| Subtotal  |           |             |           | <b>\$20,293,000</b> |  |
| Construction Management, Insurance, Bonds, Profit | 13%       |             |           | \$2,638,000         | Allowance (13%)  |
| Construction Cost Subtotal                        |           |             |           | \$22,931,000        |  |
| Total Capital Cost                                |           |             |           | \$22,931,000        | Rounded  |
|   |           |             |           | \$1.53              | Per Gallon of Capacity   |

Notes:

1. 25 MGD Finished Water Capacity
2. 15 MGD First Phase

## OPERATING AND MAINTENACE COSTS FOR HIGH RATE CONVENTIONAL SYSTEM

15.0 MGD Finished Water Capacity

### VARIABLE COSTS

#### Electrical Costs

Cost per kW-hr = \$0.06

|                                  | No. of Units | Horsepower | % Utilization | Power              | Cost per kgal produced |
|----------------------------------|--------------|------------|---------------|--------------------|------------------------|
|                                  |              |            |               | Consumption, kW-hr |                        |
| Low Lift Pumps                   | 4            | 50         | 100%          | 3,581              | \$0.0143               |
| Clarifier System                 | 2            | 15         | 100%          | 537                | \$0.0021               |
| Backwash pumps and blowers       | 1            | 400        | 5%            | 358                | \$0.0014               |
| Transfer Pumps                   | 4            | 50         | 100%          | 3,581              | \$0.0143               |
| WW EQ Recycle Pum                | 2            | 30         | 75%           | 806                | \$0.0032               |
| Sludge pumping and               | 4            | 30         | 75%           | 1,611              | \$0.0064               |
| Miscellaneous                    | 1            | 100        | 100%          | 1,790              | \$0.0072               |
| <b>Electrical Costs Subtotal</b> |              |            |               |                    | <b>\$0.049</b>         |

#### Chemical Costs

|  | Cost (\$/Ton-Dry Equivalent) | Dose (mg/l of dry equivalent) | Flow (mgd) | Cost per kgal produced |
|--|------------------------------|-------------------------------|------------|------------------------|
|  |                              |                               |            |                        |
| Ferric   | \$450                        | 30                            | 16.5       | \$0.062                |
| Cationic Polymer                                 | \$1,000                      | 5                             | 16.5       | \$0.023                |
| Anionic Polymer                                  | \$1,500                      | 1                             | 16.5       | \$0.003                |
| Sodium Chlorite (1.5 mg/l Chlorine dioxide dose) | \$1,000                      | 0.8                           | 16.5       | \$0.004                |
| Chlorine - ClO2 (1.5 mg/l Chlorine dioxide dose) | \$400                        | 0.8                           | 16.5       | \$0.002                |
| Chlorine - BW                                    | \$400                        | 5                             | 0.8        | \$0.000                |
| Chlorine - Residual Disinfectant                 | \$400                        | 3                             | 15.0       | \$0.005                |
| Ammonia  | \$350                        | 1.0                           | 15.0       | \$0.001                |
| PAC  | \$1,100                      | 10.0                          | 16.5       | \$0.050                |
| Caustic Soda                                     | \$600                        | 10.0                          | 15.0       | \$0.025                |
| Flouride   | \$1,500                      | 0.6                           | 15.0       | \$0.004                |
| Corrosion Inhibitor, mg/L                        | \$5,200                      | 0.5                           | 15.0       | \$0.011                |
| <b>Chemical Costs Subtotal</b>                   |                              |                               |            | <b>\$0.190</b>         |

#### Sludge Disposal Costs

| Sludge Produced, cy wet sludge/YR | Dried Percent Solids | Handling/Disposal, \$/cy | Cost per kgal produced |
|-----------------------------------|----------------------|--------------------------|------------------------|
| 4,920                             | 45%                  | \$15.0                   | \$0.013                |

#### Raw Water Costs

(contained in raw water analysis)

**Variable Operating Costs, cost per kgal treated**

**\$0.253**

### FIXED COSTS

#### Maintenance

% of CC's  
1.7%      Capital Costs  
\$22,931,000      Annual Cost  
**\$390,000**

#### GAC Replacement

3499 cu ft/yr      \$ 100.00 per cu ft      **\$350,000**

#### Labor

|                              | No. of Equivalent Full-Time | Avg. Salary \$/Hr | Avg. Burdened Salary \$/Hr | Annual Cost |
|------------------------------|-----------------------------|-------------------|----------------------------|-------------|
| Total                        | 12.5                        | \$18.44           | \$27.66                    | \$718,000   |
| Process Operators            | 6                           | \$17.00           | \$25.50                    | \$318,000   |
| Electrician, Instrument Tech | 2                           | \$22.50           | \$33.75                    | \$140,000   |
| Maintenance                  | 3                           | \$18.00           | \$27.00                    | \$168,000   |
| Administration               | 1                           | \$13.00           | \$19.50                    | \$41,000    |
| Superintendent               | 0.5                         | \$33.00           | \$49.50                    | \$51,000    |

Burden Multiplier      1.15

#### Admin

**\$600,000**

**Fixed Operating Costs, cost per year**

**\$2,058,000**

**Fixed Operating Costs, cost per 1000 gallons provided**

**\$0.63**

## CAPITAL COSTS FOR 10 MGD EXPANSION - HIGH RATE CONVENTIONAL SYSTEM

| Unit  | Unit Cost | Units       | Quantity  | Cost Estimate      | Notes  |
|---|-----------|-------------|-----------|--------------------|--|
| Sitework  | \$175,000 | per acre    | 0.0       | \$0                |  |
| Yard Piping                                       | \$85,000  | per mgd     | 10.0      | \$850,000          |  |
| Low Lift Pumping                                  | \$12,000  | per mgd     | 11.0      | \$132,000          | Includes VFDs                                      |
| Mixing/Flocculation/Sedimentation                 | \$515,000 | per unit    | 1.0       | \$515,000          | Superpulsators                                     |
| Filters   | \$1,500   | per sf      | 911.0     | \$1,367,000        | Deep bed, GAC/sand, air scour                      |
| Transfer Pumping                                  | \$12,000  | per mgd     | 10.0      | \$120,000          | Includes VFDs                                      |
| PAC System  | \$125,000 | per sys     | 0.0       | \$0                | Silo storage                                       |
| Backwash Equalization Tank                        | \$0.90    | per gal     | 0.0       | \$0                | Tank and recycle pumps                             |
| Backwash Clarification                            | \$175,000 | per mgd     | 0.3       | \$53,000           | Lamella settlers                                   |
| Gravity thickeners/holding tanks                  | \$40,000  | per mgd     | 0.2       | \$8,000            |  |
| Chemical Systems, Building, Tanks                 | \$135,000 | ls per sys. | 11.0      | \$1,485,000        | Chlorine, caustic soda, ammonia, ferric, PEC, PEA, |
| Sludge Lagoons                                    | \$175,000 | per acre    | 1.7       | \$296,000          | chlorine dioxide, flouride, orthophosphate, spare  |
| Ground Storage Tanks                              | \$0.40    | per gal     | 3,000,000 | \$1,200,000        |  |
| Subtotal  |           |             |           | <b>\$6,026,000</b> |  |
| Electrical, Instrumentation, and Controls         | 13%       |             |           | \$783,000          | Allowance  |
| Subtotal  |           |             |           | <b>\$6,809,000</b> |  |
| Mobilization                                      | 3%        |             |           | \$204,000          | Allowance  |
| Subtotal  |           |             |           | <b>\$7,013,000</b> |  |
| Construction Management, Insurance, Bonds, Profit | 13%       |             |           | \$912,000          | Allowance  |
| Construction Cost Subtotal                        |           |             |           | <b>\$7,925,000</b> |  |
| Total Capital Cost                                |           |             |           | <b>\$7,930,000</b> | Rounded  |
|   |           |             |           | \$0.32             | Per Gallon of Capacity                             |

Notes:

1. 25 MGD Finished Water Capacity
2. 10 MGD Expansion

## OPERATING AND MAINTENACE COSTS FOR HIGH RATE CONVENTIONAL SYSTEM

25.0 MGD Finished Water Capacity

### VARIABLE COSTS

#### Electrical Costs

Cost per kW-hr = \$0.06

|                                  | No. of Units | Horsepower | % Utilization | Power Consumption,<br>kW-hr | Cost per kgal produced |
|----------------------------------|--------------|------------|---------------|-----------------------------|------------------------|
| Low Lift Pumps                   | 4            | 80         | 100%          | 5,729                       | \$0.0138               |
| Clarifier System                 | 2            | 15         | 100%          | 537                         | \$0.0013               |
| Backwash pumps and blowers       | 1            | 400        | 5%            | 358                         | \$0.0009               |
| Transfer Pumps                   | 4            | 80         | 100%          | 5,729                       | \$0.0138               |
| WW EQ Recycle Pumps              | 2            | 30         | 75%           | 806                         | \$0.0019               |
| Sludge pumping and mixing        | 4            | 30         | 75%           | 1,611                       | \$0.0039               |
| Miscellaneous                    | 1            | 100        | 100%          | 1,790                       | \$0.0043               |
| <b>Electrical Costs Subtotal</b> |              |            |               |                             | <b>\$0.040</b>         |

#### Chemical Costs

|   | Cost<br>(\$/Ton-Dry<br>Equivalent) | Dose<br>(mg/l of dry<br>equivalent) | Flow (mgd) | Cost per kgal produced |
|---|------------------------------------|-------------------------------------|------------|------------------------|
| Ferric  | \$450                              | 30                                  | 27.5       | \$0.062                |
| Cationic Polymer                                    | \$1,000                            | 5                                   | 27.5       | \$0.023                |
| Anionic Polymer                                     | \$1,500                            | 1                                   | 27.5       | \$0.003                |
| Sodium Chlorite<br>(1.5 mg/l Chlorine dioxide dose) | \$1,000                            | 0.8                                 | 27.5       | \$0.004                |
| Chlorine - ClO2<br>(1.5 mg/l Chlorine dioxide dose) | \$400                              | 0.8                                 | 27.5       | \$0.002                |
| Chlorine - BW                                       | \$400                              | 5                                   | 1.3        | \$0.000                |
| Chlorine - Residual Disinfectant                    | \$400                              | 3                                   | 25.0       | \$0.005                |
| Ammonia   | \$350                              | 1.0                                 | 25.0       | \$0.001                |
| PAC   | \$1,100                            | 10.0                                | 27.5       | \$0.050                |
| Caustic Soda  | \$600                              | 10.0                                | 25.0       | \$0.025                |
| Flouride  | \$1,500                            | 0.6                                 | 25.0       | \$0.004                |
| Corrosion Inhibitor, mg/L                           | \$5,200                            | 0.5                                 | 25.0       | \$0.011                |
| <b>Chemical Costs Subtotal</b>                      |                                    |                                     |            | <b>\$0.190</b>         |

#### Sludge Disposal Costs

| Sludge Produced, cy wet<br>sludge/YR | Dried Percent<br>Solids | Handling/Disposal,<br>\$/cy | Cost per kgal produced |
|--------------------------------------|-------------------------|-----------------------------|------------------------|
| 8,200                                | 45%                     | \$15.0                      | \$0.013                |

#### Raw Water Costs

(contained in raw water analysis)

**Variable Operating Costs, cost per kgal treated \$0.244**

### FIXED COSTS

#### Maintenance

% of CC's  
1.7%      Capital Costs  
\$30,860,000      **\$525,000**

**GAC Replacement**      5832 cu ft/yr      \$      100.00 per cu ft      **\$583,000**

| Labor                        | No. of<br>Equivalent<br>Full-Time | Avg. Salary \$/Hr | Avg. Burdened Salary |  |                  |
|------------------------------|-----------------------------------|-------------------|----------------------|--|------------------|
|                              |                                   |                   | \$/Hr                |  |                  |
| Total                        | 13                                | \$19.00           | \$28.50              |  | <b>\$770,000</b> |
| Process Operators            | 6                                 | \$17.00           | \$25.50              |  | \$318,000        |
| Electrician, Instrument Tech | 2                                 | \$22.50           | \$33.75              |  | \$140,000        |
| Maintenance                  | 3                                 | \$18.00           | \$27.00              |  | \$168,000        |
| Administration               | 1                                 | \$13.00           | \$19.50              |  | \$41,000         |
| Superintendent               | 1                                 | \$33.00           | \$49.50              |  | \$103,000        |
| Burden Multiplier            | 1.5                               |                   |                      |  |                  |

**Admin**      **\$600,000**

**Fixed Operating Costs, cost per year \$2,478,000**  
**Fixed Operating Costs, cost per 1000 gallons of capacity \$0.70**

**Appendix G**

**TWDB Region H Cost Estimation Schedules**

---

**PUBLIC SUPPLY WELL COSTS**

| Well Depth<br>(feet)   | Well Capacity (gpm) |            |            |            |            |
|--|---------------------|------------|------------|------------|------------|
|  | 200                 | 400        | 700        | 1,000      | 1,500      |
| <b>Static Water Level Less Than 200 Feet Below Land Surface</b>        |                     |            |            |            |            |
| 300  | \$ 150,000          | \$ 229,200 | \$ 250,800 | -          | -          |
| 500  | \$ 180,000          | \$ 260,400 | \$ 285,600 | \$ 404,400 | -          |
| 700  | \$ 235,000          | \$ 282,000 | \$ 308,400 | \$ 430,800 | \$ 459,600 |
| 1,000  | \$ 270,000          | \$ 328,800 | \$ 355,200 | \$ 469,200 | \$ 498,000 |
| 1,500  | \$ 310,000          | \$ 340,200 | \$ 405,600 | \$ 520,200 | \$ 564,000 |
| <b>Static Water Levels Between 200 and 300 Feet Below Land Surface</b> |                     |            |            |            |            |
| 500  | \$ 160,000          | \$ 221,000 | -          | -          | -          |
| 700  | \$ 190,000          | \$ 224,400 | \$ 315,800 | \$ 440,200 | \$ 470,600 |
| 1,000  | \$ 240,000          | \$ 335,400 | \$ 365,600 | \$ 485,500 | \$ 530,100 |
| 1,500  | \$ 320,000          | \$ 350,900 | \$ 415,600 | \$ 530,900 | \$ 600,500 |
| <b>Static Water Levels Between 300 and 400 Feet Below Land Surface</b> |                     |            |            |            |            |
| 500  | \$ 170,000          | -          | -          | -          | -          |
| 700  | \$ 210,000          | \$ 238,000 | \$ 350,000 | \$ 470,000 | \$ 500,000 |
| 1,000  | \$ 260,000          | \$ 414,400 | \$ 367,200 | \$ 510,000 | \$ 550,000 |
| 1,500  | \$ 330,000          | \$ 415,000 | \$ 564,000 | \$ 690,000 | \$ 750,000 |
| <b>Static Water Levels Between 400 and 500 Feet Below Land Surface</b> |                     |            |            |            |            |
| 1,000  | \$ 283,000          | \$ 400,800 | \$ 485,800 | \$ 596,400 | -          |
| 1,500  | \$ 328,000          | \$ 434,400 | \$ 576,000 | \$ 767,000 | -          |

<sup>1</sup> Values as of Second Quarter 1999.

<sup>2</sup> Costs based on underreamed, gravel-packed wells, with steel casing and stainless steel screens.

<sup>3</sup> Costs as estimated by LBG-Guyton Associates.

<sup>4</sup> Irrigation well costs assumed to be 55% of above public water supply well cost values.

### OFF-CHANNEL RESERVOIR COSTS

| <b>Storage Volume<br/>(ac-ft)</b> | <b>Ring Dike Cost<br/>(\$)</b> |
|-----------------------------------|--------------------------------|
| 500                               | 965,000                        |
| 1,000                             | 1,393,000                      |
| 2,500                             | 2,313,000                      |
| 5,000                             | 4,590,000                      |
| 7,500                             | 5,733,000                      |
| 10,000                            | 6,733,000                      |
| 12,500                            | 7,642,000                      |
| 15,000                            | 10,788,000                     |
| 17,500                            | 11,732,000                     |
| 20,000                            | 15,728,000                     |
| 22,000                            | 16,542,000                     |
| 25,000                            | 17,705,000                     |

<sup>1</sup> Values as of Second Quarter 1999.

<sup>2</sup> Values are based on ring dike construction.

<sup>3</sup> Values also used for cost of dams on minor tributaries.



### WATER STORAGE TANK COSTS

| Storage Capacity<br>(MG) | Cost<br>(\$) |
|--------------------------|--------------|
| 0.01                     | 161,998      |
| 0.05                     | 192,277      |
| 0.10                     | 250,864      |
| 0.5                      | 494,717      |
| 1.0                      | 741,476      |
| 2.0                      | 1,105,507    |
| 4.0                      | 1,662,686    |
| 6.0                      | 2,226,462    |
| 7.5                      | 2,691,516    |
| 9.0                      | 3,065,107    |
| 10.0                     | 3,302,218    |
| 15.0                     | 4,709,555    |

<sup>1</sup> Values as of Second Quarter 1999.

<sup>2</sup> Costs based on ground level prestressed concrete construction.

**Appendix H**

**Modified Region H Raw Water Alternative Costs**

---

**CAPITAL AND O&M COSTS**

Alternative 1: 16.5 MGD untreated water to be purchase water from the GCWA.

Phase 1: 16.5 MGD (2010)

| <b>CAPITAL COSTS</b>  |           |       |          |       |              |
|---|-----------|-------|----------|-------|--------------|
| ITEMS   | Unit Cost | Units | Quantity | Units | Updated Cost |
| <b>RAW WATER SUPPLY</b>   |           |       |          |       |              |
| Pump Stations   |           |       | 0        |       | \$ -         |
| Piping  |           |       | 0        |       | \$ -         |
| <b>TOTAL Construction</b>                                       |           |       |          |       | \$ -         |
| <b>LAND ACQUISITION</b>   |           |       | 0        |       | \$ -         |
| <b>ENVIRONMENTAL &amp; ARCHEOLOGICAL STUDIES AND MITIGATION</b> |           |       | 0        |       | \$ -         |
| <b>Total Capital</b>  |           |       |          |       | \$ -         |

| <b>ANNUAL O&amp;M COSTS</b> |             |             |                   |
|-----------------------------|-------------|-------------|-------------------|
| Purchase of Raw Water       | 29.32 \$/AF | 18482.06 AF | \$ 542,000        |
| <b>TOTAL O&amp;M COST</b>   |             |             | <b>\$ 542,000</b> |

**CAPITAL AND O&M COSTS**

Alternative 1: 27.5 MGD untreated water to be purchase water from the GCWA.

Phase 2: 11 MGD (2030 Expansion)

| <b>CAPITAL COSTS</b>  |           |       |          |              |
|---|-----------|-------|----------|--------------|
| ITEMS   | Unit Cost | Units | Quantity | Updated Cost |
| <b>RAW WATER SUPPLY</b>   |           |       |          |              |
| Pump Stations   |           |       | 0        | \$ -         |
| Piping  |           |       | 0        | \$ -         |
| <b>TOTAL Construction</b>                                       |           |       |          | <b>\$ -</b>  |
| <b>LAND ACQUISITION</b>   |           |       | 0        | \$ -         |
| <b>ENVIRONMENTAL &amp; ARCHEOLOGICAL STUDIES AND MITIGATION</b> |           |       | 0        | \$ -         |
| <b>Total Capital</b>  |           |       |          | <b>\$ -</b>  |

| <b>ANNUAL O&amp;M COSTS</b> |             |             |                   |
|-----------------------------|-------------|-------------|-------------------|
| Purchase of Raw Water       | 29.32 \$/AF | 30803.44 AF | \$ 903,000        |
| <b>TOTAL O&amp;M COST</b>   |             |             | <b>\$ 903,000</b> |

CAPITAL AND O&M COSTS

Alternative 2: 16.5 MGD untreated water to be purchase water from the BRA to Site A

Phase 1: 16.5 MGD (2010)

| CAPITAL COSTS   |                     |           |          |       |                      |
|---|---------------------|-----------|----------|-------|----------------------|
| ITEMS   | Unit Cost           | Units     | Quantity | Units | Updated Cost         |
| <b>RAW WATER SUPPLY</b>   |                     |           |          |       |                      |
| <b>Pump Stations</b>  |                     |           |          |       |                      |
| Raw water Pump Station  | 330 HP              |           | 1        | LS    | \$ 3,207,000         |
| Intake Structure  | 20% of Pump Station |           | 1        | LS    | \$ 641,000           |
| Power Connection  |                     | 125 \$/Hp | 330      | HP    | \$ 41,000            |
| Standby Power   | 35% of Pump Station |           | 1        | LS    | \$ 1,122,000         |
| <b>Total</b>  |                     |           |          |       | <b>\$ 5,011,000</b>  |
| <b>Piping</b>   |                     |           |          |       |                      |
| Open Cut Trenches   |                     |           |          |       |                      |
| Pipe @ 42" in rural areas                                       | 210 \$/ft           |           | 30000    | LF    | \$ 6,300,000         |
| <b>Total</b>  |                     |           |          |       | <b>\$ 6,300,000</b>  |
| <b>Total Construction</b>                                       |                     |           |          |       |                      |
|   |                     |           |          |       | <b>\$ 11,311,000</b> |
| <b>LAND ACQUISITION</b>   |                     |           |          |       |                      |
| Right of Way Pipeline in rural areas                            | 8,000 \$/a          |           | 41       | acres | \$ 328,000           |
| Right of Way Pipeline in urban areas                            | 10,748 \$/a         |           | 0        | acres | \$ -                 |
| Pump Station Site acquisition                                   | 2,000 \$/a          |           | 4        | acres | \$ 8,000             |
| <b>ENVIRONMENTAL &amp; ARCHEOLOGICAL STUDIES AND MITIGATION</b> |                     |           |          |       |                      |
| Pipeline  | 25,000 \$/mile      |           | 5.7      | miles | \$ 142,500           |
| Other   | 48,000 \$           |           |          |       | \$ 48,000            |
| <b>TOTAL CONSTRUCTION COST</b>                                  |                     |           |          |       |                      |
|   |                     |           |          |       | <b>\$ 11,837,500</b> |

| ANNUAL O&M COSTS          |        |              |          |       |                     |
|---------------------------|--------|--------------|----------|-------|---------------------|
| Pipeline O&M              | 0.25 % | 6,300,000 \$ |          |       | \$ 16,000           |
| Intake Pump Stations O&M  | 3 %    | 5,011,000 \$ |          |       | \$ 150,000          |
| Pump Pressure             | 40 psi |              |          |       |                     |
| Pump Efficiency           | 0.8    |              |          |       |                     |
| Pumping Energy Costs      |        | 0.06 \$/kW-  | 5983.159 | kW-hr | \$ 131,000          |
| Purchase of Raw Water     |        | 45 \$/AF     | 18482.06 | AF    | \$ 832,000          |
| <b>TOTAL O&amp;M COST</b> |        |              |          |       |                     |
|                           |        |              |          |       | <b>\$ 1,129,000</b> |

CAPITAL AND O&M COSTS

Alternative 2: 27.5 MGD untreated water to be purchase water from the BRA to Site A

Phase 2: 11 MGD (2030 Expansion)

| CAPITAL COSTS               |                     |               |                |                  |
|-----------------------------|---------------------|---------------|----------------|------------------|
| ITEMS                       | Unit Cost           | Units         | Quantity       | Updated Cost     |
| <b>RAW WATER SUPPLY</b>     |                     |               |                |                  |
| <b>Pump Stations</b>        |                     |               |                |                  |
| Raw water Pump Station      | 220 HP              | 1,589,000 \$  | 1 LS           | \$ 1,589,000     |
| Intake Structure            | 20% of Pump Station | 317,800 \$    | 1 LS           | \$ 318,000       |
| Power Connection            |                     | 125 \$/Hp     | 220 HP         | \$ 28,000        |
| Standby Power               | 35% of Pump Station | 556,150 \$    | 1 LS           | \$ 556,000       |
| <b>Total</b>                |                     |               |                | <b>2,491,000</b> |
| <b>Total Construction</b>   |                     |               |                | <b>2,491,000</b> |
| <b>ANNUAL O&amp;M COSTS</b> |                     |               |                |                  |
| Pipeline O&M                | 0.25 %              | 20,370,000 \$ |                | \$ 51,000        |
| Intake Pump Stations O&M    | 3 %                 | 9,710,000 \$  |                | \$ 291,000       |
| Pump Pressure               | 40 psi              |               |                |                  |
| Pump Efficiency             | 0.8                 |               |                |                  |
| Pumping Energy Costs        |                     | 0.06 \$/kW    | 9971.931 kW-hr | \$ 218,000       |
| Purchase of Raw Water       |                     | 45 \$/AF      | 30803.44 AF    | \$ 1,386,000     |
| <b>TOTAL O&amp;M COST</b>   |                     |               |                | <b>1,946,000</b> |

CAPITAL AND O&M COSTS

Alternative 2: 16.5 MGD untreated water to be purchase water from the BRA to Site E

Phase 1: 16.5 MGD (2010)

| CAPITAL COSTS   |                     |           |          |       |                      |
|---|---------------------|-----------|----------|-------|----------------------|
| ITEMS   | Unit Cost           | Units     | Quantity | Units | Updated Cost         |
| <b>RAW WATER SUPPLY</b>   |                     |           |          |       |                      |
| <b>Pump Stations</b>  |                     |           |          |       |                      |
| Raw water Pump Station  | 470 HP              |           | 1        | LS    | \$ 4,619,000         |
| Intake Structure  | 20% of Pump Station |           | 1        | LS    | \$ 924,000           |
| Power Connection  |                     | 125 \$/Hp | 470      | HP    | \$ 59,000            |
| Standby Power   | 35% of Pump Station |           | 1        | LS    | \$ 1,617,000         |
| <b>Total</b>  |                     |           |          |       | <b>\$ 7,219,000</b>  |
| <b>Piping</b>   |                     |           |          |       |                      |
| Open Cut Trenches   |                     |           |          |       |                      |
| Pipe @ 42" in rural areas                                       | 210 \$/ft           |           | 97000    | LF    | \$ 20,370,000        |
| <b>Total</b>  |                     |           |          |       | <b>\$ 20,370,000</b> |
| <b>Total Construction</b>                                       |                     |           |          |       |                      |
|   |                     |           |          |       | <b>\$ 27,589,000</b> |
| <b>LAND ACQUISITION</b>   |                     |           |          |       |                      |
| Right of Way Pipeline in rural areas                            | 8,000 \$/a          |           | 134      | acres | \$ 1,072,000         |
| Right of Way Pipeline in urban areas                            | 10,748 \$/a         |           | 0        | acres | \$ -                 |
| Pump Station Site acquisition                                   | 2,000 \$/a          |           | 4        | acres | \$ 8,000             |
| <b>ENVIRONMENTAL &amp; ARCHEOLOGICAL STUDIES AND MITIGATION</b> |                     |           |          |       |                      |
| Pipeline  | 25,000 \$/mile      |           | 18       | miles | \$ 450,000           |
| Other   | 48,000 \$           |           |          |       | \$ 48,000            |
| <b>TOTAL CONSTRUCTION COST</b>                                  |                     |           |          |       |                      |
|   |                     |           |          |       | <b>\$ 29,167,000</b> |

| ANNUAL O&M COSTS          |        |               |          |       |                     |
|---------------------------|--------|---------------|----------|-------|---------------------|
| Pipeline O&M              | 0.25 % | 20,370,000 \$ |          |       | \$ 51,000           |
| Intake Pump Stations O&M  | 3 %    | 7,219,000 \$  |          |       | \$ 217,000          |
| Pump Pressure             | 56 psi |               |          |       |                     |
| Pump Efficiency           | 0.8    |               |          |       |                     |
| Pumping Energy Costs      |        | 0.06 \$/kW-   | 8376.422 | kW-hr | \$ 183,000          |
| Purchase of Raw Water     |        | 45 \$/AF      | 18482.06 | AF    | \$ 832,000          |
| <b>TOTAL O&amp;M COST</b> |        |               |          |       |                     |
|                           |        |               |          |       | <b>\$ 1,283,000</b> |

**CAPITAL AND O&M COSTS**

Alternative 2: 27.5 MGD untreated water to be purchase water from the BRA to Site E

Phase 2: 11 MGD (2030 Expansion)

| <b>CAPITAL COSTS</b>        |                     |               |       |               |                  |
|-----------------------------|---------------------|---------------|-------|---------------|------------------|
| ITEMS                       |                     | Unit Cost     | Units | Quantity      | Updated Cost     |
| <b>RAW WATER SUPPLY</b>     |                     |               |       |               |                  |
| <b>Pump Stations</b>        |                     |               |       |               |                  |
| Raw water Pump Station      | 310 HP              | 2,958,000 \$  |       | 1 LS          | \$ 2,958,000     |
| Intake Structure            | 20% of Pump Station | 591,600 \$    |       | 1 LS          | \$ 592,000       |
| Power Connection            |                     | 125 \$/Hp     |       | 310 HP        | \$ 39,000        |
| Standby Power               | 35% of Pump Station | 1,035,300 \$  |       | 1 LS          | \$ 1,035,000     |
| <b>Total</b>                |                     |               |       |               | <b>4,624,000</b> |
| <b>Total Construction</b>   |                     |               |       |               | <b>4,624,000</b> |
| <b>ANNUAL O&amp;M COSTS</b> |                     |               |       |               |                  |
| Pipeline O&M                | 0.25 %              | 20,370,000 \$ |       |               | \$ 51,000        |
| Intake Pump Stations O&M    | 3 %                 | 11,843,000 \$ |       |               | \$ 355,000       |
| Pump Pressure               | 56 psi              |               |       |               |                  |
| Pump Efficiency             | 0.8                 |               |       |               |                  |
| Pumping Energy Costs        |                     | 0.06 \$/kW-   |       | 13960.7 kW-hr | \$ 306,000       |
| Purchase of Raw Water       |                     | 45 \$/AF      |       | 30803.44 AF   | \$ 1,386,000     |
| <b>TOTAL O&amp;M COST</b>   |                     |               |       |               | <b>2,098,000</b> |



CAPITAL AND O&M COSTS

Alternative 3: 16.5 MGD untreated water to be purchase water from the CBWC

Phase 1: 16.5 MGD (2010)

| CAPITAL COSTS   |                     |               |           |       |                      |
|---|---------------------|---------------|-----------|-------|----------------------|
| ITEMS   | Unit Cost           | Units         | Quantity  | Units | Updated Cost         |
| <b>RAW WATER SUPPLY</b>   |                     |               |           |       |                      |
| <b>Pump Stations</b>  |                     |               |           |       |                      |
| Raw water Pump Station  | 250 HP              | 2,099,000 \$  | 1         | LS    | \$ 2,099,000         |
| Intake Structure  | 20% of Pump Station | 419,800 \$    | 1         | LS    | \$ 420,000           |
| Power Connection  | 125 \$/Hp           |               | 250       | HP    | \$ 31,000            |
| Standby Power   | 35% of Pump Station | 734,650 \$    | 1         | LS    | \$ 735,000           |
| <b>Total</b>  |                     |               |           |       | <b>\$ 3,285,000</b>  |
| <b>Piping</b>   |                     |               |           |       |                      |
| Open Cut Trenches   |                     |               |           |       |                      |
| Pipe @ 30" in rural areas                                       | 120 \$/feet         |               | 11600     | LF    | \$ 1,392,000         |
| <b>Total Construction</b>                                       |                     |               |           |       | <b>\$ 4,677,000</b>  |
| <b>LAND ACQUISITION</b>   |                     |               |           |       |                      |
| Right of Way Pipeline in rural areas                            | 8,000 \$/a          |               | 16        | acres | \$ 128,000           |
| Right of Way Pipeline in urban areas                            | 10,748 \$/a         |               | 0         | acres | \$ -                 |
| Pump Station Site acquisition                                   | 2,000 \$/a          |               | 4         | acres | \$ 8,000             |
| <b>ENVIRONMENTAL &amp; ARCHEOLOGICAL STUDIES AND MITIGATION</b> |                     |               |           |       |                      |
| Pipeline  | 25,000 \$/mile      |               | 2         | miles | \$ 50,000            |
| Other   | 48,000 \$           |               |           |       | \$ 48,000            |
| <b>Purchase Water Rights</b>                                    | 200 \$/AF           |               | 30794     | AF    | \$ 6,159,000         |
| <b>TOTAL CAPITAL COST</b>                                       |                     |               |           |       | <b>\$ 11,070,000</b> |
| <b>ANNUAL O&amp;M COSTS</b>                                     |                     |               |           |       |                      |
| Pipeline O&M  | 1 %                 | 1,392,000 \$  |           |       | \$ 14,000            |
| Intake Pump Stations O&M  | 2.5 %               | 3,285,000 \$  |           |       | \$ 82,000            |
| Pump Pressure   | 30 psi              |               |           |       |                      |
| Pump Efficiency   | 0.8                 |               |           |       |                      |
| Pumping Energy Costs  |                     | 0.06 \$/kW-hr | 4487.369  | kW-hr | \$ 98,000            |
| Existing CBWC Energy Costs (10 psi)                             |                     | 0.06 \$/kW-hr | 1495.7897 | kW-hr | \$ 33,000            |
| <b>TOTAL O&amp;M COST</b>                                       |                     |               |           |       | <b>\$ 227,000</b>    |

**CAPITAL AND O&M COSTS**

Alternative 3: 27.5 MGD untreated water to be purchase water from the CBWC

Phase 1: 11 MGD (2030 Expansion)

| <b>CAPITAL COSTS</b>                |                     |                 |           |       |                   |
|-------------------------------------|---------------------|-----------------|-----------|-------|-------------------|
| ITEMS                               | Unit Cost           | Units           | Quantity  | Units | Updated Cost      |
| <b>RAW WATER SUPPLY</b>             |                     |                 |           |       |                   |
| <b>Pump Stations</b>                |                     |                 |           |       |                   |
| Raw water Pump Station              | 170 HP              | 560,000 \$      | 1         | LS    | \$ 560,000        |
| Intake Structure                    | 20% of Pump Station | 112,000 \$      | 1         | LS    | \$ 112,000        |
| Power Connection                    |                     | 125 \$/Hp       | 170       | HP    | \$ 21,000         |
| Standby Power                       | 35% of Pump Station | 196,000 \$      | 1         | LS    | \$ 196,000        |
| <b>Total</b>                        |                     |                 |           |       | <b>\$ 889,000</b> |
| <b>Total Construction</b>           |                     |                 |           |       | <b>\$ 889,000</b> |
| <b>TOTAL CAPITAL COST</b>           |                     |                 |           |       | <b>\$ 889,000</b> |
| <b>ANNUAL O&amp;M COSTS</b>         |                     |                 |           |       |                   |
| Pipeline O&M                        | 1 %                 | 1,392,000 \$    |           |       | \$ 14,000         |
| Intake Pump Stations O&M            | 3 %                 | 4,174,000 \$    |           |       | \$ 125,000        |
| Pump Pressure                       | 30 psi              |                 |           |       |                   |
| Pump Efficiency                     | 0.8                 |                 |           |       |                   |
| Pumping Energy Costs                |                     | 0.06 \$/kW-hr   | 7478.9484 | kW-hr | \$ 164,000        |
| Existing CBWC Energy Costs (10 psi) |                     | 0.0598 \$/kW-hr | 2492.9828 | kW-hr | \$ 54,000         |
| <b>TOTAL O&amp;M COST</b>           |                     |                 |           |       | <b>\$ 357,000</b> |



**Appendix I**  
**Raw Water Capital and O&M Costs**

---

**Capital and O&M Costs**

**Alternative 1: Raw Water Purchase from GCWA**

| ITEMS                             | COST (M\$, YR 2000)    |                      |
|-----------------------------------|------------------------|----------------------|
|                                   | 16.5 MGD Initial Phase | 11 MGD Expansion     |
| <b>Raw Water Pumping Station</b>  |                        |                      |
| Property                          | \$ -                   | \$ -                 |
| Pump Station                      | \$ -                   | \$ -                 |
| <b>Raw Water Pipeline</b>         |                        |                      |
| Pipelines                         | \$ -                   | \$ -                 |
| Easements                         | \$ -                   | \$ -                 |
| <b>Subtotal</b>                   | \$ -                   | \$ -                 |
| Engineering Contingency (10%)     | \$ -                   | \$ -                 |
| Construction Contingency (5%)     | \$ -                   | \$ -                 |
| Cost Contingency (20%)            | \$ -                   | \$ -                 |
| <b>Total Construction</b>         | \$ -                   | \$ -                 |
| Environmental Studies             | \$ -                   | \$ -                 |
| Water Rights Purchase             | \$ -                   | \$ -                 |
| Engineering (15%)                 | \$ -                   | \$ -                 |
| Construction Administration (5%)  | \$ -                   | \$ -                 |
| MBCPG Administration (3%)         | \$ -                   | \$ -                 |
| <b>Total Capital Cost</b>         | \$ -                   | \$ -                 |
| <b>Annual O&amp;M Costs</b>       |                        |                      |
| ITEMS                             | COST (M\$, YR 2000)    |                      |
|                                   | 2010-2030 (16.5 MGD)   | 2030-2050 (27.5 MGD) |
| Raw Water Pumping                 | \$ -                   | \$ -                 |
| Raw Water Pipelines               | \$ -                   | \$ -                 |
| Cost of Raw Water                 | \$ 542,000             | \$ 903,000           |
| <b>Total Annual O&amp;M Cost</b>  | \$ 542,000             | \$ 903,000           |
| <b>Present Worth (Yr 2000 \$)</b> | <b>\$15,276,000</b>    |                      |

**Capital and O&M Costs**

**Alternative 2: Raw Water Purchase through CBWC**

| ITEMS                            | COST (M\$, YR 2000)    |                     |
|----------------------------------|------------------------|---------------------|
|                                  | 16.5 MGD Initial Phase | 11 MGD Expansion    |
| <b>Raw Water Pumping Station</b> |                        |                     |
| <i>Property</i>                  | \$ 8,000               | \$ -                |
| <i>Pump Station</i>              | \$ 3,285,000           | \$ 889,000          |
| <b>Raw Water Pipeline</b>        |                        |                     |
| <i>Pipelines</i>                 | \$ 1,392,000           | \$ -                |
| <i>Easements</i>                 | \$ 128,000             | \$ -                |
| <b>Subtotal</b>                  | <b>\$ 4,813,000</b>    | <b>\$ 889,000</b>   |
| Engineering Contingency (10%)    | \$ 480,000             | \$ 90,000           |
| Construction Contingency (5%)    | \$ 240,000             | \$ 40,000           |
| Cost Contingency (20%)           | \$ 960,000             | \$ 180,000          |
| <b>Total Construction</b>        | <b>\$ 6,493,000</b>    | <b>\$ 1,199,000</b> |
| Environmental Studies            | \$ 98,000              | \$ -                |
| Water Rights Purchase            | \$ 6,159,000           | \$ -                |
| Engineering (15%)                | \$ 970,000             | \$ 180,000          |
| Construction Administration (5%) | \$ 320,000             | \$ 60,000           |
| MCBPG Administration (3%)        | \$ 190,000             | \$ 40,000           |
| <b>Total Capital Cost</b>        | <b>\$ 14,230,000</b>   | <b>\$ 1,479,000</b> |

**Annual O&M Costs**

| ITEMS                             | COST (M\$, YR 2000)  |                      |
|-----------------------------------|----------------------|----------------------|
|                                   | 2010-2030 (16.5 MGD) | 2030-2050 (27.5 MGD) |
| <i>Raw Water Pumping</i>          | \$ 131,000           | \$ 218,000           |
| <i>Maintenance</i>                | \$ 96,000            | \$ 139,000           |
| <i>Cost of Raw Water</i>          | \$ -                 | \$ -                 |
| <b>Total Annual O&amp;M Cost</b>  | <b>\$ 227,000</b>    | <b>\$ 357,000</b>    |
| <b>Present Worth (Yr 2000 \$)</b> | <b>\$17,873,000</b>  |                      |

## Capital and O&M Costs

### Alternative 3A: Raw Water Purchase through BRA to Site A in Manvel

| ITEMS                             | COST (M\$, YR 2000)    |                      |
|-----------------------------------|------------------------|----------------------|
|                                   | 16.5 MGD Initial Phase | 11 MGD Expansion     |
| <b>Raw Water Pumping Station</b>  |                        |                      |
| Property                          | \$ 8,000               | \$ -                 |
| Pump Station                      | \$ 5,011,000           | \$ 2,491,000         |
| <b>Raw Water Pipeline</b>         |                        |                      |
| Pipelines                         | \$ 6,300,000           | \$ -                 |
| Easements                         | \$ 328,000             | \$ -                 |
| <b>Subtotal</b>                   | <b>\$ 11,647,000</b>   | <b>\$ 2,491,000</b>  |
| Engineering Contingency (10%)     | \$ 1,160,000           | \$ 250,000           |
| Construction Contingency (5%)     | \$ 580,000             | \$ 120,000           |
| Cost Contingency (20%)            | \$ 2,330,000           | \$ 500,000           |
| <b>Total Construction</b>         | <b>\$ 15,717,000</b>   | <b>\$ 3,361,000</b>  |
| Environmental Studies             | \$ 190,500             | \$ -                 |
| Water Rights Purchase             | \$ -                   | \$ -                 |
| Engineering (15%)                 | \$ 2,360,000           | \$ 500,000           |
| Construction Administration (5%)  | \$ 790,000             | \$ 170,000           |
| MCBPG Administration (3%)         | \$ 470,000             | \$ 100,000           |
| <b>Total Capital Cost</b>         | <b>\$ 19,527,500</b>   | <b>\$ 4,131,000</b>  |
| <b>Annual O&amp;M Costs</b>       |                        |                      |
| ITEMS                             | COST (M\$, YR 2000)    |                      |
|                                   | 2010-2030 (16.5 MGD)   | 2030-2050 (27.5 MGD) |
| Raw Water Pumping                 | \$ 131,000             | \$ 218,000           |
| Maintenance                       | \$ 166,000             | \$ 342,000           |
| Cost of Raw Water                 | \$ 832,000             | \$ 1,386,000         |
| <b>Total Annual O&amp;M Cost</b>  | <b>\$ 1,129,000</b>    | <b>\$ 1,946,000</b>  |
| <b>Present Worth (Yr 2000 \$)</b> | <b>\$49,113,000</b>    |                      |

**Capital and O&M Costs**

**Alternative 3B: Raw Water Purchase through BRA to Site E in Alvin**

| ITEMS                             | COST (M\$, YR 2000)    |                      |
|-----------------------------------|------------------------|----------------------|
|                                   | 16.5 MGD Initial Phase | 11 MGD Expansion     |
| <b>Raw Water Pumping Station</b>  |                        |                      |
| Property                          | \$ 8,000               | \$ -                 |
| Pump Station                      | \$ 7,219,000           | \$ 4,624,000         |
| <b>Raw Water Pipeline</b>         |                        |                      |
| Pipelines                         | \$ 20,370,000          | \$ -                 |
| Easements                         | \$ 1,072,000           | \$ -                 |
| <b>Subtotal</b>                   | <b>\$ 28,669,000</b>   | <b>\$ 4,624,000</b>  |
| Engineering Contingency (10%)     | \$ 2,870,000           | \$ 460,000           |
| Construction Contingency (5%)     | \$ 1,430,000           | \$ 230,000           |
| Cost Contingency (20%)            | \$ 5,730,000           | \$ 920,000           |
| <b>Total Construction</b>         | <b>\$ 38,699,000</b>   | <b>\$ 6,234,000</b>  |
| Environmental Studies             | \$ 498,000             | \$ -                 |
| Water Rights Purchase             | \$ -                   | \$ -                 |
| Engineering (15%)                 | \$ 5,800,000           | \$ 940,000           |
| Construction Administration (5%)  | \$ 1,930,000           | \$ 310,000           |
| MCBPG Administration (3%)         | \$ 1,160,000           | \$ 190,000           |
| <b>Total Capital Cost</b>         | <b>\$ 48,087,000</b>   | <b>\$ 7,674,000</b>  |
| <b>Annual O&amp;M Costs</b>       |                        |                      |
| ITEMS                             | COST (M\$, YR 2000)    |                      |
|                                   | 2010-2030 (16.5 MGD)   | 2030-2050 (27.5 MGD) |
| Raw Water Pumping                 | \$ 183,000             | \$ 306,000           |
| Maintenance                       | \$ 268,000             | \$ 406,000           |
| Cost of Raw Water                 | \$ 832,000             | \$ 1,386,000         |
| <b>Total Annual O&amp;M Cost</b>  | <b>\$ 1,283,000</b>    | <b>\$ 2,098,000</b>  |
| <b>Present Worth (Yr 2000 \$)</b> | <b>\$75,979,000</b>    |                      |



**Annual O&M Costs**

**Alternative 4: Raw Water Delivery to GCWA FT Bend, Harris County WTP**

| ITEMS                                      | COST (M\$, YR 2000)    |                   |
|--|------------------------|-------------------|
|  | 16.5 MGD Initial Phase | 11 MGD Expansion  |
| <i>Cost of Water (\$0.07 per 1000 gal)</i> | \$ 422,000             | \$ 703,000        |
| <b>Total Annual O&amp;M Cost</b>           | <b>\$ 422,000</b>      | <b>\$ 703,000</b> |
| <b>Present Worth (Yr 2000 \$)</b>          | <b>\$11,893,000</b>    |                   |

**Appendix J**  
**Finished Water Transmission and O&M Costs**

---

| <b>Capital and O&amp;M Costs</b>                                |                      |                      |  |
|---|----------------------|----------------------|--|
| <b>Alternative 1A: Manvel Site Delivering Water At Pressure</b> |                      |                      |  |
| ITEMS   | COST (M\$, YR 2000)  |                      |  |
|   | 15 MGD Initial Phase | 10 MGD Expansion     |  |
| <b>Water Treatment Plant</b>                                    |                      |                      |  |
| Property  | \$ 700,000           | \$ -                 |  |
| Plant   | \$ 22,931,000        | \$ 7,930,000         |  |
| Additional Site Work (Flood Plain)                              | \$ 60,000            | \$ -                 |  |
| <b>Finished Water Transmission</b>                              |                      |                      |  |
| High Service Pump Station                                       | \$ 840,000           | \$ 560,000           |  |
| Booster Pump Station and Ground Storage                         | \$ 1,848,000         | \$ 1,232,000         |  |
| Pipelines   | \$ 19,820,000        | \$ -                 |  |
| Easements   | \$ 760,000           | \$ -                 |  |
| <b>Subtotal</b>   | <b>\$ 46,959,000</b> | <b>\$ 9,722,000</b>  |  |
| Engineering Contingency (10%)                                   | \$ 4,700,000         | \$ 970,000           |  |
| Construction Contingency (5%)                                   | \$ 2,350,000         | \$ 490,000           |  |
| Cost Contingency (20%)  | \$ 9,390,000         | \$ 1,940,000         |  |
| <b>Total Construction</b>                                       | <b>\$ 63,399,000</b> | <b>\$ 13,122,000</b> |  |
| Engineering (15%)   | \$ 9,510,000         | \$ 1,970,000         |  |
| Construction Administration (5%)                                | \$ 3,170,000         | \$ 660,000           |  |
| MBCPG Administration (3%)                                       | \$ 1,900,000         | \$ 390,000           |  |
| <b>Total Capital Cost</b>                                       | <b>\$ 77,979,000</b> | <b>\$ 16,142,000</b> |  |
| <b>Annual O&amp;M Costs</b>                                     |                      |                      |  |
| ITEMS   | COST (M\$, YR 2000)  |                      |  |
|   | 2010-2030 (15 MGD)   | 2030-2050 (25 MGD)   |  |
| Plant   | \$ 3,443,000         | \$ 4,702,000         |  |
| Finished Water Pumping and Pipelines                            | \$ 370,000           | \$ 560,000           |  |
| <b>Total Annual O&amp;M Cost</b>                                | <b>\$ 3,813,000</b>  | <b>\$ 5,262,000</b>  |  |
| <b>Present Worth (Yr 2000 \$)</b>                               | <b>\$159,841,000</b> |                      |  |

**Capital and O&M Costs**

**Alternative 1B: Manvel Site Delivering Water To GSTs**

| ITEMS                                   | COST (M\$, YR 2000)  |                      |
|---|----------------------|----------------------|
|   | 15 MGD Initial Phase | 10 MGD Expansion     |
| <b>Water Treatment Plant</b>            |                      |                      |
| Property                                | \$ 700,000           | \$ -                 |
| Plant                                   | \$ 22,931,000        | \$ 7,930,000         |
| Additional Site Work (Flood Plain)      | \$ 60,000            | \$ -                 |
| <b>Finished Water Transmission</b>      |                      |                      |
| High Service Pump Station               | \$ 840,000           | \$ 560,000           |
| Booster Pump Station and Ground Storage | \$ 3,924,000         | \$ 2,616,000         |
| Pipelines                               | \$ 18,530,000        | \$ -                 |
| Easements                               | \$ 760,000           | \$ -                 |
| <b>Subtotal</b>                         | <b>\$ 47,745,000</b> | <b>\$ 11,106,000</b> |
| Engineering Contingency (10%)           | \$ 4,770,000         | \$ 1,110,000         |
| Construction Contingency (5%)           | \$ 2,390,000         | \$ 560,000           |
| Cost Contingency (20%)                  | \$ 9,550,000         | \$ 2,220,000         |
| <b>Total Construction</b>               | <b>\$ 64,455,000</b> | <b>\$ 14,996,000</b> |
| Engineering (15%)                       | \$ 9,670,000         | \$ 2,250,000         |
| Construction Administration (5%)        | \$ 3,220,000         | \$ 750,000           |
| MBCPG Administration (3%)               | \$ 1,930,000         | \$ 450,000           |
| <b>Total Capital Cost</b>               | <b>\$ 79,275,000</b> | <b>\$ 18,446,000</b> |
| <b>Annual O&amp;M Costs</b>             |                      |                      |
| ITEMS                                   | COST (M\$, YR 2000)  |                      |
|   | 2010-2030 (15 MGD)   | 2030-2050 (25 MGD)   |
| Plant                                   | \$ 3,443,000         | \$ 4,702,000         |
| Finished Water Pumping and Pipelines    | \$ 460,000           | \$ 690,000           |
| <b>Total Annual O&amp;M Cost</b>        | <b>\$ 3,903,000</b>  | <b>\$ 5,392,000</b>  |
| <b>Present Worth (Yr 2000 \$)</b>       | <b>\$163,748,000</b> |                      |

**Capital and O&M Costs**

**Alternative 2A: Alvin Site Delivering Water At Pressure**

| ITEMS                                   | COST (M\$, YR 2000)  |                      |
|---|----------------------|----------------------|
|   | 15 MGD Initial Phase | 10 MGD Expansion     |
| <b>Water Treatment Plant</b>            |                      |                      |
| Property                                | \$ -                 | \$ -                 |
| Plant                                   | \$ 22,931,000        | \$ 7,930,000         |
| Additional Site Work                    | \$ -                 | \$ -                 |
| <b>Finished Water Transmission</b>      |                      |                      |
| High Service Pump Station               | \$ 840,000           | \$ 560,000           |
| Booster Pump Station and Ground Storage | \$ 1,848,000         | \$ 1,232,000         |
| Pipelines                               | \$ 26,520,000        | \$ -                 |
| Easements                               | \$ 820,000           | \$ -                 |
| <b>Subtotal</b>                         | <b>\$ 52,959,000</b> | <b>\$ 9,722,000</b>  |
| Engineering Contingency (10%)           | \$ 5,300,000         | \$ 970,000           |
| Construction Contingency (5%)           | \$ 2,650,000         | \$ 490,000           |
| Cost Contingency (20%)                  | \$ 10,590,000        | \$ 1,940,000         |
| <b>Total Construction</b>               | <b>\$ 71,499,000</b> | <b>\$ 13,122,000</b> |
| Engineering (15%)                       | \$ 10,720,000        | \$ 1,970,000         |
| Construction Administration (5%)        | \$ 3,570,000         | \$ 660,000           |
| MBCPG Administration (3%)               | \$ 2,140,000         | \$ 390,000           |
| <b>Total Capital Cost</b>               | <b>\$ 87,929,000</b> | <b>\$ 16,142,000</b> |
| <b>Annual O&amp;M Costs</b>             |                      |                      |
| ITEMS                                   | COST (M\$, YR 2000)  |                      |
|   | 2010-2030 (15 MGD)   | 2030-2050 (25 MGD)   |
| Plant                                   | \$ 3,443,000         | \$ 4,702,000         |
| Finished Water Pumping and Pipelines    | \$ 410,000           | \$ 600,000           |
| <b>Total Annual O&amp;M Cost</b>        | <b>\$ 3,853,000</b>  | <b>\$ 5,302,000</b>  |
| <b>Present Worth (Yr 2000 \$)</b>       | <b>\$168,571,000</b> |                      |

**Capital and O&M Costs**

**Alternative 2B: Alvin Site Delivering Water To GSTs**

| ITEMS                                   | COST (M\$, YR 2000)  |                      |
|---|----------------------|----------------------|
|   | 15 MGD Initial Phase | 10 MGD Expansion     |
| <b>Water Treatment Plant</b>            |                      |                      |
| Property                                | \$ -                 | \$ -                 |
| Plant                                   | \$ 22,931,000        | \$ 7,930,000         |
| Additional Site Work                    | \$ -                 | \$ -                 |
| <b>Finished Water Transmission</b>      |                      |                      |
| High Service Pump Station               | \$ 840,000           | \$ 560,000           |
| Booster Pump Station and Ground Storage | \$ 3,924,000         | \$ 2,616,000         |
| Pipelines                               | \$ 23,610,000        | \$ -                 |
| Easements                               | \$ 820,000           | \$ -                 |
| <b>Subtotal</b>                         | <b>\$ 52,125,000</b> | <b>\$ 11,106,000</b> |
| Engineering Contingency (10%)           | \$ 5,210,000         | \$ 1,110,000         |
| Construction Contingency (5%)           | \$ 2,610,000         | \$ 560,000           |
| Cost Contingency (20%)                  | \$ 10,430,000        | \$ 2,220,000         |
| <b>Total Construction</b>               | <b>\$ 70,375,000</b> | <b>\$ 14,996,000</b> |
| Engineering (15%)                       | \$ 10,560,000        | \$ 2,250,000         |
| Construction Administration (5%)        | \$ 3,520,000         | \$ 750,000           |
| MBCPG Administration (3%)               | \$ 2,110,000         | \$ 450,000           |
| <b>Total Capital Cost</b>               | <b>\$ 86,565,000</b> | <b>\$ 18,446,000</b> |

**Annual O&M Costs**

| ITEMS                                | COST (M\$, YR 2000)  |                     |
|--------------------------------------|----------------------|---------------------|
|                                      | 2010-2030 (15 MGD)   | 2030-2050 (25 MGD)  |
| Plant                                | \$ 3,443,000         | \$ 4,702,000        |
| Finished Water Pumping and Pipelines | \$ 490,000           | \$ 720,000          |
| <b>Total Annual O&amp;M Cost</b>     | <b>\$ 3,933,000</b>  | <b>\$ 5,422,000</b> |
| <b>Present Worth (Yr 2000 \$)</b>    | <b>\$170,158,000</b> |                     |

**Capital and O&M Costs**

**Alternative 3A: GCWA Fort Bend County Regional WTP Delivering Water At Pressure**

| ITEMS                                   | COST (M\$, YR 2000)  |                      |
|---|----------------------|----------------------|
|   | 15 MGD Initial Phase | 10 MGD Expansion     |
| <b>Water Treatment Plant</b>            |                      |                      |
| Property                                | \$ -                 | \$ -                 |
| Plant                                   | \$ 13,950,000        | \$ 7,100,000         |
| Additional Site Work                    | \$ -                 | \$ -                 |
| <b>Finished Water Transmission</b>      |                      |                      |
| High Service Pump Station               | \$ 840,000           | \$ 560,000           |
| Booster Pump Station and Ground Storage | \$ 1,848,000         | \$ 1,232,000         |
| Pipelines                               | \$ 37,050,000        | \$ -                 |
| Easements                               | \$ 1,750,000         | \$ -                 |
| <b>Subtotal</b>                         | <b>\$ 55,438,000</b> | <b>\$ 8,892,000</b>  |
| Engineering Contingency (10%)           | \$ 5,540,000         | \$ 890,000           |
| Construction Contingency (5%)           | \$ 2,770,000         | \$ 440,000           |
| Cost Contingency (20%)                  | \$ 11,090,000        | \$ 1,780,000         |
| <b>Total Construction</b>               | <b>\$ 74,838,000</b> | <b>\$ 12,002,000</b> |
| Engineering (15%)                       | \$ 11,230,000        | \$ 1,800,000         |
| Construction Administration (5%)        | \$ 3,740,000         | \$ 600,000           |
| MBCPG Administration (3%)               | \$ 2,250,000         | \$ 360,000           |
| <b>Total Capital Cost</b>               | <b>\$ 92,058,000</b> | <b>\$ 14,762,000</b> |
| <b>Annual O&amp;M Costs</b>             |                      |                      |
| ITEMS                                   | COST (M\$, YR 2000)  |                      |
|   | 2010-2030 (15 MGD)   | 2030-2050 (25 MGD)   |
| Plant                                   | \$ 2,464,000         | \$ 4,015,000         |
| Finished Water Pumping and Pipelines    | \$ 410,000           | \$ 600,000           |
| <b>Total Annual O&amp;M Cost</b>        | <b>\$ 2,874,000</b>  | <b>\$ 4,615,000</b>  |
| <b>Present Worth (Yr 2000 \$)</b>       | <b>\$154,472,000</b> |                      |

**Capital and O&M Costs**

**Alternative 3B: GCWA Fort Bend County Regional WTP Delivering Water to GSTs**

| ITEMS                                   | COST (M\$, YR 2000)  |                      |
|---|----------------------|----------------------|
|   | 15 MGD Initial Phase | 10 MGD Expansion     |
| <b>Water Treatment Plant</b>            |                      |                      |
| Property                                | \$ -                 | \$ -                 |
| Plant                                   | \$ 13,950,000        | \$ 7,100,000         |
| Additional Site Work                    | \$ -                 | \$ -                 |
| <b>Finished Water Transmission</b>      |                      |                      |
| High Service Pump Station               | \$ 840,000           | \$ 560,000           |
| Booster Pump Station and Ground Storage | \$ 3,924,000         | \$ 2,616,000         |
| Pipelines                               | \$ 35,870,000        | \$ -                 |
| Easements                               | \$ 1,750,000         | \$ -                 |
| <b>Subtotal</b>                         | <b>\$ 56,334,000</b> | <b>\$ 10,276,000</b> |
| Engineering Contingency (10%)           | \$ 5,630,000         | \$ 1,030,000         |
| Construction Contingency (5%)           | \$ 2,820,000         | \$ 510,000           |
| Cost Contingency (20%)                  | \$ 11,270,000        | \$ 2,060,000         |
| <b>Total Construction</b>               | <b>\$ 76,054,000</b> | <b>\$ 13,876,000</b> |
| Engineering (15%)                       | \$ 11,410,000        | \$ 2,080,000         |
| Construction Administration (5%)        | \$ 3,800,000         | \$ 690,000           |
| MBCPG Administration (3%)               | \$ 2,280,000         | \$ 420,000           |
| <b>Total Capital Cost</b>               | <b>\$ 93,544,000</b> | <b>\$ 17,066,000</b> |
| <b>Annual O&amp;M Costs</b>             |                      |                      |
| ITEMS                                   | COST (M\$, YR 2000)  |                      |
|   | 2010-2030 (15 MGD)   | 2030-2050 (25 MGD)   |
| Plant                                   | \$ 2,464,000         | \$ 4,015,000         |
| Finished Water Pumping and Pipelines    | \$ 550,000           | \$ 810,000           |
| <b>Total Annual O&amp;M Cost</b>        | <b>\$ 3,014,000</b>  | <b>\$ 4,825,000</b>  |
| <b>Present Worth (Yr 2000 \$)</b>       | <b>\$159,874,000</b> |                      |



**Capital and O&M Costs**

**Null Alternative: All Groundwater Well Option**

| ITEMS                             |                             | COST (M\$, YR 2000)  |                      |
|-----------------------------------|-----------------------------|----------------------|----------------------|
|                                   |                             | 15 MGD Initial Phase | 10 MGD Expansion     |
| <b>Wells</b>                      |                             |                      |                      |
|                                   | <i>GST</i>                  | \$ 5,659,000         | \$ 2,767,000         |
|                                   | <i>Well</i>                 | \$ 4,623,000         | \$ 3,658,000         |
|                                   | <i>Booster Pump Station</i> | \$ 577,000           | \$ 433,000           |
| <b>Total</b>                      |                             | <b>\$ 10,859,000</b> | <b>\$ 6,858,000</b>  |
| Engineering Contingency (10%)     |                             | \$ 1,090,000         | \$ 690,000           |
| Construction Contingency (5%)     |                             | \$ 540,000           | \$ 340,000           |
| Cost Contingency (20%)            |                             | \$ 2,170,000         | \$ 1,370,000         |
| <b>Total Construction</b>         |                             | <b>\$ 14,659,000</b> | <b>\$ 9,258,000</b>  |
| Engineering (15%)                 |                             | \$ 2,200,000         | \$ 1,390,000         |
| Construction Administration (5%)  |                             | \$ 730,000           | \$ 460,000           |
| MBCPG Administration (3%)         |                             | \$ 440,000           | \$ 280,000           |
| <b>Total Capital Cost</b>         |                             | <b>\$ 18,029,000</b> | <b>\$ 11,388,000</b> |
| <b>Annual O&amp;M Costs</b>       |                             |                      |                      |
| ITEMS                             |                             | COST (M\$, YR 2000)  |                      |
|                                   |                             | 2010-2030 (15 MGD)   | 2030-2050 (25 MGD)   |
|                                   | <i>Electricity</i>          | \$ 1,063,700         | \$ 1,864,000         |
|                                   | <i>Maintenance</i>          | \$ 170,300           | \$ 279,000           |
| <b>Total Annual O&amp;M Cost</b>  |                             | <b>\$ 1,234,000</b>  | <b>\$ 2,143,000</b>  |
| <b>Present Worth (Yr 2000 \$)</b> |                             | <b>\$52,273,000</b>  |                      |

**Appendix K**  
**Water Well Alternative Costs**

---

### ***Phase 1 Water Well Construction and O&M Costs***

| <b>Participating Utility</b> | <b>Capacity Increase (MGD)</b> | <b>Construction Cost</b> | <b>O&amp;M Cost</b> |
|------------------------------|--------------------------------|--------------------------|---------------------|
| Alvin                        | 2.26                           | \$475,000                | \$173,100           |
| Angleton                     | 1.34                           | \$411,000                | \$104,400           |
| Brookside Village            | 0.31                           | \$192,000                | \$27,100            |
| Danbury                      | 0.27                           | \$189,000                | \$24,300            |
| Hillcrest                    | 0.05                           | -                        | -                   |
| Iowa Colony                  | 0.14                           | \$183,000                | \$15,100            |
| Manvel                       | 2.26                           | \$717,000                | \$176,900           |
| Pearland                     | 7.81                           | \$2,456,000              | \$610,700           |
| <b>Total</b>                 | <b>14.44</b>                   | <b>\$4,623,000</b>       | <b>\$1,131,600</b>  |

### ***Phase 2 Water Well Construction and O&M Costs***

| <b>Participating Utility</b> | <b>Capacity Increase (MGD)</b> | <b>Construction Cost</b> | <b>O&amp;M Cost</b> |
|------------------------------|--------------------------------|--------------------------|---------------------|
| Angleton                     | 1.11                           | \$344,000                | \$191,200           |
| Brookside Village            | 0.26                           | \$188,000                | \$50,600            |
| Danbury                      | 0.21                           | \$185,000                | \$44,200            |
| Hillcrest                    | 0.02                           | -                        | -                   |
| Iowa Colony                  | 0.10                           | \$182,000                | \$27,500            |
| Manvel                       | 1.51                           | \$465,000                | \$294,700           |
| Pearland                     | 5.85                           | \$1,839,000              | \$1,068,200         |
| <b>Total</b>                 | <b>9.06</b>                    | <b>\$3,203,000</b>       | <b>\$1,676,400</b>  |

### ***Phase 1 Ground Storage Tank Cost***

| <b>Participating Utility</b> | <b>GST Volume (MG)</b> | <b>Construction Cost</b> | <b>Maintenance Cost</b> |
|------------------------------|------------------------|--------------------------|-------------------------|
| Alvin                        | 2.55                   | \$1,266,000              | \$3,200                 |
| Angleton                     | 0.07                   | \$217,000                | \$500                   |
| Brookside Vill.              | 0.26                   | \$345,000                | \$900                   |
| Danbury                      | 0.24                   | \$331,000                | \$800                   |
| Hillcrest                    | 0.02                   | \$177,000                | \$400                   |
| Iowa Colony                  | 0.10                   | \$238,000                | \$600                   |
| Manvel                       | 1.95                   | \$1,092,000              | \$2,700                 |
| Pearland                     | 5.18                   | \$1,993,000              | \$5,000                 |
| <b>Total</b>                 | <b>10.37</b>           | <b>\$5,659,000</b>       | <b>\$14,100</b>         |

### ***Phase 2 Ground Storage Tank Cost***

| <b>Participating Utility</b> | <b>GST Volume (MG)</b> | <b>Construction Cost</b> | <b>Maintenance Cost</b> |
|------------------------------|------------------------|--------------------------|-------------------------|
| Alvin                        | 2.09                   | \$1,135,100              | \$6,000                 |
| Angleton                     | -                      | -                        | \$500                   |
| Brookside Vill.              | -                      | -                        | \$900                   |
| Danbury                      | -                      | -                        | \$800                   |
| Hillcrest                    | -                      | -                        | \$400                   |
| Iowa Colony                  | -                      | -                        | \$600                   |
| Manvel                       | -                      | -                        | \$2,700                 |
| Pearland                     | 3.91                   | \$1,631,800              | \$9,100                 |
| <b>Total</b>                 | <b>6</b>               | <b>\$2,766,900</b>       | <b>\$21,000</b>         |

**Phase 1 Booster Pump Station Cost**

| Participating Utility | Well Capacity Addition (MGD) | Well Capacity Addition (GPM) | Pump Station Construction Cost | Station Operating Capacity (GPM) | Power (kw-hr) | Annual Operating Cost (\$) | Annual Maintenance Cost (\$) |
|-----------------------|------------------------------|------------------------------|--------------------------------|----------------------------------|---------------|----------------------------|------------------------------|
| Alvin                 | 2.31                         | 1604.17                      | \$92,000                       | 1604.17                          | 518.06        | \$11,300                   | \$2,800                      |
| Angleton              | 1.34                         | 930.56                       | \$54,000                       | 930.56                           | 300.52        | \$6,600                    | \$1,600                      |
| Brookside Village     | 0.31                         | 215.28                       | \$12,000                       | 215.28                           | 69.52         | \$1,500                    | \$400                        |
| Danbury               | 0.27                         | 187.50                       | \$11,000                       | 187.50                           | 60.55         | \$1,300                    | \$300                        |
| Hillcrest             | *                            | *                            | *                              | *                                | *             | *                          | *                            |
| Iowa Colony           | 0.14                         | 97.22                        | \$6,000                        | 97.22                            | 31.40         | \$700                      | \$200                        |
| Manvel                | 2.26                         | 1569.44                      | \$90,000                       | 1569.44                          | 506.84        | \$11,100                   | \$2,700                      |
| Pearland              | 7.81                         | 5423.61                      | \$312,000                      | 5423.61                          | 1751.52       | \$38,400                   | \$9,400                      |
| <b>Total</b>          | <b>14.44</b>                 | <b>10027.78</b>              | <b>\$577,000</b>               |                                  |               | <b>\$70,900</b>            | <b>\$17,400</b>              |

\* - included in Alvin

**Phase 2 Booster Pump Station Cost**

| Participating Utility | Well Capacity Addition (MGD) | Well Capacity Addition (GPM) | Pump Station Construction Cost | Station Operating Capacity (GPM) | Power (kw-hr) | Annual Operating Cost (\$) | Annual Maintenance Cost (\$) |
|-----------------------|------------------------------|------------------------------|--------------------------------|----------------------------------|---------------|----------------------------|------------------------------|
| Alvin                 | 1.82                         | 1263.89                      | \$73,000                       | 2868.06                          | 926.22        | \$20,300                   | \$5,000                      |
| Angleton              | 1.11                         | 770.83                       | \$44,000                       | 1701.39                          | 549.45        | \$12,000                   | \$2,900                      |
| Brookside Village     | 0.26                         | 180.56                       | \$10,000                       | 395.83                           | 127.83        | \$2,800                    | \$700                        |
| Danbury               | 0.21                         | 145.83                       | \$8,000                        | 333.33                           | 107.65        | \$2,400                    | \$600                        |
| Hillcrest             | *                            | *                            | *                              | *                                | *             | *                          | *                            |
| Iowa Colony           | 0.10                         | 69.44                        | \$4,000                        | 166.67                           | 53.82         | \$1,200                    | \$300                        |
| Manvel                | 1.51                         | 1048.61                      | \$60,000                       | 2618.06                          | 845.48        | \$18,500                   | \$4,500                      |
| Pearland              | 5.85                         | 4062.50                      | \$234,000                      | 9486.11                          | 3063.48       | \$67,100                   | \$16,400                     |
| <b>Total</b>          | <b>10.86</b>                 | <b>7541.67</b>               | <b>\$433,000</b>               |                                  |               | <b>\$124,300</b>           | <b>\$30,400</b>              |

\* - included in Alvin

**Appendix L**  
**Progress Meetings**

---

# Mid Brazoria County Water Planning Group TWBD Facility Plan Study

## Kickoff Meeting Agenda

Date: January 29, 2001

Time: 7:00 PM

Place: City of Alvin City Hall

### Agenda:

- 1) Introduction of Attendees
- 2) General Overview of Project
  - A) Project Scope
  - B) Project Schedule
- 3) Review of Requested Information.
  - A) Background Information on the MBCPG member including: City Area, ETJ size, year 2000 population, year 2000 water demand
  - B) Maps of the existing water distribution system (electronic maps if at all possible)
  - C) Maps of Groundwater wells (electronic maps if at all possible)
  - D) Population and Water Demand projections for the year 2010, 2020, 2030, 2040, and 2050
  - E) Existing groundwater water quality records
  - F) MBCPG member data on existing raw water quantity (including contracts), quality, demand, distribution capacity, and storage capacity.
  - G) Description of existing water distribution systems, including water sources, number of wells, length of water distribution mains, number of customers, number and size of ground and elevated storage tanks
  - H) MBCPG Member Water Conservation Plans
  - I) Existing MBCPG well installation costs (size, depth), and existing operations and maintenance.
  - J) Potential regional water treatment plant sites (approximately 40 acres)
  - K) USGS maps of Mid-Brazoria County
- 4) Proposed Report Outline
- 5) Time and Location of Next Progress Meetings
- 6) Discuss the status of formation of the Fresh Water Supply District.

**CITY OF ALVIN**  
**Mid-Brazoria County Planning Group Facility Plan Study**

**Progress Meeting Agenda**

Date: February 26, 2001

Time: 7:00 PM

Place: City of Alvin City Hall

**Agenda:**

- 1) Introductions and Schedule Update
- 2) Present Water Demand Projections
  - a) Region H Projections
  - b) Participating Utilities Projections from Surveys.
- 3) Briscoe Property Presentation
- 4) Alternative Water Treatment Plant Site Locations
  - a) Review Sites
  - b) Review Siting Criteria
  - c) Discuss Pros and Cons of Each Site
- 5) Discuss Water Plant Capacity
  - a) Percentage of Demand to be met through regional facility
- 6) Open Discussion



***Mid Brazoria County Planning  
Group Facility Plan Progress  
Meeting***

Montgomery Watson  
February 26, 2000

---

---

---

---

---

---

---

---

***AGENDA***

- Introductions
- Progress Report
- Water Demand Projections
- Discuss Water Plant Capacity
- Briscoe Property Presentation
- Alternative Water Treatment Plant Site Locations
- Open Discussion

---

---

---

---

---

---

---

---

***Work Completed Last Month***

- Reviewed Region H Data
- Started Water Conservation Plan
- Reviewed FWSD Feasibility
- Completed Population and Water Demand Projections
- Identified Alternate Water Plant Locations

---

---

---

---

---

---

---

---

***Schedule Impacts***

- Currently On Schedule
- Next Step is to:
  - Review / Screen Alternative Site Selections
  - Review Water Demand Allocation
  - Identify Participating Utility Take Points

---

---

---

---

---

---

---

---

***Mid Brazoria County Planning Group Population and Water Demand Projections***

---

---

---

---

---

---

---

---

***Water Demand Source Information***

- TWDB / Region H Planning Group
- Participating Utilities Surveys

---

---

---


---

---

---

---

---



---

---

---

---

---


---

---

---

---

---



---

---

---

---

---

---

---

---

---

---

### Regional Plant Capacity

---

---

---

---

---

---


---

---

---

---

### ***How Is Plant Capacity Determined***



*Meet Demand with Combination of Surface Water And Groundwater*

---

---

---

---

---

---

---

---

### ***Water Plant Capacity Development Constraints***

- Existing Surface Water Contracts
- Blending
- Use of Existing Infrastructure

---

---

---

---

---

---

---

---

### ***Surface Water Plant Capacity Options***

- 1) Meet Average and Peak Demand with Regional Surface Water Plant
- 2) Meet Percentage of Average Demand, Use Groundwater to meet Peak Demands

---

---

---

---

---

---

---

---

### ***Water Plant Capacity Recommendations***

- Smaller Community (< 1 MGD Demand)
  - Construct Facilities to meet 100% Demand Including peak day demand
- Larger Community (> 1 MGD Demand)
  - Construct Facilities to meet 80% Average Demand (minus existing contracts)
  - Use Groundwater To Supplement For Peak Flow

---

---

---

---


---

---

---

---

### ***Plant Capacity***



---

---

---

---


---

---

---

---

### ***Alternate WTP Locations***



---

---

---

---

---

---

---

---

### Site A - Manvel

Location: State Hwy 6 and Iowa Lane  
in Manvel, Texas

53 acres


Asking Price: \$700,000

Raw Water Source: Brazos River through  
GCWA Canal

Adjacent to Hwy 6

Adjacent to Power and Utilities

Sludge Disposal: off-site



---

---

---

---

---

---

---

---

### Site B - Pearland / Alvin

Location: CR 144 and CR 285  
in Alvin ETD


120 acres

Appraisal Value: \$300,000

Raw Water Source: Brazos River through  
GCWA American Canal

Not Adjacent to Power and Utilities

Sludge Disposal: on-site



---

---

---

---

---

---

---

---

### Site C - Alvin Landfill

Location: Adjacent to City of Alvin Landfill,  
off Saladino Road

643 acres

Asking Price: \$\*\*\*\*

Raw Water Source: Brazos River through  
GCWA Canal and Briscoe Property Canal Laterals

Available Space for Raw Water Reservoir

Sludge Disposal: on-site

Not adjacent to Utilities or Power

Not adjacent to Major Thoroughfare



---

---

---

---

---

---

---

---

### Site D - Alvin Landfill

Location: off Parker Davis and West Road  
near Alvin, Texas

919 acres

Asking Price: \$\*\*\*\*

Raw Water Source: Brazos River through  
GCWA Canal


Available Space for Raw Water Reservoir

Sludge Disposal: on-site

Not adjacent to Utilities

Overhead Power Available

Not adjacent to Major Thoroughfare



---

---

---

---

---

---

---

---

### Site E - Alvin

Location: Bitasco Canal and Highway 35  
in Alvin, Texas

278 acres

Asking Price: \$\*\*\*\*

Raw Water Source: Brazos River through  
GCWA Canal

Available Space for Raw Water Reservoir


Sludge Disposal: on-site

Not adjacent to Utilities

Overhead Power Available

Adjacent to Hwy 35

Adjacent to Power and Utilities



---

---

---

---

---

---

---

---

### Action Items

- Evaluate Alternative WTP Sites
  
- Set Design Plant Capacity of
  - ◆ 20 MGD by YR 2010
  - ◆ 29 MGD by YR 2030
  - ◆ Supplement With Groundwater For Peak Demand
  
- Take Points

---

---

---

---

---

---

---

---

**CITY OF ALVIN**  
**Mid-Brazoria County Planning Group Facility Plan Study**

**Progress Meeting Agenda**

Date: April 12, 2001

Time: 7:00 PM

Place: City of Alvin City Hall

**Agenda:**

- 1) Introductions and Schedule Update
- 2) Surface Water Resource Information
- 3) Review Water Plant Capacity
- 4) Review Alternative Water Treatment Plant Site Locations
- 5) Take Points and Pipeline Corridor Analysis Discussion
- 6) Review Model Construction Scenarios
  - a) At Pressure
  - b) Fill Ground Storage Tank
  - c) Other
- 7) Open Discussion



# April Progress Meeting

## Regional Water Supply Facility Plan for Mid-Brazoria County

April 12, 2001

---

---

---

---

---

---

---

---

### AGENDA

- Schedule Update
- Review of Surface Water options for the Mid-Brazoria County Planning Group
- Review of alternate Surface Water Treatment Plant Sites
- Review of selected SWTP Capacity
- Review of Transmission Main System Analysis

---

---

---

---

---

---

---

---

### Schedule Update

| C | ID  | Task Name   | 1st Quarter |             | 2nd Quarter |     |     | 3rd Quarter |     |     |     |  |
|---|-----|---|-------------|-------------|-------------|-----|-----|-------------|-----|-----|-----|--|
|   |     |   | Start       | Finish      | Jan         | Feb | Mar | Apr         | May | Jun | Jul |  |
|   | 3   | Task 2: Data Collection                                     | Fri 2/2/01  | Mon 3/7/01  |             |     |     |             |     |     |     |  |
|   | 53  | Task 14: Population and Water Demand Analysis               | Fri 2/2/01  | Fri 3/2/01  |             |     |     |             |     |     |     |  |
|   | 59  | Task 15: Assess Primary and Secondary Drinking Water Status | Fri 2/2/01  | Thu 3/15/01 |             |     |     |             |     |     |     |  |
|   | 63  | Task 16: Surface Water Flood Control Site Selection         | Fri 2/2/01  | Mon 3/19/01 |             |     |     |             |     |     |     |  |
|   | 107 | Task 18: Cultural Resources Survey                          | Fri 2/2/01  | Thu 2/15/01 |             |     |     |             |     |     |     |  |
|   | 14  | Task 4: Surface Water Advantages                            | Mon 2/12/01 | Mon 2/12/01 |             |     |     |             |     |     |     |  |
|   | 17  | Task 3: Water Quality                                       | Mon 3/19/01 | Fri 3/2/01  |             |     |     |             |     |     |     |  |
|   | 22  | Task 8: Progress Meetings                                   | Mon 3/19/01 | Mon 3/19/01 |             |     |     |             |     |     |     |  |
|   | 103 | Task 20: Design Criteria                                    | Fri 3/2/01  | Thu 3/8/01  |             |     |     |             |     |     |     |  |
|   | 76  | Task 6: Transmission Modeling                               | Mon 3/19/01 | Mon 3/19/01 |             |     |     |             |     |     |     |  |
|   | 40  | Task 7: Water Conservation Plan                             | Mon 3/19/01 | Mon 4/23/01 |             |     |     |             |     |     |     |  |
|   | 60  | Task 10: Analysis of Water Treatment Modes from CWA Reg     | Thu 3/22/01 | Mon 4/9/01  |             |     |     |             |     |     |     |  |
|   | 102 | Task 21: Feasibility Study                                  | Thu 4/12/01 | Mon 4/23/01 |             |     |     |             |     |     |     |  |
|   | 2   | Task 5: Cost Analysis                                       | Mon 4/16/01 | Fri 4/6/01  |             |     |     |             |     |     |     |  |
|   | 17  | Task 9: Draft Report  | Fri 3/16/01 | Fri 4/20/01 |             |     |     |             |     |     |     |  |
|   | 54  | Task 13: Submittal Draft to TWSB                            | Mon 3/19/01 | Thu 3/22/01 |             |     |     |             |     |     |     |  |
|   | 52  | Task 11: Public Hearing                                     | Thu 3/22/01 | Mon 3/19/01 |             |     |     |             |     |     |     |  |
|   | 62  | Task 12: Final Report                                       | Mon 4/2/01  | Wed 4/25/01 |             |     |     |             |     |     |     |  |

---

---

---

---

---

---

---

---

**Surface Water Options for the  
Mid-Brazoria County Planning Group**

---

---

---

---

---

---

---

---

**TWDB/Region H Planning Group Projects  
Water Shortage in Mid-Brazoria Planning  
Area**

- Pearland
- Angleton
- Alvin
- No other shortages  
Projected

---

---

---

---

---

---

---

---

**Region H has Projected Water Needs for  
Mid-Brazoria Planning Area**

- 50% Groundwater
- 50% Surface Water
- Sustainable yield of Groundwater will  
not support 100% of area needs  
through 2050.

---

---

---

---

---

---

---

---

**Region H Projected Surface Water Need  
Pearland by 2050 = 5544 ac\*ft/yr or  
5MGD**

City of Pearland Currently has:

- 5,559 ac\*ft/yr raw water option contract with GCWA.
- No infrastructure to use contract water

Region H addresses shortage through extension of GCWA contract

---

---

---

---

---

---

---

---

**Region H Projected Surface Water  
Need for Angleton by 2050 = 2,992  
ac\*ft/yr or 2.7MGD**

City of Angleton currently has:

- 1,815 ac\*ft/yr treated water contract with BWA
- Contract expires 2040

Region H addresses shortage through extension of BWA contract

---

---

---

---

---

---

---

---

**Region H Projected Surface Water Need  
for Alvin by 2050 = 2,967 ac\*ft/yr or  
2.7MGD**

City of Alvin has:

- Groundwater Infrastructure
- No Surface Water Contracts

Region H Addresses shortage through new contract with GCWA

---

---

---

---

---

---

---

---

Everybody else in Mid-Brazoria County  
Planning Group continues with  
groundwater according to Region H.

---

---

---

---

---

---

---

---

**Water Issues faced by the  
Mid-Brazoria Planning Group**

---

---

---

---

---

---

---

---

**Water supply issues for the Mid-Brazoria  
Planning Group**

- No Groundwater Protection District
- Cost of various supply choices
- Reliability of supply sources

---

---

---

---

---

---

---

---

**Texas water law identifies ownership and allocation of water**

- Groundwater - belongs to person who can capture it
- Surface Water - State owned and allocated

---

---

---

---

---

---

---

---

**Surface water owned by State is identified by law**

- Every River
- Every Natural Stream
- Lakes
- Storm Water and Flood water in Water shed
- Every water right bay and river on Gulf of Mexico
- Nobody can appropriate water without a permit

---

---

---

---

---

---

---

---

**Water source alternatives identified by Region H**

---

---

---

---


---

---

---

---

Region H water source alternatives



---

---

---

---

---

---

---

---

Region H identifies water source alternatives

Region H Option 1: Raw water contract with GCWA

- Build Alvin Regional WTP
- Withdraw raw water from Briscoe Canal
- Estimated Capital Cost: \$7 Million
- Estimated Average O&M Cost: \$.144/kgal

---

---

---

---

---

---

---

---

Region H identifies water source alternatives

Region H Option 2: Raw water contract with BRA

- Water sources
  - BRA has 75,000 ac\*fu/yr potentially available
  - Little River Reservoir
  - Allens Creek Reservoir
- Build Alvin Regional WTP
- Construct Raw Water conveyance pipeline & PS
- Alternately contract use of GCWA Canal
- Estimated Capital Cost: \$35 Million
- Estimated Average O&M Cost: \$.29/kgal

---

---

---

---

---

---

---

---

Region H identifies water source alternatives

Region H Option 3: Water Rights Contract from CBWC

- Purchase/Finance water rights
- Build Alvin Regional WTP
- Purchase CBWC canal for conveyance
- Estimated Capital Cost: *\$12 Million\**
- Estimated Average O&M Cost: *\$.10/kgal*
- *N. Harris County Paid \$650 an AF or \$100 Million for these water rights*

---

---

---

---

---


---

---

---

City of Houston is another water source alternative

- COH will sell treated water
  - SEWTP
  - No WTP to build
  - Build transmission main from SEWTP Mains to central repumping facility near Alvin




---

---

---

---

---

---

---

---

Freeport Desal Plant is Another Water Source Alternative

- Poseidon Resources to estimate cost for City of Alvin

---

---

---

---

---

---

---

---

**Water Source Recommendations for  
Mid-Brazoria Planning Group**

- Implement groundwater protection district
- Plan to maintain groundwater production at current withdraw, use surface water for growth
- Review water contract opportunities with GCWA, BRA, CBWC, COH & DOW

The feasibility study will proceed in accordance with Region H's most economically attractive alternative

---

---

---

---

---

---

---

---

**REVIEW OF SURFACE WATER  
TREATMENT PLANT SITE SELECTION**

---

---

---

---


---

---

---

---

**Review of Alternative Treatment Plant Sites**



---

---

---

---

---

---

---

---



## REVIEW OF SURFACE WATER TREATMENT PLANT CAPACITY

---

---

---


---

---

---

---

## Mid-Brazoria County Planning Group Water Demand



---

---

---

---

---

---

---

## Surface Water Treatment Plant Options

- One phase construction
- Two phase construction

---

---

---


---

---

---

---

### Proposed Water Treatment Plant Capacity




---

---

---

---

---

---

---

---


---

---

---

---

### Proposed Water Treatment Plant Capacity




---

---

---

---

---

---

---

---

---

---

---

---

### TRANSMISSION SYSTEM ANALYSIS

---

---

---

---

---

---

---

---


---

---

---

---

### Take Points for Participating Utilities




---

---

---

---

---


---

---

---

### Take Points for Participating Utilities (Northern Half)

- **Manvel:**
  - TP 1: Intersection of SH288 and SH6
- **Pearland:**
  - TP 2a: Intersection of SH288 and FM518
  - TP 2b: Intersection of FM518 and SH35
- **Brookside Village:**
  - TP 3a: Intersection of Garden Road and Brookside Road
  - TP 3b: Intersection of Cemetery Road and Mykawa Road
- **Alvin:**
  - TP 4a: Intersection of SH 6 and Heights-Manvel Road
  - TP 4b: Intersection of SH 35 and CR 171
- **Iowa Colony:**
  - TP 5: Near CR 64 and Chocolate Bayou.




---

---

---

---

---


---

---

---

### Take Points for Participating Utilities (Southern Half)

- **Danbury:**
  - TP 6: Intersection of CR 365 and St Spur 28
- **Angleton:**
  - TP 7: On West Henderson Road, to the west of Velesco Road




---

---

---

---

---

---

---

---

**TRANSMISSION MAIN OPTIONS**

---

---

---


---

---

---

---

---



---

---

---


---

---

---

---

---



---

---

---

---

---

---

---

---

# TRANSMISSION MAIN SYSTEM OPERATION ALTERNATIVES

---

---

---


---

---

---

---

---




---

---

---

---

---

---

---

---

### Analysis of Distribution System Alternatives

| Options  | ADVANTAGES  | DISADVANTAGES  |
|--|---|--|
| Transmission main system "at Pressure"               | <ul style="list-style-type: none"> <li>No individual Utility Booster Pump Stations required</li> <li>No individual Utility ground storage tanks required</li> </ul> | <ul style="list-style-type: none"> <li>Larger diameter pipelines</li> <li>Larger WTP Pump Station</li> <li>One Pressure Plane</li> </ul>           |
| Transmission main system with "ground storage tanks" | <ul style="list-style-type: none"> <li>Larger diameter transmission mains</li> </ul>  | <ul style="list-style-type: none"> <li>Construction of individual ground storage tank and booster pump station at each Utility required</li> </ul> |

Recommendation: Transmission main with ground storage tanks, as this scenario has lower expected life cycle cost

---

---

---

---

---

---

---

---

**Mid Brazoria County Water Planning Group  
TWBD Facility Plan Study**

**Progress Meeting Agenda**

Date: June 14, 2001

Time: 12:00 P.M.

Place: City of Alvin Library

**Agenda:**

- 1) Introduction of Attendees
- 2) MBCPG – Project Definition
- 3) MBCPG – Facility Plan Progress
  - A) Water Treatment Plant Capacity
  - B) Screened alternative WTP Sites
  - C) Alternative Site evaluation
  - D) Hydraulic modeling of finished water system
  - E) Capital and O&M Cost Estimates for Alternatives
  - F) Resource Management Plan
  - G) Water Conservation Plan
- 4) Open Discussion.

# Mid-Brazoria County Regional Planning Group

## June Progress Meeting

---

---

---

---

---

---

---

---

### Agenda

- MBCPG Project Mission
- Work Completed
- Review of Alternatives
- What's Next

---

---

---

---

---


---

---

---

### The MBCPG Project Definition

- Study Feasibility of Regional WTP to Provide Safe, Economical, and Reliable Water Supply to serve:
  - Alvin
  - Angleton
  - Brookside Village
  - Danbury
  - Hillcrest Village
  - Iowa Colony
  - Marvel
  - Pearland
- Develop Regional Surface WTP Facility Plan
- Develop Cost Estimate for Facility Plan



---

---

---

---


---

---

---

---

## TWDB Governs Raw Water Source Development



- MCBPG can identify other sources, but Facility Plan must be coordinated with Region H Regional Water Plan

---

---

---

---

---

---

---

---

## MCBPG Facility Plan Progress

- MCBPG Decisions to Date
  - Water Treatment Plant Capacity
  - Screened Alternative WTP Sites to Site A and Site E
- Work Completed Since Last Meeting
  - Alternative WTP Site Evaluation
  - Hydraulic Modeling of Finished Water System
  - Capital and O&M Cost Estimates for Alternatives
  - Resource Management Plan
  - Water Conservation Plan

---

---

---

---


---

---

---

---

## Review of MCBPG Decisions - WTP Capacity




---

---

---

---


---

---

---

---






---

---

---

---

---

---

---

---

### Work Completed This Period: WTP Location Evaluation

|  |  |
|--|--|
| <p><u>Intangibles</u></p> <ul style="list-style-type: none"> <li>• Public Acceptance</li> <li>• Expandability</li> <li>• Reliability</li> <li>• Environmental Impacts</li> <li>• Permitting</li> </ul> | <p><u>Tangibles</u></p> <ul style="list-style-type: none"> <li>• Raw Water Conveyance</li> <li>• WTP</li> <li>• Finished Water Conveyance</li> </ul> |
|--|--|

---

---

---

---

---

---

---

---

### WTP Location Evaluation: Economic Evaluation

- Compare present worth cost to construct and operate the necessary facilities

- Includes Administration, Engineering, and Contingency

---

---

---

---


---

---

---

---

## Economic Breakdown



---

---

---

---

---

---

---

---

## Raw Water Conveyance

- Separate Raw Water Conveyance Analysis
  - No firm contract for raw water
  - Variability in raw water cost from each entity
  - Gives MBCPG information from which to negotiate for necessary raw water
- Updated Capital and O&M costs from Region H to reflect screened locations of alternative WTP sites
- Raw Water Demand 10% Higher Than Required WTP Production to account for losses through plant

---

---

---

---


---

---

---

---

## Raw Water Alternatives



---

---

---

---


---

---

---

---

### Raw Water Facilities Construction Costs




---

---

---

---


---

---

---

---

### Raw Water Facilities O&M Cost




---

---

---

---


---

---

---

---

### Raw Water Present Worth




---

---

---

---

---


---

---

---

## WTP Alternative Economics

- Water Treatment and Finished Water Transmission Costs
- Two Alternatives for Finished Water



---

---

---

---


---

---

---

---

## WTP Site Alternatives



---

---

---

---


---

---

---

---

## Treatment and Transmission Costs



---

---

---

---


---

---

---

---

25 MGD High Rate Conventional WTP  
Construction Costs




---

---

---

---

---

---


---

---

---

---

25 MGD High Rate Conventional WTP  
O&M Costs



\*Not including cost of raw water

---

---

---

---

---

---


---

---

---

---

Finished Water Transmission Costs




---

---

---

---

---


---

---

---

---

---




---

---

---

---

---


---

---

---

---

---




---

---

---

---

---


---

---

---

---

---




---

---

---

---

---

---

---

---

---

---

## Resource Management Alternatives

- Four General Alternatives to Manage Regional Water Authority
  - Contract with Existing Authority
  - Create New Authority Under Existing Water Code Rules and Regulations
  - Create New Authority by Legislative Action
  - Establish a Non Profit Water Corporation

---

---

---

---

---

---

---

---

## Recommendations

- Develop facility plan for 25 MGD plant at the Marvel site (MW)
- Negotiate for raw water contract or purchase
- Establish communication with other regional participants for cost savings of larger Regional Water Plant
- Brazoria County Groundwater Protection District Confirmation
- Create Regional Water Supply District

---

---

---

---

---

---

---

---

## What's next

- Schedule:
  - Draft Report : June 30, 2001
  - On target to meet this deadline
  - Comments of Draft Report due back July 30, 2001
- Working on:
  - Compiling Report
  - Comparing alternative to larger Regional WTP alternative
  - Detailed Facility Plan
  - Financing
- Outstanding Items:
  - Dow Chemical Cost Proposal
  - Briscoe Properties Cost Proposal

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

### Contract with Existing Regional Authority

- | Advantages  | Disadvantages   |
|---|---|
| <ul style="list-style-type: none"><li>• Existing Authority with power to implement and finance necessary improvements</li><li>• No requirement for creation of another regional authority</li><li>• Leverage Administration Costs Across Larger Area</li><li>• Experience in O&amp;M of Regional Water Treatment and Distribution Systems</li></ul> | <ul style="list-style-type: none"><li>• No Protection of Groundwater Sources</li><li>• No Representation on Board</li></ul> |

---

---

---

---

---

---

---

---

### Create New Authority Under Existing Water Code Rules and Regulations

- | Advantages  | Disadvantages  |
|---|--|
| <ul style="list-style-type: none"><li>• No additional rules required to establish authority</li><li>• Authority can be created with a petition, approval of county commissioners and voters of new District</li></ul> | <ul style="list-style-type: none"><li>• Require approval of voters</li><li>• Perception of Taxing Agency</li></ul> |

---

---

---

---

---

---

---

---



### Create New Authority by Legislative Action

#### Advantages

- Authority creation does not require petition or voter approval
- Rules and governing provisions can be customized
- Can establish power to regulate groundwater protection and potable water treatment and distribution

#### Disadvantages

- Legislature may not pass bill creating new district

---

---

---

---

---

---

---

---

### Establish a Non Profit Water Corporation

#### Advantages

- Creation through application to Texas Secretary of State
- Can design, build, and operate water treatment and distribution facilities

#### Disadvantages

- No Taxing Authority
- No Authority to Regulate Groundwater Withdrawal

---

---

---

---

---

---

---

---

**Mid Brazoria County Water Planning Group  
TWBD Facility Plan Study**

**Progress Meeting Agenda**

Date: July 19, 2001  
Time: 7:00 P.M.  
Place: City of Alvin, City Hall

**Agenda:**

- 1) Introduction of Attendees
- 2) Project Approach
- 3) Water Demand Needs
- 4) Water Treatment Plant Site Location
- 5) Raw Water Source Alternatives
- 6) Planning Group Recommendations
- 7) Open Discussion

**Regional Water Facility Provides a  
Reliable and Feasible  
Water Supply Alternatives**

ALVIN, TEXAS  
JULY 2001

---

---

---

---

---

---

---

---

**Presentation Topics**

- Project Approach
- Water Demand Needs
- WTP Site Selection
- Raw Water Source Alternatives
- Planning Group Recommendations

---

---

---

---

---

---


---

---

**Approach**

- Study Feasibility of Regional WTP to Provide Safe, Economical, and Reliable Water Supply to serve Mid-Brazoria County Planning Group (MBCPG):

- Alvin
- Angleton
- Brookside Village
- Danbury
- Hillcrest Village
- Iowa Colony
- Marvel
- Pearland



- Develop Regional Surface WTP Facility Plan
- Develop Cost Estimate for Facility Plan

---

---

---

---


---

---

---

---

## Mid Brazoria County Planning Group Population and Water Demand Projections




---

---

---

---

---

---

---

---


---

---

---

---

## Mid Brazoria County Planning Group Water Demand




---

---

---

---

---

---

---

---


---

---

---

---

## Proposed Water Treatment Plant Capacity




---

---

---

---

---

---

---

---

---

---

---

---

**SURFACE WATER TREATMENT  
PLANT SITE SELECTION**

---

---

---

---

---

---

---

---

**ALTERNATIVE PLANT SITE  
SELECTION PROCESS**

- Met with MBCPG to review engineering requirements for a site
  - Size of Property
  - Proximity to Water Demand
  - Proximity to Raw Water Source
  - Proximity to Highways and Utilities
  - Site Surface Features

---

---

---


---

---

---

---

---



---

---

---


---

---

---

---

---



---

---

---

---

---

---

---

**EVALUATION OF SCREENED  
ALTERNATIVE WTP SITES**

---

---

---

---

---

---

---

- Treatment and Transmission Alternatives  
Evaluation Criteria**
- Non-Economic Factors
    - Impact of Project on Intangibles
  
  - Economic Lifecycle Cost to:
    - Construct Necessary Facilities
    - Operate and Maintain Facilities Until Year 2050

---

---

---

---

---

---

---

**Non-Economic Criteria  
Site Selection Summary**

**MBCPG noted no discernable difference  
between the Manvel and Alvin Site**

---

---

---

---

---

---

---

---

**Economics**

- Capital Cost to Construct Facilities
- Annual O&M Cost to Produce and Deliver Potable Water

---

---

---

---





---

---

---

---

**Treatment and Transmission Costs**

|   |  |
|---|--|
| <br>Site Development | <br>Water Treatment |
| <br>Transmission     | <br>Distribution    |

---

---

---

---

---

---

---

---

**FINISHED WATER TRANSMISSION**

---

---

---


---

---

---

---

---



---

---

---

---

---

---

---

---

**ECONOMIC COMPARISON**

---

---

---

---

---

---


---

---



## Surface Water Treatment and Transmission Present Worth Cost

Plant Site Present Worth Cost (\$M)




---

---

---

---

---

---


---

---

---

---

## Contributing Factor To Cost Savings of Manvel Site




---

---

---

---

---

---

---

---

---

---

## RAW WATER SUPPLY ECONOMICS

---

---

---

---

---

---


---

---

---

---

### TWDB Governs Raw Water Source Development



- MCBPG can identify other sources, but Facility Plan must be coordinated with Region H Regional Water Plan

---

---

---

---


---

---

---

---

### Raw Water Facilities Present Worth Cost



---

---

---

---

---

---

---

---

### COMPARISON TO PROPOSED GCWA REGIONAL SURFACE WATER TREATMENT PLAN

---

---

---

---


---

---

---

---

**Finished Water Transmission from GCWA WTP Site**




---

---

---

---


---

---

---

---

**Total Present Worth Cost**




---

---

---

---

---

---

---

---

**Recommendations**

- **Create Regional Water Supply District**
  - Incorporation in Larger Regional Water Plant
    - Capitalize on cost savings associated with economy of scale
    - Initiate communication with agencies in Fort Bend, Harris, and Brazoria County for this larger regional water plant
  - Local Regional Water Plant
    - Construct a 25 MGD WTP at the Manvel site
    - Negotiate for raw water contract or purchase from CBWC, GCWA, or third party

---

---

---

---

---

---

---

---

## NOTICE OF PUBLIC HEARING

The City of Alvin invites you to a public meeting on the feasibility of a Mid-Brazoria County Regional Water Plant. This water plant would serve the residents of Manvel, Brookside Village, Pearland, Alvin, Hillcrest Village, Danbury, Angleton, and Iowa Colony.

Meeting Location: City of Alvin City Hall  
216 W. Sealy  
Alvin, TX 77511

Meeting Time: September 24, 2001 - 7:00 PM

### Meeting Agenda:

- 1) Mid-Brazoria County Planning Group Project Review
- 2) Report Overview
- 3) TWDB Comments Review
- 4) Regional Water Supplier round table
- 5) Comments

If you have any questions or comments on the agenda, please feel free to contact Chris Canonico, at Montgomery Watson (713)-403-1600.

**Appendix M**  
**Correspondence with State Regulatory Authorities**

---



MONTGOMERY WATSON



April 23, 2001

Bill Martin  
Department of Antiquities Protection  
Texas Historical Commission  
P.O. Box 12276  
Austin, Texas 78711

Subject: Mid-Brazoria County Planning Group (MBCPG) Regional Surface Water Plant.

Dear Mr. Martin,

Montgomery Watson would like to request a cultural resources assessment of the proposed transmission pipelines from the MBCPG Regional Water Plant to be located in Mid-Brazoria County. This cultural assessment is requested as part of a study to determine the feasibility of locating a new regional water plant in the Mid-Brazoria County area. The results from this cultural resources assessment will be used to minimize impact on the cultural resources of Texas.

The attachments show the proposed site locations and proposed pipeline routes. Construction of each pipeline will require a strip of land approximately 20 feet in width along the entire length of the proposed pipelines. The majority of the proposed pipelines are aligned within existing TXDOT easements and construction of these pipelines will occur in areas that have been previously disturbed.

If you have any questions or need additional information, please feel free to call me. If the results of the cultural resources assessment shows any areas where construction is not feasible, please let me know as soon as possible as the final feasibility study will be issued in early June.

Sincerely,

Sushrut Joshi.

Attachments:

1. Figure 1-Alternate Water Treatment Plant Sites.
2. Figure 2-Detailed map of Water Treatment Plant Site 1.
3. Figure 3-Detailed map of Water Treatment Plant Site 2.
4. Figure 4-Alternate Pipeline alignments.

cc: Chris Canonico,  
Montgomery Watson




Figure 3-Detailed map of Water Treatment Plant Site 2




Figure 2-Detailed map of Water Treatment Plant Site 1






Figure 1- Alternate Water Treatment Plant Sites.




Figure 4- Alternate Pipeline alignments



TEXAS  
HISTORICAL  
COMMISSION

*The State Agency for Historic Preservation*

RICK PERRY, GOVERNOR

JOHN L. NAU, III, CHAIRMAN

F. LAWRENCE OAKS, EXECUTIVE DIRECTOR

May 10, 2001

Sushrut Joshi  
Montgomery Watson  
5100 Westheimer, Suite 580  
Houston, TX 77056-5507

Re: Project review under Section 106 of the National Historic Preservation Act of 1966  
and the Antiquities Code of Texas  
Mid-Brazoria County Regional Water Plant  
(TWDB)

Dear Mr. Joshi:

Thank you for your correspondence describing the above referenced project. This letter serves as comment on the proposed undertaking from the State Historic Preservation Officer, the Executive Director of the Texas Historical Commission. As the state agency responsible for administering the Antiquities Code of Texas, these comments also provide recommendations on compliance with state and federal antiquities laws and regulations.

The review staff, led by Ed Baker, has completed its review. While we know of no cultural resources within the areas outlined on your maps, the areas submitted have not been professionally surveyed for cultural resources. Proposed plant site #1 may have a slightly greater chance to contain buried archeological material due to the presence of Chocolate Bayou, but either location could contain cultural resources. Previously disturbed roadways in the area are not likely to contain cultural resources. Exceptions may occur within broad rights-of-way or in areas where easements are expanded into previously undisturbed areas.

You may wish to engage a cultural resources consultant to conduct further records review and reconnaissance of the plant and pipeline alternatives. We would then be happy to review any recommendations they have for further work. Alternately, you may wish to re-submit the project for further review after preferred plant and pipeline locations are identified. In this case, please provide 7.5-minute topographic maps with proposed project elements outlined and described in detail.


We look forward to further consultation with your office and hope to maintain a partnership that will foster effective historic preservation. Thank you for your cooperation in this federal review process, and for your efforts to preserve the irreplaceable heritage of Texas. **If you have any questions concerning our review or if we can be of further assistance, please contact Ed Baker at 512/463-5866.**

Sincerely,

A handwritten signature in black ink, appearing to read "William A. Oaks".

for  
F. Lawrence Oaks, State Historic Preservation Officer  
FLO/elb

enclosure: *Council of Texas Archeologists Archeological Contractors List*



# Texas Department of Transportation

P.O. BOX 1386 • HOUSTON, TEXAS 77251-1386 • (713) 802-5000

June 13, 2001

CONTACT: DOM

Preliminary Permit Review  
Proposed Pipeline Corridor  
SH 288 Within the limits of Pearland and Angleton

Mr. Sushrut Joshi  
Montgomery Watson  
5100 Westheimer, Suite 580  
Houston, Texas 77056

Dear Mr. Joshi:

We have reviewed both of your requests dated April 18, 2001, and April 26, 2001, for access on SH 288 right-of-way for the proposed water pipelines serving the City of Brookside and the City of Angleton. The current Texas Department of Transportation Utility Accommodation Policy stipulates that new utilities will not be installed longitudinally within control of access lines of any freeway. We have verified that the existing control of access boundaries will not allow any utilities to be placed in the areas you identified along SH 288 for the proposed Pearland corridor and will require an alternate route. Our right-of-way maps verify that the majority of limits along SH 288 indicated in your proposal for the Angleton corridor are within a controlled access area although there are certain areas that are accessible within the limits you requested. Attached is a map showing where access is denied, indicated by a heavy blue line, and where it is allowed, indicated by the X's marked along SH 288.

If you should have any questions, please contact Ms. Alexine Stittiams-Ward, P.E., Maintenance Support Engineer (713) 802-5554.

Sincerely,

*Alexine Stittiams-Ward, P.E.*  
for Michael W. Alford, P.E.  
Director of Maintenance  
Houston District

FHS:pm

Attachments

cc: Mr. Larry Heckathorn, P.E.  
Ms. Alexine Stittiams-Ward, P.E.



**MONTGOMERY WATSON**

5100 Westheimer, Suite 580  
 Houston, TX 77056  
 713/403-1653  
 713/850-7901 (fax)

To: Michael Alford, P. E.  
 Company: Director of Maintenance,  
 Texas Department of Transportation  
 Fax: 713-802-5550  
 Phone: 713-802-5554  
 Date: 4/18/01


From: Sushrut Joshi  
 Subject: Preliminary Report for Right-of-Way along SH 288  
 No. of pages: 8  
 (including cover page)  
 Reference:

Dear Mr. Alford,

Please find attached a request for preliminary report for right-of-way along SH 288, for a water transmission pipeline from the city of Manvel to the city of Angleton.

A project summary and map of the region with the the proposed pipeline along SH 288 is attached for your perusal.

Thank You,

  
 Sushrut Joshi.

TEXAS DEPARTMENT OF TRANSPORTATION  
 HOUSTON DISTRICT MAINTENANCE

APR 18 2001 *rh*

*Alt ASW*  
*Pls handle*

**If you do not receive all pages, or if there are any problems with this transmission, please call 713-403-1653**

*mi*

**MONTGOMERY WATSON**

April 18, 2001

Michael Alford, P.E.  
Director of Maintenance  
Texas Department of Transportation  
P.O. Box 1386  
Houston, Texas 77251-1386

Subject: Right-of-way along State Highway 288 for a proposed water transmission pipeline.

Dear Mr. Alford,

Montgomery Watson would like to request a preliminary report for availability of right-of-way along State Highway 288 for a proposed water transmission pipeline. The water pipeline will be owned and operated by governmental agencies charged with providing residents in the Mid-Brazoria County with potable water. Your preliminary report will help us determine if it is feasible to have 20" water pipeline routed along SH 288. We would like to know if there are any regulatory or any of your concerns for use of the right-of-way.

The proposed finished water transmission pipeline will start from a proposed water treatment plant located in the City of Manvel, along State Highway 6, and run south along the east side of the SH 288 corridor to the City of Angleton.

Please let me know if any further information is necessary. If you have any questions or need additional information, please feel free to call me. I understand that this review requires time, but since the project is advancing, we would greatly appreciate if you can respond by the 1<sup>st</sup> of May.

Sincerely,

Sushrut Joshi



Attachments:

1. Photocopy of road map of Brazoria County.
2. Detailed map of major roads in the Mid-Brazoria County region.
3. Detailed map showing the proposed pipeline corridor along State Highway 288.

CC: Chris Canonico


**Attachment 1: Photocopy of road map of Brazoria County**

AREA SHOWN  
IN ATTACHMENTS 2 AND 3






**Attachment 2: Detailed map of major roads in the Mid-Brazoria County region.**



**Attachment 3: Map showing the proposed pipeline corridor for finished water transmission.**





**MONTGOMERY WATSON**

5100 Westheimer, Suite 580  
Houston, TX 77056  
713/403-1653  
713/850-7901 (fax)

---

|   |  |
|---|--|
| To: Frankie                                 | From: Sushrut Joshi                                |
| Company: Texas Department of Transportation | Subject: Key Maps for Right-of-Way<br>along SH 288 |
| Fax: 713-802-5550                           | No. of pages: 87<br>(including cover page)         |
| Phone: 713-802-5554                         | Reference:   |
| Date: 4/26/01                               |  |

---

Frankie,

As per our phone conversation, please find attached detailed key maps of the probable finished water pipeline serving the cities of Angleton and Brookside Village.

Here are the details of the pipeline routes:

**Pipeline Corridor serving the City of Brookside Village:**

The pipeline runs West along Hwy 6, and then North-North East along SH 288 upto the intersection of SH 288 and FM 518. At the intersection, it runs East along FM 518, and then North along Suburban Garden Road, to the "water take point" for the City.

Please refer to Figures 1, 2, and 3 for the routing of this pipeline.

**Pipeline Corridor serving the City of Angleton:**

The pipeline runs West along Hwy 6, and then South along SH 288 for a short distance. It then veers off SH 288 to run south along CR 48 for approximately 1.75 miles, then east along CR 56 for approximately 0.2 miles, south along CR 65 for 1 mile, and then West along CR 64 for approximately 1 mile to join SH 288.

Along 288, the pipeline runs South upto Spur 300. Then it runs South-South East along Business SH 288 till the intersection of Henderson Road. On Henderson Road, the pipeline turns West to the "water take point" for the City.

Please refer to Figures 4, 5, and 6 for the routing of this pipeline.

If you have any more questions, please feel free to call me.

Sincerely,

Sushrut Joshi.

*ALL CONTROLLED  
ACCESS ON SH 288 + SW  
FM 518 TO CR 94  
AS PART  
OF SH 288*

***If you do not receive all pages, or if there are any problems with this transmission, please call 713-403-1653***

1




Figure 1

SEE HC 573 MAP

613 <sup>121</sup>




Figure 2

SEE HC 573 MAP

KEY MAPS NO 2000

SEE HC 574 MAP





Figure 3



SEE 652 MAP




4

SEE 651 MAP

SEE 722 MAP

KEY MAPS INC. 2000


Figure 4



795

51

Figure 5




SEE 827 MAP

SEE 796 MAP


SEE 353 MAP

© KEY MAPS INC. 2000



Figure 6.




SEE 614 MAP



SEE 654 MAP






SEE 691 MAP

0 1/4 1/2 3/4 1 Mile


SEE 727 MAP



0 1/4 1/2 3/4 1 Mile

SEE 762 MAP






SEE 761 MAP



SEE 727 MAP

761




SEE 762 MAP

0 1 Mile

SEE 795 MAP

© KEY MAPS INC. 2000



**Appendix N**  
**Comments from the TWDB and the City of Pearland**

---

TEXAS WATER DEVELOPMENT BOARD COMMENTS ON  
REGIONAL WATER SUPPLY FACILITY GRANT FOR  
MID-BRAZORIA COUNTY REGIONAL WATER PLANNING GROUP  
CONTRACT NO. 2001-483-367

**SCOPE OF WORK ITEMS**

The review of the draft report identified: 1) scope items that were completed, 2) scope items for which documentation is insufficient and 3) scope items that were not completed. Task 12, which is the incorporation of review comments, will occur later and therefore is excluded from this analysis.

**Scope Items That Were Completed**

- Task 3 - Water quality determinations for the SB1 Regional Plan.
- Task 4 - Advantages of using treated surface water.
- Task 9 – Prepare and distribute preliminary draft report.
- Task 10 - Submission of draft report to the TWDB for review.

**Scope Items For Which Documentation is Insufficient**

1. Task 1 addresses a public notice for a kickoff public meeting. A copy of the notice and possibly other documentation of the public meeting should be included in the report.
2. Task 8 requires up to four progress meetings with plan participants. A statement giving information such as dates and locations of these meetings should be included.
3. Task 11 is to publish a notice of public hearing in local paper and develop a presentation for the public hearing. A copy of the notice and presentation materials should be included.
4. Task 13 is coordination with participants and the TWDB and progress reports. Documentation or at least a statement addressing this task should be included.

**Scope Items That Were Not Completed**

1. Task 2 is data collection and includes the stipulation that only SB1 or HGCSO population and demand numbers will be used.
  - a. Section 3 of the draft report addresses the population and water demand numbers developed for and included in the regional water plan for Region H. The population projections for Angleton, Brookside Village, Danbury and Iowa Colony are consistent with the scope for Task 2; whereas those for Alvin, Manvel and Pearland are not. The population for Hillcrest was rounded up to 1000 for 2000 and 2010, but otherwise matches those approved for the Region H water plan.
  - b. The difficulty is that the numbers were increased substantially for Alvin, Manvel and Pearland. The last two paragraphs on pg 3-1 state that the Participating Utilities in the study felt that the “Region H” numbers underestimated the future population for the planning area and that they then prepared individual projections of population

and water demand based on recent growth in the area. The report, however, does not describe the data, data sources and methodology used by the Participating Utilities in preparing their individual projections.

- c. In developing 50-year projections the TWDB examines and compiles data from the U.S. census on long-term trends in birth and death rates, employment trends, migration rates and other factors. These data are entered into cohort models that generate long-term estimates of population by decades. The population and water demand numbers in the Region H water plan were developed from TWDB model results, with a possible modification in the year 2000 numbers which served as the base year. Year 2000 numbers were adjusted upward to match year the 2000 estimates developed for the Harris Galveston Coastal Subsidence District (Turner Collie & Braden, 1996) or actual population numbers from State Data Center projected to 2000, if either if those numbers were higher than the TWDB estimates for 2000. Projections after 2000 were made using the percent changes from the TWDB modeling effort.
- d. The population and water demand projections from the approved Region H plan must be utilized as the basis for facility planning for consistency with Task 2 of the Scope of Work and the Texas Water Code. As noted above the population projections in the Region H plan are based on a technically sound methodology that is generally accepted for 50-year population forecasts.

2. Task 5 is to prepare a regional surface water transmission system

- a. The scope for Task 5 specifies that static models would be developed for peak day for all entries and that all model outputs would be reviewed for acceptable line velocities, head losses and pressures. Section 3 of the draft report discusses peak flows but does not provide model results for the peak day.
- b. Certain critical information on meeting peak flows and Texas Natural Resource Conservation Commission (TNRCC) requirements for peak flows are not included in the draft report. 30 TAC Chapter 290.45, which is administered by the TNRCC, requires a daily peak system capacity of 0.6 gallons per minute per connection. The daily peak flow developed in Table 3-4 is significantly lower than this TNRCC requirement. The report should address this discrepancy in peak flow amounts.
- c. Another consideration is how a peak flow of 63.83 million gallons per day (mgd) will be supplied. The sum of the recommended surface water treatment plant capacity of 25 mgd, 11.47 mgd existing well capacity, and existing wear contracts with Brazosport Water Authority and the City of Houston is less than the total needed. It should be noted that the total peak flow may be lowered after population and water demand projections are adjusted pursuant to the comments on Task 2.

3. Task 6 is to determine costs and conduct cost analyses.

- a. All aspects of Task 6 appear complete except for 6.d. and 6.g. Subtask 6.d. is the determination of the cost of a transmission system that would provide peak day requirements to each participant. Before this subtask can be completed, a strategy for meeting peak day requirements as discussed above under Task 5 would have to

be determined. Subtask 6.g. is a desktop review of potential biological, cultural resources, and socio-economic impacts of the proposed regional facilities.

4. Task 7 is to prepare a water conservation plan.
  - a. The draft report does not address the following requirements, which are part of the preparation of the water conservation plan in the scope of work for Task 7:
  - b. 7.c. Develop a consensus model management authority from the participant's viewpoint.
  - c. 7.e. Review of water conservation and drought management plans of the plan participants.
  - d. 7.g. Identify potential savings from alternative conservation measures.
  - e. 7.h. Develop water conservation plan that maintains or improves upon the per capita use reductions built into the Region H plan.

### **STATUTORY REQUIREMENT**

Section 16.054 of the Texas Water Code mandates that individual water plans not be in conflict with the applicable approved regional water plan. Particularly with respect to population and water demands, there are conflicts between the draft report and the approved Region H water plan. The Mid-Brazoria County Planning Group either must revise the draft report to conform to the Region H water plan or have Region H amend its regional water plan to incorporate the revised information.

### **SUGGESTED CHANGES AND/OR CORRECTIONS**

- 1) The third paragraph on page ES-1 and the second paragraph on page 1-1 refer to 13 counties in Region H. Region H includes 13 complete counties, plus portions of 2 additional counties, for a total of 15.
- 2) The second paragraph under BACKGROUND on page ES-2 refers to the 2003 State Water Plan in which the quantity of available sustainable surface water will be revisited. The next State Water Plan will be the 2002 State Water Plan. The 2002 State Water Plan will compile the surface water availability information that was presented in the 16 approved regional water plans and should not be considered as a new or independent effort.
- 3) The third paragraph under BACKGROUND on page ES-2 and the last paragraph on page 1-3 state that Region H will plan and construct facilities. The authority of the Region H water planning group is limited to planning and does not include the construction or development of water supply facilities.
- 4) The second paragraph under FACILITY DEMAND on page ES-3 refers to the Harris-Galveston Coastal Subsidence District as having responsibility for groundwater usage. The Harris-Galveston Coastal Subsidence District would be better described as a regulatory entity that controls the amount of groundwater pumped.
- 5) The second bullet under RAW WATER on page ES-7 incorrectly states that Region H proposed that for this option, the MBCPG would initially purchase the water rights owned by the Chocolate Bayou Water Company (CBWC). The recommendation to purchase water rights from the CBWC was made by Turner Collie & Braden in a letter report to

Jim Adams dated February 27, 2001, which appears as Appendix E of the draft report. The letter report was prepared and submitted after the Region H water plan was adopted, and Region H has not taken any formal action on the letter report.

- 6) The third paragraph on page 1-1 states that the Texas Water Development Board through Region H has just completed their review of the water needs in the area and has compiled a list of proposed projects to supply the region with adequate water supply. Although the TWDB managed the study contract and provided guidance, the Region H Water Planning Group reviewed water needs and compiled the projects.
- 7) The first paragraph under Planning Area on page 1-2 refers to a list of utilities and manufacturing units electing to be included in the study. No manufacturing units appear on the list.
- 8) The paragraph on groundwater under WATER SOURCE AND SUPPLY on page 2-1 states that groundwater availability for Brazoria County is 40,400 acre-feet per year. A reference should be provided for the 40,400 acre-feet per year, as it differs from that presented in the Region H plan, which shows the groundwater availability for Brazoria County as 50,315 acre-feet per year from the Gulf Coast aquifer and 85 acre-feet per year from an undifferentiated aquifer.
- 9) The statement under MID-BRAZORIA COUNTY PLANNING GROUP EXISTING FACILITIES on page 2-2 that the Participating Utilities receive water from the Gulf Coast aquifer or treated surface water from the City of Houston is not consistent with the previous paragraph. The previous paragraph states that Pearland has a contract for surface water with the Gulf Coast Water Authority and that Angleton has a contract for surface water with the Brazosport Water Authority.
- 10) The Mid-Brazoria County Planning Group Existing Facilities Description on pages 2-2 to 2-6 would be more helpful and easier to understand if it included water supply sources along with facilities. As presently drafted, the report refers only to Angleton's 6 wells and groundwater supply, which gives an inaccurate picture since most of Angleton's supply is surface water purchased from the Brazosport Water Authority. The same applies to Pearland, where the discussion covers Pearland's wells and ground storage tanks but not its contact with the City of Houston for surface water.
- 11) Table 2-3 on page 2-4 lists the diameter of wells incorrectly as "(Feet)." Should be 'inches'.
- 12) The last two sentences under the City of Angleton on page 2-5 state that Angleton has experienced taste and odor problems over the past five years and that the 40-year contract with the Brazosport Water Authority is a major constraint to solution of those problems. Additional explanation should be added as to why the 40-year contract is constraining the solution of taste and odor problems.
- 13) Section 3 of the draft report does not explain why "modified" population projections were considered more reliable ("better reflected realistic projections") than the Region H population projections. These "modified" population projections are nearly twice the Region H population projections for the year 2050 (400,000 vs. 215,000 per Figure 3-1, page 3-2). Based on the 2000 census, Region H population estimates appear to be more accurate than the "modified" population estimates for the year 2000 used in the



report. As it turns out, the previous Region H population projections for the year 2000 were already greater than the 2000 census estimate by approximately 5,000 people (see table below). In addition, the "modified" 2000 population value used as a starting population (100,000) in the draft report appears to be approximately 15,000 too great (based on 2000 Census numbers).

| CITY                               | Census 2000  | Region H 2000 | Numerical Difference<br>(Region H-Census) | % Difference |
|------------------------------------|--------------|---------------|---|--------------|
| Angleton                           | 18130        | 23870         | 5740                                      | 32%          |
| Alvin                              | 21413        | 24075         | 2662                                      | 12%          |
| Danbury                            | 1611         | 1870          | 259                                       | 16%          |
| Manvel                             | 3046         | 5152          | 2106                                      | 69%          |
| Pearland                           | 37640        | 31983         | -5657                                     | -15%         |
|                                    | <i>81840</i> | <i>86950</i>  | <i>5110</i>                               | <i>6%</i>    |
| <b>2000 TWDB-2000 Census Proj.</b> |              |               |   |              |

- 14) The projected water use estimates in this report (based on the "modified" population projects) may be greatly overstated. For the City of Manvel's 2050 water demand, the Turner Collie & Braden letter report (February 2001) estimates 1.1mgd (see Appendix E) whereas Table 2-3 of this report shows 4.4 mgd. Angleton is another example. Table 3-1 on page 3-1 shows an average daily demand for Angleton of 2.89 mgd for the year 2000, where as information submitted to the TWDB as part of a funding application reports an average daily demand of 2.0 mgd. Therefore, the resulting projected total water demands, water treatment plant capacity, storage capacity, pipeline sizes, and capital and operating cost estimates as well as the conservation plan also may be greatly overstated. The result of implementing a construction program based on overestimated capacity needs could include significant excess infrastructure capacity and inefficient operation.
- 15) Portions of the report for example Figures 3-1 and 3-2 use the label "Populations based on regional surveys". For consistency the label should be "modified" populations, per the last paragraph on page 3-1.
- 16) Table 3-4 on page 3-4 gives a peaking factor of 2.61 for Hillcrest. Is there a reason for Hillcrest having a significantly higher peaking factor than any other Participating Utility?
- 17) The second sentence in the last paragraph on page 3-5 should be clarified to state "This table shows that the MBCPG has 3.63 mgd in reserve or excess capacity beyond the year 2000 peak demand."
- 18) The first bullet at the top of page 3-7 states that the City of Angleton's contract with the Brazosport Water Authority will continue through the planning horizon, which is 2050. This is in contrast to the statement on page 2-5 that it is a 40-year contract.
- 19) The fourth bullet on page 3-7 states that the Participating Utilities will meet peak daily demand through water stored in their individual water distribution system infrastructure. TNRCC requirements are for 200 gallons storage per connection and a system capacity of 0.6 gpm per connection. The 200 gallons per connection is addressed and the required ground storage tank volumes are presented in Table 6-9 on page 6-13.

- However that amount of storage does not satisfy the requirement for capacity of 0.6 gpm per connection.
- 20) Table 3-7 on page 3-7 shows Pearland needing an additional 13.66 mgd by 2050. The approved need for Pearland as presented in the Region H plan is about 5.4 mgd.
  - 21) The first paragraph under Brazos River on page 3-9 refers to the TWDB Region H report dated April 2001. This report is not listed in the Bibliography in Appendix A, and it is not clear what report is being referred to.
  - 22) The first paragraph on page 4-1, the first paragraph under RAW WATER DELIVERY SYSTEM on page 6-16, and the first paragraph under Raw Water Sources on page 6-17 refer to a Region H report dated February 2001, which is the letter report included in Appendix E. This letter report was prepared by Turner Collie & Braden and was not a specific deliverable under their contract to the San Jacinto River Authority on behalf of the Region H water planning group. For purposes of the contract it was intended that the information would be incorporated in the Region H water plan. For this and other reasons the letter report has not been reviewed or approved by the TWDB or the Region H water planning group. Accordingly it should be referenced only as a Turner Collie & Braden report that was submitted to the Chairman of the Region H water planning group.
  - 23) The paragraph under Proximity to Major Highway and Utilities on page 5-5 refers to HL&P. Houston Light and Power has changed its name to Reliant Energy.
  - 24) The discussion of economic methodology on page 7-1 should explain the basis for including inflation in the economic analysis.
  - 25) The discussion of non-economic factors on pages 7-3 and 7-4 should explain how the relative non-economic criteria weights were assigned/established.
  - 26) The first bullet on page 7-7 states that the deal between the Chocolate Bayou Water Company and the North Harris County Regional Water Authority was tabled due to various concerns. The two parties had entered into an option contract. One or more of the conditions in the contract could not be met, and no final contract was pursued. The term tabled infers that a contractual arrangement still may be in the works versus in actuality the negotiations ended without a final contract.
  - 27) The first entry in the Bibliography in Appendix A should be revised to reflect the Region H water plan prepared by the Joint Venture of Brown & Root and Turner Collie & Braden, Ekistics Corp. and LBG-Guyton Associates.
  - 28) The title for Appendix B should be changed to reflect that it contains two separate analyses: 1) the water conservation and drought contingency plan and 2) resource management authority alternatives. The present title of Resource Management Plan is not specific enough.
  - 29) The first paragraph under Service Area Description on page 1 of the Mid-Brazoria County Planning Group Water Conservation Drought Contingency Plan refers to the Region H Board. The reference should be corrected to read Region H water planning group or Region H group.

- 30) The first paragraph under Groundwater Protection on page 1 of the Mid-Brazoria County Planning Group Resource Management Authority Alternatives incorrectly states that TNRCC approval is required to install and operate a new well.
- 31) The first paragraph under Brazos River Authority on page 2 of the Mid-Brazoria County Planning Group Resource Management Authority Alternatives incorrectly states that the Brazos River Authority operates the Brazosport Water Plant in Freeport.



**MWH**  
MONTGOMERY WATSON HARZA

5100 Westheimer, Suite 580  
Houston, Texas 77056

Tel: 713-403-1600  
Fax: 713-850-7901

**Date:** September 18, 2001

---

|                 |  |                      |                         |
|-----------------|--|----------------------|-------------------------|
| <b>To:</b>      | Ernest Rebuck  | <b>Fax No:</b>       | 512-475-2053            |
| <b>From:</b>    | Chris Canonico   | <b>Reference:</b>    |                         |
| <b>Subject:</b> | Mid-Brazoria County Regional<br>Water Planning Group Draft<br>Report | <b>No. of Pages:</b> | 11<br>(including cover) |

---

Dear Mr. Rebuck,

Please find attached the responses to the Texas Water Development Board's comments dated August 20<sup>th</sup>, 2001 on the draft report for the Mid-Brazoria County Planning Group Regional Water Feasibility Study.

Thanks,

Chris Canonico.

*If you do not receive all pages, or if there are any problems with this transmission, please call the receptionist at 713-403-1600.*

**MONTGOMERY WATSON HARZA'S RESPONSE TO TWDB COMMENTS DATED  
8/20/2001**

**Montgomery Watson Harza's responses to "Scope Items For Which  
Documentation is Insufficient"**

1. Task 1 addresses a public notice for a kickoff public meeting. A copy of the notice and possibly other documentation of the public meeting should be included in the report.

**Response:** A copy of the public notice of kickoff meeting and presentation will be incorporated as an appendix .

2. Task 8 requires up to four progress meetings with plan participants. A statement giving information such as dates and locations of these meetings should be included.

**Response:** Dates and locations of meetings will be incorporated in the appendix.

3. Task 11 is to publish a notice of public hearing in local paper and develop a presentation for the public hearing. A copy of the notice and presentation materials should be included.

**Response:** Copy of the notice and presentation will be incorporated in the appendix.

4. Task 13 is coordination with participants and the TWDB and progress reports. Documentation or at least a statement addressing this task should be included.

**Response:** A summary of the progress reports will be incorporated in the appendix.

**Montgomery Watson Harza's responses to "Scope Items That Were Not Completed"**

1. Task 2 is data collection and includes the stipulation that only SB1 or HGCSO population and demand numbers will be used.

**Response:** TWDB Region H population and water demand numbers will be used.

2. Task 5 is to prepare a regional surface water transmission system
  - a. The scope for Task 5 specifies that static models would be developed for peak day for all entries and that all model outputs would be reviewed for acceptable line velocities, head losses and pressures. Section 3 of the draft report discusses peak flows but does not provide model results for the peak day.

**Response:** Model results will be incorporated as a separate appendix.

- b. Certain critical information on meeting peak flows and Texas Natural Resource Conservation Commission (TNRCC) requirements for peak flows are not included in the draft report. 30 TAC Chapter 290.45, which is administered by the TNRCC, requires a daily peak system capacity of 0.6 gallons per minute per connection. The daily peak flow developed in Table 3-4 is significantly lower than this TNRCC requirement. The report should address this discrepancy in peak flow amounts.

**Response:** The WTP will provide a maximum flow equal to the capacity of the plant. During peak flow days, the participating utilities will meet peak flow demand flows through a combination of WTP flow, existing well flow, and future wells as needed to be in compliance with TNRCC regulations.

- c. Another consideration is how a peak flow of 63.83 million gallons per day (mgd) will be supplied. The sum of the recommended surface water treatment plant capacity of 25 mgd, 11.47 mgd existing well capacity, and existing water contracts with Brazosport Water Authority and the City of Houston is less than the total needed. It should be noted that the total peak flow may be lowered after population and water demand projections are adjusted pursuant to the comments on Task 2.

**Response:** The WTP will provide a maximum flow equal to the capacity of the plant. During peak flow days, the participating utilities will meet peak flow demand flows through a combination of WTP flow, existing well flow, and future wells as needed to be in compliance with TNRCC regulations.

3. Task 6 is to determine costs and conduct cost analyses.

- a. All aspects of Task 6 appear complete except for 6.d. and 6.g. Subtask 6.d. is the determination of the cost of a transmission system that would provide peak day requirements to each participant. Before this subtask can be completed, a strategy for meeting peak day requirements as discussed above under Task 5 would have to be determined. Subtask 6.g. is a desktop review of potential biological, cultural resources, and socio-economic impacts of the proposed regional facilities.

**Response:** The transmission system from the water treatment plant is sized to transport the maximum output from the WTP and carry flow to the individual Participating Utility distribution system. Each Participating Utility will augment this water with water from wells to meet peak flow in their distribution system. As part of the desktop review of biological, cultural resources, and socio-economic impacts of the proposed facilities, letter was sent to the Texas Historical Commission. Meetings were held with Participating Utilities to review non-economic factors including impact on biological and socio-economic conditions on the site. These factors are presented in Section 7.

4. Task 7 is to prepare a water conservation plan.

- a. The draft report does not address the following requirements, which are part of the preparation of the water conservation plan in the scope of work for Task 7:
  - b. 7.c. Develop a consensus model management authority from the participant's viewpoint.

**Response:** Formation of a Regional District under the Texas Water Code.

- c. 7.e. Review of water conservation and drought management plans of the plan participants.

**Response:** Water conservation and drought management plans from the cities of Alvin, Angleton, Pearland and Manvel were reviewed to compile the Water Conservation and Drought Contingency Plan and Resource Management Authority Alternatives in Appendix B. Other cities did not provide water conservation plans.

- d. 7.g. Identify potential savings from alternative conservation measures.

**Response:** This will be incorporated in the Water Conservation Plan.

- e. 7.h. Develop water conservation plan that maintains or improves upon the per capita use reductions built into the Region H plan.

**Response:** This will be incorporated in the water conservation plan.

**Montgomery Watson Harza's responses to "suggested changes and/or corrections"**

- 1) The third paragraph on page ES-1 and the second paragraph on page 1-1 refer to 13 counties in Region H. Region H includes 13 complete counties, plus portions of 2 additional counties, for a total of 15.

**Response:** Change will be incorporated.

- 2) The second paragraph under BACKGROUND on page ES-2 refers to the 2003 State Water Plan in which the quantity of available sustainable surface water will be revisited. The next State Water Plan will be the 2002 State Water Plan. The 2002 State Water Plan will compile the surface water availability information that was presented in the 16 approved regional water plans and should not be considered as a new or independent effort.

**Response:** Change will be incorporated.

- 3) The third paragraph under BACKGROUND on page ES-2 and the last paragraph on page 1-3 state that Region H will plan and construct facilities. The authority of the Region H water planning group is limited to planning and does not include the construction or development of water supply facilities.

**Response:** Change will be incorporated.

- 4) The second paragraph under FACILITY DEMAND on page ES-3 refers to the Harris-Galveston Coastal Subsidence District as having responsibility for groundwater usage. The Harris-Galveston Coastal Subsidence District would be better described as a regulatory entity that controls the amount of groundwater pumped.

**Response:** Change will be incorporated.

- 5) The second bullet under RAW WATER on page ES-7 incorrectly states that Region H proposed that for this option, the MBCPG would initially purchase the water rights owned by the Chocolate Bayou Water Company (CBWC). The recommendation to purchase water rights from the CBWC was made by Turner Collie & Braden in a letter report to Jim Adams dated February 27, 2001, which appears as Appendix E of the draft report. The letter report was prepared and submitted after the Region H water plan was adopted, and Region H has not taken any formal action on the letter report.

**Response:** Change will be incorporated.

- 6) The third paragraph on page 1-1 states that the Texas Water Development Board through Region H has just completed their review of the water needs in the area



and has compiled a list of proposed projects to supply the region with adequate water supply. Although the TWDB managed the study contract and provided guidance, the Region H Water Planning Group reviewed water needs and compiled the projects.

**Response:** Change will be incorporated.

- 7) The first paragraph under Planning Area on page 1-2 refers to a list of utilities and manufacturing units electing to be included in the study. No manufacturing units appear on the list.

**Response:** Change will be incorporated.

- 8) The paragraph on groundwater under WATER SOURCE AND SUPPLY on page 2-1 states that groundwater availability for Brazoria County is 40,400 acre-feet per year. A reference should be provided for the 40,400 acre-feet per year, as it differs from that presented in the Region H plan, which shows the groundwater availability for Brazoria County as 50,315 acre-feet per year from the Gulf Coast aquifer and 85 acre-feet per year from an undifferentiated aquifer.

**Response:** Change will be incorporated.

- 9) The statement under MID-BRAZORIA COUNTY PLANNING GROUP EXISTING FACILITIES on page 2-2 that the Participating Utilities receive water from the Gulf Coast aquifer or treated surface water from the City of Houston is not consistent with the previous paragraph. The previous paragraph states that Pearland has a contract for surface water with the Gulf Coast Water Authority and that Angleton has a contract for surface water with the Brazosport Water Authority.

**Response:** Change will be incorporated.

- 10) The Mid-Brazoria County Planning Group Existing Facilities Description on pages 2-2 to 2-6 would be more helpful and easier to understand if it included water supply sources along with facilities. As presently drafted, the report refers only to Angleton's 6 wells and groundwater supply, which gives an inaccurate picture since most of Angleton's supply is surface water purchased from the Brazosport Water Authority. The same applies to Pearland, where the discussion covers Pearland's wells and ground storage tanks but not its contact with the City of Houston for surface water.

**Response:** Change will be incorporated.

- 11) Table 2-3 on page 2-4 lists the diameter of wells incorrectly as “(Feet).” Should be ‘inches’.

**Response:** Change will be incorporated.

- 12) The last two sentences under the City of Angleton on page 2-5 state that Angleton has experienced taste and odor problems over the past five years and that the 40-year contract with the Brazosport Water Authority is a major constraint to solution of those problems. Additional explanation should be added as to why the 40-year contract is constraining the solution of taste and odor problems.

**Response:** The paragraph has been clarified.

- 13) Section 3 of the draft report does not explain why “modified” population projections were considered more reliable (“better reflected realistic projections”) than the Region H population projections. These “modified” population projections are nearly twice the Region H population projections for the year 2050 (400,000 vs. 215,000 per Figure 3-1, page 3-2). Based on the 2000 census, Region H population estimates appear to be more accurate than the “modified” population estimates for the year 2000 used in the report. As it turns out, the previous Region H population projections for the year 2000 were already greater than the 2000 census estimate by approximately 5,000 people (see table below). In addition, the “modified” 2000 population value used as a starting population (100,000) in the draft report appears to be approximately 15,000 too great (based on 2000 Census numbers).

| CITY                               | Census 2000 | Region H 2000 | Numerical Difference<br>(Region H-Census) | % Difference |
|------------------------------------|-------------|---------------|---|--------------|
| Angleton                           | 18,130      | 23,870        | 5,740                                     | 32%          |
| Alvin                              | 21,413      | 24,075        | 2,662                                     | 12%          |
| Danbury                            | 1,611       | 1,870         | 259                                       | 16%          |
| Manvel                             | 3,046       | 5,152         | 2,106                                     | 69%          |
| Pearland                           | 37,640      | 31,983        | -5,657                                    | -15%         |
|                                    | 81,840      | 86,950        | 5,110                                     | 6%           |
| <b>2000 TWDB-2000 Census Proj.</b> |             |               |   |              |

**Response:** The “modified” population projections have been replaced by Region H population projections.

- 14) The projected water use estimates in this report (based on the "modified" population projects) may be greatly overstated. For the City of Manvel's 2050 water demand, the Turner Collie & Braden letter report (February 2001) estimates 1.1mgd (see Appendix E) whereas Table 2-3 of this report shows 4.4 mgd. Angleton is another example. Table 3-1 on page 3-1 shows an average daily demand for Angleton of 2.89 mgd for the year 2000, where as information submitted to the TWDB as part of a funding application reports an average daily

demand of 2.0 mgd. Therefore, the resulting projected total water demands, water treatment plant capacity, storage capacity, pipeline sizes, and capital and operating cost estimates as well as the conservation plan also may be greatly overstated. The result of implementing a construction program based on overestimated capacity needs could include significant excess infrastructure capacity and inefficient operation.

**Response:** The population projections have been changed to reflect Region H numbers.

- 15) Portions of the report for example Figures 3-1 and 3-2 use the label "Populations based on regional surveys". For consistency the label should be "modified" populations, per the last paragraph on page 3-1.

**Response:** Change will be incorporated.

- 16) Table 3-4 on page 3-4 gives a peaking factor of 2.61 for Hillcrest. Is there a reason for Hillcrest having a significantly higher peaking factor than any other Participating Utility?

**Response:** The peaking factor documented is as reported by Hillcrest Village.

- 17) The second sentence in the last paragraph on page 3-5 should be clarified to state "This table shows that the MBCPG has 3.63 mgd in reserve or excess capacity beyond the year 2000 peak demand."

**Response:** Change will be incorporated.

- 18) The first bullet at the top of page 3-7 states that the City of Angleton's contract with the Brazosport Water Authority will continue through the planning horizon, which is 2050. This is in contrast to the statement on page 2-5 that it is a 40-year contract.

**Response:** Change has been incorporated.

- 19) The fourth bullet on page 3-7 states that the Participating Utilities will meet peak daily demand through water stored in their individual water distribution system infrastructure. TNRCC requirements are for 200 gallons storage per connection and a system capacity of 0.6 gpm per connection. The 200 gallons per connection is addressed and the required ground storage tank volumes are presented in Table 6-9 on page 6-13. However that amount of storage does not satisfy the requirement for capacity of 0.6 gpm per connection.

**Response:** Change will be incorporated.

- 20) Table 3-7 on page 3-7 shows Pearland needing an additional 13.66 mgd by 2050. The approved need for Pearland as presented in the Region H plan is about 5.4 mgd.

**Response:** Change will be incorporated.

- 21) The first paragraph under Brazos River on page 3-9 refers to the TWDB Region H report dated April 2001. This report is not listed in the Bibliography in Appendix A, and it is not clear what report is being referred to.

**Response:** The report referred to on page 3-9 is the letter report prepared by Turner Collie & Braden for the TWDB, dated February 27, 2001. The report mentioned on page 3-9 will be edited accordingly.

- 22) The first paragraph on page 4-1, the first paragraph under RAW WATER DELIVERY SYSTEM on page 6-16, and the first paragraph under Raw Water Sources on page 6-17 refer to a Region H report dated February 2001, which is the letter report included in Appendix E. This letter report was prepared by Turner Collie & Braden and was not a specific deliverable under their contract to the San Jacinto River Authority on behalf of the Region H water planning group. For purposes of the contract it was intended that the information would be incorporated in the Region H water plan. For this and other reasons the letter report has not been reviewed or approved by the TWDB or the Region H water planning group. Accordingly it should be referenced only as a Turner Collie & Braden report that was submitted to the Chairman of the Region H water planning group.

**Response:** The change will be incorporated.

- 23) The paragraph under Proximity to Major Highway and Utilities on page 5-5 refers to HL&P. Houston Light and Power has changed its name to Reliant Energy.

**Response:** Change will be incorporated.

- 24) The discussion of economic methodology on page 7-1 should explain the basis for including inflation in the economic analysis.

**Response:** An explanation for basis of inflation will be incorporated.

- 25) The discussion of non-economic factors on pages 7-3 and 7-4 should explain how the relative non-economic criteria weights were assigned/established.

**Response:** Change will be incorporated.

- 26) The first bullet on page 7-7 states that the deal between the Chocolate Bayou Water Company and the North Harris County Regional Water Authority was

tabled due to various concerns. The two parties had entered into an option contract. One or more of the conditions in the contract could not be met, and no final contract was pursued. The term tabled infers that a contractual arrangement still may be in the works versus in actuality the negotiations ended without a final contract.

**Response:** Change will be incorporated to reflect that the no final contract was completed.

- 27) The first entry in the Bibliography in Appendix A should be revised to reflect the Region H water plan prepared by the Joint Venture of Brown & Root and Turner Collie & Braden, Ekistics Corp. and LBG-Guyton Associates.

**Response:** Change will be incorporated.

- 28) The title for Appendix B should be changed to reflect that it contains two separate analyses: 1) the water conservation and drought contingency plan and 2) resource management authority alternatives. The present title of Resource Management Plan is not specific enough.

**Response:** Change will be incorporated.

- 29) The first paragraph under Service Area Description on page 1 of the Mid-Brazoria County Planning Group Water Conservation Drought Contingency Plan refers to the Region H Board. The reference should be corrected to read Region H water planning group or Region H group.

**Response:** Change will be incorporated.

- 30) The first paragraph under Groundwater Protection on page 1 of the Mid-Brazoria County Planning Group Resource Management Authority Alternatives incorrectly states that TNRCC approval is required to install and operate a new well.

**Response:** Change will be incorporated.

- 31) The first paragraph under Brazos River Authority on page 2 of the Mid-Brazoria County Planning Group Resource Management Authority Alternatives incorrectly states that the Brazos River Authority operates the Brazosport Water Plant in Freeport.

**Response:** Change will be incorporated.

**CITY OF PEARLAND COMMENTS ON  
REGIONAL WATER PLANT FEASIBILITY STUDY FOR  
MID-BRAZORIA COUNTY REGIONAL WATER PLANNING GROUP**

| No. | Commentator                   | Page No.             | Comment  | Response                                       |
|-----|-------------------------------|----------------------|--|--|
| 1   |                               | ES-1                 | This will be very expensive since all rights are gone.   |  |
| 2.  |                               | ES-1,<br>Figure ES-1 | Pearland City limits NOT correct at FM 521   | Change incorporated                            |
| 3.  |                               | ES-4                 | very important as to where the plant should be located. The further East you go the more treated water pipelines we will need to cross to get to Pearland.                 |  |
| 4.  |                               | ES-7                 | Option 1 is my vote although there are questions that need answers?  |  |
| 5.  |                               | ES-10                | Manvel would be excellent for Pearland's use   |  |
| 6.  | Gene Simeon, City of Pearland | ES-10                | I'm afraid of just being a customer - If supplies get short the ability to just buy water dwindles - Last year it happened to Texas City area - buying water from Houston. |  |
| 7.  |                               | 3-2                  | with planning area or entire city?   | Part of City of Pearland in the planning area. |
| 8.  |                               | 3-3                  | with planning area? Total facility is greater?   | Part of City of Pearland in the planning area. |
| 9.  |                               | 3-5                  | My vote is to buy Pearland's wells and do an 80-20 or 60-40 split.   |  |
| 10. |                               | 3-10                 | "Technologically feasible" does not guarantee palatable  |  |
| 11. |                               | 6-2,<br>Figure 6-1   | Pearland City limits are out of date.  | Change incorporated                            |
| 12. |                               | 7-7                  | Scary  |  |
| 13. |                               | 7-13                 | very significant point for Pearland  |  |
| 14. |                               | 8-1                  | Again - I would rather be a provider than just a buyer subject to rationing  |  |

**Appendix O**  
**Hydraulic Modeling Results**

---

### H2ONET Report - WTP at GCWA Site at Pressure

| Number | ID  | Demand (mgd) | Elevation (ft) | Grade (ft) | Pressure (psi) |
|--------|-----|--------------|----------------|------------|----------------|
| 1      | 12  | 0.57         | 50             | 173.94     | 53.73          |
| 2      | 16  | 13.66        | 60             | 256.54     | 85.2           |
| 3      | 18  | 3.77         | 55             | 249.33     | 84.24          |
| 4      | 20  | 0.24         | 50             | 223.07     | 75.03          |
| 5      | 200 | 0            | 60             | 279.11     | 94.98          |
| 6      | 22  | 2.45         | 20             | 144.58     | 54             |
| 7      | 24  | 0.48         | 20             | 80.09      | 26.05          |
| 8      | 28  | 4.13         | 40             | 171.17     | 56.86          |
| 9      | 34  | 0            | 50             | 237.33     | 81.21          |
| 10     | 36  | 0            | 20             | 167.19     | 63.81          |
| 11     | 42  | 0            | 60             | 264.52     | 88.66          |



### H2ONET Report - WTP at GCWA Site to Ground Storage Tanks

| Number | ID  | Demand (mgd) | Elevation (ft) | Grade (ft) | Pressure (psi) |
|--------|-----|--------------|----------------|------------|----------------|
| 1      | 12  | 0.57         | 50             | 89.44      | 17.1           |
| 2      | 16  | 13.66        | 60             | 172.04     | 48.57          |
| 3      | 18  | 3.77         | 55             | 214.33     | 69.07          |
| 4      | 20  | 0.24         | 50             | 188.07     | 59.85          |
| 5      | 200 | 0            | 60             | 244.11     | 79.81          |
| 6      | 22  | 2.45         | 20             | 92.06      | 31.24          |
| 7      | 24  | 0.48         | 20             | 45.09      | 10.87          |
| 8      | 28  | 4.13         | 40             | 75.62      | 15.44          |
| 9      | 34  | 0            | 50             | 202.33     | 66.03          |
| 10     | 36  | 0            | 20             | 132.19     | 48.63          |
| 11     | 42  | 0            | 60             | 229.52     | 73.49          |

### H2ONET Report - WTP at Site A at Pressure

| Number | ID | Demand (mgd) | Elevation (ft) | Grade (ft) | Pressure (psi) |
|--------|----|--------------|----------------|------------|----------------|
| 1      | 12 | 0.57         | 50             | 168.21     | 51.24          |
| 2      | 16 | 13.66        | 60             | 250.81     | 82.72          |
| 3      | 18 | 3.77         | 55             | 274.97     | 95.36          |
| 4      | 20 | 0.24         | 50             | 243.74     | 83.99          |
| 5      | 22 | 2.45         | 20             | 169.37     | 64.75          |
| 6      | 24 | 0.48         | 20             | 162.6      | 61.82          |
| 7      | 28 | 4.13         | 40             | 196.81     | 67.98          |
| 8      | 31 | 0            | 55             | 274.98     | 95.36          |
| 9      | 34 | 0            | 50             | 248.66     | 86.12          |
| 10     | 36 | 0            | 20             | 191.99     | 74.56          |
| 11     | 42 | 0            | 60             | 258.79     | 86.18          |

### H2ONET Report - WTP at Site A to Ground Storage Tanks

| Number | ID | Demand (mgd) | Elevation (ft) | Grade (ft) | Pressure (psi) |
|--------|----|--------------|----------------|------------|----------------|
| 1      | 12 | 0.57         | 50             | 90.04      | 17.36          |
| 2      | 16 | 13.66        | 60             | 172.65     | 48.83          |
| 3      | 18 | 3.77         | 55             | 204.8      | 64.94          |
| 4      | 20 | 0.24         | 50             | 173.57     | 53.57          |
| 5      | 22 | 2.45         | 20             | 46.98      | 11.7           |
| 6      | 24 | 0.48         | 20             | 57.73      | 16.36          |
| 7      | 28 | 4.13         | 40             | 66.09      | 11.31          |
| 8      | 31 | 0            | 55             | 204.81     | 64.94          |
| 9      | 34 | 0            | 50             | 178.49     | 55.7           |
| 10     | 36 | 0            | 20             | 87.11      | 29.09          |
| 11     | 42 | 0            | 60             | 180.63     | 52.29          |

### H2ONET Report - WTP at Site E at Pressure

| Number | ID | Demand (mgd) | Elevation (ft) | Grade (ft) | Pressure (psi) |
|--------|----|--------------|----------------|------------|----------------|
| 1      | 10 | 0.57         | 50             | 188.27     | 59.94          |
| 2      | 14 | 13.66        | 40             | 229.34     | 82.08          |
| 3      | 18 | 3.77         | 55             | 177.89     | 53.27          |
| 4      | 20 | 0.24         | 50             | 182.67     | 57.51          |
| 5      | 22 | 2.45         | 20             | 179.35     | 69.08          |
| 6      | 24 | 0.48         | 20             | 196.54     | 76.53          |
| 7      | 26 | 4.13         | 30             | 259.92     | 99.67          |
| 8      | 38 | 0            | 40             | 196.04     | 67.64          |
| 9      | 40 | 0            | 20             | 215.43     | 84.72          |

### H2ONET Report - WTP at Site E to Ground Storage Tanks

| Number | ID | Demand (mgd) | Elevation (ft) | Grade (ft) | Pressure (psi) |
|--------|----|--------------|----------------|------------|----------------|
| 1      | 10 | 0.57         | 50             | 85.06      | 15.2           |
| 2      | 14 | 13.66        | 40             | 126.13     | 37.34          |
| 3      | 18 | 3.77         | 55             | 96.73      | 18.09          |
| 4      | 20 | 0.24         | 50             | 72.77      | 9.87           |
| 5      | 22 | 2.45         | 20             | 52.57      | 14.12          |
| 6      | 24 | 0.48         | 20             | 97.72      | 33.69          |
| 7      | 26 | 4.13         | 30             | 190.92     | 69.76          |
| 8      | 38 | 0            | 40             | 127.04     | 37.73          |
| 9      | 40 | 0            | 20             | 116.6      | 41.88          |