

**TRANSPORTATION OF STATIONARY CONTAINERS TO AND FROM POINT  
OF INSTALLATION**

- Container **secured** against unsafe movement during transit 6.5.2.2
- Valves, Regulators, & other container appurtenances must be **protected** against damage during transit 6.5.2.3
- Pressure relief valves** communicate directly with the vapor space of container during transit 6.5.2.4
- Material identification number must be on each side and each end of unit for containers **of 1,000 gallons WC or More** 172.302(a)(1)
- Material identification number must be on two opposing sides on units transporting containers **of less than 1,000 gallons WC** 172.302(a)(2)
- Material identification number on orange panels or on placards 172.332(a)
- Material identification number on placards must be primary hazard class of material, Flammable Gas Placard 172.332(c)(3)
- Placards for primary hazard class of material, Flammable Gas Placards, must be **on each side and each end** 172.504(a)
- Placards must be **readily visible** 172.515(a)
- Placarding must be maintained in **good condition** 172.516(c)(6)

*NOTE: See Special Permit 13341 for transporting stationary containers with more than 5% product.*