



*Tyco Fire Suppression  
& Building Products*  
One Stanton Street  
Marinette, WI 54143-2542


Tele: 1-715-735-7411

November 24, 2008

Ansul has released Bulletin 5165a dated September 30, 2008 announcing ANSUL R102 UL 300 Fire Protection for Henny Penny mono rail center lift and dual lift fryers that automatically lift out the fried product. The UL 300 fire suppression protection offers protection in both the fully open and intermediate positions.

These fryers were previously protected using “Ansul Recommended” protection which only provided protection with the lid of the fryer in the fully open position. Non-UL 300 fire protection can be identified by the over head nozzle placement with the nozzles aiming into the vat area.

The UL 300 Fire Protection can be identified by the method of the nozzle placement. The UL 300 fire protection uses two nozzles and is directly mounted on the fryer utilizing a “tee block” as shown in the picture below.



If you should have any questions regarding the UL 300 protection please contact Ansul Technical Services Department at 1-800-862-6785/1-715-735-7415 or Ansul District Sales Manager Britt Johnson at 972-329-7669