



CITY OF TOMBALL
 Fire Marshal's Office
 501 James Street
 Tomball, Texas 77375
 281-290-1440 O
 281-290-1439 F



Business Name _____
 Address _____
 Phone _____
 Date _____

TENT & CANOPY INSPECTION

YES

NO

- _____ "No Smoking" signs posted in conspicuous locations?
- _____ Fire extinguisher(s) (dry chemical) present, easily accessible and inspected?
- _____ Exits clearly marked? (Signs needed over 50 OL)
- _____ Flame-resistant coatings in accordance to NFPA 701?
- _____ Proper access to tent for emergency vehicles?
- _____ Fire lanes blocked or inaccessible?
- _____ At least 20ft from other structures, parked vehicles, lot lines (including supports)?
- _____ Fire resistant label permanently affixed to canopy?
- _____ Combustible materials inside tent (i.e. hay, straw, shavings) (not permitted)
- _____ Tent supports, guy wires not in path of egress.
- _____ Open cooking, heaters or other open flames. (not permitted)
- _____ Electrical receptacles and other electrical cords covered?
- _____ Doors easily open?
- _____ Flammable waste properly disposed of (within 30 ft outside)?
- _____ Ignition sources removed?
- _____ Permit issued and posted?
- _____ Occupancy Load sign posted if over 50?
- _____ Generator is located no less that 20ft from tent or canopy?

OK to Permit

Date Issued ___/___/___

Temporary tents may not be used for any period longer than 180 days within a 12-month period on a single premise

Comments:

In order for a permit to be issued, there must be no outstanding code violations regarding this structure.

If you wish to discuss any hazard, or have any questions, please call the City of Tomball Fire Marshal's Office at (281)290-1440.

RECEIVED BY

INSPECTOR

For All Emergencies Call "9-1-1"