


# **Testing and Evaluation Protocol for Spectroscopy- Based Portal Monitors Used for Homeland Security**

**T&E Protocol N42.38, 2010**

**Version 1.02**

## Table of Content

1.	Scope.....	1
2.	References.....	1
3.	Compliance Level Information.....	1
4.	Test and evaluation steps .....	1
5.	Recording test results.....	2
6.	Test report .....	2
7.	Guidance for testing ANSI N42.42 data format requirements .....	2
8.	Test modifications from ANSI/IEEE N42.38-2006 requirements.....	3
9.	Considerations .....	3

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 1 of 103

## Testing and Evaluation Protocol for Spectroscopy-Based Portal Monitors Used for Homeland Security

### 1. Scope

This document establishes the protocol for testing alarming personal radiation detectors based on the performance requirements established in ANSI N42.38, “American National Standard for Evaluation and Performance of Radiation Detection Portal for Use in Homeland Security.”

### 2. References

This protocol shall be used in conjunction with the following documents:

[R1] ANSI N42.38, “American National Standard for Evaluation and Performance of Radiation Detection Portal for Use in Homeland Security.”

[R2] ANSI/IEEE N42.42, “Data Format Standard for Radiation Detectors Used for Homeland Security.”

[R3] NIST Handbook 150:2006, NVLAP Procedures and General Requirements

[R4] NIST Handbook 150-23:2007 (DRAFT) NVLAP Radiation Detection Instruments


### 3. Compliance Level Information

Instrument under test might meet all the requirements listed in the ANSI/IEEE N42.38 standard. Therefore, different agencies developed documents describing the compliance levels required for particular applications of the instruments under test. Examples of such compliance level requirements are those required by the Graduated Rad/Nuc Detector Evaluation and Reporting (GRaDER<sup>SM</sup>) program. For this program, information can be found in the “Compliance Level for GRaDER Instrument Performance” document located at <http://www.dhs.gov/GRaDER>.

### 4. Test and evaluation steps

It is recommended that testing laboratories perform the tests listed in this protocol in the following order:

- Check all items listed in the general requirements
- Perform the radiological tests
- Perform the temperature and humidity tests
- Perform the entire electrical and electromagnetic test except the Electrostatic Discharge (ESD) test
- Perform the impact and the vibration tests
- Perform the moisture and dust test
- Perform the ESD test
- Perform the drop test, as required

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 2 of 103

Excel template sheets are provided by NIST to the testing laboratory to guarantee that all data required is being provided in the test report.

## 5. Recording test results

This Test and Evaluation protocol contains data sheets that shall be used to record and report all test results. Each data sheet is associated with a specific section(s) of the referenced ANSI standard, N42.38. An electronic version of the data sheets is provided in the form of spreadsheets that may be used to record and report the results of the tests. These spreadsheets were verified and validated (V&V) using Microsoft Excel 2007 (compatibility mode).

Instrument status shall be recorded on the “Test Summary” sheet as testing is performed. The comment section in each data sheet shall be used to record changes to the test requirements and methods listed in the ANSI standard. The comment section shall also include the rationale of the changes.


## 6. Test report

A test report summarizing the results of the test shall include the following sections:

- a. Laboratory equipment information:
  1. Identify all participating laboratory facilities. Include points of contact names, mailing address, telephone number, and electronic mail addresses.
  2. Identify the tests performed in the different facilities.
  3. List all supporting equipment name, model number and last day of calibration used for each test.
- b. Test equipment information :
  1. Include manufacturer name, instrument model, instrument serial number, software and firmware version identification, and last day of calibration.
  2. List the operating modes and parameter setting of the instrument and accessory kit(s) used in each test.
- c. Data sheets:
  1. The data sheets listed in this document shall be completed and provided as part of the report.
  2. Include changes to the ANSI standard test requirements or methods and rationale to the changes.

## 7. Guidance for testing ANSI N42.42 data format requirements

The standard associated with this Test and Evaluation Protocol requires verification that an output data file is created that complies with ANSI/IEEE N42.42 standard requirements. The range of

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 3 of 103

complexity of the N42.42 compliant instrument output file is extremely broad. Data output files from these instruments are simple files that can be checked manually using a text editor such as Notepad or WordPad. These files can also be verified using additional tools. In principle, all data output files that meet ANSI N42.42 can be verified manually using a text editor as these files are XML files. File reading software, such as Altova XMLSpy® 2009 Standard Edition can also be used for manual viewing and validating of structure and content.

N42.42 schemas can be used to validate the file format as specified in the ANSI/IEEE N42.42 standard. These schemas are available at the NIST web site  
<http://physics.nist.gov/Divisions/Div846/Gp4/ANSIN4242/xml.html>.


There are several XML validators that can be used to verify the XML structure of the N42.42 compliant instrument output file. Examples of these validators can be found at  
<http://www.xmlvalidation.com/> or <http://validator.w3.org/>.

## 8. Test modifications from ANSI/IEEE N42.38-2006 requirements

Some issues were observed and new considerations were taken about the enrichment of some of the sources listed in the ANSI/IEEE N42.38 standard. The testing laboratories should note that the source enrichment to be used for all the tests described in the ANSI/IEEE N42.38 standard is the following: HEU has an enrichment that is  $\geq 90\%$   $^{235}\text{U}$ , DU at  $0.2\%$   $^{235}\text{U}$ , and  $U_{\text{nat}}$  at  $0.7\%$   $^{235}\text{U}$ , RGPu containing  $\geq 10\%$   $^{240}\text{Pu}$ , and WGPu  $\leq 6\%$   $^{240}\text{Pu}$ .

## 9. Considerations

The standard establishes exposure rates for test in Roentgen per hour (R/h). When testing instruments that read in rem per hour, the test field shall be in rem/h instead of R/h. Refer to the “Units and Uncertainties” section in the standard for additional information.


	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 4 of 103

**Test Summary Sheet  
ANSI N42.38**

<b>Manufacturer:</b>	
<b>Model:</b>	

Test Number	Serial#		Serial#		Serial#	
	Date	Status	Date	Status	Date	Status
5.3						
5.4						
5.5						
5.6						
5.7						
5.8						
5.9						
5.10						
5.11.1						
5.11.2.1						
5.11.2.2						
5.11.2.3						
5.11.2.4						
6.2						
6.3						
6.4						
6.5						
6.6						
6.7						
6.8.1						
6.8.2.2						
6.8.2.3						
6.8.3						
6.8.4						
6.8.5						
6.8.6						
6.9						
6.10						
7.1						
7.2						
7.3						
8.1						
8.2						
8.3						
8.4						
8.5						
8.6						
9.1						
9.2						
10.0						

<b>Comments:</b>	


	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 5 of 103

## Setup Data Sheet and Report

<b>Instrument:</b>			
<b>Model:</b>		<b>Serial Number:</b>	
<b>Date Performed:</b>		<b>Test Location:</b>	
<b>Requirement:</b>	<p>Following the manufacturer-provided information, it shall be possible to set up the monitor for use. The manufacturer shall provide the designation type for testing purposes (pedestrian, vehicle, rail, and/or package).</p> <p>The evaluation shall be performed without the benefit of any radiation shielding against the natural background, except for that shielding which is a permanent feature of the monitor.</p> <p>NOTE - If the monitor has multiple uses, it should be tested for each usage designation.</p>		
<b>Test Protocol:</b>	<p>Set up the monitor for use using the technical manual as a guide. The actual set-up process may be performed by the manufacturer at the usage or test location while being observed by the testing organization. Document the results indicating whether all steps and information needed are available in the supplied technical information.</p>		
<b>Note:</b>	<p>Comments are required when the requirement is not verified.</p>		

### Test Results

<b>Classification:</b>	(choose one)	<input type="checkbox"/> Pedestrian	<input type="checkbox"/> Package
		<input type="checkbox"/> Vehicle	<input type="checkbox"/> Rail
<b>Setup performed by:</b>	(choose one)	<input type="checkbox"/> Manufacturer	<input type="checkbox"/> Test Organization
Were all steps for setup clearly defined?		<input type="checkbox"/> Yes	<input type="checkbox"/> No
Was it necessary to seek technical assistance from the manufacturer?		<input type="checkbox"/> Yes	<input type="checkbox"/> No
Did the technical manual provide all steps necessary for setup?		<input type="checkbox"/> Yes	<input type="checkbox"/> No
Was all information necessary for setup (diagrams, schematics, etc.) provided in the technical manual?		<input type="checkbox"/> Yes	<input type="checkbox"/> No
<b>Comments:</b>			
<b>Completed by:</b>		<b>Date:</b>	
<b>Reviewed by:</b>		<b>Date:</b>	

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 6 of 103

## Pre-Test Data Sheet and Report


<b>Instrument:</b>			
<b>Model:</b>		<b>Serial Number:</b>	
<b>Date Performed:</b>		<b>Test Location:</b>	
<b>Requirement:</b>	Verify that the manufacturer supplied an operation and maintenance manual containing the information listed below.		
<b>Test Protocol:</b>	Review the information provided and indicate whether the required information has been provided. Also verify that the documentation is complete and understandable. The documentation should not be in draft form with incomplete sections.		
<b>Note:</b>	Comments are required when the requirement is not verified.		

### Test Results

Requirement	Yes		No
Operating instructions and restrictions	<input type="checkbox"/>		<input type="checkbox"/>
Electrical connection schematic	<input type="checkbox"/>		<input type="checkbox"/>
Spare parts list	<input type="checkbox"/>		<input type="checkbox"/>
Troubleshooting guide.	<input type="checkbox"/>		<input type="checkbox"/>
Description and protocol for communication methods of transmitting and receiving data	<input type="checkbox"/>		<input type="checkbox"/>
Contact information for the manufacturer including name, address, telephone #, fax #, email address, etc.	<input type="checkbox"/>		<input type="checkbox"/>
Power supply requirements	<input type="checkbox"/>		<input type="checkbox"/>
Recommended operational parameters such as: detector response and false alarm probability	<input type="checkbox"/>		<input type="checkbox"/>
Complete description of system or unit	<input type="checkbox"/>		<input type="checkbox"/>
Enclosure specification classification	<input type="checkbox"/>		<input type="checkbox"/>
Inclusion of any hazardous material that may require additional regulation	<input type="checkbox"/>		<input type="checkbox"/>
Description of data analysis software and radionuclide identification procedure	<input type="checkbox"/>		<input type="checkbox"/>
Description of operation and performance of the system or unit	<input type="checkbox"/>		<input type="checkbox"/>

<b>Comments:</b>			
<b>Completed by:</b>		<b>Date:</b>	
<b>Reviewed by:</b>		<b>Date:</b>	




	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 7 of 103

## Section 5.3 Spectral identification Data Sheet and Report

<b>Instrument:</b>					
<b>Model:</b>			<b>Serial Number:</b>		
<b>Date Performed:</b>			<b>Test Location:</b>		
<b>Requirement:</b>	<p>a) A displayed gamma-ray spectrum is not required during routine operation. The spectrum display shall be available by manufacturer-defined user actions.</p> <p>b) The monitor shall have the ability to internally store at least 1000 complete occupancy data sets. For monitors that do not use occupancy sensors, the monitor shall have the ability to store 3 hours of measurement data as defined in item c).</p> <p>c) Each occupancy data set shall contain collection and identification results information including:</p> <ol style="list-style-type: none"> <li>1) Unprocessed spectrum (spectra for multi-detector systems) obtained during a single occupancy,</li> <li>2) Time and date</li> <li>3) Real time for alarm spectrum</li> <li>4) Run time for alarm spectrum</li> <li>5) Identified radionuclides, categories, and confidence level (if available)</li> <li>6) Occupancy time</li> <li>7) Monitor identification</li> <li>8) Alarm condition (gamma-ray and/or neutron)</li> <li>9) Background (gamma-ray and neutron) count rate and spectrum (includes real time and run time)</li> <li>10) Gamma-ray count rate</li> <li>11) Neutron count rate</li> <li>12) Vehicle speed (if available)</li> </ol> <p>d) The monitor shall have the ability to store background count rate and spectra, and transfer that information at user selectable intervals to an external device, such as a computer.</p> <p>e) The monitor shall have the ability to store gamma-ray and neutron count rate time-history data.</p> <p>f) An indication shall be displayed or otherwise provided (e.g. "not identified") if a radionuclide cannot be identified when or after a measurement takes place.</p> <p>g) If a reliability or confidence level is associated with the identification of a radionuclide(s), the confidence level shall be provided in the data set and the manufacturer shall describe the meaning of the displayed value.</p> <p>h) The monitor shall have the ability to perform identification measurements with an object stationary in the detection zone. This function shall be user selectable and does not supersede the requirements stated in 6.8. The recommended measurement time shall be stated by the manufacturer and should be less than or equal to 1 min.</p>				
<b>Note:</b>	Comments are required when the requirement is not verified.				



	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 9 of 103


## Section 5.4 Indication Features Data Sheet and Report

<b>Instrument:</b>			
<b>Model:</b>		<b>Serial Number:</b>	
<b>Date Performed:</b>		<b>Test Location:</b>	
<b>Requirement:</b>	<p>The monitor shall provide an indication of its operational status and alarm condition, and be capable of transmitting these signals to additional remote stations. The user shall have the ability to select the visibility of the status indication.</p> <p>All alarm indicators shall automatically or manually reset as defined by the user.</p>		
<b>Test Protocol:</b>	<p>Perform each action with the monitor set to automatically reset. Although there are many actions required by this test, acceptance is based on pass or failing each action.</p>		
<b>Note:</b>	<p>Comments are required when the requirement is not verified.</p>		

### Test Results

	Yes	No
With the monitor operating normally and with all indicators functioning (remote and/or local), verify that the indicators show the monitor is operating normally. Perform a measurement and verify that this action is indicated as required.	<input type="checkbox"/>	<input type="checkbox"/>
Repeat the measurement using a radiation source that will cause an alarm and verify that this is indicated.	<input type="checkbox"/>	<input type="checkbox"/>
Verify that this alarm automatically resets after the user enterable reset time.	<input type="checkbox"/>	<input type="checkbox"/>
Remove a component such as a detector panel and verify that this failure is indicated.	<input type="checkbox"/>	<input type="checkbox"/>
Reconnect the detector panel, and after the monitor returns to normal indication, remove line power and verify that this is indicated.	<input type="checkbox"/>	<input type="checkbox"/>
Repeat the alarm test with the monitor set for manual reset and verify that the monitor will not reset without user action.	<input type="checkbox"/>	<input type="checkbox"/>

<b>Comments:</b>			
<b>Completed by:</b>		<b>Date:</b>	
<b>Reviewed by:</b>		<b>Date:</b>	

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 10 of 103


### Section 5.5 Occupancy and Speed Sensors for Vehicle Monitors Data Sheet and Report

<b>Instrument:</b>		<b>Serial Number:</b>	
<b>Model:</b>		<b>Test Location:</b>	
<b>Date Performed:</b>			
<b>Requirement:</b>	<p>Monitors shall have the ability to support occupancy sensors and should have the ability to measure speed.</p> <p>If used, occupancy and speed sensors:</p> <ul style="list-style-type: none"> <li>- Shall be able to detect presence and to estimate vehicle speed to within <math>\pm 30\%</math> of a known speed, indicate if a vehicle stops within the detection zone, and not count a single vehicle or object in the detection zone more than once,</li> <li>- Should be capable of operating on a mix of traffic (cars, vans, pickup trucks, buses, cargo trucks, trains, etc.), and</li> <li>- Should function under all environmental conditions stated in this standard.</li> </ul> <p>Rail monitors should have the ability to approximate the location of an alarm when monitoring multi-car trains.</p> <p>For test purposes, a system that incorporates an occupancy sensor should have the ability to perform a user selected series of consecutive occupancies automatically without the need to activate the occupancy sensor. Function variables such as occupancy time and time between occupancies shall be user-selectable.</p>		
<b>Note:</b>	Comments are required when the requirement is not verified.		

#### Test Results

	Verify	
	Yes	No
The monitor has an occupancy sensor?		
<b>If yes,</b>		
Can it detect the presence of a vehicle?		
It is capable to operate in mix traffic?		
Can indicate if a vehicle or object stops within the detection zone?		
Does it count a single vehicle or object more than once?		
The monitor has a speed sensor?		
<b>If yes,</b>		
Can it estimate the vehicle speed?		
For rail monitors, does it have the ability to approximate the location of an alarm when monitoring multi-car trains?		

<b>Comments:</b>	
<b>Completed by:</b>	<b>Date:</b>
<b>Reviewed by:</b>	<b>Date:</b>

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 11 of 103

## Section 5.6 Markings Data Sheet and Report

<b>Instrument:</b>			
<b>Model:</b>		<b>Serial Number:</b>	
<b>Date Performed:</b>		<b>Test Location:</b>	

**Requirement:** Internal controls shall be identified through markings on circuit boards and identification in technical manuals.

Markings shall be easily readable and permanently fixed under normal conditions of use.

Exterior markings shall be limited to the manufacturer's unique serial number, voltage and current requirements, if equipped with an outlet plug, and shall meet minimum applicable municipal, state, federal, and international code requirements.

**Test Protocol:** Open detector cabinets or other protected components and verify that the items as marked in the technical manual match those marked in each detection assembly and other components, such as a remote alarm panel.

**CAUTION**  
Perform the following with line and battery power removed from the monitor.

Using a damp cloth, wipe at some of the markings to verify that they are permanently affixed to the component.

Verify that only the minimal markings exist on the exterior of the unit.


**Note:** Comments are required when the requirement is not verified.


### Test Results

	Yes	No
Are internal controls on electrical circuit boards and/or individual components marked as identified in the technical manuals?	<input type="checkbox"/>	<input type="checkbox"/>
REMOVE THE POWER FROM THE MONITOR. Using a damp cloth wipe at some of the markings. Are the markings permanently fixed?	<input type="checkbox"/>	<input type="checkbox"/>
Are the exterior markings limited to the ones listed in the requirement?	<input type="checkbox"/>	<input type="checkbox"/>

<b>Comments:</b>			
<b>Completed by:</b>		<b>Date:</b>	
<b>Reviewed by:</b>		<b>Date:</b>	



	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 13 of 103

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 14 of 103

	Voltage + 12% of Nominal			Voltage - 12% of Nominal		
	Gamma Response	Neutron Response	Isotopes Identified	Gamma Response	Neutron Response	Isotopes Identified
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
Mean	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	

	Frequency at 58 Hz			Frequency at 62 Hz		
	Gamma Response	Neutron Response	Isotopes Identified	Gamma Response	Neutron Response	Isotopes Identified
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
Mean	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	

Test Report

	Gamma Response		Neutron Response		Isotope Identification	
	Yes	No	Yes	No	Yes	No
- 12 %	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
+ 12 %	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
58 Hz	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
62 Hz	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Comments:


Completed by:

Date:

Reviewed by:


Date:



	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 15 of 103

### Section 5.8 Battery Lifetime Data Sheet and Report

<b>Instrument:</b>			
<b>Model:</b>			<b>Serial Number:</b>
<b>Date Performed:</b>			<b>Test Location:</b>
<b>Requirement:</b>	Monitors shall be able to operate including storing measurement data for up to 3 hours if there is a loss of external power.		
<b>Note:</b>	Comments are required when the requirement is not verified.		
<b>Yes</b> <b>No</b>			
Did the monitor performed within specification for the entire 3 h period?			<input type="checkbox"/>
Did the monitor store all the required information from each occupancy within the 3 h?			<input type="checkbox"/>
Was the low-battery indication activated?			<input type="checkbox"/>
<b>Comments:</b>			
<b>Completed by:</b>			<b>Date:</b>
<b>Reviewed by:</b>			<b>Date:</b>

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 16 of 103


## Section 5.9 Protection of Switches Data Sheet and Report

<b>Instrument:</b>									
<b>Model:</b>					<b>Serial Number:</b>				
<b>Date Performed:</b>					<b>Test Location:</b>				
<b>Requirement:</b>	Switches and other controls should be designed to ensure that the monitor is operated properly while minimizing accidental switch operation.								
<b>Note:</b>	Comments are required when the requirement is not verified.								

### Test Results

	Yes	No
External switches or controls are protected to prevent accidental operation	<input type="checkbox"/>	<input type="checkbox"/>

<b>Comments:</b>									
<b>Completed by:</b>					<b>Date:</b>				
<b>Reviewed by:</b>					<b>Date:</b>				


	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 17 of 103

## Section 5.10 Effective Range of Measurement Data Sheet and Report

<b>Instrument:</b>			
<b>Model:</b>			<b>Serial Number:</b>
<b>Date Performed:</b>			<b>Test Location:</b>
<b>Requirement:</b>	The effective gamma-ray energy response range shall be stated by the manufacturer, and should be at least 25 keV to 3 MeV.		
	The manufacturer shall state the range for gamma-ray count rate measurement and for neutron count rate indication.		
<b>Note:</b>	Comments are required when the requirement is not verified.		

	Verify	
	Yes	No
Is the effective gamma-ray energy response stated by the manufacturer?		
Does the gamma-ray energy range go from 25 keV to 3 MeV?		
Is the gamma-ray count rate measurement range stated by the manufacturer?		
Is the neutron count rate measurement range stated by the manufacturer?		

	Energy response range:			
	Gamma-ray count rate range:			
	Neutron count rate range:			
<b>Comments:</b>				
<b>Completed by:</b>			<b>Date:</b>	
<b>Reviewed by:</b>			<b>Date:</b>	

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 18 of 103


## Section 5.11.1 Communications Protocol and Data Format Data Sheet and Report

<b>Instrument:</b>			
<b>Model:</b>	<b>Serial Number:</b> 0		
<b>Date Performed:</b>	<b>Test Location:</b>		
<b>Requirement:</b>	<p>The monitor shall have the ability to transfer data to an external device, such as a computer. The transfer shall be based on a commonly available technology such as Ethernet, USB, RS-232, wireless (e.g., 802.11), or RS-485. Consideration should be given to data security when using wireless data transfer techniques. When used, wireless techniques shall have the ability to be encrypted.</p> <p>The transfer protocol and format shall be fully described in the technical manual and shall also be freely distributable.</p> <p>Data format shall be as defined in ANSI N42.42.</p>		
<b>Note:</b>	Comments are required when the requirement is not verified.		

	Verify	
	Yes	No
Does the monitor have the ability to transfer data to an external device?		
Is the transfer based on commonly available technology? (e.g. Ethernet, wireless, USB, RS-232)		
If the transfer is wireless, does it have the ability to encrypt the data?		
Is the transfer protocol described in the technical manual?		
Is the format described in the technical manual?		
Is it freely distributable?		
The data format complies with ANSI N42.42 requirements?		

Describe method used by monitor to transfer data:

<b>Comments:</b>			
<b>Completed by:</b>			<b>Date:</b>
<b>Reviewed by:</b>			<b>Date:</b>


	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 19 of 103

## Section 5.11.2.1 Visual Indicators Data Sheet and Report

<b>Instrument:</b>			
<b>Model:</b>			<b>Serial Number:</b>
<b>Date Performed:</b>			<b>Test Location:</b>
<b>Requirement:</b>	The monitor should provide a color-based visual indication for the following actions:		
	<b>Alarm color</b>	<b>Type</b>	
	Red	Neutron alarm	
	Blue	SNM identification and user-selectable high-radiation alarms	
	Orange	Other gamma-ray alarms (e.g., NORM)	
	Amber	System error/failure	
	Green	Power/system Okay	
	White	Checking	
<b>Note:</b>	Comments are required when the requirement is not verified.		

	Verify	
	Yes	No
Neutron alarm? (Red)		
SNM identification and user-selectable high-radiation alarms? (Blue)		
Other gamma-ray alarms (e.g., NORM)? (Orange)		
System error/failure? (Amber)		
Power/system Okay? (Green)		
Checking? (White)		

<b>Describe visual indicators:</b>			
<b>Comments:</b>			
<b>Completed by:</b>			<b>Date:</b>
<b>Reviewed by:</b>			<b>Date:</b>

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 20 of 103


### Section 5.11.2.2 Warning indicators Data Sheet and Report

<b>Instrument:</b>					
<b>Model:</b>			<b>Serial Number:</b>		
<b>Date Performed:</b>			<b>Test Location:</b>		
<b>Requirement:</b>	<p>The following indications shall be provided at the user interface as a minimum.</p> <ul style="list-style-type: none"> <li>- Background changes during non-occupancies that can affect the overall sensitivity of the monitor</li> <li>- Hi-Lo detector count rate conditions</li> <li>- Energy stabilization invalid or not acceptable</li> <li>- Occupancy sensor failure, if occupancy sensors are used</li> <li>- Changes in operational status (i.e., occupied, alarm, monitoring background, fault, blocked, etc.)</li> <li>- Loss of line power</li> <li>- Battery status</li> </ul>				
<b>Note:</b>	Comments are required when the requirement is not verified.				

#### Test Results

The following indications are provided:	Yes	No
Background changes during non-occupancies that can affect the overall sensitivity of the monitor?	<input type="checkbox"/>	<input type="checkbox"/>
Hi-Lo detector count rate conditions?	<input type="checkbox"/>	<input type="checkbox"/>
Energy stabilization invalid or not acceptable?	<input type="checkbox"/>	<input type="checkbox"/>
Occupancy sensor failure, if occupancy sensors are used?	<input type="checkbox"/>	<input type="checkbox"/>
Changes in operational status (i.e., occupied, alarm, monitoring background, fault, blocked, etc.)?	<input type="checkbox"/>	<input type="checkbox"/>
Loss of line power?	<input type="checkbox"/>	<input type="checkbox"/>
Battery status?	<input type="checkbox"/>	<input type="checkbox"/>

<b>Comments:</b>					
<b>Completed by:</b>			<b>Date:</b>		
<b>Reviewed by:</b>			<b>Date:</b>		


	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 21 of 103

### Section 5.11.2.3 Basic Indications and Functions Data Sheet and Report

<b>Instrument:</b>									
<b>Model:</b>					<b>Serial Number:</b>				
<b>Date Performed:</b>					<b>Test Location:</b>				
<b>Requirement:</b>	The following information and control shall be provided for the trained user.								
	<ul style="list-style-type: none"> <li>- View operational status</li> <li>- View alarm indication.</li> <li>- Ability to reset alarms</li> <li>- View identified radionuclide(s) (user selectable through advanced or supervisory access)</li> </ul>								
<b>Note:</b>	Comments are required when the requirement is not verified.								

	Verify	
	Yes	No
The operational status can be viewed?		
The alarm indication can be viewed?		
The trained user has the ability to reset the alarms?		
The identified radionuclides can be viewed?		
Is the viewing of identified radionuclides user selectable through advance or supervisory access?		

<b>Comments:</b>									
<b>Completed by:</b>					<b>Date:</b>				
<b>Reviewed by:</b>					<b>Date:</b>				

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 22 of 103

### Section 5.11.2.4 Advanced Indications and Functions Data Sheet and Report


<b>Instrument:</b>	
<b>Model:</b>	<b>Serial Number:</b>
<b>Date Performed:</b>	<b>Test Location:</b>
<b>Requirement:</b>	The following information and control shall be provided for the supervisory user through the use of access controls or special commands.
	<ul style="list-style-type: none"> <li>- Access to and control of operating parameters (radionuclide library, alarm control),</li> <li>- Access to and control of data logging intervals,</li> <li>- Access to alarm history,</li> <li>- Access to spectra,</li> <li>- Access to radionuclide identification results and control of basic indication function,</li> <li>- Access to occupancy data set (if occupancy sensors are used),</li> <li>- Access to vehicle photo (if available),</li> <li>- Access to radiation profiles (count rate time history data),</li> <li>- Access to background radiation information,</li> <li>- Access to alarm selection criteria including the ability to select specific radionuclides</li> <li>- Access to energy and/or efficiency calibration information</li> </ul>
<b>Note:</b>	Comments are required when the requirement is not verified.

#### Test Results

	Yes	No
Access to and control of operating parameters (radionuclide library, alarm control)	<input type="checkbox"/>	<input type="checkbox"/>
Access to and control of data logging intervals	<input type="checkbox"/>	<input type="checkbox"/>
Access to alarm history	<input type="checkbox"/>	<input type="checkbox"/>
Access to radionuclide identification results and control of basic indication function	<input type="checkbox"/>	<input type="checkbox"/>
Access to spectra	<input type="checkbox"/>	<input type="checkbox"/>
Access to occupancy data set (if occupancy sensors are used)	<input type="checkbox"/>	<input type="checkbox"/>
Access to vehicle photo (if available)	<input type="checkbox"/>	<input type="checkbox"/>
Access to radiation profiles (count rate time history data)	<input type="checkbox"/>	<input type="checkbox"/>
Access to radiation profiles (count rate time history data)	<input type="checkbox"/>	<input type="checkbox"/>
Access to background radiation information	<input type="checkbox"/>	<input type="checkbox"/>
Access to alarm selection criteria including the ability to select specific radionuclides	<input type="checkbox"/>	<input type="checkbox"/>
Access to energy and/or efficiency calibration information	<input type="checkbox"/>	<input type="checkbox"/>

<b>Comments:</b>	
<b>Completed by:</b>	<b>Date:</b>
<b>Reviewed by:</b>	<b>Date:</b>



	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 23 of 103

## Section 6.2 False Alarms Data Sheet and Report

<b>Instrument:</b>			
<b>Model:</b>		<b>Serial Number:</b>	
<b>Date Performed:</b>		<b>Test Location:</b>	
<b>Requirement:</b>	When tested in an area with a stable background (only natural fluctuations) at the levels stated in Table 4, the false alarm rate shall be less than 1 per 1000 occupancies for systems that use occupancy sensors or one alarm over a 2 h time period for monitors that do not use occupancy sensors. In addition, the monitor shall not identify a radionuclide that is not present during the test period.		
<b>Note:</b>	Comments are required when more than one alarm and/or identification other than background is observed.		

### Test Results

<b>Background Reading:</b>	(add units)		
<b>Temperature:</b>	° C	<b>Humidity:</b>	%
		<b>Pressure:</b>	In. Hg.
	Number of Occupancies or test time	Number of gamma alarms	Number of neutron alarms
	Number of identifications		
<b>Comments:</b>			
<b>Completed by:</b>			<b>Date:</b>
<b>Reviewed by:</b>			<b>Date:</b>

<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 24 of 103

### Section 6.3 Response to Gamma-ray Radiation Data Sheet and Report

<b>Instrument:</b>				<b>Serial Number:</b>			
<b>Model:</b>				<b>Test Location:</b>			
<b>Date Performed:</b>							

**Requirement:** A monitor shall alarm when gamma-ray exposure rate (i.e., overall count rate) measured as an object transits through the detection zone at the speed stated for that specific application (see Table 2) is greater than the alarm setting. The monitor shall alarm a minimum of 49 times in 50 occupancies. The visual indication shall be activated as defined in step 5.11.2.1.

**Note:** Comments are required when the requirement is not verified.


#### Test Results

<b>Background Reading:</b>				(add units)			
<b>Temperature:</b>			° C	<b>Humidity:</b>			%
				<b>Pressure:</b>			In. Hg.

<b>Source:</b>	<sup>57</sup> Co		<sup>133</sup> Ba	
<b>Source Data:</b>				
	Number of occupancies	Number of alarms	Number of occupancies	Number of alarms
<b>Bottom</b>				
<b>Mid-Point Bottom/Middle</b>				
<b>Middle</b>				
<b>Mid-Point Middle/Top</b>				
<b>Top</b>				

**Comments:**

<b>Completed by:</b>				<b>Date:</b>			
<b>Reviewed by:</b>				<b>Date:</b>			


	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 25 of 103

### Section 6.4 Response to Neutron Radiation Data Sheet and Report

<b>Instrument:</b>			
<b>Model:</b>			<b>Serial Number:</b>
<b>Date Performed:</b>			<b>Test Location:</b>
<p><b>Requirement:</b> A monitor shall alarm when the neutron exposure rate (i.e., count rate) measured as an object transits through the detection zone at the speed stated for that specific application (see Table 2), is greater than the alarm setting.</p> <p>The monitor shall alarm a minimum of 49 times in 50 occupancies. The visual indication shall be activated as defined in step 5.11.2.1.</p>			
<p><b>Note:</b> Comments are required when the requirement is not verified.</p>			

#### Test Results

<b>Background Reading:</b>	(add units)		
<b>Temperature:</b>	° C	<b>Humidity:</b>	%
		<b>Pressure:</b>	In. Hg.
<b>Source:</b>		<sup>252</sup> Cf	
<b>Source Data:</b>			
	<b>Number of occupancies</b>	<b>Number of alarms</b>	
<b>Bottom</b>			
<b>Mid-Point Bottom/Middle</b>			
<b>Middle</b>			
<b>Mid-Point Middle/Top</b>			
<b>Top</b>			
<b>Comments:</b>			
<b>Completed by:</b>		<b>Date:</b>	
<b>Reviewed by:</b>		<b>Date:</b>	

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 26 of 103

### Section 6.5 Overload Data Sheet and Report

<b>Instrument:</b>		<b>Serial Number:</b>	
<b>Model:</b>		<b>Test Location:</b>	
<b>Date Performed:</b>			

**Requirement:** If a monitor is subjected to an exposure rate that is greater than the manufacturer-stated maximum during an occupancy or when performing measurements without an occupancy sensor, an alarm indicating, for example "high background" or "high counts," shall be activated and shall remain activated until the exposure rate is reduced or the alarm is reset/acknowledged by the user. The visual indication for the user selectable high radiation alarm shall be activated as defined in step 5.11.2.1.

The time required to return to non-alarm condition after the exposure rate is returned to background shall be not greater than 1 min.

**Note:** Comments are required when the requirement is not verified.

#### Test Data

<b>Background Reading:</b>		(add units)		
<b>Temperature:</b>	° C	<b>Humidity:</b>	%	<b>Pressure:</b> In. Hg.
<b>Source Data:</b>				
<b>Maximum exposure rate stated by manufacturer:</b>	(add units)			

	Count Rate Beginning	Alarm		Count Rate End	The time to recover is ≤1min	
		Y	N		Yes	No
1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			
2	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			
3	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			

Did the monitor remain in alarm until the exposure rate was reduced to the pre-test level?	Yes	No
--	-----	----


**Comments:**

---




---

<b>Completed by:</b>	<b>Date:</b>
<b>Reviewed by:</b>	<b>Date:</b>

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 27 of 103

## Section 6.6 Neutron Indication in the Presence of Photons Data Sheet and Report

<b>Instrument:</b>																												
<b>Model:</b>						<b>Serial Number:</b>																						
<b>Date Performed:</b>						<b>Test Location:</b>																						
<b>Requirement:</b>	Gamma radiation at exposure rates of up to 10 mR/h (at the face of the center of the detection assembly) shall not trigger the neutron alarm.																											
<b>Note:</b>	Comments are required when the requirement is not verified.																											
<b>Background Reading:</b>											(add units)																	
<b>Temperature:</b>			° C	<b>Humidity:</b>			%	<b>Pressure:</b>			In. Hg.																	
<b>Source Data:</b>																												
	<table border="1" style="margin: auto;"> <thead> <tr> <th colspan="3">Test Data</th> </tr> <tr> <th rowspan="2"></th> <th colspan="2">Neutron Alarm</th> </tr> <tr> <th>Y</th> <th>N</th> </tr> </thead> <tbody> <tr> <td>1</td> <td style="text-align: center;"><input type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> </tr> <tr> <td>2</td> <td style="text-align: center;"><input type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> </tr> <tr> <td>3</td> <td style="text-align: center;"><input type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> </tr> </tbody> </table>											Test Data				Neutron Alarm		Y	N	1	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>	<input type="checkbox"/>	3	<input type="checkbox"/>	<input type="checkbox"/>
Test Data																												
	Neutron Alarm																											
	Y	N																										
1	<input type="checkbox"/>	<input type="checkbox"/>																										
2	<input type="checkbox"/>	<input type="checkbox"/>																										
3	<input type="checkbox"/>	<input type="checkbox"/>																										
<b>Comments:</b>																												
<b>Completed by:</b>						<b>Date:</b>																						
<b>Reviewed by:</b>						<b>Date:</b>																						

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 28 of 103

### Section 6.7 Background Effects Data Sheet and Report

<b>Instrument:</b>			
<b>Model:</b>			<b>Serial Number:</b>
<b>Date Performed:</b>			<b>Test Location:</b>
<b>Requirement:</b>	The monitor shall provide a warning indication when a change in background is large enough to cause a substantial change in alarm probability. The indication shall be visual and audible and shall be different than monitoring alarms.		
<b>Note:</b>	Comments are required when the requirement is not verified.		


#### Test Data

<b>Background Reading:</b>				(add units)	
<b>Temperature:</b>	° C	<b>Humidity:</b>	%	<b>Pressure:</b>	In. Hg.
<b>Source Data:</b>					

Test Number	<sup>137</sup> Cs			<sup>252</sup> Cf	
	Background Change Indication (Choose One)			Background Change Indication (Choose One)	
1	<input type="checkbox"/> Yes	<input type="checkbox"/> No		<input type="checkbox"/> Yes	<input type="checkbox"/> No
2	<input type="checkbox"/> Yes	<input type="checkbox"/> No		<input type="checkbox"/> Yes	<input type="checkbox"/> No
3	<input type="checkbox"/> Yes	<input type="checkbox"/> No		<input type="checkbox"/> Yes	<input type="checkbox"/> No

	Verify	
	Yes	No
Is the visual indication for gammas different from the gamma monitoring alarm?		
Is the audible indication for gammas different from the gamma monitoring alarm?		
Is the visual indication for neutrons different from the neutron monitoring alarm?		
Is the audible indication for neutrons different from the neutron monitoring alarm?		

<b>Comments:</b>			
<b>Completed by:</b>			<b>Date:</b>
<b>Reviewed by:</b>			<b>Date:</b>

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 29 of 103

## Section 6.8.1 Radionuclide Categorization Data Sheet and Report

<b>Instrument:</b>			
<b>Model:</b>			<b>Serial Number:</b>
<b>Date Performed:</b>			<b>Test Location:</b>
<b>Requirement:</b>	<p>The manufacturer shall state the radionuclides that the monitor can identify and their category. The categories selected should be based on the list shown in 6.8.1. The following tests shall be performed based on the manufacturer-provided list.</p> <ul style="list-style-type: none"> <li>- Special Nuclear Materials: Uranium (used to indicate 233U, 235U), 237Np, Pu.</li> <li>- Medical radionuclides: 18F, 67Ga, 51Cr, 75Se, 89Sr, 99Mo, 99mTc, 103Pd, 111In, Iodine (123I, 125I, 131I), 153Sm, 201Tl, 133Xe.</li> <li>- Naturally occurring radioactive materials (NORM): 40K, 226Ra, 232Th and daughters, 238U and daughters.</li> <li>- Industrial radionuclides: 57Co, 60Co, 133Ba, 137Cs, 192Ir, 204Tl, 226Ra, and 241Am.</li> </ul>		
<b>Note:</b>	Comments are required when the requirement is not verified.		

### Test Results

	Yes	No
The manufacturer states the radionuclides that the monitor can identify by category?	<input type="checkbox"/>	<input type="checkbox"/>
The monitor can identify (at a minimum) the four different categories of radionuclides listed in the requirement?	<input type="checkbox"/>	<input type="checkbox"/>

<b>Comments:</b>			
<b>Completed by:</b>			<b>Date:</b>
<b>Reviewed by:</b>			<b>Date:</b>

<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 30 of 103

### Section 6.8.2.2 Single Radionuclide Identification - Unshielded Data Sheet and Report

<b>Instrument:</b>				
<b>Model:</b>			<b>Serial Number:</b>	
<b>Date Performed:</b>			<b>Test Location:</b>	
<b>Requirement:</b>	<p>The monitor shall identify the following radionuclides, or at least those stated by the manufacturer at the reference speed for that specific application, or measurement cycle time as stated by the manufacturer:</p> <p style="margin-left: 20px;">– 40K, 57Co, 60Co, 67Ga, 99mTc, 131I, 133Ba, 137Cs, 192Ir, 201Tl, 226Ra, 232Th, DU, 241Am</p>			
<b>Note:</b>	Comments are required when the requirement is not verified.			

**Transitory measurements**

#### Single Radionuclide Identification Unshielded Sources Test Data


**Date Performed:**

		<sup>40</sup> K				
		Bottom	Mid-point Bottom and Middle	Middle	Mid-point Top/Middle	Top
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
Corr						

**Date Performed:**

		<sup>57</sup> Co				
		Bottom	Mid-point Bottom and Middle	Middle	Mid-point Top/Middle	Top
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
Corr						



	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 31 of 103

<b>Date Performed:</b>	<b><sup>60</sup>Co</b>				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					
<b>Date Performed:</b>	<b><sup>67</sup>Ga</b>				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					
<b>Date Performed:</b>	<b><sup>99m</sup>Tc</b>				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					





<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 34 of 103

<b>Date Performed:</b>	<b><sup>232</sup>Th</b>				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

<b>Date Performed:</b>	<b>DU</b>				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

<b>Date Performed:</b>	<b><sup>241</sup>Am</b>				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 35 of 103

Source Information				(add units)
Date	Radionuclide	Activity	Exposure rate	
	<sup>40</sup> K			
	<sup>57</sup> Co			
	<sup>60</sup> Co			
	<sup>67</sup> Ga			
	<sup>99m</sup> Tc			
	<sup>131</sup> I			
	<sup>133</sup> Ba			
	<sup>137</sup> Cs			
	<sup>192</sup> Ir			
	<sup>201</sup> Tl			
	<sup>226</sup> Ra			
	<sup>232</sup> Th			
	DU			
	<sup>241</sup> Am			


**Stationary measurements**

**Single Radionuclide Identification Unshielded Sources Test Data**

Measurement time: \_\_\_\_\_ min

Date Performed: \_\_\_\_\_

<sup>40</sup> K					
	Bottom	Mid-point Bottom and Middle	Middle	Mid-point Top/Middle	Top
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 36 of 103

<b>Date Performed:</b>	<b><sup>57</sup>Co</b>				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

<b>Date Performed:</b>	<b><sup>60</sup>Co</b>				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

<b>Date Performed:</b>	<b><sup>67</sup>Ga</b>				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 37 of 103

<b>Date Performed:</b>	<b><sup>99m</sup>Tc</b>				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

<b>Date Performed:</b>	<b><sup>131</sup>I</b>				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

<b>Date Performed:</b>	<b><sup>133</sup>Ba</b>				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					


<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 38 of 103

<b>Date Performed:</b>	<sup>137</sup> Cs				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

<b>Date Performed:</b>	<sup>192</sup> Ir				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

<b>Date Performed:</b>	<sup>201</sup> Tl				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					




	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 39 of 103

<b>Date Performed:</b>		<sup>226</sup> Ra				
		<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
Corr						

<b>Date Performed:</b>		<sup>232</sup> Th				
		<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
Corr						

<b>Date Performed:</b>		DU				
		<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
Corr						

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 40 of 103

Date Performed:		<sup>241</sup> Am				
		Bottom	Mid-point Bottom and Middle	Middle	Mid-point Top/Middle	Top
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
Corr						


Source Information			
Date	Radionuclide	Activity	Exposure rate
	<sup>40</sup> K		
	<sup>57</sup> Co		
	<sup>60</sup> Co		
	<sup>67</sup> Ga		
	<sup>99m</sup> Tc		
	<sup>131</sup> I		
	<sup>133</sup> Ba		
	<sup>137</sup> Cs		
	<sup>192</sup> Ir		
	<sup>201</sup> Tl		
	<sup>226</sup> Ra		
	<sup>232</sup> Th		
	DU		
	<sup>241</sup> Am		

(add units)

**Comments:** \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Completed by:** \_\_\_\_\_ **Date:** \_\_\_\_\_

**Reviewed by:** \_\_\_\_\_ **Date:** \_\_\_\_\_

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 41 of 103

### Section 6.8.2.3 Unshielded SNM Data Sheet and Report


<b>Instrument:</b>			
<b>Model:</b>			<b>Serial Number:</b>
<b>Date Performed:</b>			<b>Test Location:</b>
<b>Requirement:</b>	The monitor shall identify the following radionuclides, or at least those stated by the manufacturer at the reference speed for that specific application, or measurement cycle time as stated by the manufacturer:  – HEU, RGPu, and WGPu.		
<b>Note:</b>	Comments are required when the requirement is not verified.		

#### Transitory measurements

#### Single Radionuclide Identification SNM Unshielded Test Data

<b>Date Performed:</b>	<b>HEU</b>				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

<b>Date Performed:</b>	<b>RGPu</b>				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 42 of 103

<b>Date Performed:</b>		<b>WGPu</b>				
		<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
Corr						

Source Information			
Date	Radionuclide	Activity	Exposure rate
	HEU		
	RGPu		
	WGPu		

(add units)


**Stationary measurements**

---

**Single Radionuclide Identification SNM Unshielded Test Data**

**Measurement time:** \_\_\_\_\_ **min**

<b>Date Performed:</b>		<b>HEU</b>				
		<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
Corr						

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 43 of 103

<b>Date Performed:</b>	<b>RGPu</b>				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

<b>Date Performed:</b>	<b>WGPu</b>				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

Source Information			
Date	Radionuclide	Activity	Exposure rate
	HEU		
	RGPu		
	WGPu		

(add units)

**Comments:**

---




---



---

**Prepared by:** \_\_\_\_\_ **Date:** \_\_\_\_\_

**Reviewed by:** \_\_\_\_\_ **Date:** \_\_\_\_\_

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 44 of 103

### Section 6.8.3 Identification of Shielded Radionuclides Data Sheet and Report

<b>Instrument:</b>				
<b>Model:</b>		<b>Serial Number:</b>		
<b>Date Performed:</b>		<b>Test Location:</b>		
<b>Requirement:</b>	<p><b>6.8.3.1 Requirements based on shielding related to shipping containers</b>  The manufacturer shall provide a list of shielded radionuclides that the monitor can identify. For this standard, the source is surrounded by 3 cm of steel on all sides. The list shall contain the following radionuclides, as a minimum:  – 133Ba, 137Cs, and 60Co  NOTE—3 cm steel is based on possible shipping container configurations and attenuation of gamma-ray emissions from each radionuclide.</p> <p><b>6.8.3.2 Requirements based on medical treatments</b>  The manufacturer shall provide a list of radionuclides that the monitor can identify when monitoring people with medical treatments. For this standard, the source is surrounded by 7.62 cm of polymethyl methacrylate (PMMA). See Table 3 for additional information. The list shall contain the following radionuclides, as a minimum:  – 67Ga, 99mTc, 131I, 201Tl</p>			
	<b>Note:</b> Comments are required when the requirement is not verified.			

**Transitory measurements**

#### Identification of Shielded Radionuclides Test Data

<b>Date Performed:</b>		<sup>133</sup> Ba				
		<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
	1					
	2					
	3					
	4					
	5					
	6					
	7					
	8					
	9					
	10					
	Corr					







<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 47 of 103

Source Information			
Date	Radionuclide	Activity	Exposure rate
	<sup>60</sup> Co		
	<sup>67</sup> Ga		
	<sup>99m</sup> Tc		
	<sup>131</sup> I		
	<sup>133</sup> Ba		
	<sup>137</sup> Cs		
	<sup>201</sup> Tl		

(add units)

**Stationary measurements**

**Identification of Shielded Radionuclides Test Data**

Measurement time: \_\_\_\_\_ min

Date Performed: \_\_\_\_\_

<sup>133</sup> Ba				
Bottom	Mid-point Bottom and Middle	Middle	Mid-point Top/Middle	Top
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
Corr				

Date Performed: \_\_\_\_\_

<sup>137</sup> Cs				
Bottom	Mid-point Bottom and Middle	Middle	Mid-point Top/Middle	Top
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
Corr				



<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 49 of 103

<b>Date Performed:</b>		<sup>131</sup> I				
		<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
Corr						

<b>Date Performed:</b>		<sup>201</sup> Tl				
		<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
Corr						

Source Information			
Date	Radionuclide	Activity	Exposure rate
	<sup>60</sup> Co		
	<sup>67</sup> Ga		
	<sup>99m</sup> Tc		
	<sup>131</sup> I		
	<sup>133</sup> Ba		
	<sup>137</sup> Cs		
	<sup>201</sup> Tl		

(add units)

**Comments:**

---




---



---

**Completed by:** \_\_\_\_\_ **Date:** \_\_\_\_\_

**Reviewed by:** \_\_\_\_\_ **Date:** \_\_\_\_\_

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 50 of 103


### Section 6.8.4 Simultaneous Radionuclide Identification Data Sheet and Report

<b>Instrument:</b>				<b>Serial Number:</b>			
<b>Model:</b>				<b>Test Location:</b>			
<b>Date Performed:</b>							
<b>Requirement:</b>	<p>a. The monitor shall have the ability to identify more than one radionuclide simultaneously. Simultaneous identification ability shall consist of radionuclides from separate categories (e.g., <sup>99m</sup>Tc + <sup>137</sup>Cs, <sup>131</sup>I + RGPu).</p> <p>b. The monitor shall have the ability to identify a radionuclide of interest when combined with other radionuclides.</p>						
<b>Note:</b>	Comments are required when the requirement is not verified.						

**Transitory measurements**

#### Simultaneous Radionuclide Identification Test Data

<b>Date Performed:</b>	<b><sup>40</sup>K + <sup>226</sup>Ra + <sup>232</sup>Th + RGPu</b>				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 51 of 103

<b>Date Performed:</b>	$^{40}\text{K} + ^{226}\text{Ra} + ^{232}\text{Th} + \text{DU}$				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

<b>Date Performed:</b>	$^{99\text{m}}\text{Tc} + \text{DU}$				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

<b>Date Performed:</b>	$^{131}\text{I} + \text{RGPu}$				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 52 of 103

Source Information				
Date	Mix	Radionuclide	Activity	Exposure rate
	$^{40}\text{K} + ^{226}\text{Ra} + ^{232}\text{Th} + \text{RGPu}$	$^{40}\text{K}$		
		$^{226}\text{Ra}$		
		$^{232}\text{Th}$		
		RGPu		
	$^{40}\text{K} + ^{226}\text{Ra} + ^{232}\text{Th} + \text{DU}$	$^{40}\text{K}$		
		$^{226}\text{Ra}$		
		$^{232}\text{Th}$		
		DU		
	$^{99\text{m}}\text{Tc} + \text{DU}$	$^{99\text{m}}\text{Tc}$		
		DU		
	$^{99\text{m}}\text{Tc} + \text{RGPu}$	$^{99\text{m}}\text{Tc}$		
		RGPu		


Stationary measurements

**Simultaneous Radionuclide Identification Test Data**

Measurement time: \_\_\_\_\_ min

Date Performed: \_\_\_\_\_


$^{40}\text{K} + ^{226}\text{Ra} + ^{232}\text{Th} + \text{RGPu}$				
Bottom	Mid-point Bottom and Middle	Middle	Mid-point Top/Middle	Top
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
Corr				

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 53 of 103

<b>Date Performed:</b>	$^{40}\text{K} + ^{226}\text{Ra} + ^{232}\text{Th} + \text{DU}$				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

<b>Date Performed:</b>	$^{99m}\text{Tc} + \text{DU}$				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

<b>Date Performed:</b>	$^{131}\text{I} + \text{RGPu}$				
	<b>Bottom</b>	<b>Mid-point Bottom and Middle</b>	<b>Middle</b>	<b>Mid-point Top/Middle</b>	<b>Top</b>
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
Corr					

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 54 of 103

Source Information					
Date	Mix	Radionuclide	Activity	Exposure rate	(add units)
	$^{40}\text{K} + ^{226}\text{Ra} + ^{232}\text{Th} + \text{RGPu}$	$^{40}\text{K}$			
		$^{226}\text{Ra}$			
		$^{232}\text{Th}$			
		RGPu			
	$^{40}\text{K} + ^{226}\text{Ra} + ^{232}\text{Th} + \text{DU}$	$^{40}\text{K}$			
		$^{226}\text{Ra}$			
		$^{232}\text{Th}$			
		DU			
	$^{99\text{m}}\text{Tc} + \text{DU}$	$^{99\text{m}}\text{Tc}$			
		DU			
	$^{99\text{m}}\text{Tc} + \text{RGPu}$	$^{99\text{m}}\text{Tc}$			
		RGPu			
<b>Comments:</b>					
<b>Completed by:</b>			<b>Date:</b>		
<b>Reviewed by:</b>			<b>Date:</b>		



<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 55 of 103

### Section 6.8.5 Overload Characteristics for Identification Test Data and Report


<b>Instrument:</b>				
<b>Model:</b>		<b>Serial Number:</b>		
<b>Date Performed:</b>		<b>Test Location:</b>		
<b>Requirement:</b>	The manufacturer shall state the maximum gamma-ray exposure rate ( $\mu\text{R/hr}$ ) relative to $^{137}\text{Cs}$ for identification.			
<b>Note:</b>	Comments are required when the requirement is not verified.			
<b>Maximum exposure rate stated by manufacturer:</b>		(add units)		
<b>Background Reading:</b>		(add units)		
<b>Temperature:</b>		<b>Humidity:</b>		<b>Pressure:</b> _____ In. Hg.
<b>Source Data:</b>				

**Transitory measurements**

Test Data	
Radionuclides Identified	
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
Correct	0%

(Enter Yes/No)

Test Report		
The monitor correctly identified $^{60}\text{Co}$ in 8 out of 10 trials	Yes	No
	<input type="checkbox"/>	<input type="checkbox"/>

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 56 of 103

**Stationary measurements**

Measurement time: \_\_\_\_\_ min

Test Data	
Radionuclides Identified	
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
Correct	0%

(Enter Yes/No)

Test Report		
The monitor correctly identified <sup>60</sup> Co in 8 out of 10 trials	Yes <input type="checkbox"/>	No <input type="checkbox"/>

**Comments:**

---



---



---

**Completed by:** \_\_\_\_\_

**Date:** \_\_\_\_\_

**Reviewed by:** \_\_\_\_\_

**Date:** \_\_\_\_\_

<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 57 of 103

### Section 6.8.6 Pile-Up Effects Test Data and Report

<b>Instrument:</b>				
<b>Model:</b>			<b>Serial Number:</b>	
<b>Date Performed:</b>			<b>Test Location:</b>	
<b>Requirement:</b>	The monitor shall correctly identify radionuclides that are associated with people who have recently received radiation therapy treatments (131I).			
<b>Note:</b>	Comments are required when the requirement is not verified.			
<b>Background Reading:</b>			(add units)	
<b>Temperature:</b>	° C	<b>Humidity:</b>	%	<b>Pressure:</b> In. Hg.
<b>Source Data:</b>				

**Transitory measurements**

Test Data Identified	
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
Correct	0%

(Enter Yes/No)

Test Report		
The monitor correctly identified <sup>131</sup> I in 8 out of 10 trials	Yes <input type="checkbox"/>	No <input type="checkbox"/>

<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 58 of 103

**Stationary measurements**

Measurement time: \_\_\_\_\_ min

Test Data	
Identified	
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
Correct	0%

(Enter Yes/No)

Test Report		
The monitor correctly identified <sup>131</sup> I in 8 out of 10 trials	Yes <input type="checkbox"/>	No <input type="checkbox"/>


**Comments:**

**Completed by:** \_\_\_\_\_

**Date:** \_\_\_\_\_

**Reviewed by:** \_\_\_\_\_

**Date:** \_\_\_\_\_


	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 59 of 103

**Section 6.9 Determination of Efficiency  
Data Sheet**


<b>Instrument:</b>			
<b>Model:</b>		<b>Serial Number:</b>	
<b>Date Performed:</b>		<b>Test Location:</b>	
<b>Requirement:</b>	The manufacturer shall state the full-energy-peak efficiency for <sup>57</sup> Co (122 keV at 85.51%, T <sub>1/2</sub> = 272 d), <sup>133</sup> Ba (356 keV at 62.05%, T <sub>1/2</sub> = 10.5 y), <sup>137</sup> Cs (662 keV at 85.1%, T <sub>1/2</sub> = 30 y), and <sup>60</sup> Co (1173 and 1332 keV at 99.857% and 99.983%, respectively, T <sub>1/2</sub> = 5.27 y).		
	NOTE—Data from Evaluated Nuclear Structure Data File (ENSDF) and Bureau National de Métrologie-Laboratoire National Henri Becquerel/Commissariat à l'énergie atomique (BNM-LNHB/CEA)		
<b>Notes:</b>	Comments are required when the requirement is not verified.		

**Test Results (Peak Efficiency)**

<b>Ambient Conditions:</b>		°C		%RH		in HG
<b>Test Equipment Used:</b>						
<i>Note: if the monitor uses multiple detectors the information below needs to be recorded for each detector</i>						

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 60 of 103

<b>Detector 1</b>																																																
<b>Efficiency Results</b>																																																
<table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th>Source</th> <th>Measured Efficiency</th> <th>Manufacturer Stated Efficiency</th> </tr> </thead> <tbody> <tr> <td>Co-57</td> <td>#VALUE!</td> <td></td> </tr> <tr> <td><sup>60</sup>Co, Pk1</td> <td>#VALUE!</td> <td></td> </tr> <tr> <td><sup>60</sup>Co, Pk2</td> <td>#VALUE!</td> <td></td> </tr> <tr> <td>Ba-133</td> <td>#VALUE!</td> <td></td> </tr> <tr> <td>Cs-137</td> <td>#VALUE!</td> <td></td> </tr> </tbody> </table>							Source	Measured Efficiency	Manufacturer Stated Efficiency	Co-57	#VALUE!		<sup>60</sup> Co, Pk1	#VALUE!		<sup>60</sup> Co, Pk2	#VALUE!		Ba-133	#VALUE!		Cs-137	#VALUE!																									
Source	Measured Efficiency	Manufacturer Stated Efficiency																																														
Co-57	#VALUE!																																															
<sup>60</sup> Co, Pk1	#VALUE!																																															
<sup>60</sup> Co, Pk2	#VALUE!																																															
Ba-133	#VALUE!																																															
Cs-137	#VALUE!																																															
<b>Test Measurements (Peak Efficiency)</b>																																																
<b>Table 1. Peak dps computations</b>																																																
<table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th>Source</th> <th>ID</th> <th>Decayed activity to date (uCi)</th> <th>Decayed Activity (Bq)</th> <th>Abundance (Abd)</th> <th>Peak (gammas/s)</th> </tr> </thead> <tbody> <tr> <td><sup>57</sup>Co</td> <td></td> <td></td> <td>#VALUE!</td> <td>0.8551</td> <td>#VALUE!</td> </tr> <tr> <td><sup>60</sup>Co, Pk1</td> <td></td> <td></td> <td>#VALUE!</td> <td>0.99857</td> <td>#VALUE!</td> </tr> <tr> <td><sup>60</sup>Co, Pk2</td> <td></td> <td></td> <td>#VALUE!</td> <td>0.99983</td> <td>#VALUE!</td> </tr> <tr> <td><sup>133</sup>Ba</td> <td></td> <td></td> <td>#VALUE!</td> <td>0.6205</td> <td>#VALUE!</td> </tr> <tr> <td><sup>137</sup>Cs</td> <td></td> <td></td> <td>#VALUE!</td> <td>0.851</td> <td>#VALUE!</td> </tr> </tbody> </table>							Source	ID	Decayed activity to date (uCi)	Decayed Activity (Bq)	Abundance (Abd)	Peak (gammas/s)	<sup>57</sup> Co			#VALUE!	0.8551	#VALUE!	<sup>60</sup> Co, Pk1			#VALUE!	0.99857	#VALUE!	<sup>60</sup> Co, Pk2			#VALUE!	0.99983	#VALUE!	<sup>133</sup> Ba			#VALUE!	0.6205	#VALUE!	<sup>137</sup> Cs			#VALUE!	0.851	#VALUE!						
Source	ID	Decayed activity to date (uCi)	Decayed Activity (Bq)	Abundance (Abd)	Peak (gammas/s)																																											
<sup>57</sup> Co			#VALUE!	0.8551	#VALUE!																																											
<sup>60</sup> Co, Pk1			#VALUE!	0.99857	#VALUE!																																											
<sup>60</sup> Co, Pk2			#VALUE!	0.99983	#VALUE!																																											
<sup>133</sup> Ba			#VALUE!	0.6205	#VALUE!																																											
<sup>137</sup> Cs			#VALUE!	0.851	#VALUE!																																											
<b>Table 2. Net Peak cps computations</b>																																																
<table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th>Source</th> <th>Gross Peak Area</th> <th>Peak Bkg</th> <th>Net Peak Area</th> <th>Acquisition time seconds</th> <th>Net Peak Count Rate</th> <th>Measured efficiency</th> </tr> </thead> <tbody> <tr> <td><sup>57</sup>Co</td> <td></td> <td></td> <td>#VALUE!</td> <td></td> <td>#VALUE!</td> <td>#VALUE!</td> </tr> <tr> <td><sup>60</sup>Co, Pk1</td> <td></td> <td></td> <td>#VALUE!</td> <td></td> <td>#VALUE!</td> <td>#VALUE!</td> </tr> <tr> <td><sup>60</sup>Co, Pk2</td> <td></td> <td></td> <td>#VALUE!</td> <td></td> <td>#VALUE!</td> <td>#VALUE!</td> </tr> <tr> <td><sup>133</sup>Ba</td> <td></td> <td></td> <td>#VALUE!</td> <td></td> <td>#VALUE!</td> <td>#VALUE!</td> </tr> <tr> <td><sup>137</sup>Cs</td> <td></td> <td></td> <td>#VALUE!</td> <td></td> <td>#VALUE!</td> <td>#VALUE!</td> </tr> </tbody> </table>							Source	Gross Peak Area	Peak Bkg	Net Peak Area	Acquisition time seconds	Net Peak Count Rate	Measured efficiency	<sup>57</sup> Co			#VALUE!		#VALUE!	#VALUE!	<sup>60</sup> Co, Pk1			#VALUE!		#VALUE!	#VALUE!	<sup>60</sup> Co, Pk2			#VALUE!		#VALUE!	#VALUE!	<sup>133</sup> Ba			#VALUE!		#VALUE!	#VALUE!	<sup>137</sup> Cs			#VALUE!		#VALUE!	#VALUE!
Source	Gross Peak Area	Peak Bkg	Net Peak Area	Acquisition time seconds	Net Peak Count Rate	Measured efficiency																																										
<sup>57</sup> Co			#VALUE!		#VALUE!	#VALUE!																																										
<sup>60</sup> Co, Pk1			#VALUE!		#VALUE!	#VALUE!																																										
<sup>60</sup> Co, Pk2			#VALUE!		#VALUE!	#VALUE!																																										
<sup>133</sup> Ba			#VALUE!		#VALUE!	#VALUE!																																										
<sup>137</sup> Cs			#VALUE!		#VALUE!	#VALUE!																																										

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 61 of 103

**Detector 2**

**Efficiency Results**

Source	Measured Efficiency	Manufacturer Stated Efficiency
Co-57	#VALUE!	
<sup>60</sup> Co, Pk1	#VALUE!	
<sup>60</sup> Co, Pk2	#VALUE!	
Ba-133	#VALUE!	
Cs-137	#VALUE!	

**Test Measurements (Peak Efficiency)**

**Table 1. Peak dps computations**

Source	ID	Decayed activity to date (uCi)	Decayed Activity (Bq)	Abundance (Abd)	Peak (gammas/s)
<sup>57</sup> Co			#VALUE!	0.8551	#VALUE!
<sup>60</sup> Co, Pk1			#VALUE!	0.99857	#VALUE!
<sup>60</sup> Co, Pk2			#VALUE!	0.99983	#VALUE!
<sup>133</sup> Ba			#VALUE!	0.6205	#VALUE!
<sup>137</sup> Cs			#VALUE!	0.851	#VALUE!

**Table 2. Net Peak cps computations**

Source	Gross Peak Area	Peak Bkg	Net Peak Area	Acquisition time seconds	Net Peak Count Rate	Measured efficiency
<sup>57</sup> Co			#VALUE!		#VALUE!	#VALUE!
<sup>60</sup> Co, Pk1			#VALUE!		#VALUE!	#VALUE!
<sup>60</sup> Co, Pk2			#VALUE!		#VALUE!	#VALUE!
<sup>133</sup> Ba			#VALUE!		#VALUE!	#VALUE!
<sup>137</sup> Cs			#VALUE!		#VALUE!	#VALUE!


**Comments:**

**Completed by:**

**Date:**

**Reviewed by:**

**Date:**

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 62 of 103

## Section 6.10 Determination of Full Width Half Maximum (FWHM) Data Sheet and Report

<b>Instrument:</b>					
<b>Model:</b>			<b>Serial Number:</b>		
<b>Date Performed:</b>			<b>Test Location:</b>		
<b>Requirement:</b>	The manufacturer shall state the FWHM as defined in the IEEE standard appropriate to the detector used for 137Cs (662 keV at 85.1%).				
<b>Notes:</b>	Comments are required when the requirement is not verified.				

<b>Ambient Conditions:</b>		°C		%RH		in HG
<b>Test Equipment Used:</b>						
<b>Source Data:</b>						

*Note: if the monitor uses multiple detectors the information below needs to be recorded for each detector*

<b>Detector 1</b>	<b>Full Width Half Maximum Measurements</b>			
	<b>Manufacturer's Stated</b>			<b>Measured value</b>
	<b>FWHM Cs-137 (keV)</b>			<b>FWHM Cs-137 (keV)</b>
	<b>Acceptance Range</b>			
	<b>(Based on Manufacturer's</b>			
	0.00	0.00		
	- 20 %	+ 20 %		





<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 64 of 103

## Section 7.1 Ambient Temperature Test Data and Report

<b>Instrument:</b>			
<b>Model:</b>		<b>Serial Number:</b>	
<b>Date Performed:</b>		<b>Test Location:</b>	
<b>Requirement:</b>	<p>The monitor shall be able to operate over an ambient temperature range from -30°C to +55°C.</p> <p>It is permissible, but not recommended, to test the system by testing components only, such as detector(s) and any components designed for use in an uncontrolled environment. If cooling or heating systems are part of the detection system it is not possible to test components only.</p> <p>This test should be carried out in an environmental chamber. Humidity levels should be low enough to prevent condensation (&lt;65% RH) and the rate of change of temperature shall not exceed 10°C per hour.</p> <p><b>NOTE: Level 1 Modification - Temperature range needs to be from -10°C to 40°C</b></p>		
<b>Note:</b>	Comments are required when the requirement is not verified.		

### Test Data

<b>Gamma Background Reading:</b>					(add units)
<b>Neutron Background Reading:</b>					(add units)
	<b>Humidity:</b>	%	<b>Pressure:</b>		In. Hg.
<b>Gamma Source Data:</b>					
<b>Neutron Source Data:</b>					


Pre-test 22°C			Isotope Key	Acceptance Range - Gamma		
Gamma Response	Neutron Response	Isotopes Identified		#DIV/0!	to	#DIV/0!
1			A - <sup>57</sup> Co	#DIV/0!		#DIV/0!
2			B - <sup>60</sup> Co	-15%		+15%
3						
4						
5						
6						
7						
8						
9						
10						
<b>Mean</b>	#DIV/0!	#DIV/0!				
<b>STD</b>	#DIV/0!	#DIV/0!				
<b>CV</b>	#DIV/0!	#DIV/0!				

Acceptance Range - Neutron		
#DIV/0!	to	#DIV/0!
-15%		+15%


  

Identification Acceptance Range		
	of	

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 65 of 103

<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 66 of 103

- 30°C									
	Beginning			8hrs			16 hrs		
	Gamma Response	Neutron Response	Isotopes Identified	Gamma Response	Neutron Response	Isotopes Identified	Gamma Response	Neutron Response	Isotopes Identified
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
<b>Mean</b>	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	
<b>STD</b>	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	
<b>CV</b>	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	
-20°C									
	Gamma Response	Neutron Response	Isotopes Identified	Gamma Response	Neutron Response	Isotopes Identified	Gamma Response	Neutron Response	Isotopes Identified
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
<b>Mean</b>	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	
<b>STD</b>	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	
<b>CV</b>	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	
0°C									
	Gamma Response	Neutron Response	Isotopes Identified	Gamma Response	Neutron Response	Isotopes Identified	Gamma Response	Neutron Response	Isotopes Identified
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
<b>Mean</b>	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	
<b>STD</b>	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	
<b>CV</b>	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	
40°C									
	Gamma Response	Neutron Response	Isotopes Identified	Gamma Response	Neutron Response	Isotopes Identified	Gamma Response	Neutron Response	Isotopes Identified
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
<b>Mean</b>	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	
<b>STD</b>	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	
<b>CV</b>	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	
55°C									
	Beginning			8hrs			16 hrs		
	Gamma Response	Neutron Response	Isotopes Identified	Gamma Response	Neutron Response	Isotopes Identified	Gamma Response	Neutron Response	Isotopes Identified
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
<b>Mean</b>	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	
<b>STD</b>	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	
<b>CV</b>	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 67 of 103

Post-test 22°C		
Gamma Response (add units)	Neutron Response (add units)	Isotopes Identified
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
Mean	#DIV/0!	#DIV/0!
STD	#DIV/0!	#DIV/0!
CV	#DIV/0!	#DIV/0!

**Test Report**

Verify if monitor responses are within the acceptance ranges

	Gamma Response		Neutron Response			Identification	
	Yes	No	Yes	No		Yes	No
55°C	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
40°C	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
0°C	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
-20°C	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
-30°C	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 68 of 103

### Section 7.2 Relative Humidity Test Data and Report

<b>Instrument:</b>			
<b>Model:</b>		<b>Serial Number:</b>	
<b>Date Performed:</b>		<b>Test Location:</b>	
<b>Requirement:</b>	<p>The monitor shall be able to operate during and after exposure to relative humidity (RH) levels of up to 93% RH at an ambient temperature of +40°C.</p> <p>There shall not be any observable effects from the exposure.</p> <p>It is permissible, but not recommended, to test to test the system by testing components only, such as detector(s) and any components designed for use in an uncontrolled environment. If cooling or heating systems are part of the detection system, it is not possible to test components only.</p>		
<b>Note:</b> Comments are required when the requirement is not verified.			

#### Test Data

<b>Gamma Background Reading:</b>		(add units)
<b>Neutron Background Reading:</b>		(add units)
<b>Gamma Source Data:</b>		
<b>Neutron Source Data:</b>		

#### 65% Relative Humidity at 22°C

	Gamma Response	Neutron Response	Isotopes Identified
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
<b>Mean</b>	#DIV/0!	#DIV/0!	
<b>STD</b>	#DIV/0!	#DIV/0!	
<b>CV</b>	#DIV/0!	#DIV/0!	

Isotope Key	
A -	<sup>57</sup> Co
B -	<sup>60</sup> Co

Acceptance Range - Gamma		
#DIV/0!	to	#DIV/0!
-15%		+15%

Acceptance Range - Neutron		
#DIV/0!	to	#DIV/0!
-15%		+15%

Identification Acceptance Range		
	of	

<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 69 of 103

93% Relative Humidity at 40°C									
	Hour 1			Hour 2			Hour 3		
	Gamma	Neutron	Isotope ID	Gamma	Neutron	Isotope ID	Gamma	Neutron	Isotope ID
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
Mean	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	

93% Relative Humidity at 40°C									
	Hour 4			Hour 5			Hour 6		
	Gamma	Neutron	Isotope ID	Gamma	Neutron	Isotope ID	Gamma	Neutron	Isotope ID
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
Mean	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	

93% Relative Humidity at 40°C									
	Hour 7			Hour 8			Hour 9		
	Gamma	Neutron	Isotope ID	Gamma	Neutron	Isotope ID	Gamma	Neutron	Isotope ID
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
Mean	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	

<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 70 of 103


93% Relative Humidity at 40°C									
	Hour 10			Hour 11			Hour 12		
	Gamma	Neutron	Isotope ID	Gamma	Neutron	Isotope ID	Gamma	Neutron	Isotope ID
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
<b>Mean</b>	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	

93% Relative Humidity at 40°C									
	Hour 13			Hour 14			Hour 15		
	Gamma	Neutron	Isotope ID	Gamma	Neutron	Isotope ID	Gamma	Neutron	Isotope ID
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
<b>Mean</b>	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	

93% Relative Humidity at 40°C									
	Hour 16								
	Gamma	Neutron	Isotope ID						
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
<b>Mean</b>	#DIV/0!	#DIV/0!							

65% Relative Humidity at 40°C									
	Hour 17								
	Gamma	Neutron	Isotope ID						
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
<b>Mean</b>	#DIV/0!	#DIV/0!							



	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 71 of 103

65% Relative Humidity at 22°C			
	Gamma	Neutron	Isotope ID
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
Mean	#DIV/0!	#DIV/0!	

Test Report

Verify if monitor responses are within the acceptance ranges

	Gamma Response		Neutron Response			Identification	
	Yes	No	Yes	No		Yes	No
93% Relative Humidity at 40°C	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
65% Relative Humidity at 40°C	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>

Comments: \_\_\_\_\_


\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Completed by: \_\_\_\_\_ Date: \_\_\_\_\_

Reviewed by: \_\_\_\_\_ Date: \_\_\_\_\_

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 72 of 103

## Section 7.3 Dust and Moisture Test Data and Report

<b>Instrument:</b>			
<b>Model:</b>	<b>Serial Number:</b>		
<b>Date Performed:</b>	<b>Test Location:</b>		
<b>Requirement:</b> The monitor, including components designed for use in an unprotected environment, shall meet the requirements stated for IP code 54 (see IEC 60529), protected from the ingress of dust and splashing water. For IP54, the ingress of dust is not totally prevented, but dust shall not penetrate in a quantity to interfere with satisfactory operation of the instrument or to impair safety, and water splashed against the enclosure from any direction shall have no harmful effects.			
<b>Note:</b> Comments are required when the requirement is not verified.			

### Test Data - Dust

<b>Temperature:</b>	°C	<b>Humidity:</b>	%	<b>Pressure:</b>	in Hg.
<b>Source Data:</b>					
	<b>Pre-Test</b>	<b>Post-Test</b>	<b>Acceptance Range - Gamma</b>		
	<sup>137</sup> Cs	<sup>137</sup> Cs	#DIV/0!	to	#DIV/0!
1			-15%		+15%
2					
3					
4					
5			<b>Inspection Results</b>		
6					
7					
8					
9					
10					
<b>Mean</b>	#DIV/0!	#DIV/0!			
<b>STD</b>	#DIV/0!	#DIV/0!			
<b>CV</b>	#DIV/0!	#DIV/0!			















<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 79 of 103

Non-Occupancy Mode without Sources (Check if alarms) - 6kV										
	Point 1		Point 2		Point 3		Point 4		Point 5	
	Yes	No	Yes	No	Yes	No	Yes	No	Yes	No
1										
2										
3										
4										
5										
6										
7										
8										
9										
10										
Alarms										

Non-Occupancy Mode with Sources (Check if out of tolerance) - 6kV										
	Point 1		Point 2		Point 3		Point 4		Point 5	
	Gamma	Neutron	Gamma	Neutron	Gamma	Neutron	Gamma	Neutron	Gamma	Neutron
1										
2										
3										
4										
5										
6										
7										
8										
9										
10										
Mean	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!

6kV - Test Report		
	Yes	No
In occupancy mode, system alarm		
In occupancy mode, readings within range		
In non-occupancy mode, system alarm		
In non-occupancy mode, readings within range		

Comments:

---



---



---


Completed by: \_\_\_\_\_ Date: \_\_\_\_\_

Reviewed by: \_\_\_\_\_ Date: \_\_\_\_\_



<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 81 of 103

		<u>With Cs-137 and Cf-252 Sources</u>		
	<b>Nominal No RF Gamma</b>	<b>Gamma Source Data:</b> _____		
1		<b>Neutron Source Data:</b> _____		
2				
3				
4				
5		<b>Acceptance Range (Gamma)</b>		
6		#DIV/0!	to	#DIV/0!
7		low (-15%)		high (+15%)
8				
9		<b>Acceptance Range (Neutron)</b>		
10		#DIV/0!	to	#DIV/0!
Mean	#DIV/0!	low (-15%)		high (+15%)
STD	#DIV/0!			
COV	#DIV/0!			
		<b>Frequency Scan Observations with Sources</b>		
	<b>Nominal No RF Neutron</b>			
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
Mean	#DIV/0!			
STD	#DIV/0!			
COV	#DIV/0!			
<b>Comments:</b>		_____		
		_____		
		_____		
		_____		
<b>Completed by:</b>		<b>Date:</b> _____		
<b>Reviewed by:</b>		<b>Date:</b> _____		


	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 82 of 103

### Section 8.3 Radiated Emissions Test Data and Report

<b>Instrument:</b>			
<b>Model:</b>		<b>Serial Number:</b>	
<b>Date Performed:</b>		<b>Test Location:</b>	
<b>Requirement:</b>	The emission limits when measured at three meters from the monitoring system shall be less than what is shown below:		
	Emission Frequency Range (MHz)		Field Strength  (micro volts/meter)
	30 – 88		100
	88 – 216		150
	216 – 960		200
	>960		500
<b>Note:</b>	Comments are required when the requirement is not verified.		

**Occupancy operations**

Test Report		
Emissions were within acceptable limits	Yes <input type="checkbox"/>	No <input type="checkbox"/>

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 83 of 103

<b>Non-occupancy operations</b>											
<table border="1"> <tr> <th colspan="3">Test Report</th> </tr> <tr> <td rowspan="2">Emissions were within acceptable limits</td> <td>Yes</td> <td>No</td> </tr> <tr> <td style="text-align: center;"><input type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> </tr> </table>				Test Report			Emissions were within acceptable limits	Yes	No	<input type="checkbox"/>	<input type="checkbox"/>
Test Report											
Emissions were within acceptable limits	Yes	No									
	<input type="checkbox"/>	<input type="checkbox"/>									
<b>Comments:</b>											
<b>Completed by:</b>		<b>Date:</b>									
<b>Reviewed by:</b>		<b>Date:</b>									

<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 84 of 103

Section 8.4 Conducted Disturbances Induced by Bursts and Radio Frequencies Test Data and Report										
<b>Instrument:</b>										
<b>Model:</b>					<b>Serial Number:</b>					
<b>Date Performed:</b>					<b>Test Location:</b>					
<b>Requirement:</b>	The monitor should not be affected by RF fields that can be conducted onto the monitor through an external conducting cable.									
<b>Note:</b>	Comments are required when the requirement is not verified.									
<b>Temperature:</b>			°C	<b>Humidity:</b>			%	<b>Pressure:</b>		
<b>Occupancy Mode</b>										
<b>Test Equipment Used:</b>										
<b>Frequency Scan Observations Without Sources</b>										

<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 85 of 103

**With Cs-137 and Cf-252 Sources**

<b>Nominal No RF Gamma</b>		<b>Gamma Source Data:</b>	
1	(add units)	<b>Neutron Source Data:</b>	
2			
3		<b>Acceptance Range (Gamma)</b>	
4		#DIV/0! to #DIV/0!	
5		low (-15%) high (+15%)	
6			
7		<b>Acceptance Range (Neutron)</b>	
8		#DIV/0! to #DIV/0!	
9		low (-15%) high (+15%)	
10			
Mean	#DIV/0!		
STD	#DIV/0!		
COV	#DIV/0!		

**Frequency Scan Observations with Sources**

<b>Nominal No RF Neutron</b>		
1	(add units)	
2		
3		
4		
5		
6		
7		
8		
9		
10		
Mean	#DIV/0!	
STD	#DIV/0!	
COV	#DIV/0!	

**Non-Occupancy Mode**

**Test Equipment Used:**

**Frequency Scan Observations Without Sources**

<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 86 of 103

**With Cs-137 and Cf-252 Sources**

	<b>Nominal No RF Gamma</b>
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
Mean	#DIV/0!
STD	#DIV/0!
COV	#DIV/0!

(add units)

**Gamma Source Data:**

**Neutron Source Data:**

**Acceptance Range (Gamma)**

#DIV/0! to #DIV/0!  
low (-15%) high (+15%)

**Acceptance Range (Neutron)**

#DIV/0! to #DIV/0!  
low (-15%) high (+15%)

	<b>Nominal No RF Neutron</b>
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
Mean	#DIV/0!
STD	#DIV/0!
COV	#DIV/0!

(add units)

**Frequency Scan Observations with Sources**

--

**Comments:**


**Completed by:**

**Date:**

**Reviewed by:**

**Date:**



	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 87 of 103

## Section 8.5 Magnetic Field Test Data and Report

<b>Instrument:</b>			
<b>Model:</b>			<b>Serial Number:</b>
<b>Date Performed:</b>			<b>Test Location:</b>
<b>Requirement:</b>	The monitor should be unaffected by a 30 Amperes/m (A/m) 60 Hz magnetic field.		
	NOTE -- 1 A/m is equivalent to a free space induction of 1.26 mTesla.		
<b>Note:</b>	Comments are required when the requirement is not verified.		

<b>Temperature:</b>		°C	<b>Humidity:</b>		%	<b>Pressure:</b>		in Hg.
<b>Test Equipment:</b>								
<b>Gamma Source Data:</b>								
<b>Neutron Source Data:</b>								

### Test Data with Sources

	Gamma Response	Neutron Response		
1				<b>Acceptance Range - Gamma</b>
2				
3			#DIV/0!      to      #DIV/0!	(add units)
4			-15%                      +15%	
5				<b>Acceptance Range - Neutron</b>
6				
7				(add units)
8			#DIV/0!      to      #DIV/0!	
9			-15%                      +15%	
10				
<b>Mean</b>	#DIV/0!	#DIV/0!		
<b>STD</b>	#DIV/0!	#DIV/0!		
<b>CV</b>	#DIV/0!	#DIV/0!		


<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 88 of 103

	Initial Orientation				Second Orientation			
	Nominal Zero Intensity		30 A/m 60 Hz		Nominal Zero Intensity		30 A/m 60 Hz	
	Gamma	Neutron	Gamma	Neutron	Gamma	Neutron	Gamma	Neutron
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
Mean	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!

**Test Data without Sources**

	Initial Orientation				Second Orientation			
	30 A/m 60 Hz				30 A/m 60 Hz			
	Gamma Alarms		Neutron alarms		Gamma Alarms		Neutron alarms	
	Yes	No	Yes	No	Yes	No	Yes	No
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
Number of alarms								



	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 90 of 103

**Section 8.6 Surges and Oscillatory Waves  
Test Data and Report**

<b>Instrument:</b>			
<b>Model:</b>		<b>Serial Number:</b>	
<b>Date Performed:</b>		<b>Test Location:</b>	
<b>Requirement:</b>	The monitor should not be affected by surges or oscillatory waves of up to 2 kV that are classified as ring waves or combination waves at 1.2/50 $\mu$ s and 8/20 $\mu$ s.		
<b>Note:</b>	Comments are required when the requirement is not verified.		

<b>Temperature:</b>		°C	<b>Humidity:</b>		%	<b>Pressure:</b>		in Hg.
<b>Test Equipment:</b>								
<b>Gamma Source Data:</b>								
<b>Neutron Source Data:</b>								

	Pre-Test		(add units)	Pre-Test		(add units)
	Ambient Gamma Background	Gamma		Ambient Neutron Background	Neutron Response	
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
<b>Mean</b>	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	
<b>STD</b>	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	
<b>COV</b>	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	

<b>Acceptance Range</b>		
Gamma Background		
#DIV/0!	to	#DIV/0!
-15%		+15%

<b>Acceptance Range - Gamma</b>		
#DIV/0!	to	#DIV/0!
-15%		+15%

<b>Acceptance Range</b>		
Neutron Background		
#DIV/0!	to	#DIV/0!
-15%		+15%

<b>Acceptance Range - Neutron</b>		
#DIV/0!	to	#DIV/0!
-15%		+15%

<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 91 of 103


Occupancy Mode

Without Sources (Check if alarms)		Cs-137 Source		(add units)	Cf-252 Source		(add units)
		With Sources (Check if out of tolerance)			With Sources (Check if out of tolerance)		
Combination Wave	Ring Wave	Combination Wave	Ring Wave		Combination Wave	Ring Wave	
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
		Mean	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!
		STD	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!
		COV	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!

Non-Occupancy Mode

Without Sources (Check if alarms)		Cs-137 Source		(add units)	Cf-252 Source		(add units)
		With Sources (Check if out of tolerance)			With Sources (Check if out of tolerance)		
Combination Wave	Ring Wave	Combination Wave	Ring Wave		Combination Wave	Ring Wave	
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
		Mean	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!
		STD	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!
		COV	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!



	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 93 of 103

### Section 9.1 Vibration Test Data and Report

<b>Instrument:</b>			
<b>Model:</b>		<b>Serial Number:</b>	
<b>Date Performed:</b>		<b>Test Location:</b>	
<b>Requirement:</b>	The monitor shall function normally when exposed to vibrations associated with equipment installed in non-weather protected locations of up to 0.5 gn over a frequency range from 10 Hz to 150 Hz. The physical condition of the monitor should not be affected by exposure (e.g., solder joints shall hold; nuts and bolts shall not come loose).		
<b>Note:</b>	Comments are required when the requirement is not verified.		

<b>Temperature:</b>		°C	<b>Humidity:</b>		%	<b>Pressure:</b>		in Hg.
<b>Test Equipment:</b>								
<b>Gamma Background Reading:</b>		(add units)	<b>Neutron Background Reading:</b>		(add units)			
<b>Gamma Source Data:</b>								
<b>Neutron Source Data:</b>								


#### Test Data

##### Readings within acceptance range with sources present

Pre-Test			Post Test		
	Gamma	Neutron		Gamma	Neutron
1			1		
2			2		
3			3		
4			4		
5			5		
6			6		
7			7		
8			8		
9			9		
10			10		
<b>Mean</b>	#DIV/0!	#DIV/0!	<b>Mean</b>	#DIV/0!	#DIV/0!
<b>STD</b>	#DIV/0!	#DIV/0!	<b>STD</b>	#DIV/0!	#DIV/0!
<b>CV</b>	#DIV/0!	#DIV/0!	<b>CV</b>	#DIV/0!	#DIV/0!

Acceptance Range - Gamma		
#DIV/0!	to	#DIV/0!
-15%		+15%

Acceptance Range - Neutron		
#DIV/0!	to	#DIV/0!
-15%		+15%

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 94 of 103

Alarms with no source present

Gamma Alarms		Neutron Alarms	
No.	Yes	No.	Yes
1		1	
2		2	
3		3	
4		4	
5		5	
6		6	
7		7	
8		8	
9		9	
10		10	
<b>Number of alarms</b>		<b>Number of alarms</b>	

Test Report		
	Yes	No
Did the system alarm during the test?		
Where the post-test readings within range?		
Where there any mechanical damage and/or loose components?		

**Comments:**


**Completed by:**

**Date:**

**Reviewed by:**

**Date:**



	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 95 of 103

## Section 9.2 Microphonics/Impact Test Data and Report

<b>Instrument:</b>			
<b>Model:</b>			<b>Serial Number:</b>
<b>Date Performed:</b>			<b>Test Location:</b>
<b>Requirement:</b>	The monitor shall be unaffected by microphonic conditions such as those that may occur from low-intensity sharp contacts at energies of up to 1.0 J. 1.0 J is equivalent to a mass of 1 kg moving at 1.4 m/s over a distance of 0.1 m.		
<b>Note:</b>	Comments are required when the requirement is not verified.		

<b>Test Equipment:</b>			
<b>Gamma Background Reading:</b>	(add units)	<b>Neutron Background Reading:</b>	(add units)
<b>Temperature:</b>	°C	<b>Humidity:</b>	%
<b>Pressure:</b>			in Hg.
<b>Gamma Source Data:</b>			
<b>Neutron Source Data:</b>			

Pretest Response		Pretest Response		Acceptance Range - Gamma		
Gamma	(add units)	Neutron	(add units)	#DIV/0!	to	#DIV/0!
1		1		low		high
2		2				
3		3				
4		4				
5		5		Acceptance Range - Neutron		
6		6		#DIV/0!	to	#DIV/0!
7		7		low		high
8		8				
9		9				
10		10				
Mean	#DIV/0!	Mean	#DIV/0!			
STD	#DIV/0!	STD	#DIV/0!			
COV	#DIV/0!	COV	#DIV/0!			

<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 96 of 103

**Test Data - Occupancy Mode**

**Without Sources**

Impact Number	Side No. 1		Side No. 2		Side No. 3	
	Record if monitor alarm during the test (Yes/No)					
	Gamma	Neutron	Gamma	Neutron	Gamma	Neutron
1						
2						
3						
<b>No. of alarms</b>						


Impact Number	Side No. 4		Side No. 5		Side No. 6	
	Record if monitor alarm during the test (Yes/No)					
	Gamma	Neutron	Gamma	Neutron	Gamma	Neutron
1						
2						
3						
<b>No. of alarms</b>						

**With Sources**

Impact Number	Side No. 1		Side No. 2		Side No. 3	
	Response After Each Impact					
	Gamma	Neutron	Gamma	Neutron	Gamma	Neutron
1						
2						
3						
<b>No. of alarms</b>						

Impact Number	Side No. 4		Side No. 5		Side No. 6	
	Response After Each Impact					
	Gamma	Neutron	Gamma	Neutron	Gamma	Neutron
1						
2						
3						
<b>No. of alarms</b>						

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 97 of 103

<b>NIST</b>	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 98 of 103


<b>Non-Occupancy Mode</b>												
<b>Test Equipment:</b>												
<b>Gamma Background Reading:</b> _____ (add units)					<b>Neutron Background Reading:</b> _____ (add units)							
<b>Temperature:</b> _____ °C			<b>Humidity:</b> _____ %		<b>Pressure:</b> _____ in Hg.							
<b>Gamma Source Data:</b>												
<b>Neutron Source Data:</b>												
<b>Pretest Response</b>												
<b>Gamma</b>					<b>Neutron</b>					<b>Acceptance Range - Gamma</b>		
										<b>#DIV/0! to #DIV/0!</b>		
1		(add units)	1		(add units)	1	low				high	
2			2			2						
3			3			3						
4			4			4						
5			5			5						
6			6			6						
7			7			7						
8			8			8						
9			9			9						
10			10			10						
Mean	#DIV/0!		Mean	#DIV/0!					<b>Acceptance Range - Neutron</b>			
STD	#DIV/0!		STD	#DIV/0!					<b>#DIV/0! to #DIV/0!</b>			
COV	#DIV/0!		COV	#DIV/0!					low to high			

**Test Data - Non-Occupancy Mode**

**Without Sources**

Impact Number	Side No. 1		Side No. 2		Side No. 3	
	Gamma	Neutron	Gamma	Neutron	Gamma	Neutron
	<b>Record if monitor alarm during the test (Yes/No)</b>					
1						
2						
3						
<b>No. of alarms</b>						

Impact Number	Side No. 4		Side No. 5		Side No. 6	
	Gamma	Neutron	Gamma	Neutron	Gamma	Neutron
	<b>Record if monitor alarm during the test (Yes/No)</b>					
1						
2						
3						
<b>No. of alarms</b>						

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 99 of 103

With Sources

Impact Number	Side No. 1		Side No. 2		Side No. 3	
	Response After Each Impact					
	Gamma	Neutron	Gamma	Neutron	Gamma	Neutron
1						
2						
3						
No. of alarms						

Impact Number	Side No. 4		Side No. 5		Side No. 6	
	Response After Each Impact					
	Gamma	Neutron	Gamma	Neutron	Gamma	Neutron
1						
2						
3						
No. of alarms						

Test Report

	Yes	No
In occupancy mode, system alarm		
In occupancy mode, readings within range		
In non-occupancy mode, system alarm		
In non-occupancy mode, readings within range		


Comments:

Completed by:

Date:

Reviewed by:

Date:

	<b>TEST AND EVALUATION PROTOCOL</b>	<b>TEP NO.</b> N42.38	<b>PREPARED BY:</b> DIV682	
	<b>TITLE: Spectroscopy- Based Portal Monitors Used for Homeland Security</b>	<b>EFF. DATE</b> 2010-11-09	<b>REV.</b> 1.02	<b>PAGE</b> 100 of 103

## Sections 10 - Documentation Test Data and Report

<b>Instrument:</b>				
<b>Model:</b>		<b>Serial Number:</b>		
<b>Date Performed:</b>		<b>Test Location:</b>		
<b>Requirements:</b>	<p><b>10. 1 Type test report</b> The manufacturer shall make available, at the request of the purchaser, the report on the type tests performed to the requirements of this standard.</p> <p><b>10.2 Report</b> The manufacturer shall provide the following information, as a minimum:</p> <ul style="list-style-type: none"> <li>- Contact information for the manufacturer including name, address, telephone number, fax number, e-mail address, etc.</li> <li>- Type of portal monitor, detector, and types of radiation the monitor is designed to measure</li> <li>- Mounting distance between detection assemblies, as appropriate</li> <li>- Power supply requirements</li> <li>- Results of tests performed to this standard</li> <li>- Recommended operational parameters such as: detector response, false alarm probability, alarm thresholds, operating parameters, and libraries</li> <li>- Complete description of the evaluated monitor</li> <li>- Enclosure specification classification</li> <li>- Inclusion of any hazardous material that may require additional regulation (such as radionuclide check source)</li> <li>- List of radionuclides that are identified by the monitor</li> <li>- Over-range exposure rate values for gross counting and identification</li> </ul> <p><b>10.3 Operation and maintenance manual</b> The manufacturer shall supply an operation and maintenance manual containing the following information to the user:</p> <ul style="list-style-type: none"> <li>- Operating instructions and restrictions</li> <li>- Module connection schematic</li> <li>- Electrical connection schematic</li> <li>- Spare parts list</li> <li>- Troubleshooting guide</li> <li>- Description and protocol for communication methods of transmitting and receiving data</li> </ul>			
<b>Note:</b>	Only one data sheet per model is required. Comments are required when the requirement is not verified.			

