


R-99-04

WATER TREATMENT ESTIMATION ROUTINE (WATER) USER MANUAL

**Water Desalination Research &
Development Program Report No. 43**

August 1999



U.S. DEPARTMENT OF THE INTERIOR
Bureau of Reclamation
Technical Service Center
Environmental Resources Services
Denver, Colorado
and
Lower Colorado Regional Office
Boulder City, Nevada

REPORT DOCUMENTATION PAGE

Form Approved
OMB No. 0704-0188

Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington DC 20503.

1. AGENCY USE ONLY (Leave Blank)	2. REPORT DATE August 1999	3. REPORT TYPE AND DATES COVERED Final	
4. TITLE AND SUBTITLE Water Treatment Estimation Routine (WaTER) User Manual		5. FUNDING NUMBERS	
6. AUTHOR(S) Michelle Chapman Wilbert, John Pellegrino, Jennifer Scott, Qian Zhang		7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Bureau of Reclamation Denver Federal Center PO Box 25007 Denver CO 80225-0007	
8. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES) Bureau of Reclamation Denver Federal Center PO Box 25007 Denver CO 80225-0007		9. PERFORMING ORGANIZATION REPORT NUMBER 2-99-04	
10. SPONSORING/MONITORING AGENCY REPORT NUMBER DesalR&D No. 43		11. SUPPLEMENTARY NOTES	
12a. DISTRIBUTION/AVAILABILITY STATEMENT Available from the National Technical Information Service, Operations Division, 5285 Port Royal Road, Springfield, Virginia 22161		12b. DISTRIBUTION CODE	
13. ABSTRACT (Maximum 200 words) As with anything else, water treatment cost estimates are difficult to get a handle on without somewhere to begin. This document and the spreadsheet program it describes are just that — a place to begin. With minimal information, such as a rough idea of the water analysis and the capacity of the treatment systems, this program provides cost estimates based on theoretical equipment sizes and chemical requirements. It is not intended to be a final design cost estimate. It is intended as a tool for comparing different process options at an early phase in the planning process. Processes included in the program are microfiltration, reverse osmosis/nanofiltration, electro dialysis, ion exchange, gravity filtration, granular activated carbon, disinfection and chemical feed systems.			
14. SUBJECT TERMS -- water treatment cost/membrane cost model/microfiltration/reverse osmosis/nanofiltration/ion exchange/electrodialysis/chlorine/chloramine/ozone/acid/alum/ferric sulfate/polymer/potassium permanganate/lime/soda ash/granular activated carbon/gravity filtration/upflow solids contact clarifier/pumps/clearwell storage		15. NUMBER OF PAGES 70	
17. SECURITY CLASSIFICATION OF REPORT UL		16. PRICE CODE	
18. SECURITY CLASSIFICATION OF THIS PAGE UL	19. SECURITY CLASSIFICATION OF ABSTRACT UL	20. LIMITATION OF ABSTRACT UL	

**WATER TREATMENT ESTIMATION ROUTINE (WATER)
USER MANUAL**

Water Desalination Research & Development Program Report No. 43

by

Michelle Chapman Wilbert'
John Pellegrino'
Jennifer Scott²
Qian Zhang¹

**Technical Service Center
Environmental Resources Services
Denver, Colorado
and
Lower Colorado Regional Office
Boulder City, Nevada**

'Environmental Resources Team
'National Institute of Standards and Technology

August 1999

*U.S. Department of the Interior
Mission Statement*

The mission of the Department of the Interior is to protect and provide access to our Nation's natural and cultural heritage and honor our **trust** responsibilities to tribes.

*Bureau **of** Reclamation
Mission Statement*

The mission of the Bureau of Reclamation is to manage, develop, and protect water and related resources in an environmentally and economically sound manner in the interest of the American public.

Disclaimer

The information contained in this report regarding commercial products or **firms** may not be used for advertising or promotional purposes and is not to be construed as an endorsement of any product or firm by the Bureau of Reclamation.

The information contained in this report was developed for the Bureau of Reclamation: no **warranty** as to the accuracy, usefulness, or completeness is expressed or implied.

ACKNOWLEDGEMENTS

Several people have been vitally important to the success of this project. Bill Boegli has been a fount of information; I must thank him for the loan of his water treatment books, and advice on determining dosage rates (without a water sample). Pat **Giarrantano**, now retired from the National Institute of Standards and Technology (**NIST**), provided the loan of her personnel for the start of this **effort**. Kim **Linton**'s review resulted in many improvements in the user experience which were sorely needed, as any who tried to review the draft product will appreciate. Most of all, this **final** product would not be possible without funding from the Water Desalination Research and Development (**DesalR&D**) Program.

CONTENTS

	<i>Page</i>
Introduction..	1
Overview of Water Treatment Estimation Routine	3
Input Requirements..	5
Production and Index Input	5
Water Analysis Input	5
Water Data Reports	5
Cost Indices	5
Cost Reports..	5
Microfiltration	7
Introduction	7
Microfiltration Input	7
Process input from Micro input worksheet	7
Operation and maintenance cost input.....	8
Process flow calculation	8
Microfiltration Output	9
Capital cost estimation:	9
Indirect capital cost.....	9
Operation and maintenance cost estimation	10
Reverse Osmosis and Nanofiltration	13
Introduction	13
RO&NF Input	13
Process input	13
Data from membrane product specifications	14
Determination of operating pressure	17
Membrane system size estimation	17
Operation and maintenance cost input parameters	17
RO&NF Output	17
Capital cost estimation	17
indirect capital cost..	21
Operation and maintenance cost estimation.....	21
ion Exchange	25
Introduction	25
Design	25
Resin Medium	26
Vessel cost	27
Regeneration	27
Regeneration and Backwashing Pump	27
output	28
Electrodialysis	29
Design	29
Input	30
Cost Computation	31

CONTENTS

	<i>Page</i>
Disinfection and Chlorine and Choramine	33
Design	33
Input	33
Cost Computation..	34
Output	35
Links	35
Assumptions..	35
Ozone Disinfection	37
Introduction	37
Purpose..	37
Links	37
Cost Computation..	37
Acid Feed	39
Design	39
Input	39
Cost Computation..	41
Output	41
Links	41
Assumptions	41
Improvements	41
Alum or Ferric Sulfate Feed	43
Design	43
Input	43
Cost Computation..	43
Output	44
Links	44
Assumptions	44
Polymer Feed	45
Design	45
Input	45
Cost Computation..	45
Output	45
Links	45
Assumptions	45
Potassium Permanganate	47
Input	47
Cost Computation	47
Output	47
Links	47

CONTENTS

	<i>Page</i>
Lime & Soda Ash Feed	49
Design	49
Input	50
Cost Computation	50
Output	50
Links	50
Assumptions..	50
Improvements	50
 Granular Activated Carbon	 51
Introduction	51
Cost estimate	51
 Gravity Filtration	 53
Introduction	53
Design	53
Cost estimation	53
Improvements	53
 Upflow Solids Contact Clarifier.....	 55
Introduction.	55
Design	55
Cost Computation	55
 Pumps	 57
Introduction..	57
Design	57
Direct costs..	57
Operating Costs	58
Output	58
 Clearwell Storage	 59
Introduction	59
Input	59
Cost Computation	59
Output	60
 Water Analysis..	 61
 Bibliography	 63
 Appendix	 A-1

CONTENTS • continued

Tables

<i>Table</i>		<i>Page</i>
1	Valid Dose ranges for chemical addition processes..	4
2	Indices used in updating water treatment costs	6
3	Membrane Data	14
4	Default values for ion exchange operational parameters	25
5	Default values for resin parameters	25
6	Default parameters for Electrodialysis cost estimates	30

INTRODUCTION

One of the primary concerns in updating an older water treatment plant, or building a new one is: “How much will it cost?” These days, there are many alternative water treatment processes in use, with pros and cons for each. Before one gets mired in the differences, similarities, and potential for success, it is reassuring to look at the price tags. Cost is one tangible way to eliminate options. Yet cost is one of the most difficult aspects of a process to get a handle on before the design process has begun. According to Peters and Timmerhaus, in *Plant Design and Economics for Chemical Engineers* (1980), an order of magnitude estimate should cost about \$4000 (1979\$). It requires knowledge of the water composition, plant capacity, location and site requirements, utility requirements, raw materials and finished product handling and storage requirements. Yet, the cost is needed before any agreements are made.

In 1994, the Bureau of Reclamation built a mobile Water Treatment Plant Trailer for the purpose of exploring ‘water treatment alternatives. One of the questions most frequently asked is “How much will these systems cost?” Because of that, we have tried to automate the cost estimation process so that we can provide a reasonable answer based on production capacity, and the water analysis. Sure, there are many ways to specify which equipment is used, but when you step back and look at a long history of water treatment system costs, it is possible to come up with a set of good generalizations.

Back in 1979, the EPA published a very thorough study on water treatment costs (EPA-60012-79-162). It separates costs into different categories for manufactured equipment, labor, pipes and valves, electrical and instrumentation, housing, etc. Then costs are repotted and graphed for different sizes of plants. The trouble is that you cannot use the graphs until you know the size of the process. For instance, chlorine feed cost is based on the number of kg/day of chlorine needed. Chlorine demand is usually determined through jar tests, which require money, time, and a fresh water sample. In addition, if you wanted to compare chlorination with ozonation, you would need to have the size of the ozone contact chamber. These items are not generally included in a standard water analysis.

In a joint effort between the Bureau of Reclamation, and the National Institute of Standards and Technology, a water treatment design spreadsheet program has been developed to address this problem. This Excel spreadsheet estimates the design parameters needed to drive the EPA cost estimates, then updates cost information for several water treatment processes to current dollars. The capacity requirements and minimal input about the process are entered on Capacity worksheet. Also, the water data report based on water analysis is shown on the Capacity worksheet. The water analysis is entered in the H2O Analysis worksheet. Cost indices based on the Engineering news Record construction cost index and Bureau of Labor Statistics (February, 1999 built in) are entered on the Cost Index worksheet and may be updated by the user. Cost and sizing calculations for the different processes are performed on linked worksheets. These worksheets contain the parameters that may be refined when the equipment is specified more exactly. Cost and relevant design parameters are reported back to the Report worksheet.

The program calculates dosage rates and cost estimates for the following water purification processes:

- pH adjustment with sulfuric acid.
- Disinfection with chlorine, chloramine, and ozone.
- Coagulation/Flocculation with alum, ferric sulfate, and lime/soda ash using upflow solids contact clarifiers.
- Filtration enhancement with polymer feed.
- Filtration with granular activated carbon, and granular media.
- Microfiltration as pretreatment to remove particulate materials

- Demineralization with ion exchange, electro dialysis, and reverse osmosis
- Pumping: raw water, backwash, and finished water pumping.

The Water Treatment Estimation Routine (WaTER) is based primarily on the EPA report *Estimating Water Treatment Costs, Vol. 2, Cost Curves Applicable to 200 mgd Treatment Plants* (EPA-600/2-79-1626, August 1979). For estimates using cost curves from this EPA report, or from Qasim et al. (AWWA, Aug. 1992). the assumptions used in the EPA report are pertinent. The EPA report details the configuration of each process, and what is not included. The EPA is working on an update to that cost study. When it is published, we hope to incorporate the new cost curves and parameters into this program.

OVERVIEW OF WATER TREATMENT ESTIMATION ROUTINE

The Water Treatment Estimation Routine is an Excel workbook. WTCOST.xls is the name for this Excel workbook. Computer requirements are as follows:

- . Windows 95 or higher
- . Microsoft Excel Office 97.
- . Pentium Co-processor is desirable.

Open the workbook by double clicking on the file name. To bring a desired worksheet into the window, single-click on the name of the worksheet tab at the bottom of the screen. To navigate through the worksheets, simply, click on the name of the worksheet tab. Remember that the worksheets are linked so that changes in one worksheet will be reflected in the other worksheets. The worksheets included are:

- Capacity-Production capacity and water data report.
- H2O Analysis -Water analysis
- Cost Index -Current cost indices
- Report-Reports for water treatment processes
- Micro Input-Input for Microfiltration sizing
- Micro Output - Output for **Microfiltration** cost
- RO&NF Input - Input for Reverse Osmosis or Nanofiltration sizing
- Rejection -Calculates observed rejection for given water and recovery rates
- RO&NF Output - Output for Reverse Osmosis or **Nanofiltration** cost.
- ION-EXH - Ion exchange resin volume and cost
- ED2 - Electrodialysis sizing and cost
- CL2 -Chlorination dosage and cost
- NHCl - **Chloramine** dosage and cost
- OZONE - **Ozone** dosage and cost
- DG&ACID - Acid dosage
- ACID -Acid feed cost
- ALUMFD - Alum dosage and cost
- LRONFD -Ferric sulfate dosage and cost
- POLYFD -Polymer dosage and cost
- KMnO₄ - Potassium **permanganate** dosage and cost
- LIMEFD -Lime and soda ash dosage and cost
- GAC -Granular activated carbon cost
- GRAVFILT - Granular media filter sizing and cost
- UFSCC - **Upflow** solids contact clarifier sizing & cost
- PUMPS -Pump sizing and cost
- CLEARWELL - Below ground and ground level **clearwell** cost
- Water Analyses - A collection of general water analyses in case you need one.

Most worksheets contain a set of data that have been used to create graphs to demonstrate the relationship between cost and capacity for a range of dosage rates, or sizes, depending on the appropriated parameter for the process. You may perform sensitivity studies with these worksheets to determine how the cost is effected by the various process parameters.

To create a new set of data for the worksheet of interest, first, erase the old set of data, then change the desired parameters, click on the Macro command button with the name of the worksheet on it located on top of the data set. Repeat this process to generate the data. The graphs incorporated into the worksheets will update automatically when data are changed. Samples of the graphs are included in the appendix.

The applicable ranges for some treatment process are listed in Table 1. If the calculated values for your system are outside these ranges, the cost values may not be representative.

Table 1. Valid Dose ranges for chemical addition processes.

Name	Range	Metric Units	Range	English Units
CL ₂	4 - 4500	kg/day	9 - 9921	lb/day
NHCL	110-2300	kg/day	243-5071	lb/day
ACID	0.04 - 20	m ³ /day	11 -5264	gal/day
ALUM (Dry)	4 - 2300	kg/hr	9 - 5071	lb/hr
ALUM (Liquid)	2 - 2500	kg/hr	4-5512	lb/hr
IRONFD	6 - 3000	kg/day	13-6614	lb/day
POLYMER	0.5 - 100	kg/day	1 - 220	lb/day
KMnO ₄	0.5 - 100	kg/day	1-220	lb/day
LIME	4 - 4500	kg/hr	9 - 9921	lb/hr

INPUT REQUIREMENTS

You may refer to the copy of [WTCOST.XLS] Capacity, H2O Analysis, and Cost Index worksheets in the appendix or, better yet, the screen version on your computer.

Production and Index Input: The Capacity, H2O Analysis, Cost Index, and Report worksheets allow the user to estimate costs for each treatment process separately. It requires following general information:

- . Required plant feed flow rate in L/sec
- . Desired plant product flow rate in L/sec
- . Water analysis
- . Cost Indices: February 1999 included.

Water Analysis Input: This table summarizes metals and inorganic components. Water analysis data is entered in the shaded column labeled "Water Analysis" in the units specified. Concentration is compared with the USEPA Drinking Water Standards Maximum Contaminant Level (MCL). If there is an **exceedance**, it is calculated and appears in BOLD in the next column, labeled "Amount over MCL." Equivalents per liter, and concentration in moles/liter, are calculated for your convenience, and for bookkeeping purposes.

Water Data Reports: Vital data from the water analysis are listed in the Capacity worksheet. These data, calculated or repeated from the water analysis, are used in the design algorithms.

Cost Indices: The cost components are based on those used by Qasim (1992). Each is tied to one of the Engineering News Record (ENR) or Bureau of Labor Statistics (BLS) indices. Table 2 lists the cost components from February 1999 used in updating water treatment costs. Cost curves from the Qasim paper were updated from April 1992. Cost curves developed directly from the EPA report were updated from October 1978.

Cost Reports: The Report worksheet is set up with sections for each process. Each contains the name of the process in the upper left corner. Variables are listed that are either taken from the Capacity worksheet, or are entered in the colored or shaded cells.

Construction cost, and operation and maintenance costs are reported in each section. This represents the first level of generalization. To refine the estimates further, it is necessary to adjust process design parameters that have assumed values on their separate worksheets.

Table 2. Indices used in updating water treatment costs.

Cost Component	Index 1967 = 100	1999 Value
Excavation & site work	ENR Skilled Labor Wage Index	548.67
Manufactured equipment	BLS General Purpose Machinery & Equipment Commodity Code 114	149.10
Concrete	BLS Concrete Ingredients Commodity Code 132	150.20
Steel	BLS Steel Mill Products Commodity Code 1017	106.60
Labor	ENR Skilled Labor Wage Index	548.67
Pipes and valves	BLS General Purpose Equipment Producer Price Index 1149	164.30
Electrical equipment and instrumentation	BLS Electrical Machinery & Equipment Commodity Code 117	120.60
Housing	ENR Building Cost Index	505.81
Energy requirements	Local \$/kWh	0.07
Maintenance material requirements	BLS Producer Price Index for Finished Goods Code SOP3000	131.30
Labor requirements	Local \$/hr	30

Now we get to the major drawback of using a spreadsheet for this type of application. The costs reported here are based entirely on the water analysis and production data as they are entered in the water analysis tables. If you want to use only one of the processes, that would be fine. However, the composition of the water will change after it has left any one of the processes. Then, the next process cost is based on the wrong water composition. You, the user, will have to pick the process flow scheme for your application, and adjust water analysis accordingly. The cost report should then be copied to another area of the spreadsheet and converted to values so that it will not change when you adjust the water analysis. In this way you can build a more accurate report for your application.

MICROFILTRATION (MF INPUT & OUTPUT)

Introduction:

Microfiltration is used as pretreatment to remove particulate material from water, including microorganisms such as protozoa, bacteria (*Giardia* and *Cryptosporidium*) to meet new and future environmental requirements. The purpose of this section is to provide cost estimation for Microfiltration. This section consists of two worksheets: Micro-input and Micro-output. The cost estimation is based on factory-assembled hollow fiber Microfiltration units.

Most of the Microfiltration membranes system includes the following equipment:

- Membrane module skids - membrane modules, backwash manifold pipework, integral valves and instruments, support legs, control panels.
- Air supply system - air compressors, air dryers, **coalescers** and air filters, process air receiver, air regulator, plant pneumatic control enclosure, solenoid valves and instruments.
- Clean in place - concentrate tank, concentrate transfer pump, solution tank, solution tank heater and control panel, re-circulation pump, valves and instruments.
- Control system main control panel, master PLC, plant *I/O*, man-machine interface.
-

The Microfiltration membrane manufacturers can provide more details on the scope of supply.

Micro input worksheet consists of:

- Process input
- Operation and maintenance cost input
- Process flow calculation

Micro output worksheet consists of:

- Capital cost estimation(direct and indirect)
- Operation and maintenance cost estimation

Microfilltration Input:

*Process input **from** Micro input worksheet:*

The following parameters are needed for cost estimation:

- Design product flow rate (gpd)
- Plant availability (%)
- Microfilters system equipment cost (\$)
- Cost per MF membrane (\$)
- MF modular system flow rate (gpm)
- No. membranes per microfilter
- Pump **efficiency** (%)
- Motor **efficiency** (%)
- Design feed pressure (psi)

- Backflush pressure (psi)
- Backwash intervals (minutes)
- Backwash and backflush duration (minutes)

Operation and maintenance cost input:

- Electricity rate (\$/kwh)
- Chemical costs (sodium hypochlorite, \$/L)
- Design dosage (mg/L)
- Specific gravity of sodium hypochlorite
- Solution concentration (%)
- Membrane life (year)
- Staff days/day
- Labor rate (salary and benefits, \$/hr)
- Amortization time (year)
- Interest rate (%)
-

Process flow calculation: All values in this section are calculated from inputs listed above. MF feed flow is the total feed flow to the **Microfiltration** plant. It is calculated by:

$$MFF = \frac{MFP}{Y}$$

Where: MFF = Microfiltration feed flow (L/sec)
 MFP = Microfiltration product flow (L/sec)
 Y = Recovery rate

MF reject flow (MFR (L/sec)) is the amount of water used for backwash and cleaning of the membranes. It is calculated by:

$$MFR = \frac{BBD * BBF}{BI}$$

Where: BBD = backwash and backflush duration (sec)
 BBF = backwash flow rate (L/sec)
 BI = backwash interval (sec)

Recovery rate (R) is calculated by:

$$R = \frac{MFP}{MFF}$$

Feed pump brake horsepower (HP) is calculated by:

$$HP = \frac{MFF * DFP * 2.31}{PP\% * 3960}$$

Where: DFP = design feed pressure (psi)

PP% = pump efficiency (%)
 2.31 = conversion factor for feet of vertical head of water per lb/in²
 3960 = another English-Metric conversion factor.

Feed pump kilowatt-hour (kwh) is calculated by:

$$kWh = \frac{MFF * DFP * 2.31 * 0.00315}{PP\% * M\% * 1000}$$

Where: M% = motor efficiency (%)
 0.00315 = conversion factor for consumption of electrical energy

Building area in square meter is estimated to be 1.23 percent of the design product flow rate in cubic meter per day.

Microfiltration Output:

The cost estimate does not include concentrate disposal, National Environmental Policy Act (NEPA) compliance, or water system storage and distribution cost.

Capital cost estimation:

Direct capital costs are the sum of **microfilters**, building, MF installation, miscellaneous, plant interconnecting piping, engineering. These cost elements are discussed below:

Microfilters: The actual price for microfilters is obtained from membrane manufacturers. The price will vary upon the type of **microfilters** and quantities involved. The total **microfilters** cost is estimated as the cost per skid unit times the number of units.

Building: The building cost is estimated \$1076 per square meter times the total building area in square meter.

MF installation: The microfilter installation cost is estimated \$70,000 per unit for a large system (at 37.85 L/s flow rate).

Miscellaneous: This cost includes that any miscellaneous items needed to complete the project. It is estimated 5 percent of the total **microfilter** cost.

Plant interconnecting piping: This cost estimated 5 percent of the sum of total **microfilter** and miscellaneous costs.

Engineering: Engineering cost is estimated 10 percent of the sum of total **microfilter** and miscellaneous costs.

Indirect capital cost:

The indirect capital costs are the sum of:

- . Interest during construction (6% of total direct capital cost)
- . Contingencies (20% of total direct capital cost)

- A&E fees and project management (10% of total direct capital cost)
- Working capital (4% of total direct capital cost)

Operation and maintenance cost estimation:

Operation and maintenance costs include:

- Electricity
- Labor
- Chemicals (sodium hypochlorite)
- Membrane replacement
- Cleaning chemicals
- Repairs and replacement and miscellaneous

Total annual cost equals the capital recovery cost plus the total operation and maintenance costs. These major O&M cost elements are discussed below:

Electricity: Electricity cost is the total kilowatt-hour for the feed pump and backflush pump times the electricity cost (\$/kwh).

Labor: This cost is estimated by the number of staff days times the going rate per day.

Chemicals: The cost of Sodium hypochlorite for disinfection is estimated based on the correlated formula from the Microfiltration membrane quotation data:

$$SHC * (.0025 * MFP - 333.33)$$

Where: SHC = sodium hypochlorite cost (\$/L)

Membrane replacement: The cost is estimated by

$$\frac{Elements * \$ I Element}{MemebraneLife}$$

Cleaning chemicals: Sodium hypochlorite cost is estimated based on the correlated formula from the Microfiltration membrane quotation data:

$$(0.00005 * MFP + 66.67) * SHC$$

Repairs and replacement and misc.: The cost for repairs and replacements assumed to be 0.5% of the total direct capital cost.

Capital recovery cost: The capital recovery cost equals

$$TCC * \left[\frac{i * (1+i)^n}{(1+i)^n - 1} \right]$$

Where: TCC = total construction cost
i = interest rate
n = number of years

REVERSE OSMOSIS AND NANOFILTRATION (RO&NF INPUT, REJECTION AND RO&NF OUTPUT)

Introduction:

The purpose of this section is to provide cost estimation for Reverse Osmosis (RO) and Nanofiltration (NF). This section is made up of three worksheets: RO&NF Input, Rejection and RO&NF Output.

RO&NF Input worksheet consists of:

- Process input
- Data from membrane product specification
- Determination of operating pressure
- Membrane system size estimation
- Pump size estimation
- Operation and maintenance cost input parameters

The Rejection worksheet calculates the actual membrane rejection and water permeation rates from the membrane specifications for the present water quality. These values are used to calculate the osmotic pressure differential and the membrane area needed.

RO&NF Output worksheet consists of:

- Capital cost estimation (direct and indirect)
- Operation and maintenance cost estimation

RO&NF Input:

Process **input**: The calculation routine is based on desired product or permeate flow rate. Desired product flow rate is the value entered on the Capacity worksheet. The percent recovery, the ratio of product flow rate to feed flow rate, is entered on the Report worksheet in the Reverse Osmosis section. If the recovery value is too high, there will be problems with the cost estimate. To give you an idea of what recovery rates should be, first check the delta G value in the water data report section in Capacity worksheet. If it is negative or close to zero, or if you plan to use acidification and/or **antiscalants**, you can use the following estimates.

Seawater	50 %
15,000 to 20,000 TDS	75 %
5,000 to 15,000 TDS	85 %
Nanofiltration	90 %

These values are only estimates; the maximum recovery possible depends on the composition of the feed water.

If the product water concentration is lower than necessary, as is often the case with RO, it may be possible to decrease the membrane system capacity by blending the product water with pretreated feed water. The blending option is specified in the RO and NF section of the Report worksheet. If the response is yes (Y), the ratio of blend water to product will be calculated based on the target product water TDS. The membrane system will be sized for the resulting smaller capacity. If no (N) is entered, this value will be

zero. The maximum portion of blend water that can be used, assuming the blend water has the same TDS as the feed water is calculated as follows:

$$C_T V_T = C_p V_p + C_b V_b$$

$$V_b = \frac{C_T - C_p}{C_b - C_p}$$

Where C stands for concentration in mg/L, V is flow, with $V_T = 1$. Subscripts *T* is for target, *p* is for RO permeate and *b* is for blend water.

Data from membrane product specifications: Information for this section is obtained from the membrane product specification sheets provided by membrane manufacturers. Table 3 lists data needed. This data should be on **all** manufacturers specification sheets.

Table 3: Membrane Data

Type of membrane	Film Tec, BW30-400	
Productivity	40	m ³ /day
Area per module	37	m ²
Operating pressure, P _{app}	1550	kPa
Test solution TDS	2000	mg/L
MW of test salt	58.44	mg/mmol NaCl
Chloride Rejection	0.995	
Sulfate Rejection	0.998	
Recovery Rate	15	%
Temperature	25	°C

These parameters are used to calculate the water transport coefficient, A, and the intrinsic and actual rejection rate. The water **transport** coefficient measures the permeation of water through a membrane for a unit of applied pressure. It is calculated by:

$$A = \frac{J_v}{NDP_o}$$

Where:

- A = water transport coefficient, m³m⁻² sec⁻¹Pa⁻¹
- J_v = initial module productivity taken from the specification sheet, m³/day
- NDP_o = net driving pressure under test conditions, kPa

$$NDP_o = P_{app} - P_{osm}$$

Net driving pressure under test conditions, NDP_o:

Where:

- P_{app} = operating pressure at test conditions, kPa
- P_{osm} = osmotic pressure of the feed water, kPa

Osmotic pressure of the feed water, P_{osm} :

$$P_{osm} = 0.99 * 2 * R * (273.15 + T) * C_w / 1000$$

Where: R = universal gas constant, $m^3.Pa/mole.K$
 T = temperature, $^{\circ}C$
 C_w = concentration at the membrane surface. As a first approximation this is **taken** as the average of the feed and concentrate concentrations, $mole/m^3$
 0.99 = NaCl dissociation constant.

Concentration of salt in feed water, C_f :

$$C_f = TDS_f / Avg MW$$

Where: TDS_f = feed TDS, mg/L
 Avg MW = feed average molecular weight, assuming NaCl is used to test the membranes, this would be 58.4 g/mole.

Osmotic pressure of the feed solution, concentration polarization and the resulting decrease in productivity are accounted for using a model method developed by Rao and Sirkar (1978) for the perfectly mixed feed and permeate model, with concentration polarization

Let C_w = boundary layer concentration at the membrane interface caused by concentration polarization. Assume that no gel formation occurs. Because the feed side is perfectly mixed, $C = C_b$, where C_b = bulk concentration.

$$\text{Then: } C_b = \frac{C_f - \theta C_p}{1 - \theta}$$

where θ = recovery rate of water. The intrinsic rejection of a membrane is defined as $R^{\circ} = 1 - C_p / C_w$. This is different from the apparent rejection, $R_a = 1 - C_p / C_f$. The intrinsic rejection is a characteristic of the membrane. The apparent rejection is determined by the operating conditions. For lack of anything better, we **assume** that the reported rejection, most likely measured under optimum conditions with a minimum **challenge**, is close to the intrinsic rejection. We can then use this to estimate C_w , the wall concentration and the C_p , the product concentration to be expected with the current operating conditions.

From the simple boundary layer model for concentration polarization and assuming that R° is constant, the following relationship for C_p is obtained:

$$C_p = C_r \left[\frac{(1 - R^{\circ}) \exp\left(\frac{J_v}{k}\right)}{R^{\circ} + (1 - R^{\circ}) \exp\left(\frac{J_v}{k}\right)} \right]$$

The wall concentration is

$$C_w = C_r \frac{\exp\left(\frac{J_v}{k}\right)}{R^o + (1 - R^o) \exp\left(\frac{J_v}{k}\right)}$$

From the material balance $C_r = C_b$ is defined by:

$$C_r = C_b = \frac{C_f}{(1 - \theta) + \frac{\theta(1 - R^o) \exp\left(\frac{J_v}{k}\right)}{R^o + (1 - R^o) \exp\left(\frac{J_v}{k}\right)}}$$

With k = the boundary layer mass transfer coefficient. The variable 'k' is obtained via a correlation that assumes that $J_v \ll U_c$, where U_c is the average cross flow velocity. The correlation used in this model is from Schock & Miquel (1987) for RO membrane in spacer filled flat channels.

$$k = 0.065 * Re^{0.875} Sc^{0.25}$$

Re is the Reynolds number and SC is the Schmidt number.

$$Re = \frac{\rho \bar{U}_c d}{\eta}$$

$$Sc = \frac{\bar{U}_c}{D}$$

d	=	representative channel or tube dimension for flow (i.e., diameter)
\bar{U}_c	=	average cross flow velocity
ρ	=	density
η	=	shear viscosity
D	=	solute diffusivity

Now we can calculate the actual rejection, R_a

$$R_a = 1 - \left(\frac{C_p}{C_f} \right)$$

The actual permeation rate J_v is now:

$$J_v = A(P_{app} - P_{osm})$$

As calculated above with the new estimation for C_w . This group of relationships is non-linear because of the exponential term and must be solved iteratively (using successive substitutions). There is a graph of R_a and J_v on the Rejection sheet showing the solution progress through much iteration. If the solution fails to stabilize, check the inputs for accuracy.

Determination of operating pressure: The NDP used for the specification testing is the default NDP used to determine the recommended operating pressure. The user can change this value. The osmotic pressure of the feed water is calculated as described above and then the operating pressure is calculated as follows:

$$P_{app} = NDP_i + P_{osm}$$

Where: P_{app} = applied operating pressure under the conditions of interest for the cost estimate, kPa
 NDP_i = net driving pressure entered by the user (may chose to enter the manufacturer's test NDP.), kPa
 P_{osm} = osmotic pressure difference between the bulk stream and product stream based on the membrane rejection and recovery rate and the water analysis provided, kPa

It is assumed that the water transport coefficient, A, is constant under all conditions, independent of feed water TDS and operating pressure. The new J_v is calculated as above using the new pressure conditions.

Membrane system size estimation: With J_v calculated for the water quality and operating pressure, the number of membrane modules can be calculated. There are user inputs for the number of modules per vessel and number of vessels per block. The required number is rounded up to fit into the specified configuration. The number of blocks determines the number of chemical feed systems and pressure pumps. The user specifies the number of product water pumps, transfer pumps, raw water pumps and the administrative building area.

There are three different types of pumps: single stage turbine (SST), centrifugal single speed (CSS) or variable speed turbine (VST). There is a different cost correlation for each type based on horsepower. All of the pumps sizing calculations are the same. Pump horsepower is based on the capacity per block, pressure differential, pipe diameter, length of piping and vertical lift needed. Pipe diameter is tied in with the capacity per block. The lengths of piping and vertical lift have default values. Pressure differential for the high pressure pumps is based on the calculated operating pressure. The other pumps have default values.

Operation and maintenance cost input parameters: Chemical costs, membrane life, cleaning rate, and operation!; labor can be input in this section. Number of labor hours includes only hours required for the reverse osmosis system. Electrical costs and labor cost are brought over from the Cost Index sheet.

RO&NF Output:

Capital cost estimation:

The relations for most of the direct capital costs are extracted from technical paper presented by Suratt (1995). Direct capital costs are the sum of membranes, RO skids, building, electrical, instrumentation & controls, high pressure pumps, raw water transfer pumps, product water pumps, degasifiers, odor control, process piping, yard piping, chemical feed with pumps, cartridge filters, membrane cleaning equipment, contractor engineering & training, concentrate treatment & piping, generators, and sitework. These major construction cost elements are discussed below:

Membranes: The actual price for membrane is obtained from membrane distributors. The price will vary upon the type of membrane and quantities involved. The total membrane cost is estimated as: \$750 per high rejection RO element is used for membrane estimation.

RO skids: This cost is a function of the number of pressure vessels. The cost is estimated as

$$\$/\text{vessel} * \text{Number of vessels}$$

RO skids include the pressure vessels supported by structural painted steel skid support frame, piping connector sets for each vessel, and piping manifolds. \$5000 per pressure vessel **is** assumed (Suratt, 1995).

Building: The cost is estimated as

$$\text{Unit Cost}(\$/\text{m}^2) * \text{Building Area}(\text{m}^2)$$

Unit costs vary depending on the level of architectural treatment and the location of the plant being built. \$1,076 per m^2 is used for this spreadsheet (Suratt, 1995).

Electrical: The cost is estimated using a model adapted from Suratt, 1995.

$$\$/\text{m}^3 * \text{product capacity}^{0.65}$$

Product capacity is in m^3/day . \$614 per m^3 of product water *is* used for this spreadsheet (Suratt, 1995).

Instrumentation & control: The formula for this cost is

$$\$300,000 + \$65,000 * \text{Number of RO skids}$$

\$300,000 is for the central computer system. Additional of \$65,000 is for the local instrumentation and controls per skid.(Suratt, 1995)

High pressure, raw water transfer, product water pumps: The cost of equipment and installation is a function of horsepower. An IF statement is built in this cell as follows: the cost for Single Speed Turbine (SST) is

$$58,000 * (\text{HP}/100)^{0.65}$$

The valid horsepower range for SST **is 3 HP** to 300 HP.

Variable Speed Turbine (VST) is

$$85,000 * (HP/100)^{0.65}$$

The valid horsepower range for VST is 3 HP to 500 HP.

Centrifugal Single Speed (CSS) equals

$$35,000 * (HP/100)^{0.65}$$

The valid horsepower range for CSS is 3 HP to 350 HP.

The horsepower (HP) is determined by using equation (10) in page 516 (Peters and Timmerhaus,1980) as:

$$W = \Delta Z + \Delta(V^2 / 2 g_c) + \Delta(pv)$$

Where:

W	= theoretical mechanical energy, hp
Z	= vertical distance above datum plane, m
V	= linear velocity of fluid, m/sec
g _c	= gravitational acceleration, 9.81 m/s ²
P	= absolute pressure, kPa
v	= specific volume of the fluid, m ³ /kg

Degasifiers: The equation used to estimate this cost is

$$1.5006 * X + 3765.7$$

where X is product capacity in m³/day.

Product degasifiers are used when hydrogen sulfide exists in raw water and large amounts of carbon dioxide are liberated when the raw water pH is lowered.

Odor control: If odor control is specified yes (y) in the RO&NF input worksheet. The cost is estimated by

$$320.9 * X^{0.6}$$

where X is product capacity in m³/day. Otherwise, it is zero

Process piping: The size is a function of plant capacity and recovery rate. The cost is

$$15.852 * X/Y$$

Where X is product capacity in m³/day and Y is recovery rate in percent

Chemical feed with pumps (acid, antiscalant, chlorine): Pump size is a function of dose rates and flow rate of feed water and product water. An IF statement is built into the cost of the acid system. It stated that

$$AC * 1000 * (X/Y) * 30 * SC / (1000^2 * \rho) + 30,000 * NS$$

if acid concentration is greater than zero, the formula to calculate the cost is where

- AC = acid concentration, mL/L
- SC = storage cost
- NS = number of skids
- X = product capacity, m³/day
- Y = recovery rate, %
- ρ = density, g/mL

If concentration is less than zero, then cost is zero.

Cost formula for antiscalant and chlorine is

$$(AS \text{ or } CCC) * 1000 * (X/Y) * 30 SC / (1000^2 * \rho) + 20,000 * NS$$

where

- AS = antiscalant concentration, mg/L
- CCC = chlorine concentration, mg/L
- SC = storage cost
- NS = number of skids
- X = product capacity, m³/day
- Y = recovery rate, %
- ρ = density, g/mL

Cartridge filters: cartridge filters are a function of feed water flow rate. The cost is estimated by

$$112,836 * CS^{0.8031} * NS * 1.2$$

where CS is capacity per skid, m³/s. NS is number of skids.

Membrane cleaning equipment: Use \$67,000 as an installed system price. This system is based upon cleaning 14 tubes at one time at a flow rate of 50 gpm per tube.

Concentrate treatment & piping: The cost is where COC is concentrate cost (\$/m³), X is product capacity (m³/day), and Y is recovery rate (%).

$$COC * X * (1 - Y) / Y$$

Generators: The cost is estimated at

$$150,000 * (kwRO / 1000)^{0.85} + 50,000$$

Where kwRO is the RO & Building electricity usage estimated as

$$14 * (x/Y) / 3785$$

X is product capacity (m³/day). Y is recovery rate (%).

Sitework: The cost is

where TC is the feed flow in m³/day. SWC is sitework cost in \$/m³.

$$TC * SWC$$

Indirect capital cost:

The indirect capital costs are the sum of:

- Interest during construction (4% of total construction cost)
- Contingencies (6% of total construction cost)
- A&E fees and project management (12% of total construction cost)
- Working capital (4% of total construction cost).

Operation and maintenance cost estimation:

Operation and maintenance costs include:

- Electricity
- Labor
- Chemicals (acid, caustic, antiscalant, and chlorine)
- Membrane replacement
- Cleaning chemicals
- Cartridge filters
- Repairs and replacement

- Insurance
- Lab fees

Total annual cost equals to capital recovery cost plus the total operation and maintenance costs. These major O&M cost elements are discussed below:

Electricity: Electricity is the largest operating cost. It is estimated by:

kwRO is the RO & Building electricity usage. X is product capacity (m³/day). Y is recovery rate (%)

$$(kwRo + kwHPP + (kwRWT + kwPWP)) * PA * 365 * 24 * Z$$

kwHPP equals: $746 * NS * PS / 1000$

kwHPP is the high pressure. pump electricity usage. NS is number of skids. PS is the pump size (hp). kwRWT and kwPWP equal

$$746 * NP * PS / 1000$$

kwRWT is raw water transfer pump electricity usage. kwPWP is product water pump electricity usage. NP is number of pumps. PS is pump size (hp).

Labor: This cost is estimated by

$$SD * LR * 8 * 365$$

where SD is staff days. LR is labor rate.

Chemicals: IF statements are built in for both acid and caustic. If acid concentration is less than zero, then cost is zero. Otherwise, acid cost equals

$$AC * (X/Y) * 365 * PA * ACC * \rho_{acid} / 1000$$

Where:

AC	=	acid concentration, mL/L
X	=	product capacity, m ³ /day
Y	=	recovery rate, %
PA	=	% availability
ACC	=	acid cost, \$/kg
ρ_{acid}	=	density of acid, g/ml

If caustic concentration is less than 1, then cost is zero. Otherwise, caustic cost equals

$$CC * TC * 1000 * 365 * PA * CAC / (\rho * 1000^2)$$

Where: CC = caustic concentration, mL/L
 TC = total capacity, m³/day
 PA = % availability
 CAC = caustic cost, \$/kg
 ρ_{base} = density, g/mL

Antiscalant cost is

$$AS * TC * 1000 * 365 * PA * ASC / (\rho * 1000^2)$$

Where: AS = antiscalant concentration, mg/L
 TC = total capacity, m³/day
 PA = plant % availability
 ASC = antiscalant cost, \$/kg
 ρ_{As} = density, g/mL

Chlorine cost equals

$$CCC * TC * 1000 * PA * 365 * CLC / (\rho_{Cl_2} * 1000^2)$$

Where: CCC = chlorine concentration, mg/L
 TC = total capacity, m³/day
 PA = % availability
 CLC = chlorine cost, \$/kg
 ρ_{Cl₂} = density, g/mL

Membrane replacement: The cost is estimated by

$$(Number\ of\ elements * \$/element) / membrane\ life$$

Cleaning chemicals: Cleaning chemicals are H₂PO₄ and NaOH. H₂PO₄ solution concentration is 0.05%

$$F * NM * (D^2 * \pi * 102/4) * 1.15 * (0.005 * PHC + 0.001 * SDC * 2) / 1000$$

NaOH solution concentration is 0.1%. The cost equals

Where: F = cleaning frequency
 NM = number of modules
 D = membrane diameter, cm
 PHC = H₂PO₄ cost, \$/kg

SDC = NaOH cost, \$/kg
 π = 3.14
 1.15 = correction factor for pipe tilling

Cartridge filters: The cost is estimated by

$$23097 * CPS \cdot 6.245 * NS * I2$$

Where: CPS = capacity per skid, m³/sec
 NS = number of skids

Repairs and replacements, insurance: The cost for repairs and replacements assumed to be 0.5% of the total capital cost and 0.2% of the total capital cost for insurance.

Lab fee: The cost equals

$$\$800 * 12 * NS$$

where \$800 is the cost for one water analysis sample test and 12 samples per year. NS is number of skids.

The install cost in (\$/m³ per day and \$/gallon per day) and total annual cost in (\$ per m³, \$ per acre-foot, \$ per 1000 gallons) of product water also can be found in the RO&NF Output worksheet.

$$TCC * i * (1+i)^n / ((1+i)^n - 1)$$

Capital recovery: Capital recovery cost equals

Where: TCC = total construction cost
 i = interest rate
 n = number of years

ION EXCHANGE (ION-EXH)

Introduction:

Ion exchange resins are insoluble granular materials which have free cationic, or anionic radicals in their structure. These ions can be exchanged for ions of the same sign in the solution. Ion exchange is used for de-mineralization.

Design:

The purpose of this worksheet is to provide a cost estimation for an ion exchange unit based on available design parameters. Data required from the Capacity worksheet includes:

- Desired flow rate L/sec
- Equivalents/L of Cation > +1 in water Equiv/L
- Equivalents/L of Anion > -1 in water Equiv/L

Parameters with default values can be modified on the ion exchange worksheet. They are shown in the table 4. Table 5 lists suggested ranges for resin parameters.

Table 4: Default values for ion exchange operational parameters.

Parameter	Value	Unit
Desired run cycle	7	Days
Resin expansion coefficient	200	%
Cost factor for pressure	1	
Aspect ratio	2	Height/diameter
Cost of NaCl	\$0.02	/kg

Table 5: Default values for resin parameters.

Parameter	Value	Unit
Required service flow rate	Range 16-40	L/(hr*L resin)
Cation equivalents/L of Resin	1.9	Equiv/L
Anion equivalents of Resin	1.4	Equiv/L
Resin price	\$6700	/m ³
Volume NaCl/volume resin for regeneration	483	kg/m ³
Regeneration fluid concentration	10	%

Resin Medium:

The minimum resin volume(m^3) is calculated by:

$$\text{Min resin Volume}(m^3) = \frac{\text{Desired flow rate}(L/s)}{\text{Service flow rate}(L/hr * L \text{ resin})}$$

Time until resin exhaustion (days) is calculated by:

$$\text{Time until Resin exhaustion}(days) = \frac{MRV * (EQC + EQA)}{FR * (ECR + EAR)}$$

Where:

MRV	=	minimum resin volume, m^3
EQC	=	Equivalents/L of Cation > +1 in water, Equiv/L
EQA	=	Equivalents/L of Anion > -1 in water, Equiv/L
ERC	=	Cation Equivalents/L of Resin, Equiv/L
EAR	=	Anion Equivalents/L of Resin, Equiv/L
FR	=	Desired flow rate (L/s)

An **IF** statement is built in for the resin volume required to meet exhaustion time. It states that if time until resin exhaustion is greater than the desired run cycle, then the resin volume required to meet exhaustion time is equal to the minimum resin volume. Otherwise, the resin volume required to meet exhaustion time is calculated by:

$$RVET = \frac{RC * FR * (EQC + EQA)}{(ECR + EAR)}$$

Where:

RVET	=	resin volume required to meet exhaustion time, days
RC	=	desired run cycle, days

Resin manufacturers recommend an expansion coefficient of two to provide ample room for the resin to expand during upflow regeneration.

Total Vessel Volume (TVV) is calculated by:

$$TW = RVET * \text{Resin expansion coefficient}$$

Resin Cost (RC) is calculated by:

$$RC = MRV * RP$$

Where:

RP	=	nominal resin price, $\$/m^3$
----	---	-------------------------------

Vessel Cost:

The fiber glass pressure vessel cost is calculated by the following formula:

$$\text{Log}(\$) = 3.44609 + 0.561757 * \text{Log}(TVV)$$

Regeneration:

NaCl is used for the resin regeneration. Amount of NaCl required is calculated by the following equation:

$$NaCl_{required} = \rho_{NaCl} * RVET$$

Where: ρ_{NaCl} = density of NaCl, kg/m³

The total chemical cost per year is calculated by:

$$NaCl_{required} * NaCl_{cost} * \frac{365}{DRC + 1}$$

Where: $NaCl_{cost}$ = sodium chloride cost, \$/kg
DRC = desired run cycle, days
365 = days per year

Storage tank cost is calculated by:

$$Tank\ Cost = 0.1427 X^3 + 5.6691 X^2 + 257.56X + 467.45$$

where X is the tank volume in m³. This formula is developed from the Snyder cone bottom tank, HDLPE model tank prices.

Regeneration and Backwashing Pump:

Construction cost and O&M cost formulas for regeneration and backwashing pump are developed from the 1979 EPA report (EPA-600/2-79-162b).

Construction cost(CC):

$$CC = 36000 + 1254.21X - 0.1212 X^2$$

Operating and Maintenance cost (O&M):

$$O + M = 73.3 * X^{0.75} + 2200$$

Where X is the filter area in m²

Output:

Total construction costs include resin cost, resin operating tank cost, storage tank cost, and regeneration and backwashing pump cost. This total construction cost and Operating cost are output to the Report worksheet.

ELECTRODIALYSIS (ED2)

Design::

The design model for electrodialysis is from a paper presented by Thomas D. Wolfe of HPD Inc. at the American Water Works Association meeting in August, 1993. It is a simplified version of the complex calculations required to design an ED system but, according to Mr. Wolfe, it is adequate for one pass desalination of brackish water. If the desalination ratio (input TDS/output TDS) is less than 3.6, the model

$$\frac{Kwh}{m^3} = \frac{\Delta N * 26.8 * V_c * 1kW}{Curr\ eff * 1000W}$$

gives a good estimate of power and membrane requirements as follows:

$$\Delta N = \frac{Feed\ TDS\ (g/m^3) - Dilute\ TDS\ (g/m^3)}{Ave.\ EqWt.\ (g/eq)}$$

$$Current\ Eff = \left[\sum C^+ Eff + \sum A^- Eff \right] \cdot \frac{.006 * \Delta N * 26.8}{100 * CD}$$

Where: 26.8 Amp*hrs/eq is Faraday's constant.

C^+ and A^- represent each cation and anion species.

0.006 (eq/(cm²*hr*eq/m³)) is the Salt Diffusion Coefficient.

$$Total\ Resistance,\ R_t = R_d + R_c + R_m$$

Where: R_d is the dilute side resistance,
 R_c is the concentrate side resistance,
 R_m is the membrane resistance,

$$V_c = R_t * CD + V_m$$

V_c is the electric potential per cell pair,

V_m is the membrane electric potential,

CD is current density.

Power requirement is given by:

$$KWatts = \frac{m^3 \text{ treated}}{hr} * \frac{kwh}{m^3}$$

Membrane area requirements:

$$Area (m^2) = \frac{watts}{Amps \text{ per } m^2 * Volts}$$

The number of pairs required:

$$No. \text{ of Pairs} = \frac{Area (m^2)}{Area (m^2)/pair}$$

Input:

There are several input requirements for this model which are taken from the Capacity and Cost Index worksheets:

- Feed and product TDS: mg/L
- Average equivalent weight: g/eq
- Flow rate: m³/day
- Percent recovery: %
- Cost of electricity: \$/kWh

The following table includes variables that are entered on the **electrodialysis** worksheet. The current values are approximations. More exact information can be obtained from the membrane manufacturer for the membrane in question.

Table 6: Default parameters for Electrodialysis cost estimates.

Variable	Value	Unit
Cost of Membrane	\$100	m ²
Cation and Anion transport efficiencies	0.874	
Area per membrane pair	0.862	m ² /pair
Resistances (Rt)	2.5	Ohms/cm'
Current density	38	Amp/dm ²
Membrane electric potential per pair	0.25	Volt/pair
Electra-osmotic coefficient	0.003	ml/ma*hr

Cost Computation:



Capital cost is determined by multiplying the membrane cost by the construction factor. The construction factor used here is 1.65. This value was arrived at by adjusting the membrane operation variables till the electrical and membrane requirements matched those listed in a published cost estimate (Pittner, 1993) and then multiplying by an appropriate construction factor so that the costs matched also.

Operation and maintenance costs are the sum of chemical addition, maintenance, membrane replacement, labor, electricity and capital recovery costs. Chemical addition costs are dependent on the TDS of the feed water and are indexed to the "Maintenance Material Index." General maintenance is 5% of the capital cost and is also indexed to Maintenance Material. Membrane replacement is the amortized cost of replacing the membranes in 15 years at the given interest rate. Labor cost is simply \$/year at the given labor wage rate. Electricity requirements are calculated above. Capital recovery is the amortized cost of the capital over the life of the plant at the given interest rate.

DISINFECTION WITH CHLORINE AND CHLORAMINE (CL₂ AND NHCL)

Design:

Cost estimation for chlorine and/or chloramine disinfection is based on the amount of chemicals used per day. Chlorine demand is determined from the concentration of nitrite and reduced inorganic transition metals, such as chromium, copper, iron, and manganese, present in the water. These metals are oxidized from +2 charge to +3 by the hypochlorite ion by the following reaction (Snoeyink & Jenkins, 1980, pp. 391-395):





Hypochlorite reacts with nitrite to form nitrate:



Therefore, one mole of aqueous chlorine is needed for each two moles of **divalent** transition metal, and one mole for each mole of nitrite, before the required chlorine residual will accumulate.

For disinfection with chloramine, ammonia is reacted with free chlorine in the water to form mono- and di-chloramine:



The ratio of ammonia to hypochlorite used for maintenance of a combined chlorine residual is 1:1

Input:

$$[Cl_{2(g)}] = \frac{[Cr^{2+}] + [Cu^{2+}] + [Fe^{2+}] + [Mn^{2+}]}{2} + [NO_2^-]$$

The concentration of chromium, copper, iron, manganese, and nitrite is taken from the H2O Analysis worksheet. Chlorine demand is given by:

Chlorine residual and chloramine residual are input from the Report worksheet. The volume of water treated is input from the Capacity worksheet. The kilograms of chlorine needed per day is then:

$$\left(\frac{\text{mg Cl}_{2d}}{L} + \frac{\text{mg Cl}_{2r}/L * 71 \text{ mg Cl}_2/L}{85 \text{ mg HClO}^-/L} \right) * \frac{L}{\text{sec}} * \frac{86400 \text{ sec}}{\text{day}} * \frac{\text{kg}}{10^6 \text{ mg}}$$

where Cl_{2d} is the chlorine demand and Cl_{2r} is the free chlorine residual.

If chloramine disinfection is used, chlorine demand is determined as for chlorine disinfection, then ammonia and chlorine are added in a one to one molar ratio to produce the required residual.

$$\frac{\text{mg NH}_3}{L} = \frac{\text{mg NH}_2\text{Cl}/L}{51.4 \text{ mg NH}_2\text{Cl}/\text{mmole}} * \frac{17 \text{ mg NH}_3}{\text{mmole NH}_2\text{Cl}}$$

$$\frac{\text{mg Cl}_{2(aq)}}{L} = \frac{\text{mg Cl}_{2d}}{L} + \frac{\text{mg NH}_2\text{Cl}/L}{51.4 \text{ mg NH}_2\text{Cl}/\text{mmole}} * \frac{71 \text{ mg Cl}_{2(aq)}}{\text{mmole NH}_2\text{Cl}}$$

Cost Computation:

Capital cost, and operation and maintenance costs are calculated from the formulas for chlorine storage and feed with cylinder storage in Qasim et al. (1992).

$$CC = 680.75 * X^{0.763} + 11010$$

$$O + MC = 47.6 * X^{0.89} + 6000$$

Where X = kg Cl_2 per day.

Cost formulas for ammonia addition are based on anhydrous ammonia feed:

$$CC = 3849.2 * X^{0.448} * e^{-3.5E-5 * X}$$

$$O + MC = 28063 * e^{(-2.41E-4 * X)} + 36160$$

Where X = kg NH₃, per day (Qasim, et al, 1992).

Output:

The worksheet for chlorine disinfection returns the capital, and O&M cost for chlorine addition sufficient to supply the chlorine demand, and provide the indicated chlorine residual. The chloramine disinfection worksheet returns capital cost and O&M cost for addition of both chlorine and ammonia, sufficient to produce the combined chlorine residual specified. This cost estimate may be high if there are overlapping costs associated with the combination of chlorine addition and ammonia addition formulas.

Links:

- Transition metal and nitrite concentration is taken from the water analysis table on the H2O Analysis worksheet.
- Treatment requirements input from the Report worksheet.
- Costs output to Report worksheet.

Assumptions:

There are three important assumptions made in the cost modeling for chlorine and chloramine disinfection:

- The sum of the concentrations of metals and nitrite will give an adequate estimate of chlorine demand. The oxidation state of these metals is not usually given in a water analysis, so it is assumed that the whole concentration is at a +II state. This is probably not accurate, but it may balance out other chlorine demand that is not accounted for in this model.
- A 1:1 ratio of residual chlorine to ammonia will produce the necessary combined chlorine residual. According to V.L. Snoeyink and D. Jenkins (Water Chemistry, p 395, 1980, John Wiley & Sons), the ratio of residual chlorine, as Cl_2 , to initial NH_3 , oxidized is 1 at a ratio of 1:1, Cl_2 dose: NH_3 initial. The combined residual at this point is composed of NH_2Cl with a trace of NHCl_2 .
- For chloramine disinfection, Qasim's cost models for chlorine addition and ammonia addition are added together using the amounts of each needed for the required residual. This may give a high cost estimate due to overlap in cost items in the two models. It is assumed that the overlap is insignificant. Manufactured equipment is the highest component for each of the processes. Housing is second for chlorine feed and storage. The two chemicals would need their own equipment for feed and storage, so these components are not highly overlapping. The portion that may be significant is the labor cost for O&M. This cost may need modification in the future.

OZONE DISINFECTION (OZONE)

Introduction:

Ozone (O_3), an allotrope of oxygen (O_2), is one of the most powerful oxidizing agents available for water treatment. A substantial amount of energy is required to split the stable oxygen-oxygen covalent bond to form ozone. The resulting O_3 molecule is highly unstable. It was thought that ozone might be a suitable replacement for chlorine, which forms tri-halomethanes. Ozone has the potential to form the same byproducts though, as long as halides are available to react with the oxidized organic compounds. Ozone decomposes rapidly, however, which makes it a safer choice for pretreatment ahead of chlorine sensitive membrane processes.

Purpose!:

This worksheet provides an estimation of capital costs and yearly power costs for an ozone system. The capital cost estimation includes costs associated with the ozone generator and the contact chamber. Estimates are derived from equations found in Qasim et al. (1992). Electricity costs are computed using a nominal power requirement per kilogram of ozone produced, and the local cost of electricity per kWh.

Links:

Ozone dosage in mg/L, and contact time in minutes, are taken from the Report worksheet. Values of 3 mg/L, and 2 minutes, are suggested as normal levels. Flow rate is taken from the Capacity worksheet. Electrical cost is taken from the Cost Index worksheet.

Cost Computation:

Ozone generation, and contact chamber costs are calculated by the following equations for 1992 dollars, then updated with the current index values.

$$OMC_{GEN} = 392.4 * x^{0.919} + 68000$$

Where x = chlorine feed capacity in kg/day

$$CC_{CONT.CHAMB.} = 1771.4 * x^{0.5967} - 1700$$

Where x = chamber volume in m^3 .

Operation and maintenance costs for the contact chamber are included with those for ozone generation.

ACID FEED (DG&ACID AND ACID)



Acid feed may be used in reverse osmosis to lower the pH of the feed water to levels compatible with the membranes used. With cellulose acetate membranes, this is about pH 5.5. Thin film composite membranes are not as sensitive to pH as cellulose acetate, but acid feed still may be used to control scaling

Design:


The Langelier Saturation Index (LSI) is normally used to predict the carbonate scaling tendency of water. In this model the Gibbs Free Energy (AG) is used instead. The AG calculations can be used for determining other solubility equilibria whereas, LSI is only for determining carbonate solubility. LSI can be calculated from AG as follows.

$$LSI = \frac{\Delta G}{2.3 * RT}$$


Where: $R = 1.987 \times 10^{-3} \text{ kcal/mol} \cdot \text{°K}$
 $T = \text{Temperature in } \text{°K}$
 2.3 is a factor for converting from natural log to log base 10
 The reaction equations of interest in carbonate solubility are:



and



Summations of equation (1) and (2) equal:



Activity coefficients are calculated for calcium and bicarbonate ions from the ionic strength taken from the Capacity worksheet.

$$\log \gamma_i = 0.5091 * Z_i^2 * \left[\frac{\sqrt{\mu}}{1 + \sqrt{\mu}} - 0.2 * \mu \right]$$

$$\mu = 0.5 * \sum C_i * Z_i^2$$

Where: C_i = Concentration of the i^{th} ionic species,
 Z_i = charge of the i^{th} ionic species,
 μ = ionic strength,
 γ = activity coefficient of the i^{th} ionic species

Gibbs Free Energy is given by:

$$\Delta G = \Delta G^\circ + RT * \ln Q$$

Where: R = 1.987×10^{-3} kcal/mol*°K, is the universal gas constant.
 ΔG° = theoretical solubility of calcium carbonate at 298°K and,
 $RT * \ln Q$ = solubility under the pH, temperature conditions with the reported concentrations of Ca^{2+} and HCO_3^- , adjusted for ionic strength.

If AG is positive, the water is over-saturated, and will tend to deposit calcium carbonate scale.

The following charge balance equation is used to calculate the amount of acid needed to change the pH:

$$[\text{Cations}] + [\text{H}^+] = [\text{Anions}] + [\text{C}^-] + [\text{HCO}_3^-] + 2[\text{CO}_3^{2-}]$$

All terms are expressed as functions of $[\text{H}^+]$, solubility constants, ionization fractions, and concentrations adjusted with their activity coefficients. This equation is solved for the target pH.

Input:

Ca^{2+} and HCO_3^- concentrations, total cations and anions, water temperature, and current pH, are input from the water analysis table of the H2O Analysis worksheet. Ionic strength is input from the water data report section on the Capacity worksheet.

Cost Computation:

Cost computations are done with ACID worksheet. Liters/second treated is input from the Capacity worksheet, and acid feed/day from DG&ACID worksheet. Formulas for capital and O&M costs are from Qasim et al, 1992.

$$CC = 61,010.6 * X^{0.7934} + 8,8180$$

$$O + MC = -42,397.4 * e^{(-6.82E-3 * X)} + 43,670$$

Where $X = \text{m}^3$ of sulfuric acid per day.

Output::

AG is output to the water data report section in the Capacity worksheet. Capital cost, O&M cost and liters 96% H_2SO_4 per day is output to the Report worksheet.

Links:

DG&ACID worksheet is linked to ACID worksheet, H2O Analysis, water data report in the Capacity worksheet and the Report worksheet. ACID worksheet cost reports to the Report worksheet.

Assumptions:

Ionic strength is accounted for, but the only scaling tendency checked is that of calcium carbonate. The system is assumed to be at equilibrium with the atmosphere. Assumptions used in the EPA report are in effect for this estimate as well.

Improvements:


Scaling tendencies for other constituents should be calculated. The AG calculation could be modified for this purpose by entering the proper solubility constants. Some good candidates would be silica, calcium sulfate, barium sulfate, strontium sulfate, and ferric hydroxide.

ALUM OR FERRIC SULFATE FEED (ALUMFD AND IRONFD)

Alum or ferric sulfate coagulation is used for clarification. It is another process, like lime softening, that is designed to lower turbidity through precipitation of a sparingly soluble salt.

Design:

Alum or ferric sulfate react with alkalinity in the water to produce a hydroxide precipitate. Both react according to the following formula:



Commercial grade alum and ferric sulfates are available as $Al_2(SO_4)_3 \cdot 18H_2O$ (MW: 666.41), and $Fe_2(SO_4)_3 \cdot 9H_2O$ (MW: 562), respectively.

Input:

Alkalinity is taken from the water analysis section of the H2O Analysis worksheet. Volume of water treated is taken from the Capacity worksheet.

Cost Computation:

Formulas For ferric and alum sulfate feed capital and O&M costs are from Qasim et al. (1992). There are formulas for both dry, and liquid (50% by weight), alum sulfate feed. Generally, the dose of liquid alum needed is twice that for dry alum.

$$Ferric\ Sulfate : CC = 10613 * X^{0.319} * e^{(3.93E-4 * X)}$$

$$Ferric\ Sulfate : O + MC = 1,260,926 * e^{(1.394E-5 * X)} - 1,257,710$$

X = Kg per day of ferric sulfate.

$$\text{Dry Alum : CC} = 12,333.4 * X^{0.3205} * e^{(5.15E-4 * X)}$$

$$\text{Liquid Alum : CC} = 13,223.3 * X^{0.285} * e^{(3.77E-4 * X)}$$

$$\text{Dry Alum : O + MC} = 1,205,293 * e^{(1.9433E-5 * X)} + 1,202,070$$

$$\text{Liquid Alum : O + MC} = 6880.7 * e^{(-6.59E-4 * X)} + 8,700$$

X = kg per hour of Alum.

output:

Capital and operation and maintenance costs are output to the Report worksheet

Links:

The links are to the Capacity, H2O Analysis, Cost Index, and Report worksheets.

Assumptions:

Those assumptions made in the EPA report on which the cost formulas are based are made here

POLYMER FEED (POLYFD)

Polymer is added to prevent scaling in RO and NF systems. It is also used for clarification and as a coagulant or flocculant aid.

Design:

The amount of polymer needed depends on the type of polymer and the purpose for adding it. In any case, very little is needed. The precise amount is determined through jar testing. For design purposes, we will use 0.5 grams per cubic meter as suggested in the *Water Treatment Handbook* (0.05 to 0.5 g/m³, Degrémont, 1991, p144) for a combination of synthetic flocculant and coagulant for clarification of surface waters.

Input:

Volume of water treated is taken from the Capacity worksheet

Cost Computation:

Formulas for polymer feed capital and operation and maintenance costs are from Qasim et al, 1992:

$$CC = 11760.71 * X^{6.65E-3} * e^{(8200 * X)}$$
$$O + MC = 3000.8 * e^{(2.07E-3 * X)}$$

Where X equals Kg polymer per day.

output:

Capital and operation and maintenance costs are output to the Report worksheet

Links:

The links are to the Capacity, H2O Analysis, Cost Index, and Report worksheets.


Assumptions:

The only assumption, other than those made in the EPA report on which the cost formulas are based, is that 0.5 mg per liter is a representative dosage of polymer.

POTASSIUM PERMANGANATE (KMNO₄)

Potassium permanganate is an oxidizing agent. It is used for iron, manganese removal

A combination of KMnO₄ oxidation and manganese-greensand filtration was selected for testing. Manganese-greensand provides effective filtration and also controls under and over dosing of KMnO₄ (prevents the development of pink water breakthrough). Manganese (II) removal depends on the precipitation of MnO₂(s)(manganese[IV] [manganic dioxide], as follows:



Manganic dioxide is insoluble over the entire pH range of interest in drinking water treatment. Also, the oxidation of both Mn⁺² and Fe⁺²(ferrous iron) using KMnO₄ is reported to be quite rapid at pH 7 and higher (Glase, 1990).

The stoichiometry for manganese and iron oxidized with permanganate is:

$$\begin{aligned} &1.92 \text{ mg/L KMnO}_4 \text{ per mg/L of Mn}^{+2} \text{ removed} \\ &0.94 \text{ mg/L KMnO}_4 \text{ per mg/L of Fe}^{+2} \text{ removed} \end{aligned}$$

Input:

Volume of water treated is taken from the Capacity worksheet.

Cost Computation:

$$CC = 9681.7 X^{0.0304} e^{0.00122X}$$

Formulas for potassium permanganate feed capital and operation and maintenance costs are from Qasim et al, 1992:

$$O+ MC = -2125.9 e^{-0.01689X} + 5600$$

Where X equals dry potassium permanganate feed in kg/day.

output:

Capital and operation and maintenance costs are output to the Report worksheet.


Links:

The links are to the Capacity, H2O Analysis, Cost Index, and Report worksheets


LIME & SODA ASH FEED (LIMEFD)

Design:

Lime and soda ash are added to precipitate excess carbonate, and in the process, removes metals and constituents that cause turbidity. Lime, Ca(OH)_2 , and soda ash, Na_2CO_3 , react with carbonate hardness to precipitate calcium carbonate and magnesium hydroxide.



The sum of these two reactions is:




This reaction is used when all components are available. The Mg^{2+} and Ca^{2+} are reacted with alkalinity and lime to form CaCO_3 and Mg(OH)_2 .

The limiting reagent is determined by the mole ratio of each component. Then the amount of lime required for the initial reaction is calculated. The remaining Mg^{2+} or Ca^{2+} is reacted with remaining alkalinity. If carbonate alkalinity is zero, no more lime is needed. If Mg^{2+} is zero, formula (1) is used to calculate amount of lime to complete softening. Reaction (1) requires one mole of Ca(OH)_2 per mole of Ca^{2+} .

If Mg^{2+} is not zero, the Ca^{2+} is zero, formula (2) is used to calculate amount of lime needed to complete softening. Reaction (2) requires 2 moles of Ca(OH)_2 per mole of Mg^{2+} .

If $\text{HCO}_3 + \text{CO}_2$ were the limiting reagent, which means that Ca^{2+} and Mg^{2+} are in excess of alkalinity. The soda ash is used to precipitate Ca^{2+} and Mg^{2+} . The following reactions demonstrate the relationship between soda ash and Ca^{2+} and Mg^{2+} :



Input:

Calcium, magnesium, carbon dioxide and alkalinity content of the water are taken from the water analysis in the H2O Analysis worksheet. If the percent reduction column is blank or zero for **these** values, the cost estimate will consider the total hardness, resulting in high cost estimates. Volume of water treated is taken from the Capacity worksheet.

Cost Computation:

Formulas for lime & soda ash feed capital, and operation and maintenance costs are developed from the 1979 EPA report (R.C. Gumerman, 1979)

$$CC = -24,950.92 + 20,424.67 * \ln(x)$$
$$O+MC = 866.29 * x^{0.51435}$$

Where X equals Kg Lime per day

output:

Capital and operation and maintenance costs are output to the Report worksheet

Links:

The links are to the Capacity, H2O Analysis, Cost Index, and Report worksheets. Water analysis data is taken from the H2O Analysis worksheet and cost data is returned to the Report worksheet.

Assumptions:

It is **assumed** that calcium and magnesium react with bicarbonate ion and calcium hydroxide at the same rate. If calcium was preferentially precipitated with bicarbonate before the magnesium, more soda ash would be needed to precipitate the magnesium. This would mean higher capital and O&M cost.

Improvements:

Since lime and soda ash softening is not the technology of choice, cost estimates for this process are primarily for comparison. Lime softening is not a precision process. As **long** as lime is added in excess, the process works. Therefore, refinement of the cost estimate would have to come from new price information, rather than improvements to the design of the cost model.

The cost estimate provided for lime feed is only for the lime feed system; it does not cover the cost a clarifier, or sludge processing or disposal.

GRANULAR ACTIVATED CARBON (GAC)

Introduction:

Granular activated carbon (GAC) is used to remove color, odor, organic chemicals, disinfection by-products, and chlorine from water through the process of adsorption. If the water has not been pre-filtered, the carbon bed may also serve as a granular filter, in which case, backwashing is a more significant design criteria.

Cost Estimate:

This worksheet provides estimates of the capital and operating costs of a granular activated carbon (GAC) bed. Both are based entirely on flow rate and bed life. Costs are estimated using relationships derived from cost data in the 1979 EPA report. It is apparent from this data that there is a change in size versus cost relationship at 4000 m³/day. Capital costs for GAC are fairly constant with respect to capacity until a production level of 4000 m³/day. Above this level, there are different cost curves for a bed life of 3, 6, and 12 months. Regeneration costs are not included. The cost parameter used in these equations is m³/day. The composition of the water is not considered.

Cost equations are as follows.

3, 6, or 12 month bed life, capacity ≤ 4000 m³/day.

$$CC = 9875 * x^{(1-.4596)}$$

12 month! bed life:

$$OM_{\leq 4000} = 2631.18 * x^{(1-.4706)}$$

$$CC_{>4000} = 1948.8 * x^{(1-.2569)} \quad OM_{>4000} = 225.42 * x^{(1-.1692)}$$

6 month bed life:

$$OM_{\leq 4000} = 2089.46 * x^{(1-.4187)}$$

$$CC_{>4000} = 150 * x \quad OM_{>4000} = 235.91 * x^{(1-.15)}$$

3 month bed life:

$$OM_{\leq 4000} = 1563.45 * x^{(1-.3463)}$$
$$CC_{>4000} = 200 * x \quad OM_{>4000} = 515.91 * x^{(1-.203)}$$

GRAVITY FILTRATION (SLOWSAND)

Introduction:

Granular filtration removes particulate matter such as algae, colloidal humic compounds, viruses, asbestos fibers, and colloidal clay from water. Matter accumulates on the surface, or is collected throughout the depth of the bed. The purpose of this worksheet is sizing and cost estimation of granular filtration systems.

Design:

There are two components: the backwashing system and the gravity filter structure with sand as the media. Costs for both are based on the area of the filter bed. Required input for area determination are:

- . Flow rate (Wsec)
- . Total suspended solids (mg/L)
- . Backwash cycle (24 hrs/cycle)
- . Density of suspended solids (35 g/L)
- . Maximum media capacity (110 L TSS/m³ media)
- . Media depth (1 m)

Flow rate is input on the Capacity worksheet. Total suspended solids is input on the H2O Analysis worksheet. The other parameters are input on the gravity filtration worksheet. Default values are listed above.

Cost Estimation:

Costs estimates are derived from equations in Qasim et al. (1992):

$$CC_{BW} = 36,000 + 1254.21 * x - 0.1212 * x^2$$

$$CC_{GF} = 35,483.47 * x^{0.591} * e^{(13.62 * 10^{-4} * x)}$$

$$OM_{BW} = 73.3 * x^{0.75} + 2,200$$

$$OM_{GF} = 359.5 * x^{0.8568} + 8,100$$

Where x is the area of the filter bed in meters.

Improvements:

Future developments may include modifications of the generalized cost estimation equations to accommodate using different media.

UPFLOW SOLIDS CONTACT CLARIFIER (UFSCC)

Introduction:

Upflow solids contact clarifiers can be used with lime softening, and alum, or ferric sulfate precipitation. The chemical slurry is fed into the reaction zone in the center of the clarifier. Feed water flows up through the precipitate at the bottom. Contact with the solids speeds precipitation so that a shorter detention time is needed. As the water flows away from the center of the reactor, the solids settle out. Water is collected at the sides from the surface. Sludge is pumped out periodically from the bottom.

Design:

The size of the clarifier is determined from the flow rate and the detention time. Flow rate is taken from the Capacity worksheet, and detention time from the Report worksheet. The height of the tank is assumed to be 4.8 meters. Operation and maintenance cost have three options based on the "rapid mix G value." The "rapid mix G value", or mean velocity gradient is used to determine the size of the flocs produced as a function of the viscosity of the fluid at a certain temperature, and the rate of power dissipated into the tank volume. These terms are used to calculate G.

$$G = \sqrt{\frac{P}{\mu V}}$$

where: G= mean velocity gradient, 1/s
P = power requirement, Watt
 μ = dynamic viscosity, N.s/m².
V= tank volume, m³

Costs for G values of 70, 110, and 150 are computed. Number of clarifiers can be specified in the Report worksheet.

Cost Computation:

Cost curves were derived from data in EPA-600/2-79-162b. These are updated with current index values.

PUMPS (PUMPS)

Introduction:

There are different types of pumps commonly employed in industrial operations. The ones examined in this worksheet are Single Speed Turbine (SST), Variable Speed Turbine (VST), and Centrifugal Single Speed pumps.

Design::

For each type of pump, the horsepower (HP) required by the pump to deliver the volume the water has to be determined. The horsepower is determined by using equation (10) in page 5 16 (Peters and Timmerhaus,1980) as:

$$W = \Delta Z + \Delta(V^2 / 2 g_c) + \Delta(pv)$$

Where:

W	= theoretical mechanical energy, hp
Z	= vertical distance above datum plane, m
V	= linear velocity of fluid, m/sec
g_c	= gravitational acceleration, 9.81 m/s ²
P	= absolute pressure, kPa
v	= specific volume of the fluid, m ³ /kg

Direct Costs:

The cost of these pumps are determined as follows,

Speed Turbine (SST):

$$58,000 * (HP/100)^{0.65}$$

The valid horsepower range for SST is 3 HP to 300 HP.

Variable Speed Turbine (VST):

$$85,000 * (HP/100)^{0.65}$$

The valid horsepower range for VST is 3 HP to 500 HP

Centrifugal Single Speed (CSS):

$$35,000 * (HP/100)^{0.65}$$

The valid horsepower range for CSS is 3 HP to 350 HP.

Operating Cost:

The operating costs **are** power consumption, lubrication, cooling water, and maintenance for the pump. The cost information **are** based on the Pump Handbook (page 9-66) edited by Karassik, Krutzsch, Fraser, and Messina. Lubricating oil consumption is based on 0.02 gal/100 hp-hr for each pair of bearings. A motor driven centrifugal pump results in 0.04 gal/100 hp-hr total. Cooling water requirements are based on 10 °F temperature rise and 2 percent energy loss to the water for each pair of bearings.

The annual operating costs associated with each pump arrangement **are** developed from the following:

Lubricating oil 0.7×0.04 (bhp per 100) $\times 8760$

Cooling water - $(0.075 \text{ per } 1,000)$ (bhp per 100) $\times 60 \times 8760$

Maintenance = $1.5 \times \text{bhp}$

Where bhp is brake horsepower.

output:

The direct costs and operating costs for the pumps **are** output to the Report worksheet.

CLEARWELL STORAGE (CLEARWELL)

Introduction:

Product water is commonly stored at the plant site with clearwells. Clearwell storage can be constructed by either below ground in reinforced concrete structures, or above ground in steel tanks. Instrumentation and control of the clearwell water level is very important to pace the plant output.

Input:

The below ground and above ground level clearwell storage capacities are input on the clearwell storage section of the Report worksheet.

Cost Computation:

Construction cost formulas for clearwell storage below ground and above ground costs are developed from the 1979 EPA report (EPA-600/2-79-162b, page 453-454).

Below ground:

$$CC = -0.0002X^2 + 99.004X + 37941$$

(for capacity less than or equal to 3785 m³)

$$CC = 49.084X + 224887$$

(for capacity greater than 3785 m³)

Ground level:

$$CC = -0.054X^2 + 104.88X + 21400$$

(for capacity less than or equal to 333 m³)

$$CC = 0.054 X^2 + 104.88X + 21400$$

(for capacity greater than 333 m³)

$$CC = 0.0002 X^2 + 39.556X + 58237$$

Where X is the clearwell capacity in m³

Output:

Construction costs for below ground and above ground level clearwell storage are output to the Report worksheet.

WATER ANALYSIS

This worksheet contains several different water analyses from locations around the country. These are listed as desert well, brackish, desert surface, seawater intrusion, agricultural influence, seawater, alkaline and range land. Feel free to use one of these that seems to fit your application if you do not have an actual water analysis. Just copy the water analysis of interest and choose "Paste Special" from the edit menu on the H2O Analysis sheet with your cursor at the top of the water analysis column and choose "paste as text".

BIBLIOGRAPHY

- Chapman-Wilbert, M. 1993. *The Desalination and Water Treatment Membrane Manual*. US Bureau of Reclamation Report R-93-I 5.
- Degrémont. 1991. *Water Treatment Handbook*. ©Degrémont, 1991
- Engineering News Record. 3/28/94, p 40 & 49.
- Gumerman, R.C., R.L. Culp, & S.P. Hansen. 1979. *Estimating Water Treatment Costs, Vol. 2, Cost Curves Applicable to 200 mgd Treatment Plants*. EPA-600/2-79-1626, August 1979.
- Peters, M.S. & K.D. Timmerhaus. 1980. *Plant Design and Economics for Chemical Engineers*. McGraw-Hill Book company
- Pittner, G.A. 1993. The Economics of Desalination Processes. Chapter in *Membrane Technology, Water Chemistry, and Industrial Applications*. Zahid Amjad ed. Van Nostrand Reinhold, NY.
- Qasim, S.R., S.W. Lim, E.M. Motley & K.G. Heung. 1992. Estimating Costs for Treatment Plant Construction. *J. AWWA*, pp 57-62, Aug. 1992
- Rao, G. and K.K. Sirkar. "Explicit flux expressions in tubular reverse osmosis desalination." *Desalination*, vol. 27, no. 99 (1978)
- Ray, R. 1992. RO Cost Estimates. in *Membrane Handbook*. Ho and Sirkar, eds.
- Schock, G and A. Miquel "Mass transfer and pressure loss in spiral wound modules." *Desalination*, 64(1987) 339-352.
- Snoeyink, V.L. & D. Jenkins. 1980. *Water Chemistry*. © 1980 John Wiley & Sons.
- Wolfe, T.D., 1993. Electrodialysis Design Approaches. *AWWA Proceedings; 1993 Membrane Technology Conference. August 1-4, 1993, Baltimore, Md.* AWWA 1993.
- Shields, C. Peter, DuPontpermassep Products, and Moch, Irving Jr., Moch & Associates, Evaluation of Global Seawater Reverse Osmosis Capital and Operating Costs, Technical Paper presented at the American Desalting Association Conference, Monterey, CA, August, 1996.
- Suratt, William B., Camp Dresser & McKee, Inc., Estimating the Cost of Membrane (RO or NF) Water Treatment Plants, Technical paper presented at the 1995 AWWA membrane Technology Conference, Reno, NV, August 13, 1995.
- Max S. Peters and Klaus D. Timmerhaus, 1980. Plant Design and Economics for Chemical Engineers. Copyright 1980 by McGraw-Hill, Inc.
- Glase, William H. "Chemical Oxidation," Chapter 12 in Water Quality and Treatment A Handbook of Community Water Supplies, 4th edition, American Water Works Association, McGraw Hill Inc., New York, NY, 1990.
- Pump Handbook, edited by Igor J. Karassik, William C. Krutzsch, Warren H. Fraser, and Joseph P. Messina, McGraw-hill, Inc., 1976

APPENDIX

APPENDIX

INPUT

General input and water data report	A1
Water Analysis: Inorganic	A2

COST INDICES

Current index values	A3
----------------------------	----

COST REPORT

Water treatment processes cost report	A4.1 -A4.3
---	------------

MF INPUT

Process, and O&M cost input	A5
Construction costs input	A6

RO&NF INPUT

Process, construction cost, and O&M cost input	A7
--	----

REJECTION

Notes	A8
-------------	----

RO&NF OUTPUT

Output for Reverse Osmosis on Nanofiltration cost	A9
---	----

DG&ACID

Acid dosage calculations	A10
Notes and balance equation and Ionic strength calculation	A11

ACID

Cost calculations	A12
Construction cost for sulfuric acid feed.....	A13
O&M cost for sulfuric acid feed	A14

CL2

Chlorine dosage and cost calculations	A15
Construction and O&M Cost for chlorine disinfection at different dosage rates	A16

NHCL	
Sizing, costs and notes	A17
Construction and O&M cost for chloramine disinfection at different dosage rates	A18
OZONE	
Input and costs and ozone generator cost calculations	A19
Construction cost for Ozone generation at different dosage rates	A20
O&M cost for Ozone generation at different dosage rates.....	A21
ALUMFD	
Sizing and costs	A22
Construction cost for dry alum and liquid alum feed at different dosage rates	A23
O&M cost for dry alum and liquid alum feed at different dosage rates	A24
IRONFD	
Sizing and Costs	A25
Construction cost for ferric sulfate feed at different dosage rates	A26
O&M cost for ferric sulfate feed at different dosage rates	A27
POLYFD	
Sizing and costs	A28
Construction cost for polymer feed at different dosage rates	A29
O&M cost for polymer feed at different dosage rates	A30
KMnO₄	
Sizing and costs	A31
Construction cost for potassium permanganate at different dosage rates	A32
O&M cost for potassium permanganate at different dosage rates	A33
LIMEFD	
Sizing and costs	A34
Notes.....	A35
Construction cost for lime softening at different dosage rates..	A36
O&M cost for lime softening at different dosage rates	A37

UFSCC	
Sizing and Costs	A38
Construction cost for upflow solids contact clarifier with different detention time	A39
O&M cost for upflow solids contact clarifier with different detention time (G=150)	A40
GAC	
Sizing and Costs	A41
Construction cost for carbon filtration	A42
O&M cost for carbon filtration	A43
GRAVFILT	
Sizing and cost report	A44
Cost calculations for backwashing and gravity filter structure	A45
Construction cost for gravity filtration at different suspended solids dosage rates	A46
O&M cost for gravity filtration at different suspended solids dosage rates	A47
ION_EXH	
Design and regeneration system	A48
Construction cost for Ion Exchange at different dosage rates	A49
O&M cost for Ion Exchange at different dosage rates	A50
ED2	
Design and cost computation	A5 1.1 -A5 1.2
Construction cost for Electrodialysis at different TDS level	A52
O&M cost for Electrodialysis at different TDS Level	A53
PUMPS	
Cost calculations	A54
CLEARWELL	
Below ground level cost calculation	A55
Above ground level cost calculation	A56
Construction cost for below ground clearwell storage	A57
Construction cost for above ground clearwell storage..	A58
WATER ANALYSIS	
Generic analyses	A59

Capacity

FLOW RATE INPUT PAGE, WATER DATA REPORT

Yellow colored cells are mandatory input cells

Enter Availability.
 Plant availability due to down time: 0.95
 *Plant availability is used to calculate energy and chemicals costs.

	L/M	GPH	GPD	MGD
INPUT CELLS: enter flowrate in ONE of these cells, set rest cells to 0=>	0	0	0	5
Flow rate converted to Liters/second and entered in workbook calculations.	0.001	0.00	0.01	219.0

Flow rates converted to a variety of units. **131421** **208,333** 5,000,000 **5.00**

PLANT FLOW RATES	u s	GPM
Required Plant Feed Flow Rate:"	292.1	4630
Desired Plant Product Flow Rate:	219.04	3472

"Feed Flow = Plant Product Flow / RO Recovery entered on cost report

WATER DATA REPORTS (based on Water Analysis)

Total dissolved solids (TDS):	700 mg/L	
Average equivalent wt.:	26.0 g/equiv	
Total equiv./L:	0.024 eq/L	2.09E-02 mol/L
Total equiv./L (Valence >+1):	0.004 eq/L	1.78E-03 >1 valence
Average MW	30.32 g/mol	
Ionic Strength:	0.015 mole*charge ² /L	
Delta G:	-0.409	
LSI:	-0.326	
Tendency to corrosion, may need remineralization .		

H2O Anal

WATER ANALYSIS

Input analysis in Yellow cells

Example

Component	Water Analysis	Units	MCL (mg/L)	Amount Over MCL	Percent Removal Required	Valence Charges	Molecular Wt.	Equivalent Weight	Moles/Liter	Equiv./Liter	Ionic Strength
METALS:											
Aluminum		mg/L	0.05		0.00	3	26.97				
Antimony		mg/L	0.006		0.00	3	121.75				
Arsenic		mg/L	0.05		0.00	3	74.92				
Barium		mg/L	2		0.00	2	137.33				
Beryllium		mg/L	0.004		0.00	2	9.01				
Cadmium		mg/L	0.005		0.00	2	112.41				
Calcium	51.00	mg/L	---			2	40.08	20.04	1.27E-03	2.54E-03	5.09E-03
Chromium, total		mg/L	0.1		0.00	2	52				
Copper		mg/L	1		0.00	2	63.55				
Iron		mg/L	0.3		0.00	2	55.85				
Lead		mg/L	0.015		0.00	2	207.2				
Magnesium	7.50	mg/L	---			2	24.3	12.15	3.09E-04	6.17E-04	1.23E-03
Manganese	0.03	mg/L	0.05		0.00	2	54.94	27.47	5.10E-07	1.02E-06	2.04E-06
Mercury		mg/L	0.002		0.00	2	200.59				
Nickel		mg/L	---		0.00	2	58.71				
Zinc	13.00	mg/L	5	8	61.54	2	65.38	32.69	1.99E-04	3.98E-04	7.95E-04
Strontium		mg/L	---			2	87.6				
Selenium		mg/L	0.05		0.00	4	78.96				
Potassium	93.00	mg/L	---			1	39.1	39.10	2.38E-03	2.38E-03	2.38E-03
Silver		mg/L	0.1		0.00	1	197.87				
Sodium		mg/L	---			1	22.99				
Thallium		mg/L	0.002		0.00	1	204.37				
INORGANICS:											
Alkalinity-Bicarbonate	211.50		---			-1	61	61.00	3.47E-03	3.47E-03	3.47E-03
Alkalinity-Carbonate	0.00		---			-2	60				
Carbon Dioxide (aq)			---			0	44				
Asbestos		MF/L	7		0.00						
Boron			---		0.00						
Chloride	114.80	mg/L	250		0.00	-1	35.45	35.45	3.24E-03	3.24E-03	3.24E-03
Residual Disinfectant		mg/L	detectable		0.00		71				
Color		cu	15		0.00						
Conductivity	889.00		---								
Corrosivity		mg/L	non-corrosive								
Cyanide, free		mg/L	0.2		0.00						
Fluoride	0.33	mg/L	4		0.00	-1	19	19.00	1.74E-05	1.74E-05	1.74E-05
Foaming Agents		mg/L	0.5		0.00						
Nitrate (as N)	3.30	mg/L	10		0.00	-1	14	14.00	2.36E-04	2.36E-04	2.36E-04
Nitrite (as N)	1.10	mg/L	1	0.1	9.09	-1	14	14.00	7.86E-05	7.86E-05	7.86E-05
Ammonia (as N)	20.00	mg/L	10	10	50.00	1	14	14.00	1.43E-03	1.43E-03	1.43E-03
Odor		ton	3		0.00						
pH	7.30	pH	6.5-8.5		0.00	1	1	1.00	7.30E-03	7.30E-03	7.30E-03
α-Phosphate			---		0.00	-3	95				
SiO2	27.00		---		0.00						
Silicon			---								
Solids (TDS)	700.00	mg/L	500	200	28.57						
Sulfate	90.00	mg/L	250		0.00	-2	96	48.00	9.38E-04	1.88E-03	3.75E-03
Temperature			---								
Total Suspended Solids:		mg/L	---								

A-2

Cost Index

COST INDICES DATA:

Input: Current Cost Indices Values

Cost Indices Categories:	Input Current Values Here		Source:
	Feb	January	
	1999	1995	
A) Excavation and Site Work	548.67	489	ENR Skilled Labor Wage Index (1967=100)
B) Manufactured Equipment	149.1	136	BLS General Purpose Machinery & Equipment WPU 114 (1912 = 100)
C) Concrete	150.2	130.2	BLS Concrete Ingredients PPI 132 (1982 = 100)
D) Steel	106.6	115.7	BLS Steel Mill Products WPU 1017 (1982 = 100)
E) Labor	548.67	489	ENR Skilled Labor Wage Index (1967=100)
F) Piping and Valves	164.3	148	BLS Miscellaneous General Purpose Equipment WPU 1149 (1982 = 100)
G) Electrical Equip. and Instrmt.	120.6	123.4	BLS Electrical Machinery & Equipment WPU 117 (1982 = 100)
H) Housing	505.81	460.6	ENR Building Cost Index (1967=100)
I) Energy (\$/kWhr)	0.07	0.1	Local Energy Cost \$/kWhr
J) Maintenance Material	131.3	126.2	BLS: PPI Finished Goods (1982 = 100)
K) Labor (\$/hour)	30	20	Local Skilled Labor Rates \$/hr
Interest Rates	8		
Amortization time (yr)	20		

A-3

ENR Engineering News Record Construction Cost Index published monthly by McGraw Hill in New York City (212-512-2000)
 BLS Bureau of Labor Statistics headquartered in Kansas City (Denver, Colorado Number: 303-844-17261)
 OR Check the BLS web site at <http://stats.bls.gov/sahome.html>

Cost reports for water treatment processes

Yellow colored cells are mandatory input cells

Capacity: 18,925 m³/day
5,000 kgal/day

Process	Parameter	Units	Construction Cost			Operating Cost		
			Total \$1000	\$/m ³ Cap	\$/kgal Cap	\$1000/yr	\$/m ³	\$/kgal
Desalination								
Microfiltration			\$3677	\$194	\$0.151	\$665	\$0.10	\$0.38
Microfilter system equipment	Memcor, 90M10C							
Number of microfilter	6							
Recovery	0.96							
Reverse Osmosis/Nanofiltration			\$6142	\$325	\$1,228	\$1780	\$0.27	\$1.03
Membrane Type	Film Tec, BW30-400							
Number of elements	792							
Operating Pressure	653 kPa	95 lb/in ²						
NaCl Rejection	0.995							
Recovery	0.75							
Target Product (TDS mg/L)	500							
Blending? (Y or N)	n							
Ratio Blend:Product	0							
Ion Exchange			\$517	\$27	\$103	\$17	\$0.00	\$0.01
Cation Equivalents/L Resin	20							
\$/m ³ Cation Exchange Resin	\$6,700							
Cation Resin Volume:	105 m ³	3755 ft ³						
To Remove Cation Equivalents/L:	3.56E-03							
Anion Equivalents /L Resin	11							
\$/m ³ Anion Exchange Resin	\$6,700							
Anion Resin Volume	63 m ³	2246 ft ³						
To Remove Anion Equivalents /L:	1.78E-02							
Run Cycle (days)	6							
Electrodialysis			\$2080	\$110	\$416	\$486	\$0.07	\$0.28
Membrane Area:	12,606 m ²	135697 ft ²						
Product TDS	400 mg/L							
Number of Stages (1 or 2)	1							
Recovery per Stage	0.5							
Recovery	0.50							
Disinfection								
Chlorination			\$60	\$3	\$12	\$25	\$0.00	\$0.01
Residual:	3.0 mg/L							
Calculated Dose Rate:	3.0 mg/L							
Alternative Dose Rate:	0.0 mg/L							
Chloramination			\$622	\$33	\$124	\$439	\$0.07	\$0.25
Residual:	3 mg/L							
Calculated Chlorine Dose:	105.59 mg/L							
Calculated Ammonia Dose:	0.99 mg/L							
Alternative Chlorine Dose	0.0 mg/L							
Alternative Ammonia Dose	0.0 mg/L							
Ozone			\$364	\$19	\$73	\$34	\$0.01	\$0.02
Dose Rate (~5mg/L):	1.0 mg/L							
Contact Time (~2 min):	2.0 min							

Cost reports for water treatment processes

Yellow colored cells are mandatory input cells

Capacity: 18,925 m³/day
5,000 kgal/day

Process	Parameter	Units	Construction Cost			Operating Cost		
			Total \$1000	\$/m ³ Cap	\$/kgal Cap	1000/yr	\$/m ³	\$/kgal
Chemical Feed Systems								
Acidification			\$27	\$1	\$5	\$45	\$0.01	\$0.03
Calculated Dose Rate 96% H ₂ SO ₄								
Alternative:								
Target LSI:								
Target pH:								
Alum (dry feed)			\$210	\$11	\$42	\$2286	\$0.35	\$1.32
Calculated Dose Rate:								
Alternative Dose Rate:								
Based on:								
Alum (liquid feed)			\$246	\$13	\$49	\$4512	\$0.69	\$2.60
Calculated:								
Alternative:								
Based on:								
Ferric Sulfate			\$138	\$7	\$28	\$33	\$0.01	\$0.02
Calculated:								
Alternative:								
Based on:								
Lime & Soda Ash			\$183	\$10	\$37	\$49	\$0.01	\$0.03
Leave out Soda Ash "Y" or "N"?								
Calculated Lime:								
Calculated Soda Ash:								
Alternative Lime:								
Alternative Soda Ash:								
Based on Lime dose:								
Based on Soda Ash:								
Polymer			\$42	\$2	\$8	\$20	\$0.00	\$0.01
Suggested:								
Alternative:								
Based on:								
(english)								
Potassium Permanganate			\$21	\$1	\$4	\$36	\$0.01	\$0.02
Calculated:								
Alternative:								
Based on:								

Report

Cost reports for water treatment processes

Yellow colored cells are mandatory input cells

Capacity: 18,925 m³/day
5,000 kgal/day

Process	Parameter	Units	Construction Cost			Operating Cost		
			Total \$1000	\$/m ³ Cap	\$/kgal Cap	\$1000/yr	\$/m ³	\$/kgal
Media Filtration								
Granular Activated Carbon								
Flow rate	292.0524691	L/sec	4630	gal/min				
Alternative Flow Rate:		L/sec		gal/min				
	Bed Life							
Months	12		\$3838	\$192	\$728	\$1024	\$0.16	\$0.59
Months	6		\$3785	\$200	\$757	\$1301	\$0.20	\$0.75
Months	3		\$5047	\$287	\$1,009	\$1863	\$0.25	\$0.96
Gravity Filtration								
Calculated Surface Area:	1.44	m ²		18	ft ²			
Alternative Surface Area:								
Structure:			\$92	\$5	\$18	\$23	\$0.00	\$0.01
Backwashing:			\$77	\$4	\$15	\$5	\$0.00	\$0.00
Media								
Rapid Sand			\$104					
Coal/Sand			\$109					
Coal/Sand/Garnet			\$327					
Misc. Equipment								
Pumps								
Single Stage Turbine			\$723	\$38	\$145	\$767	\$0.12	\$0.44
Variable Speed Turbine			\$938	\$50	\$188			
Centrifugal, Single Stage			\$555	\$29	\$111			
Number of pumps:	4							
Height differential:	1	m		2.9	ft			
Discharge pressure:	1750	kPa		254	psi			
Full flow rate:	0.292	m ³ /s		4630	gal/min			
Basis flow rate	0.073	m ³ /s		1157	gal/min			
Pump Efficiency:	75	%						
Pipe Diameter:	0.1	m		4	in			
Motor Efficiency:	87	%						
HP		236						
Power consumption:		271						
Upflow Solids Contact Clarifier								
How Many?	2		\$932	\$49	\$188.50			
Retention Time (min)	180							
Calculated Surface Area:	328.6	m ²		3537	ft ²			
Alternative Surface Area:		m ²			ft ²			
G Rating %	70					\$41	\$0.01	\$0.02
G Rating %	110					\$45	\$0.01	\$0.03
G Rating %	150					\$51	\$0.01	\$0.03
Clearewell								
Below Ground Capacity:	1500	m ³	\$358	396.4	kgal			
Ground Level Capacity:	1500	m ³	\$237	396.4	kgal			
Daily Production:	18,925	m ³		5001.3	kgal			

Micro input


Microfiltration Cost Estimation Program

Yellow colored cells are mandatory input cells

Process input					
(Inputs in yellow cells)					
Design MF product flow rate	5,000,000	208,333	3472	219	18925
	GPD	GPH	GPM	L/s	m ³ /day
Plant availability (%)	95				
Microfilters system equipment cost	\$270,000	90M10C			
Cost per membrane	\$650				
MF modular system flow rate	600 gpm		37.85 L/s		
No. membranes per microfilter	90				
Pump efficiency	80 %				
Motor efficiency	93 %				
Design feed pressure	30 psi		207 kpa		
Backflush pressure	29 psi		200 kpa		
Backwash intervals	60 minutes		3600 second		
Backwash and backflush duration	2.5 minutes		150 second		

Operations & Maintenance Cost Input	
Electricity Rate	0.08 \$/kWh
Chemical Costs	
Sodium Hypochlorite	0.43 \$/L
Design dosage	200 mg/l
Specific gravity (NaOCl)	1.168
Solution concentration	12 %
Membrane Life	5 Years
Staff Days/day	5
Labor Rate (salary and benefits)	35 \$/hr
Amortization time	30 Years
Interest Rate	8 %

Process Flow Calculation		
MF feed flow	228.9 L/s	3629 gpm
MF product flow	219.0 L/s	3472 gpm
MF reject flow (backwash)	10 L/s	157 gpm
Recovery rate	95.7 %	
Feed pump horsepower	79 hp	
Feed pump (kwh)	61 kwh	
Backflush (kwh)	3 kwh	
Number of microfilters	6	
Number of membranes	540	
Building Area	2500 ft2	232 m2



A-5

Estimating Construction Costs for Microfiltration Membrane Treatment Plant

Direct Capital Costs			
Microfilters	\$	1,620,000	@ 270000 \$/90M10C
Building	\$	250,000	@ 100 \$/m ² 1076 \$/m ²
MF installation	\$	420,000	@ 70000 \$/90M10C
Miscellaneous	\$	81,000	5 % of microfilters
Plant interconnecting piping	\$	85,050	5 % of microfilters and misc.
Engineering	\$	170,100	10 % of microfilters and misc.
Total Direct Capital Costs	\$	2,626,150	

Indirect Capital Costs			
Interest During Construction	\$	158,000	6 % of Total direct
Contingencies	\$	525,000	20 % of Total direct
A&E Fees, Proj. Management	\$	263,000	10 % of Total direct
Working Capital	\$	105,000	4 % of Total direct
Total Indirect Capital Cost	\$	1,051,000	

Total Construction Cost	\$	3,677,150
--------------------------------	-----------	------------------

Cost per gpd capacity	\$	0.74
------------------------------	-----------	-------------

Operations & Maintenance Cost Estimation

Electricity	\$	45,000
Labor	\$	485,000
Chemicals (Sodium Hypochlorite)	\$	10,000
Membrane Replacement	\$	70,000
Cleaning Chemicals(NaOCl)	\$	2,000
Repairs and Replacement and Misc.	\$	53,000
Total O & M Cost	\$	665,000

Total costs	
Capital Recovery	\$ 327,000
O&M	\$ 665,000
Annual cost	\$ 992,000
\$/m ³ Product	\$ 0.151
\$/1000 gal Product	\$ 0.57
\$/acre foot Product	\$ 186


RO&NF Input

Available Flow	292.1 L/s	4630 gpm	Bypass	18,975 m ³ /day	1,000,000 gpd	Efficiency Rate	0.14 \$/kg
Target Flow	219.0 L/s	3472 gpm	Total Capacity	24 m ³ /day	6,392 gpd	Chemical Costs	4.37 \$/kg
Target Dissolved Solids	700 mg/L		Module Productivity	20.32 (10.16 of 20.32 cm)	8.0 in	Acid	0.2 \$/L
Target Dissolved Solids	0.91 Decimal	271.65	Membrane Diameter	6		Antiscalant	23.7 \$/kg
Mono valent	0.09 Decimal	69.86	Number of modules per vessel	24		H ₂ PO ₄	18 \$/kg 50%
Multi valent	30.32 g/mol	19,588	Max Vessels per Skid	792 # of modules		NaOH	
Average Molecular Mass	0.75 Decimal		Membrane Area	132 for 2.1 array		Membrane Life	3 Years
Flow Blending	4 mg/L		Number of Pressure Vessels	0.75 Decimal		Ave Intrinsic Rejection	0.996 for NF, .987 for RO
Recovery Rate	219.0 L/s	3472 gpm	Number of RO Skids	3		Ave Observed Rejection	99.5, .45 for NF, .85 for RO
Product TDS	292.1 L/s	4630 gpm	Chemical Feed Dosages	0.03 mL Conc. H ₂ SO ₄ /L		Chloride Rejection	0.995 %
Product Flow	2789 mg/L	1157 gpm	Acid	3.0 mg/L		Sulfate Rejection	0.998 %
Membrane Feed Flow	7.30 L/s	0 gpm	Disinfectant	604 m ³		Productivity	40 m ³ /module
Concentrate TDS	0.0 %		Building Area	20 m ²		Cleaning Rate	12 per Year
Concentrate Volume			Administrative Area	n	Yes (Y) or No (N)	Staff Days/day	30 Shr
Bypass flow for blending			Door Control?	hp		Labor Rate	20 Years
% blending			Emergency Generator Size	VST		Lifetime	8 %
Data from Membrane Manufacturer Specification							
Type of membrane	Film Lec. BW40-400		High Pressure Pump	1 m	3.28 ft		
Productivity	40 m ³ /day	224.93 psi	Height Difference	0.10 m	4 in		
Operating pressure, P _{op}	1550 kPa		Pipe Diameter	10 m	32.8 ft		
Test solution TDS	2000 mg/L		Length of Pipe	82			
Avg. MW of TDS	58.44 mg/mole NaCl		Efficiency	2			
Salt rejection	99.5 %		Number of High Service Pumps	653 kPa	95 psi		
Recovery Rate	85 %		Operating Pressure	0.146 m ³ /s	2315 gpm		
Temperature	25 °C		Capacity per Skid	182 hp			
NaCl dissociation constant	0.99		Size	SST	sst, vst or css		
C ₁ conc. of salt in feed water	34 mole/m ³		Transfer Pumps	1 m	3.28 ft		
C ₂ conc. of salt in product water	0.17 mole/m ³		Height Difference	0.12 m	0.40 ft		
C ₃ conc. of salt in reject	227 mole/m ³		Pipe Diameter	10 m	32.81 ft		
C ₄ conc. of	131 mole/m ³		Length of Pipe	78			
Osmotic pressure	841 kPa	93 psi	Efficiency	2			
Net driving pressure, NDP	908 kPa	131.96 psi	Number Transfer Pumps	200 kPa	29.0 psi		
A ₁ water transport coefficient	0.014 m/sec.Pa		Pressure Differential	46.8 hp	2314.8 gpm		
Determination of operating pressure							
User input pressure, NDP ₁	550 kPa	79.812 psi	Capacity per Pump	SST	sst, vst or css		
C ₁ conc. of salt in feed water	23.087 mole/m ³		Size	10 m	32.81 ft		
C ₂ conc. of salt in product water	0.115 mole/m ³		Height Difference	0.14 m	0.47 ft		
C ₃ conc. of salt in reject	22.740 mole/m ³		Pipe Diameter	20 m	65.62 ft		
C ₄ conc. of	103 kPa	15 psi	Length of Pipe	78			
Osmotic pressure, P _{osm}	653 kPa	95 psi	Efficiency	50 kPa			
Operating pressure, P _{op}			Number Pumps	0.110 m ³ /s	7.3 psi		
			Pressure Differential	13.1 hp	1736.1 gpm		
			Capacity per Pump				
			Size				

Colored cells are changeable here
White cells are equations or taken from the input, cost, notices and cost report worksheets.

WTCost

Pure water permeability (m^3/s)	4.63E-04
Feed Flow (m^3/s)	3.09E-03
Transmembrane pressure (Pa)	1550000
Area (m^2)	37
Channel height d,(m)	1.67E-03
C_f (mol/m^3)	34.22
Density (kg/m^3)	1000
Viscosity (Pa s)	0.001
a ($Pa m^3 mol^{-1}$)	4908
Diffusivity of NaCl (m^2/s)	1.20E-09
Calculated paramters determined by configuration and operating conditions	
J_v (m/s) 1st pass	1.25E-05
$P\sqrt{t_m}$ ($m^3 m^{-2} s^{-1} Pa^{-1}$)	8.07E-12
Average U_c (m/s)	9.99E-02
Schmidt Number	838
Renolds Number	166
a	0.875
b	0.250
c	0.065
k (m/s) for laminar flow in flat channel	2.20E-05



Solving the design equations

J_v/k	0.57	0.44	0.46	0.46	0.46	0.46	0.46	0.46
Recovery	0.1500	0.1165	0.1216	0.1209	0.1210	0.1210	0.1210	0.1210
Intrinsic Rejection R^o	0.996	0.996	0.996	0.996	0.996	0.996	0.996	0.996
Apparent Rejection R_a	0.9917	0.9930	0.9928	0.9928	0.9928	0.9928	0.9928	0.9928
C_w (mol/L)	70.7728	6.01E+01	6.16E+01	6.13E+01	6.14E+01	6.14E+01	6.14E+01	6.14E+01
C_p (mol/L)	0.2831	2.40E-01	2.46E-01	2.45E-01	2.46E-01	2.45E-01	2.45E-01	2.45E-01
C, (mol/L)	40.2126	38.7050	38.9262	38.8950	36.8994	38.8988	38.8989	38.8989
J_v Theoretical ($m^3 m^{-2} s$)	9.72E-06	1.01E-05	1.01E-05	1.01E-05	1.01E-05	1.01E-05	1.01E-05	1.01E-05
Exp (J_v/k)	1.77	1.56	1.59	1.58	1.58	1.58	1.58	1.58

RO&NF Output

Estimating Construction Costs for BW-30-400 Membrane Treatment Plant				
Membranes	\$	594,000	@	750 \$/element
RO Skids	\$	660,000	@	5000 \$/Vessel
Building	\$	650,000	@	1076 \$/m ² \$100/ft ²
Electrical	\$	370,064	With base of	614 \$/m ³
Instrumentation & Controls	\$	495,000		
High Pressure Pumps	\$	250,962		272 kWh
Transfer Pumps	\$	70,836		70 kWh
Product Water Pumps	\$	30,996		20 kWh
Degasifiers	\$	32,165		
Odor Control	\$	-		
Process Piping	\$	399,999		
Yard Piping	\$	200,688		
Chemical Feed w/ Pumps				
Acid	\$	91,157	1	\$/L storage for 45 days
Antiscalant	\$	60,076	1	\$/L storage for 30 days
Chlorine	\$	61,706	1	\$/L storage for 30 days
Cartridge Filters	\$	57,605		
Membrane Cleaning Equip	\$	67,000		
Contractor Engineering & Training	\$	50,000		
Concentrate Treatment & Piping	\$	62,500	13	\$/m ³ Concentrate
Generators	\$	69,981		93 kWh RO & Building
Sitework	\$	275,000	\$	14.53 \$/m ³
Total Direct Capital Costs	\$	4,549,735		
Indirect Capital Costs				
Interest During Construction		245,686	4	% of Total
Contingencies		367,050	6	% of Total
A&E Fees, Proj. Management		733,986	12	% of Total
Working Capital		245,686	4	% of Total
Total Indirect Capital Cost	\$	1,592,407		
Total Construction Cost	\$	6,142,143		
Cost per m ³ /day capacity	\$	325		
Cost per gpd capacity	\$	1.23		

Estimating Operations & Maintenance Costs		
Electricity	\$	264,726
Labor	\$	525,600
Acid	\$	69
Antiscalant	\$	2,868
Chlorine	\$	3,945
Membrane Replacement	\$	198,000
Cleaning Chemicals	\$	17,299
Cartridge Filters	\$	80,797
Repairs and Replacement	\$	22,749
Insurance	\$	9,099
Lab fees	\$	28,800
Total O & M Cost	\$	1,153,951

Total Costs	
Capital Recovery	\$ 625,591
O&M	\$ 1,153,951
Annual cost	\$ 1,779,542
\$/m³ Product	\$ 0.27
\$/1000 gal Product	\$ 1.03
\$/acre foot Product	\$ 334

Based on "Estimating the Cost of Membrane (RO or NF) Water Treatment Plants" By William B. Suratt, P.E., Camp Dresser & McKee Inc. Vero Beach Florida Presented at the AWWA Membrane Technology Conference, Reno, NV, 1995. also published as "Estimating the cost of membrane water treatment plants." AWWA Proceedings Membrane Technologies in the Water Industry. Orlando, Florida, March 10-13, 1991.

DGACID

Calculation of Free Energy to determine scaling propensity.
 If dG is < 0 water is corrosive, if it is > 0 it is oversaturated.
 (from Snoeyink & Jenkins, Water Chemistry, 1980, John Wiley & Sons, Inc. p288)

Some water analyses include LI calculation.
 $LI = dG/2.3 \cdot R \cdot T$

Equations:
 Act Coef. = $10^{-.5 \cdot \sum q_i^2 \cdot (u^{.5/(1+u^{.5})} - 0.2 \cdot u)}$
 q_i is the charge on the i 'th species, u is ionic strength.
 $\log K = \log K_{so} + \log 1/K_a,2$
 $dG = dG^{\circ} + R \cdot T \cdot \ln Q$
 $dG^{\circ} = -R \cdot T \cdot \ln K$
 $Q = \frac{\{Ca^{2+}\} \cdot \{HCO_3^-\}}{\{H^+\}}$
 $u = @SUM(Ci \cdot Zi^2)/2$

Tendency to corrosion, may need remineralization.

Acid addition calculations:
 Assume system open to the atmosphere, $H_2CO_3^*$ is approximately $K_H P_{CO_2}$
 The calculation is based on carbonate system equilibrium. Bicarbonate concentration is input from the water analysis. $\{CO_3^{2-}\}$ is calculated from 2nd dissociation constant

Calculation of ionic strength:
 3 methods:

- 1) Lewis & Randall, J. Am. Chem. Soc. 43:1111 (1921)
 $u = @SUM(Ci \cdot Zi^2)/2$
 C_i = Concentration of i 'th species in moles/L.
 Z_i = Charge on i 'th species.
- 2) W.F. Langelier, J. Am. Water Works Assoc., 28:1500 (1936).
 $u = 2.5E-5 \cdot TDS$
- 3) L.L. Russel Ph.D. Thesis, U of California, Berkeley, Dec. 1976.
 $u = 1.6E-5 \cdot \text{specific conductance (umho/cm)}$

Species	Zi	MW	Conc. mg/L	Moles/L	Ci*Zi^2
Ca 2+	2	40	51.0	0.00128	0.0051
Mg 2+	2	24.3	7.5	0.00031	0.001234568
Na +	1	23	0.0	0	0
K +	1	39	93.0	0.00238	0.002384615
CO3 -2	-2	60	0.0	0	0
HCO3 -	-1	61	211.5	0.00347	0.003467213
SO4 -2	-2	96	90.0	0.00094	0.00375
Cl-	-1	35.4	114.8	0.00324	0.003242938
Ionic Strength =		0.01918		Charge Balance	
				+ 0.00158	
				- 0.00765	

The equations behind these calculations are derived from the charge balance equation:
 $\{Cations\} + \{H^+\} = \{Anions\} + \{OH^-\} + \{HCO_3^-\} + 2\{CO_3^{2-}\} + 2\{SO_4^{2-}\}$

All terms expressed as functions of $\{H^+\}$ concentration, the above constants, ionization fractions, and given concentrations.

$\{Anions\} =$ Sum of Anions other than sulfate and bicarbonate
 $\{Cations\} =$ Sum of Cations from interface
 $\{H^+\} = 10^{-\{Target\ pH\}}$
 $\{OH^-\} = K_w/\{H^+\}$
 $\{H_2CO_3^*\} = K_H \cdot P_{CO_2} = 10^{-1.5} \cdot 10^{-3.5} = 10^{-5} \text{ M}$
 $\{HCO_3^-\} = \{HCO_3\}$
 $\{CO_3^{2-}\} = \{H_2CO_3^*\} \cdot a_2/a_0$
 $\{SO_4^{2-}\} =$ Input adjusted by solver
 $a_0 = \{H^+\}^2/E$
 $a_1 = \{H^+\} \cdot K_{a,1}/E$
 $a_2 = K_{a,1} \cdot K_{a,2}/E$
 $E = \{H^+\}^2 + \{H^+\} \cdot K_{a,1} + K_{a,1} \cdot K_{a,2}$
 $E = 10000$
 p 432, Water Chemistry, Snoeyink & Jenkins, 1980.

Input from water analysis.

Species:	Concentration	Activity Coefficient	Concentration w/ Activity Coef.
Ionic strength:	1.451E-02	square root μ :	0.12
Ca 2+ and Mg 2+ moles/L:	1.581E-03	0.81	9.682E-04
HCO3- moles/L:	3.467E-03	0.88	3.067E-03
pH:	7.30		5.012E-08
Temp deg.C:	0	deg K:	273
H2CO3*:	0.00E+00		0.000E+00

Constants at 20 deg C:		w/activity coef.
log Kw:	-14.17	-14.06
log Kso:	-8.28	-7.85
log Ka,1:	-6.38	-6.27
log Ka,2:	-10.38	-10.59
log K:	2.10	
log Kh:	-1.5	
gas const. R (kcal/deg K*mole):	1.987E-03	

Calculations:			
Q:	5.925E+01		
dG*:	-2.623		
dG:	-0.409	LSI :	-0.328
Fine - pH is:	7.30		
Target dG	-0.062	Target LSI:	-0.05
pH for Target dG	7.58	Looks fine	

Input: From above.	Concentration	w/Activity Coef	Units
[H+]	2.646E-08	2.341E-08	moles/L
[H2CO3*]	1.000E-05	1.000E-05	moles/L
[HCO3-]	1.575E-04	1.575E-04	moles/L
[CO3 2-]	2.482E-07	1.520E-07	moles/L
[OH-]	2.555E-07	2.260E-07	moles/L
C _{T,CO3}	1.678E-04	1.677E-04	
Target pH:	7.58		
H2SO4 added:	5.709E-04	moles/L	
ml 96% H2SO4/Liter	0.030	ml/L	

A-11

Acid

Acid addition cost estimation

Litershec	treated	292.05
H ₂ SO ₄ (96%)	mL/L	0.03
H ₂ SO ₄ (96%)	m ³ /day	0.77
Basis:	0.77	Applicable Range: 0.04 - 20 m ³ /day
Acid Cost (\$/ton):		75

1978 Capital Cost: Percentages	13,052	1978 index value basis	Current index value 1999
A) Excavation and Site Wor	0	247	548.67
B) Manufactured Equipment	0.6	72.9	149.1
C) Concrete	0	71.6	150.2
D) Steel	0	75	106.6
E) Labor	0.16	247	548.67
F) Piping and Valves	0.07	70.2	164.3
G) Electrical Equip. and Inst	0.1	72.3	120.6
H) Housing	0.07	254.8	505.81

1999 Capital Cost: 1 .00 **\$26,784**

1978 O&M Cost: 1,445

I) Energy	\$/kW*h	0.05	169	0.03	0.07
J) Maintenance	Material	0.04	106	71.6	131.3
K) Labor	\$/hour	0.91	3,945	10	30
Chemical Cost	\$/yr:		40,886		

1999 O & M Cost: 1.00 **\$45,105**


Sulfuric Acid feed

Formula from Qasim. et al, Aug. 1992, AWWA

General Form: $A \cdot X^B + C$


	Capital Cost	O&M Cost	$A \cdot e^{(B \cdot X)} + C$
A =	6010.6	A =	-42397.4
B =	0.7934	B =	-0.00682
C =	8180	C =	43670

Construction Cost for Sulfuric Acid Feed



A-13

O&M Cost for Sulfuric Acid Feed



Chlorine disinfection Cost Estimation Worksheet

Input	mg/L	mMoles/L
Chromium (Cr 2+):	0.00	0.00E+00
Nickel (Ni 2+):	0.00	0.00E+00
Iron (Fe 2+):	0.00	0.00E+00
Manganese (Mn 2+):	0.03	5.10E-07
Total:		5.10E-07
Nitrite (NO2 -)	1.10	7.86E-05
Desired Residual (mg/L):	3.00	4.23E-02
mg Cl2 needed/L	3.01	4.23E-02
Volume to be treated (L/sec):	292.05	
Cl ₂ needed kg/day:	75.84	Applicable Range: 4 - 4,500
Basis kg/day:	75.84	
Cl2 Cost	250	\$/short ton, tanks

1978 Capital Cost:	Percentages	29,517.83	1978 index value basis	Current index value 1999
A) Excavation and Site Work	0	0.00	247	548.67
B) Manufactured Equipment	0.47	28,374.77	72.9	149.1
C) Concrete	0	0.00	71.6	150.2
D) Steel	0	0.00	75	106.6
E) Labor	0.06	3,934.14	247	548.67
F) Piping and Valves	0.04	2,763.41	70.2	164.3
G) Electrical Equip. and Instrmnt.	0.05	2,461.86	72.3	120.6
H) Housing	0.38	22,266.71	254.8	505.81
1999 Capital Cost:	1.00	59,800.88		
1978 O&M Cost:		8,242.45		
I) Energy \$/kW*h	0.18	4,945.47	0.03	0.1
J) Maintenance Material	0.18	2,615.02	71.6	126.2
K) Labor \$/hour	0.64	10,550.34	10	20
Chemical Cost		7,315.05		
1999 Operation and Maintenance:	1.00	25,425.88		

Chlorine demand is usually found by experimentation, but in this case we will use the concentration of reduced transition metal ions and nitrite to calculate a chlorine demand. The molar ratio is 1:2 Cl₂ to +2 metal cation and 1:1 for Cl₂ to NO₂-.


Chlorine storage and feed with Cylinder storage
Formula from Qasim, et al, Aug. 1992, AWWA

General Form: $A \cdot X^B + C$
Capital Cost
A=
B=
C=

O&M Cost
A= 47.6
B= 0.89
C= 6000

Construction and O&M Cost for Chlorine Disinfection at Different Dosage Rates

A-16



Chloramine disinfection Cost Estimation Spreadsheet

Data from water analysis:	mg/L	mMoles/L
Chromium (Cr):	0.00	0.00E+00
Copper (Cu):	0.00	0.00E+00
Iron (Fe):	0.00	0.00E+00
Manganese (Mn):	0.03	5.09E-04
Nitrite (NO ₂ - as N):	20.00	1.43E+00
Desired NH ₂ Cl Residual (mg/L):	3.00	5.84E-02
Current Cl ₂ Concentration:	0.00	0.00E+00
Cl ₂ needed/L:	105.59	1.49E+00
Ammonia Needed/L:	0.99	5.84E-02
Volume to be treated (L/sec):		292
Calculated Cl ₂ Dose kg/day:		2664.40 Applicable Range: 4 - 4,500
Alternative Cl ₂ Dose kg/day:		0.00
Basis:		2664.40
Cl ₂ Cost \$/ton:	250	
Calculated Aqua Ammonia kg/day:		25.04 Applicable Range: 110 - 2300
Alternative Aqua Ammonia kg/day:		0.00
Basis:		25.04
NH ₄ OH Cost \$/ton:	285	

Total Capital Cost 1999 \$:	622,490
Total O&M Cost 1999 \$:	438,577

****Chlorine Feed****

Percentages	1978		Current	
	index value	basis	index value	1999
1978 Capital Cost:		290,727.99		
A) Excavation and Site Work	0	0.00	247	548.67
B) Manufactured Equipment	0.47	279,469.76	72.9	149.1
C) Concrete	0	0.00	71.6	150.2
D) Steel	0	0.00	75	106.6
E) Labor	0.06	38,748.27	247	548.67
F) Piping and Valves	0.04	27,217.44	70.2	164.3
G) Electrical Equip. and Instrmt.	0.05	24,247.44	72.3	120.6
H) Housing	0.38	219,310.00	254.8	505.81
1999 Capital Cost:	1.00	588,993		

1978 O&M Cost		1999		
1978 O&M Cost:		59,258.74		
I) Energy \$/KW ^h	0.18	24,888.67	0.03	0.07
J) Maintenance Material	0.18	19,560.35	71.6	131.3
K) Labor \$/hour	0.64	113,776.78	10	30
Chlorine Cost		256,987.58		
1999 O&M Cost:	1.00	415,213		

****Ammonia Feed****

Percentages	1978		Current	
	index value	basis	index value	1999
1978 Capital Cost:		16,276.26		
A) Excavation and Site Work	0	0.00	247	548.67
B) Manufactured Equipment	0.56	18,642.01	72.9	149.1
C) Concrete	0	0.00	71.6	150.2
D) Steel	0	0.00	75	106.6
E) Labor	0.15	5,423.26	247	548.67
F) Piping and Valves	0.1	3,909.39	70.2	164.3
G) Electrical Equip. and Instrmt.	0.1	2,714.96	72.3	120.6
H) Housing	0.09	2,907.94	254.8	505.81
1999 Capital Cost:	1.00	33,498		

1978 O&M Cost		1999		
1978 O&M Cost:		8,265.80		
I) Energy \$/KW ^h	0.06	1,157.21	0.03	0.07
J) Maintenance Material	0.4	6,063.13	71.6	131.3
K) Labor \$/hour	0.54	13,390.60	10	30
Ammonia Cost		2,752.95		
1999 O&M Cost:	1.00	23,364		

The addition of Chlorine and Ammonia to water produces chloramines. Chloramines are the "combined chlorine residual." They are more persistent in the water lines than "free chlorine," which is HOCl, and OCl⁻. If there is sufficient ammonia in the water already, it doesn't need to be added, of course. If not, chlorine and aqueous ammonia should be added at the molar ratio of 1:1, Cl₂:NH₃(aq). We will use the moles of divalent metal ions and NO₂- to calculate a chlorine demand. The molar ratio is 1:2 Cl₂ to divalent cations, and 1:1 for Cl₂:NO₂-. The residual for Chloramines must be at least 2 mg/L which translates to approximately .03 moles per liter at pH 7.

Chlorine storage and feed with Cylinder storage

Formula from Qasim, et al. Aug. 1992, AWWA
General Form: A*XⁿB + C


Capital Cost	
A=	680.75
B=	0.763
C=	100.00
O&M Cost	
A=	47.6
B=	0.89
C=	6000

Anhydrous Ammonia Feed,
same place and form.
X=kg/day ammonia feed capacity

Capital Cost: A*X ⁿ B*e ⁿ (C*X)	
A=	3849.2
B=	0.448
C=	-0.000035

O&M Cost: A*e ⁿ (B*X) + C	
A=	-28063
B=	-2.41E-04
C=	36160

Construction and O&M Cost for Chloramine Disinfection at Different Dosage Rates



OZONE DISINFECTION

Desired Flow Rate:	292.05 L/s	
Flow rate (L/min):	17523 L/min	4630 gpm
Enter ozone level required (mg/L): (Typically 1-5 mg/L)	1 mg/L	
Total ozone needed:	25 kg/day	11.5 lbs/day
Enter contact time :	2 min	
Contact chamber size:	35.0 m ³	1237.7 ft ³
Power (~26.5kWh per kg ozone):	304 kWh	

TOTAL CONSTRUCTION COSTS: \$364,494

TOTAL OPERATING COSTS: \$34,016

Ozone Generator:

Contact Chamber:

Ozone Requirements: 25.23 kg/day Applicable Range: 13-2600 m³

1978 Capital Cost:	Percentages	1978 basis	1978 Current index value index value		1978 Capital Cost:	Percentages	1978 Capital Cost:
			1978	Current			
A) Excavation and Site Work	0.00	0	247	548.67	A) Excavatio	0.06	1,745
B) Manufactured Equipment	0.81	271,070	72.9	149.1	B) Manufact	0.00	0
C) Concrete	0.00	0	71.6	150.2	C) Concrete	0.19	5,218
D) Steel	0.00	0	75	106.6	D) Steel	0.31	5,768
E) Labor	0.16	58,154	247	548.67	E) Labor	0.44	12,795
F) Piping and Valves	0.00	0	70.2	164.3	F) Piping an	0.00	0
G) Electrical Equip. and Instrmnt.	0.00	0	72.3	120.6	G) Electrica	0.00	0
H) Housing	0.03	9,744	254.8	505.81	H) Housing	0.00	0
1999 Capital Cost:	1.00	\$338,968			1999 Capita	1.00	\$25,526

1978 O&M Cost:	\$14,423			
I) Energy \$/kWh	0.77	25,914	0.03	0.07
J) Maintenance Material	0.11	2,909	71.6	131.3
K) Labor \$/hour	0.12	5,192	10	30
1999 O & M Cost:	1.00	\$34,016		

Ozone Generation Costs from Qasim, et al, Aug. 1992, AWWA

Construction Costs:

General Form: A * X ^ B * e ^ (C * X)

A= 18631.2
B= 0.674
C= -0.000121

O & M Costs:

General Form: A * X ^ B + C

A= 392.4
B= 0.919
C= 6800

Ozone Contact Chamber Costs from Qasim, et al, Aug. 1992, AWWA


Construction Costs:

General Form: A * X ^ B + C


A=
B=
C=

O & M Costs: NONE

Construction Cost for Ozone Generator at Different Dosage Rates



O&M Cost for Ozone Generator at Different Dosage Rates



ALUMFD

Dry Alum Feed Cost Calculations.


Volume Treated L/Sec:	292	
Volume Treated (m3/Hour):	1051	
Alternative dosage rate mg/L	0	0 kg/hr
	mg/L	mmoles/L
Bicarbonate Alkalinity:	212	3.5
Alum Feed Dry mg/L:	385	
Calculated Alum Feed Dry kg/hour:	405	0.576 Applicable Range 4 - 2,300 kg/hr
Basis Feed Rate	405	
Alum Cost \$/100 lbs.:		30

	Percentages		1976 index value basis	Current index value 1999
1976 Capital Cost:		\$104,062		
A) Excavation and Site Work	0	\$0	247	546.671
B) Manufactured Equipment	0.41	\$87,262	72.9	149.1
C) concrete	0	\$0	71.6	150.2
D) Steel	0	\$0	75	106.6
E) Labor	0.03	\$6,935	247	546.67
F) Piping and Valves	0.04	99,742	70.2	164.3
G) Electrical Equip. and Instrmnt.	0.05	\$6,679	72.3	120.6
H) Housing	0.47	\$97,091	254.6	505.61
1999 Capital cost:	1.00	\$209,706		
1976 O&M Cost:		\$12,744		
I) Energy \$/kW*h	0.17	\$5,055	0.03	0.07
J) Maintenance Material	0.03	\$701	71.6	131.3
K) Labor \$/hour	0.6	\$30,585	10	30
Alum cost:		\$2,249,797		
1999 Operation & Maintenance:	1.00	\$2,286,138		

Alum Feed Liquid kg/hour:	810 -Applicable range 2 - 2500 kg/hour
Need twice as much as dry.	
Alternative dose rate mg/L	0
Basis dose rate kg/hr:	810


	Percentages		1970 index value basis	current index value 1999
1976 Capital cost:		\$121,006		
A) Excavation and Site Work	0	\$0	247	548.67
B) Manufactured Equipment	0.64	\$156,393	72.9	149.1
C) concrete	0	\$0	71.6	150.2
D) Steel	0	\$0	75	106.6
E) Labor	0.12	\$32,255	247	546.67
F) Piping and Valves	0.02	\$5,664	70.2	164.3
G) Electrical Equip. and Instrmnt.	0.07	\$14,129	72.3	120.6
H) Housing	0.15	\$36,032	254.8	505.61
1999 Capital cost:	1.00	\$246,4741		
1978 O&M Cost:		\$4,665		
I) Energy \$/kW*h	0.59	56,422	0.03	0.07
J) Maintenance Material	0.04	\$342	71.6	131.3
K) Labor \$/hour	0.37	\$5,176	10	30
Alum cost:		\$4,499,594		
1999 Operation & Maintenance:	1.00	\$4,511,535		

Construction Cost for Dry Alum and Liquid Alum Feed



O&M Cost for Dry Alum and Liquid Alum Feed

A-24



IRONFD

Coagulation With Ferric Sulfate

Volume Treated L/sec	292	
	mg/L	mmoles/L
Bicarbonate Alkalinity:	212	3.47
Alternative dose rate:	10	252.3 kg/day
Calculated dose rate:	325	0.578
Basis dose rate kg/day:	Applicable Range 6 - 3000 kg/day	
Chemical Cost \$/ton bulk:		252.3 kg/day
		117

1978 Capital Cost:	Percentages	\$68,413	1978 index value basis	Current index value 1999
A) Excavation and Site Work	0	\$0	247	548.67
B) Manufactured Equipment	0.63	\$88,151	72.9	149.1
C) Concrete	0	\$0	71.6	150.2
D) Steel	0	\$0	75	106.6
E) Labor	0.02	\$3,039	247	543.67
F) Piping an* Valves	0.05	\$8,006	70.2	164.3
G) Electrical Equip. and Instmnt.	0.09	\$10,270	72.3	120.6
H) Housing	0.21	\$28,520	x 4.8	505.81
1999 Capital Cost:	1.00	\$137,986		

1978 O&M Cost:		\$7,659		
I) Energy \$/kW*h	0.09	\$1,608	0.03	0.07
J) Maintenance Material	0.07	\$983	71.6	131.3
K) Labor \$/hour	0.84	\$19,301	10	30
Ferric Sulfate Cost \$/yr:		\$11,390		
1999 Operation & Maintenance:	1.00	\$33,283		

Ferric Sulfate Feed Capital cost

General Form: $A \cdot X^A \cdot B^A \cdot e^A \cdot (C \cdot X)$


A =	10613
B =	0.319
C =	am393

O&M Cost

General Form: $A \cdot e^A \cdot (B \cdot X) + C$

A =	1260926
B =	0.00001394
C =	-1257710


Construction Cost for Ferric Sulfate Feed at Different Dosage Rates



A-26

O&M Cost for Ferric Sulfate Feed at Different Dosage Rates

A-27



Polymer Addition for Antiscalant

Volume Treated L/Sec:	292
Volume Treated (m3/day):	25233
Alternative dosage rate (default = 0.5 mg/L):	0.3
Polymer Feed kg/day:	7.6 Applicable range 0.5 - 100 kg/day
Hypersperse AF200 \$1500 lb.:	990

1978 Capital cost:	Percentages	\$20,566	1978 index value basis	current index value 1999
A) Excavation and Site Work	0	\$0	247	546.67
B) Manufactured Equipment	0.7	\$29,447	72.9	149.1
C) concrete	0	\$0	71.6	150.2
D) Steel	0	\$0	75	106.6
E) Labor	0.04	\$1,828	247	546.67
F) Piping and Valves	0.01	\$461	70.2	164.3
G) Electrical Equip. and Instrmnt.	0.06	\$2,058	72.3	120.6
H) Housing	0.19	\$7,758	254.6	505.61

1999 Capital Cost: 1.00 \$41,572

1978 O&M cost:		\$3,046		
I) Energy \$/kW*h	0.24	\$1,707	0.03	0.07
J) Maintenance Material	0.1	\$559	71.6	131.3
K) Labor \$/hour	0.66	\$6,035	10	30
Polymer Cost		\$11,567		

1999 Operation & Maintenance: 1.00 \$19,869


Polymer Feed Capital Cost
General Form: $A \cdot e^{(B \cdot X)} + C$

A =	11760.71
B =	0.00665
c =	6200

O&M cost
General Form: $A \cdot e^{(B \cdot X)}$


A =	3000.6
B =	0.00207

Construction Cost for Polymer Feed at Different Dosage Rates



O&M Cost for Polymer Feed at Different Dosage Rates

A-30



KMnO4

Potassium Permanganate Oxidation

Mn 2+ concentration:	0.03 mg/L
Fe 2+ concentration:	0.00 mg/L
Calculated KMnO4 Dose:	-0.042 mg/L
Volume Treated L/Sec:	292.1
Volume Treated (m3/day):	25,233
Alternative dosage rate. mg/L:	1
KMnO4 kg/day:	25.2 Applicable range 0.5 - 100 kg/day
KMnO4 \$/lb (hopper trucks):	1.21

	Percentages	1978 indexvalue basis	current indexvalue 1999
1978 Capital Cost:		\$11,014	
A) Excavation and Site Work	0	\$0	247 546.67
B) Manufactured Equipment	0.34	\$7,659	72.9 149.1
C) concrete	0	\$0	71.6 150.2
D) Steel	0	\$0	75 106.6
E) Labor	0.05	\$1,223	247 548.67
F) Piping and Valves	0.1	\$2,576	70.2 164.3
G) Electrical Equip. and Instrmnt.	0.32	\$5,879	72.3 120.6
H) Housing	0.19	\$4,154	254.8 505.81
1999 Capital Cost:	1.00	\$21,493 J	
1978 O&M Cost:		\$4,212	
I) Energy \$/kW*h	0.05	\$491	0.03 0.071
J) Maintenance \$/hour material	0.03 0.92	\$11,625 \$232	71.6 10 131.3 30 1
KMnO4 Cost:		\$23,563	
1999 Operation & Maintenance:	1.00	\$35,911	

Permanganate Feed Capital Cost

General Form: $A \cdot X^B \cdot e^{(C \cdot X)}$


A =	9681.7
B =	0.0304
c =	0.00122

O&M Cost


General Form: $A \cdot e^{(B \cdot X)} + C$

A =	-2125.9
B =	-0.01689
c =	5600

Construction Cost for Potassium Permanganate at Different Dosage Rates



O&M Cost for Potassium Permanganate at Different Dosage Rates



LIMEFD

Lime and Soda Softening

Volume Treated U/Sec:		292			
FROM WATER ANALYSIS					
	mg/L	mmoles/L	Lime Requirement	Soda Ash Requirement	purity
			0.9	0.58	
Ca (2+):	51.0	1.3		0.0	
Mg (2+):	7.5	0.3	68.5		
HCO3 (-):	211.5	3.5	22.8		
CO2 (2-):	0.0	0.0	0.0		
Excess:			30.0		
Total g/m3:			134.8	0.0	
m3/hr treated:	1051.4				
kg/hr Lime:	141.8		141.8	0.0	
Lime Cost \$/ton:	45.0		Applicable Range 4-4500 kg/hr		
Soda Ash Cost \$/ton:	145.0				
Alternative dosage rate Lime (kg/hr):	31.5		Basis Lime:	31.5	kg/hr
Alternative dosage rate Soda (kg/hr):	31.5		Basis Soda:	31.5	kg/hr

	Percentages		1978 index value basis	Current index value 1999
1978 Capital Cost:		\$90,969		
A) Excavation and Site Work	0	\$0	247	548.67
B) Manufactured Equipment	0.63	\$117,215	72.9	149.1
C) Concrete	0	\$0	71.6	150.2
D) Steel	0	\$0	75	106.6
E) Labor	0.02	\$4,041	247	548.67
F) Piping and Valves	0.03	\$6,387	70.2	164.3
G) Electrical Equip. and Instrmnt.	0.07	\$10,622	72.3	120.6
H) Housing	0.25	\$45,146	254.8	505.81
1999 Capital Cost:	1.00	\$183,411		
1978 O&M Cost:		\$12,612		
I) Energy \$/kW*h	0.09	\$2,649	0.03	0.07
J) Maintenance Material	0.06	\$1,388	71.6	131.3
K) Labor \$/hour	0.85	\$32,160	10	30
Lime Cost:		\$13,143		
1999 Operation & Maintenance:	1.00	\$49,339		

Updated from
EPA-600/2-79-162b, Aug. 1979
Estimating Water Treatment Costs
Volume 2
pp 61-64

Lime & Soda Ash Feed Capital Cost
General Form = A + B(lnx)
x = kg Lime/hr
A= -24950.92
B= 20424.674

Operating Cost:
General Form = Ax*B
x = kg Lime/hr
A= 866.28504
B= 0.5143525


LIMEFD

	Mg	Ca	HCO ₃ +CO ₂	Ca(OH) ₂	Mg and Ca react with Alkalinity and Lime to precipitate CaCO ₃ and Mg(OH) ₂
Ratio	1	1	4	3	
Limit	0.309				
eq	0.31	0.31	1.23	0.93	
mg/L	7.5	12.3	75.3	68.5	

	Mg	Ca	HCO ₃ +CO ₂	Ca(OH) ₂	Remaining Mg or Ca react with remaining alkalinity
Ratio	1	1	2	1	
eq	0.00	0.97	6.32	0.31	
mg/L	0.0	38.7	385.3	22.8	

	Mg	Ca	Na ₂ CO ₃	Ca(OH) ₂	If Ca and/or Mg are in excess of Alkalinity, then add soda ash
Ratio	1	1	1*mg+1*Ca	1*Mg	
eq	0.000	0.000	0.000	0.000	
mg/L	0.0	0.0	0.0	0.0	


Construction Cost for Lime Softening at 30 mg/L Dosage



A-36

O&M Cost for Lime Softening at 30 mg/L Dosage

A-37



Upflow Solids Contact Clarifier

Flow Rate L/sec	292	4630 gpm
Retention Time (min.)	180	
Assumed Depth = 4.8 m	4.8	
Calculated Settling Area (m ²)	328.559	Basis: 328.55903
Alternative settling Area (m ²)	0	

Percentages			1978 index value basis	Current index value 1999
Construction Cost 1978 \$		229,695		
A) Excavation and Site Work	0.046	23,471	247	548.67
B) Manufactured Equipment	0.509	239,122	73.9	149.1
C) Concrete	0.081	39,030	71.6	150.2
D) Steel	0.11	35,912	75	106.6
E) Labor	0.247	126,027	247	548.67
F) Piping and Valves	0	0	70.2	164.3
G) Electrical Equip. and Instmnt.	0.007	2,682	72.3	120.6
H) Housing	0	0	254.8	505.81
1999 Capital Cost:		466,244		

1978 O&M Cost:	%	G=70	%	G=110	%	G=150		
		7,713		8,700		10,009		
I) Energy \$/kW*h	0.23	4,139	0.38	7,714	0.5	11,677	0.03	0.07
J) Maintenance Material	0.17	2,405	0.14	2,233	0.11	2,019	71.6	131.3
K) Labor \$/hour	0.6	13,084	0.48	12,527	0.39	11,710	10	30
1999 Operation & Maintenance Cost:		20,428		22,474		25,406		

Construction Cost Equations (From EPA-600/2-79-162b)

\$ = a+b*x


	a	b
<400 m ²	62801.114	416.77163
>400 m ²	132264.71	244.33215

Operation & Maintenance Cost (From EPA-600/2-79-162b)


\$=a+b*x

	a	b
G = 70	5967.9519	5.3118202
G = 110	5806.5744	8.80491
G = 150	5939.8245	12.384121

Construction Cost for Upflow Solids Contact Clarifier



O&M Cost for Upflow Solids Contact Clarifier with Different G values




GAC

Granular Activated Carbon Filtration

Desired Flow Rate:	292 L/s	4630 gpm
	25233.33 m ³ /day	

Bed Life (months)	Construction Costs:	Operating Costs:
12	\$3,638,100	\$1,023,646
6	\$3,785,000	\$1,301,467
3	\$5,046,667	\$1,663,217


Construction Cost for Carbon Filtration



A-42

—◆— 12 mon. bed life cc —△— 6 mon. bed life cc —*— 3 mon. bed life cc

O&M Cost for Carbon Filtration



—■— 12 mon. bed life O&MC X 6 mon. bed life O&MC —●— 3 mon. bed life O&MC

GRAVFILT

GRAVITY FILTRATION:

Desired Flow Rate:	292 l/s	4631 gpm
Total Suspended Solids:	0.2 mg/L	
Wash Cycle:	24 hr	
TSS Density:	35 g/L*	
Media Depth:	1 m	0.91 yd
Maximum Media Capacity:	110 L-TSS/m ³ *	
Required Media Volume :	1.44 m ³	1.89 yd ³
Calculated Bed Area:	1.44 m ²	1.73 yd ²
Alternative Bed Area:	0.00 m ²	0.00 yd ²
Tank Depth:	1.3 m	1.4 yd
Media Cost Delivered		
\$/yd ³ Sand	\$55.00	42.05 m ³
\$/yd ³ Coal	\$80.00	45.87 m ³
\$/yd ³ Garnet	\$408.00	309.64 m ³

TOTAL CONSTRUCTION COSTS:	\$169,507
Rapid Sand:	\$104
Coal/ Sand:	\$109
Coal/ Sand/ Garnet:	\$327
TOTAL OPERATING COSTS:	\$27,963

Media costs assume equal parts of each type.

*Media capacity based on information in "Water Treatment and Plant Design", R.L. Sanks, Co: 1978, Ann Arbor Science Publishers, Inc.

Construction cost is 100% Manufactured Equipment
O&M costs are included with the structure.

BACKWASHING PUMP:

Gravity Filter Structure

Filter area (m ²):	1.44 Applicable Range: 13-2600 m ²	Filter area (m ²):	1.44 Applicable Range: 13-2600 m ²
--------------------------------	---	--------------------------------	---

Percentages		1978 index value		Current index value	Percentages	
1978 Capital Cost:		\$37,810	base	1999	1978 Capital Cost:	
A) Excavation and Site Work	0.00	0	247	548.67	A) Excavation and Site Work	0.01
B) Manufactured Equipment	0.47	36,346	72.9	149.1	B) Manufactured Equipment	0.20
C) Concrete	0.00	0	71.6	150.2	C) Concrete	0.06
D) Steel	0.00	0	75	106.6	D) Steel	0.05
E) Labor	0.07	5,879	247	548.67	E) Labor	0.21
F) Piping and Valves	0.24	21,238	70.2	164.3	F) Piping and Valves	0.23
G) Electrical Equip. and Instrmnt.	0.22	13,875	72.3	120.6	G) Electrical Equip. and Instrmnt.	0.06
H) Housing	0.00	0	254.8	505.81	H) Housing	0.18
1999 Capital Cost:	1.00	\$77,339			1999 Capital Cost:	1.00
						\$92,168
1978 O&M Cost:		\$2,297			1978 O&M Cost:	
I) Energy S/kW ^h	0.52	2,786	0.03	0.07	I) Energy S/kW ^h	0.36
J) Maintenance Material	0.24	1,011	71.6	131.3	J) Maintenance Material	0.12
K) Labor \$/hour	0.24	1,654	10	30	K) Labor \$/hour	0.52
1999 O & M Cost:	1.00	\$5,451			1999 O & M Cost:	1.00
						\$22,513

Backwash Pumping Costs from Qasim, et al, Aug. 1992, AWWA

Construction Costs:

General Form: $A + B \cdot X + C \cdot X^2$

A=	36000
B=	1254.21
C=	-0.1212

O & M Costs:

General Form: $A \cdot X \cdot B + C$

A=	73.3
B=	0.75
C=	2200

Gravity Filter Structure Costs from Qasim, et al, Aug. 1992, AWWA

Construction Costs:

General Form: $A \cdot X \cdot B \cdot e^{(CX)}$


A=	35483.4
B=	0.591
C=	0.000162

O & M Costs:


General Form: $A \cdot X \cdot B + C$

A=	359.5
B=	0.8568
C=	8100

Construction Cost for Gravity Filtration at Different Flow Rates



O&M Cost for Gravity Filtration at Different Flow Rates



A-47

ION_EXH

Ion Exchange

Desired Flow Rate :	From Capacity	292.1 L/s
Equiv/L , CATION >>1	From Capacity	3.56E-03 equiv/L
Equiv/L , ANION	From Capacity	1.76E-02 equiv/L
Service Flow Rate :	Range = 18 - 40	20 L/(hr*L resin)
Cation Equivalents/Liter of Resin		20 equiv/L
Anion Equivalents/Liter of Resin		11 equiv/L
Desired Run Cycle:		7 days

Medium:	Cation	Anion
Min Volume:	52.6	52.6 m ³
Time until exhaustion of min volume:	11.7	1.3 days
Resin for desired Run Cycle:	52.57	31.45 days
Total Vessel Volum	105	63
Resin Expansion Coefficient		2 m ³
Nominal Resin Price \$/m ³	\$6,700	\$6,700 m ³
Resin Cost:	\$352,215	\$210,705

Vessel:	
Aspect ratio:	height/dia
Bed area :	7.03 m ²
Base pressure vessel correlation: (446 kPa/ 50 psig)	b= 3.446
log(S) = b + m*log(m ³)	m= 0.562
Cost factor for operating pressure:	1
Tank cost at base pressure:	\$38,179
TOTAL TANK COST:	\$38,179

Regeneration (with NaCl)		
Mass of NaCl Vol of resin:	150 kg/m ³	9 lb/ft ³
NaCl required:	12,603 kg	27784 lb
Chemical cost per kg:	\$0.02	\$0.01 \$/lb
TOTAL CHEMICAL COST PER YEAR:	\$10,925	
Chemical concentration:	10 percent	
Regeneration fluid req'd :	126 m ³	33 kgal
STORAGE TANK COST:	\$31,507	

Backwash Pumping Costs from Qasim, et al, Aug. 1992, AWWA

Construction Costs:

General Form: A + B*X + C*X²

A=	36000
B=	1254.21
C=	-0.1212

O & M Costs:

General Form: A*X^{0.75} + B

A=	73.3
B=	2200

REGENERATION/BACKWASHING PUMP:


Filter area (m ²):	7.03 Applicable Range: 13-2600 m ²
--------------------------------	---

1978 Capital Cost:	Percentages	1978 index value	Current index value	
		base	1999	
A) Excavation and Site Work	0.00	\$0	247	548.67
B) Manufactured Equipment	0.47	\$43,075	72.9	149.1
C) Concrete	0.00	\$0	71.6	150.2
D) Steel	0.00	\$0	75	106.6
E) Labor	0.07	\$6,968	247	548.67
F) Piping and Valves	0.24	\$25,170	70.2	164.3
G) Electrical Equip. and Instrmnt.	0.22	\$16,444	72.3	120.6
H) Housing	0.00	\$0	254.8	505.81
1978 Capital Cost:	1.00	\$95,061		


1978 O&M Cost:	Percentages	1978 index value	Current index value	
		base	1999	
I) Energy \$/kW*h	0.52	\$3,053	0.03	0.07
J) Maintenance Material	0.24	\$1,108	71.6	131.3
K) Labor \$/hour	0.24	\$1,812	10	30
1978 O & M Cost:	1.00	\$5,973		

Total Construction Cost:	\$516,962
Total Operating Cost:	\$16,898

Construction Cost for Ion Exchange at Different Flow Rates



O&M Cost for Ion Exchange at Different Flow Rates



Electrodialysis Cost Estimation

Input from Interface	Sample Values:	Value:
Flow Rate (L/s):		292.1
Flow Rate (m ³ /Hr):		1051
Feed TDS (mg/L):		700
Product TDS (mg/L):		400
Ave Equivalent Weight:		25.99
Percent Recovery:		0.50

Production Data	
Delta N eq/m ³ :	11.54
Desal Ratio:	1.75

Membrane Characteristics	
Transport efficiencies Sum <= 1.00	
Insert rows after Na+ or Cl- to add more ion efficiencies.	
Na+:	0.400 0.470
Sum cations efficiencies:	0.470
Cl-:	0.400 0.470
Sum anions efficiencies:	0.470
Transport efficiency:	0.939
Sum of Anion & Cation Efficiency:	
Area/membrane pair (m ²) Asahi is 0.85 m ² :	0.850
Dilute side resistance "Rd" (ohms/cm)/cm ² :	0
Concentrate side resistance "Rc" (ohms/cm)/cm ² :	0
Membrane resistance "Rm" (ohms/cm)/cm ² :	0.070
Total resistance Rt = (Rd+Rc+Rm):	0.860 0.070
Current density (amps/m ²):	30 - 300 30
Current Efficiency:	0.860
Membrane Voltage Potential "Vm" (volts/pair):	0.850
Voltage per cell Vc = Rt*CD+Vm:	1.000 0.671

Energy Requirements	
Power requirements kWhr/m ³ :	0.24
Pumping energy requirements kWhr/m ³ :	0.17 0.37
Total kWh/day:	10380

Membrane Requirements	
Total Membrane Area (m ²):	12,606
Number of cell pairs:	14,831

EC

Membrane Replacement		Suggested Values
Membrane Cost/m ² :	\$100.00	100
Membrane Life Expectancy (yrs):	15	15

Construction Cost Items	
Construction Cost Factor (%):	1.65
Contingency (%):	15
Electricity Cost \$/kWh:	\$0.07

Labor and Overhead	
Labor cost, Lh (\$/h):	30
Labor overhead, LOH (%):	30
Shifts per day, S (number/day):	0.2
Workers per shift, Ws (number/shift):	1

Capital Recovery	
System lifetime, r (yr):	15
Downtime, Dt (%):	15
Annual interest rate, i (%):	8

Cost Indices Categories:	1999
A) Excavation and Site Work	548.67
B) Manufactured Equipment	149.1
C) Concrete	150.2
D) Steel	106.6
E) Labor	548.67
F) Piping and Valves	164.3
G) Electrical Equip. and Instrmnt.	120.6
H) Housing	505.81
I) Energy (\$/kWhr)	0.07
J) Maintenance Material	131.3
K) Labor (\$/hour)	30
Interest Rate	8

Capital Costs	
Based on Membrane Cost @ \$100/m ²	\$2,080,039

Operation & Maintenance Costs/ year	
Chemicals	12,894
Maintenance	111,747
Membrane Replacement:	80,189
Labor Cost:	2,628
ED Electricity Cost/year @ \$0.07/kWhr:	39,781
Capital Recovery	238,535
Total 1999 O&M Costs:	\$485,775

A-51.1

Second Stage Electrodialysis Cost Estimation

Input from Interface	Sample Values:	Value:
Flow Rate (L/s):		146.0
Flow Rate (m3/Hr):		526
Feed TDS (mg/L):		779
Product TDS (mg/L):		400
Ave Equivalent Weight:		25.99
Percent Recovery:		0.50

Production Data		
Delta N eq/m3:		14.58
Desal Ratio:		1.95

Membrane Characteristics		
Transport efficiencies Sum <= 1.00		
Insert rows after Na+ or Cl- to add more ion efficiencies.		
Na+:	0.400	0.470
Sum cations efficiencies:		0.470
Cl-:	0.400	0.470
Sum anions efficiencies:		0.470
Transport efficiency:		0.939
Sum of Anion & Cation Efficiency.		
Area/membrane pair (m2) Asahi is 0.85 m^2		0.654
Dilute side resistance "Rd" (ohms/cm)/cm2:		0
Concentrate side resistance "Rc" (ohms/cm)/cm2:		0
Membrane resistance "Rm" (ohms/cm)/cm2:		0.070
Total resistance Rt = (Rd+Rc+Rm):	0.860	0.070
Current density (amps/m2):	30 - 300	0.950
Current Efficiency:		0.860
Membrane Voltage Potential "Vm" (volts/pair):		0.650
Voltage per cell Vc = Rt*CD+Vm:	1.000	0.671

Energy Requirements		
Power requirements kWhr/m3:		0.30
Pumping energy requirements kWhr/m3	0.17	0.17
Total kWhr/day:		5992

Membrane Requirements		
Total Membrane Area (m2):		7,964
Number of cell pairs:		9,369

Membrane Replacement		Suggested Values	
Membrane Cost/m2:	\$100.00		100
Membrane Life Expectancy (yrs):	15		15

Construction Cost Items			
Construction Cost Factor (%):	1.65		1.65
Contingency (%):	15		15
Electricity Cost \$/kWh:	\$0.07		0.08

Labor and Overhead			
Labor cost, Lh (\$/h)		30	15
Labor overhead, LOH (%)		30	30
Shifts per day, S (number/day)		0.2	0.2
Workers per shift, Ws (number/shift)		1	1

Capital Recovery			
System lifetime, r (yr)		15	15
Downtime, Dt (%)		15	15
Annual interest rate, I (%)		8	10


Cost Indices Categories:		1999
A) Excavation and Site Work		548.67
B) Manufactured Equipment		149.1
C) Concrete		150.2
D) Steel		106.6
E) Labor		548.67
F) Piping and Valves		164.3
G) Electrical Equip. and Instrmnt.		120.6
H) Housing		505.81
I) Energy (\$/kWhr)		0.07
J) Maintenance Material		131.3
K) Labor (\$/hour)		30
Interest Rate		8

Capital Costs	
Based on Membrane Cost @ \$100/m2	\$1,314,050

Operation & Maintenance Costs/ year	
Chemicals	12,894
Maintenance	70,595
Membrane Replacement:	50,659
Labor Cost:	2,628
ED Electricity Cost/year @ \$0.07/kWhr:	22,966
Capital Recovery	238,535
Total 1999 O&M Costs:	\$398,277


Total capital cost (1st and 2nd stage)	\$3,394,088
Total O&M cost (1st and 2nd stage)	\$884,051

Construction Cost for Electrodialysis (1st and 2nd stage)



A-52

O&M Cost for Electrodialysis (1st and 2nd stage)



Pumps

Number of pumps:	4	
Height differential:	1 m	2.9 m
Discharge pressure:	1750 kPa	254 psi
Full flow rate:	0.29 m ³ /s	4630 gal/min
Basis flow rate	0.07 m ³ /s	1157 gal/min
Pump Efficiency:	75 %	
Pipe Diameter:	0.1 m	4 in
Motor Efficiency:	87 %	
HP	236	
Power consumption:	271 kWhr	

Direct Costs (material and labor)	SST	VST	c s s	
Pump, drive, and driver	405105	593689	244460	
Piping	283816	283816	283816	
Controls		16000		
Total Direct Cost	688921	893505	528276	
Taxes	5.0%	34446	44675	26414
Total Capital Cost	\$723,367	\$938,180	\$554,690	

Operating Costs

Power Cost \$/year		631389
Lubrication (\$/L oil)	1	826
Cooling water (\$/m ³ water)	0.1	123904
Maintenance (hr/Hp)	1.5	10608
		\$766.727

CLEARWELL

Construction cost for clear well storage

Below Ground (concrete)

Storage Capacity (kgal) 5677.5

m³ 1500

1978 Capital Cost:		\$185,997	modified index value basis	Current index value 1999
Components	Percentages			
A) Excavation and Site Work	0.05	19,543	247	548.67
B) Manufactured Equipment	0.00	0	72.9	149.1
C) Concrete	0.26	100,256	71.6	150.2
D) Steel	0.28	72,779	75	106.6
E) Labor	0.27	109,955	247	548.67
F) Piping and Valves	0.00	0	70.2	164.3
G) Electrical Equip. and Instmnt.	0.02	7,403	72.3	120.6
H) Housing (Misc. & contingency)	0.13	48,000	254.8	505.81
1999 Capital Cost:	1.00	\$357,935		
1999 Unit Cost (\$/gal)	\$238.62			

Data from EPA-600/2-79-162b, August 1979, pg453-454. They are used in determining cost formula.

Ground Level (steel)

Storage Capacity (kgal)

5677.5

m³


1500

1978 Capital Cost:

\$117,121


Components	Percentages		modified index value basis	Current index value 1999
A) Excavation and Site Work	0.00	0	247	548.67
B) Manufactured Equipment	0.66	157,883	72.9	149.1
C) Concrete	0.06	13,980	71.6	150.2
D) Steel	0.04	7,325	75	106.6
E) Labor	0.01	2,115	247	548.67
F) Piping and Valves	0.07	19,369	70.2	164.3
G) Electrical Equip. and Instmnt.	0.03	6,003	72.3	120.6
H) Housing (Misc. & contingency)	0.13	30,225	254.8	505.81
1999 Capital Cost:	1.00	\$236,900		
1999 Unit Cost (\$/gal)	\$157.93			

Construction Cost for Clearwell Below Ground Storage



A-57

Construction Cost for Clear-well Ground Level Storage



A-58

Water Analysis

	Desert Well	Brackish	Desert Surface	Seawater Intrusion	Agricultural Influence	Seawater	Alkaline	Rangeland	
Component	Water Analysis	Water Analysis	Water Analysis	Water Analysis	Water Analysis	Water Analysis	Water Analysis	Water Analysis	Water Analysis
Metals									
Aluminum		0.35				0.01	0.05		
Antimony						3.30E-04			
Arsenic	0.012					3.00E-03		0.017	
Barium	0.050	0.0983		0.025		0.03	0.01	0.11	
Beryllium						6.00E-07		0.0005	
Cadmium	0.001					1.10E-04			
Calcium	100.000	182	58.7	136	36	400	180	99	51
Chromium	0.010	0.023				5.00E-05			
Copper	0.050	0.09				3.00E-03			
Iron	0.050	0.019		0.1		0.01	1.4		
Lead	0.005	0.006				3.00E-05			
Magnesium	35.000	85	27.3	47	22.1	1.35E+03	90	19	7.5
Manganese	0.550	0.0811		0.04		2.00E-03	0.5	0.03	0.028
Mercury	0.001					3.00E-05			
Nickel						5.40E-03		0.004	
Potassium	1.800	4.78	5.52	6		380	8	12	13
Selenium	0.005					9.00E-05		0.005	
Silver	0.005					3.00E-04			
Sodium	110.000	168	98	101.32	98.1	10500	250	31	93
Strontium	1.300	2.71				8.1	1.3	0.61	
Thallium						1.00E-05			
Zinc	0.050				0.078	0.01		0.02	
Inorganics									
Alkalinity-Bicarbonate	232.000	189.00	98.80	250.00	46.36	142.33	580	260	211.5
Alkalinity-Carbonate	0.000					2.89			0
Carbon Dioxide (aq)						5.15E-04		29	
Asbestos									
Boron									
Chloride	95.000	560	97.5	51	162	19000	29	19	114.8
Residual Disinfectant									
Color		3							
Conductivity		2200					2150	920	889
Corrosivity									
Cyanide									
Flouride	0.640	0.31	0.404	0.6	0.12	1.3		0.5	0.33
Foaming Agents									
Nitrate (as N)	1.000	10.7	20.556	4	1	0.5	0.05	55	3.3
Nitrite (as N)			0.0373				0.01	0.04	1.1
Ammonia (as N)	0.200							0.09	20
Odor		2							
pH	7.620	7.39	7.39	7.6	7.2	8	7.4	7.2	7.3
o-Phosphate		0.37				0.07		0.04	
SiO2	15.000	25.3							27
Silicon	17.000	11.9				3	12	28	
Solids (TDS)	880.000	1800	633	1015	94	32681	1620	533	
Sulfate	300.000	231	262	450		885	729	130	90
Temperature	24	24	24			24	7	13	
Total Suspended Solids:		1.3							

A-59