

# The Daily Environmental Redispatch Retrospective

An indepth report for **7/10/2011**

	ENV DISPL	Total BPA BA Thermal Generation	ENV RDISP	Total BPA BA Wind Generation	UNUSED INTERTIE CAPACITY			MT EXPORT
	(Non VER Only)		(VER Only)		(NOB)	(COB)	(NI)	( minus = import)
HE01	1	198	108	1985	135	897	1850	142
HE02	1	184	658	1080	652	820	1850	138
HE03	1	186	712	628	1066	983	1492	154
HE04	1	181	750	348	969	1182	1691	156
HE05	1	165	686	346	1242	1164	1332	150
HE06	11	188	815	261	1062	1691	1672	101
HE07	11	202	576	13	1194	1360	1846	206
HE08	16	194	0	428	404	921	1850	252
HE09	0	198	0	417	265	923	1850	289
HE10	0	198	0	393	413	1126	1850	36
HE11	0	217	0	418	810	1032	1850	-32
HE12	0	299	0	311	581	905	1850	-75
HE13	0	340	0	322	491	709	1850	-43
HE14	0	372	0	359	319	772	1850	-19
HE15	0	375	0	488	457	583	1850	41
HE16	0	413	0	493	480	564	1850	63
HE17	0	451	0	499	504	502	1850	71
HE18	0	412	0	636	650	508	1850	-46
HE19	0	445	0	625	648	549	1850	-115
HE20	0	436	0	759	457	670	1850	-234
HE21	0	399	0	1030	573	740	1850	-281
HE22	0	228	0	1212	748	832	1850	-338
HE23	0	258	0	1121	358	909	1850	-254
HE24	0	280	0	1056	480	1612	1850	-137
Day Total (MWh)	43	6819	4306					
CUMM (MWh)*	11,897		97,557					

\* Cummulative totals since May 17th.

**Comments:**

The unused NOB, COB and NI capacities are equal to the export limit minus the export schedule. If there is an import on the path, this simply equals the export limit.

The Unused NOB, COB and NI transmission values reflect total export limits minus total export usage of both BPAT and non-BPAT transmission capacity. BPA Traders sell surplus energy down to no cost to the Agency, which includes the cost of purchasing transmission from transmission services, but can prohibit them from buying third-parties' share of intertie capacity when power prices don't exceed third-party transmission costs.

**Oregon High 12-hour average percent TDG**

	TDG%	Qspill	LEVEL 1 CAP	LEVEL 2 CAP	LEVEL 3 CAP	LEVEL 4 CAP
	(TW)	(Davg-kcfs)	(kcfs)	(kcfs)	(kcfs)	(kcfs)
GCL	121.4	42.6	0	0	15	30
CHJ	118.3	100.8	150	189	200	210
LWG	117.5	26.3	41	45	52	63
LGS	116.6	34.8	40	52	59	70
LMN	120.2	21.7	28	44	60	80
IHR	117.9	62.3	72	75	85	110
MCN	124.8	213.4	190	190	235	240
JDA	119.0	122.8	130	144	177	190
TDA	117.7	129.4	130	135	160	269
BON	119.2	167.3	121	107	120	183

Based on 7/08/11 15:55 spill priority table

TDG%
120
122
125
127

The goal of this reports is to highlight when Environmental Redispatch and Environmental Displacement has occurred. Data included in this report should not be used for billing purposes. If you have questions about your bill, please contact your billing representative.